



e-FILING REPORT COVER SHEET

Send completed Cover Sheet and the Report in an email addressed to:
PUC.FilingCenter@state.or.us

REPORT NAME: Major Event Report - Replacement Page

COMPANY NAME: Pacific Power

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? [X]No [ ]Yes

If yes, please submit only the cover letter electronically. Submit confidential information as directed in OAR 860-001-0070 or the terms of an applicable protective order.

If known, please select designation: [X]RE (Electric) [ ]RG (Gas) [ ]RW (Water) [ ]RO (Other)


Report is required by: [ ]OAR OAR 860-023-0161
[ ]Statute
[ ]Order
[ ]Other

Is this report associated with a specific docket/case? [ ]No [X]Yes

If yes, enter docket number: RE 107

List applicable Key Words for this report to facilitate electronic search:
Major Event Report

DO NOT electronically file with the PUC Filing Center:



- Annual Fee Statement form and payment remittance or
• OUS or RSPF Surcharge form or surcharge remittance or
• Any other Telecommunications Reporting or
• Any daily safety or safety incident reports or
• Accident reports required by ORS 654.715

Please file the above reports according to their individual instructions.



825 NE Multnomah, Suite 2000  
Portland, Oregon 97232

December 22, 2014

*VIA ELECTRONIC FILING*

Public Utility Commission of Oregon  
3930 Fairview Industrial Drive SE  
Salem, OR 97302

Attn: Filing Center

RE: PacifiCorp Major Event Report—Replacement Page

An inadvertent error was found on the Company's Major Event Report filed on December 9, 2014. Please find enclosed for filing a revised page 3 of the report.

If you require further information regarding this report, please contact Heide Caswell, Director, Asset Performance, at (503) 813-6216.

Sincerely,

A handwritten signature in cursive script that reads "R Bryce Dalley 1/22/15".

R. Bryce Dalley  
Vice President, Regulation

Enclosure

cc: Lori Koho/Administrator, Safety, Reliability, and Security Division

### Restoration Intervals

Reliability Region	Total Customers Sustained	< 3 Hrs	> 3 < 24 Hrs	> 24 < 48 Hrs	> 48 < 72 Hrs	> 72 < 96 Hrs	>= 96 Hrs
WImVly	16,923	4,127	11,441	1,355	0	0	0

### SAIDI, SAIFI, CAIDI by Reliability Reporting Region and System-wide

Please see the attached system-generated reports.

### Major Event Declaration

PacifiCorp designates these events and the consequences thereof a major event in accordance with OAR 860-023-0161. This is a major event because it exceeded the design or operating limits of the system, and the CML Threshold for the reliability reporting region as calculated annually by the company according to IEEE 1366-2003 methodology (commonly referred to as the 2.5 beta method). Current year thresholds for the reliability reporting regions are shown below.

State/Region	2014 Cust	SAIDI Threshold	CML Threshold
Central OR	78,794	4.44	349,946
CoastPlus	151,443	9.57	1,449,117
Northeast OR	25,752	9.20	236,978
South OR	226,303	11.64	2,635,154
WImVly	122,115	14.71	1,796,334