



e-FILING REPORT COVER SHEET

COMPANY NAME: PORTLAND GENERAL ELECTRIC COMPANY

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes If yes, submit a redacted public version (or a cover letter) by email. Submit the confidential information as directed in OAR 860-001-0070 or the terms of an applicable protective order.

Select report type: RE (Electric) RG (Gas) RW (Water) RT (Telecommunications)
 RO (Other, for example, industry safety information)

Did you previously file a similar report? No Yes, report docket number: RE 112

Report is required by: OAR 860-023-0161

Statute

Order

Note: A one-time submission required by an order is a compliance filing and not a report (file compliance in the applicable docket)

Other

(For example, federal regulations, or requested by Staff)

Is this report associated with a specific docket/case? No Yes, docket number:

List Key Words for this report. We use these to improve search results.

MAJOR EVENT EXCLUSION

Send the completed Cover Sheet and the Report in an email addressed to PUC.FilingCenter@state.or.us

Send confidential information, voluminous reports, or energy utility Results of Operations Reports to PUC Filing Center, PO Box 1088, Salem, OR 97308-1088 or by delivery service to 201 High Street SE Suite 100, Salem, OR 97301.



Portland General Electric
121 SW Salmon Street · Portland, Ore. 97204

October 7, 2022

Oregon Public Utility Commission
Attn: Filing Center
201 High Street, S.E.
Salem, OR 97308-1088

Re: Major Event Exclusion
Period: September 9, 2022

Portland General Electric (PGE) hereby submits this report in compliance with OAR 860-023-0161 which requires the electric company to file a report with the Commission within 30 business days after the conclusion of an event. This report provides a summary of the major storm event that occurred on September 9, 2022.

OAR 860-023-0161: Major Event Filing by Electric Companies

1. Description of the major event, the interruption causes, and factors that impacted restoration of service.

On September 9, 2022, high, gusty winds and extreme fire conditions prompted PGE to initiate a Public Safety Power Shutoff (PSPS). Due to the PSPS, customers in affected areas could not be energized until weather conditions were safe (acceptable), all line patrols were completed, and all repairs needed were complete.

2. The Reliability reporting area and geographic area impacted.

PGE's ten designated PSPS areas and seven additional high-risk areas across its service territory were impacted by the September 9, 2022 PSPS. Most outages occurred in PGE's Eastern service territory.

3. The total number of customers affected and the number of customers without service at periodic intervals.

At the peak of the storm, PGE had approximately 37,968 customers without power. During the storm, a total of 42,850 customers were affected.

4. The calculated SAIDI, SAIFI, and CAIDI impacts (i.e., “Event SAIDI, SAIFI, CAIDI”) associated with the Major Event to customers on a reliability reporting area and a system-wide basis.

The following table represents the calculated impacts for SAIDI, SAIFI, CAIDI, TMED, and system-wide basis totals:

	RELIABILITY REPORTING AREAS			SYSTEM-WIDE BASIS
	EASTERN ¹	SOUTHERN	WESTERN	PGE SERVICE TERRITORY
SAIDI²	51.45	19.22	17.84	88.50
SAIFI³	0.023	0.012	0.012	0.046
CAIDI⁴	2285	1597	1521	1913
Customers out at peak	16,990	10,976	10,002	37,968
TMED				6.50

¹ Eastern and Central regions are now combined and represented as the Eastern region.

² SAIDI - System Average Interruption Duration Index

³ SAIFI - System Average Interruption Frequency Index

⁴ CAIDI - Customer Average Interruption Duration Index

**Additional Reporting Related to the
September 9, 2022 Storm Event:**

Attachment A provides a summary of outages within PGE's service territory lasting 5 hours or longer.

For questions regarding this filing, please contact Mary Widman at mary.widman@pgn.com. Please direct all formal correspondence and requests to the following email address pgc.opuc.filings@pgn.com.

Sincerely,

A handwritten signature in black ink that reads "Benjamin H Hillam". The signature is written in a cursive, flowing style.

Benjamin Hillam
Manager, Asset Management Analytics

Enclosures

Major Event Exclusion Period: September 9, 2022
Attachment A

Summary of Outages 5 Hours and Longer for
the Entire PGE Service Territory

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1309312	9/9/22	8:15 AM	OAK GROVE-LAKE HARRIET	5	6405	32026.83	9/13/22	7:01 PM	FUSE_OH:D5731C-167 / ABC / 25 A	0.034586	5.4E-06	6,405
1312790	9/9/22	2:36 AM	WELCHES-ZIG ZAG	5	4809	24043.58	9/12/22	10:44 AM	FUSE_OH:D3713D-489 / A / 6 A	0.025965	5.40E-06	4,809
1308982	9/9/22	2:36 AM	WELCHES-ZIG ZAG	29	4056	117624	9/11/22	10:12 PM	FUSE_OH:D3704B-1117 / AB / 100 A	0.127024	3.13E-05	4,056
1308999	9/9/22	2:36 AM	WELCHES-ZIG ZAG	7	4028	28196	9/11/22	9:44 PM	FUSE_OH:D3703B-24 / C / 25 A	0.030449	7.56E-06	4,028
1309000	9/9/22	2:36 AM	WELCHES-ZIG ZAG	100	4024	402400	9/11/22	9:40 PM	FUSE_OH:D3703B-25 / ABC / 65 A	0.434557	1.08E-04	4,024
1309001	9/9/22	2:36 AM	WELCHES-ZIG ZAG	4	4024	16096	9/11/22	9:40 PM	FUSE_OH:D3703D-46 / A / 65 A	0.017382	4.32E-06	4,024
1309002	9/9/22	2:36 AM	WELCHES-ZIG ZAG	35	4024	140840	9/11/22	9:40 PM	FUSE_OH:D3703D-46 / AC / 100 A	0.152095	3.78E-05	4,024
1309017	9/9/22	2:36 AM	WELCHES-ZIG ZAG	33	4022	132726	9/11/22	9:38 PM	FUSE_OH:D3714A-710 / B / 25 A	0.143332	3.56E-05	4,022
1309019	9/9/22	2:36 AM	WELCHES-ZIG ZAG	25	4022	100550	9/11/22	9:38 PM	FUSE_OH:D3714A-710 / C / 25 A	0.108585	2.70E-05	4,022
1309004	9/9/22	2:36 AM	WELCHES-ZIG ZAG	16	4010	64157.07	9/11/22	9:25 PM	FUSE_OH:D3702C-45 / B / 65 A	0.069284	1.73E-05	4,010
1309003	9/9/22	2:36 AM	WELCHES-ZIG ZAG	12	4009	48108	9/11/22	9:25 PM	FUSE_OH:D3702C-45 / A / 65 A	0.051952	1.30E-05	4,009
1308984	9/9/22	2:36 AM	WELCHES-ZIG ZAG	8	3939	31512	9/11/22	8:15 PM	FUSE_OH:D3704A-67 / C / 65 A	0.03403	8.64E-06	3,939
1312795	9/9/22	2:36 AM	WELCHES-ZIG ZAG	41	3924	160868.3	9/11/22	7:59 PM	FUSE_OH:D3818D-114 / AC / 40 A	0.173724	4.43E-05	3,924
1308412	9/9/22	2:30 AM	DUNNS CORNER-DUNNS CORNER 13	7	3920	27440	9/11/22	7:50 PM	FUSE_OH:D2504C-1144 / ABC / 40 A	0.029633	7.56E-06	3,920
1312796	9/9/22	2:36 AM	WELCHES-ZIG ZAG	98	3911	383278	9/11/22	7:47 PM	FUSE_OH:D3818D-513 / AB / 40 A	0.413907	1.06E-04	3,911
1309011	9/9/22	2:36 AM	WELCHES-ZIG ZAG	28	3908	109425.9	9/11/22	7:44 PM	FUSE_OH:D3711C-857 / B / 40 A	0.11817	3.02E-05	3,908
1309014	9/9/22	2:36 AM	WELCHES-ZIG ZAG	8	3908	31264.13	9/11/22	7:44 PM	FUSE_OH:D3714A-663 / B / 15 A	0.033763	8.64E-06	3,908
1309012	9/9/22	2:36 AM	WELCHES-ZIG ZAG	3	3908	11723.9	9/11/22	7:43 PM	FUSE_OH:D3711D-668 / C / 6 A	0.012661	3.24E-06	3,908
1309016	9/9/22	2:36 AM	WELCHES-ZIG ZAG	6	3908	23446	9/11/22	7:43 PM	FUSE_OH:D3714A-689 / C / 25 A	0.02532	6.48E-06	3,908
1309005	9/9/22	2:36 AM	WELCHES-ZIG ZAG	65	3878	252070	9/11/22	7:14 PM	FUSE_OH:D3711B-846 / BC / 65 A	0.272214	7.02E-05	3,878
1312791	9/9/22	2:36 AM	WELCHES-ZIG ZAG	105	3854	404668.3	9/11/22	6:49 PM	FUSE_OH:D3713D-491 / B / 40 A	0.437006	1.13E-04	3,854
1319717	9/9/22	2:34 AM	WELCHES-ZIG ZAG	54	3846	207677.7	9/11/22	6:40 PM	FUSE_OH:D3704B-1113 / A / 25 A	0.224274	5.83E-05	3,846
1309009	9/9/22	2:36 AM	WELCHES-ZIG ZAG	3	3835	11505	9/11/22	6:31 PM	FUSE_OH:D3711A-216 / A / 6 A	0.012424	3.24E-06	3,835
1309021	9/9/22	2:36 AM	WELCHES-ZIG ZAG	25	3834	95850	9/11/22	6:30 PM	FUSE_OH:D3713B-759 / B / 25 A	0.10351	2.70E-05	3,834
1308993	9/9/22	2:36 AM	WELCHES-ZIG ZAG	4	3824	15296	9/11/22	6:20 PM	FUSE_OH:D2734C-466 / C / 6 A	0.016518	4.32E-06	3,824
1308990	9/9/22	2:36 AM	WELCHES-ZIG ZAG	19	3821	72592.67	9/11/22	6:16 PM	FUSE_OH:D2734C-106 / B / 10 A	0.078394	2.05E-05	3,821
1308989	9/9/22	2:36 AM	WELCHES-ZIG ZAG	7	3818	26723.67	9/11/22	6:13 PM	FUSE_OH:D2734C-10 / A / 15 A	0.028859	7.56E-06	3,818
1309008	9/9/22	2:36 AM	WELCHES-ZIG ZAG	8	3816	30528	9/11/22	6:12 PM	FUSE_OH:D3711A-242 / B / 10 A	0.032968	8.64E-06	3,816
1308988	9/9/22	2:36 AM	WELCHES-ZIG ZAG	22	3814	83908	9/11/22	6:10 PM	FUSE_OH:D3703B-75 / C / 25 A	0.090613	2.38E-05	3,814
1308987	9/9/22	2:36 AM	WELCHES-ZIG ZAG	15	3812	57179.25	9/11/22	6:07 PM	FUSE_OH:D3703B-74 / AC / 40 A	0.061749	1.62E-05	3,812
1310863	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	53	3796	201191.5	9/11/22	5:51 PM	FUSE_OH:D2619D-18 / A / 40 A	0.217269	5.72E-05	3,796
1308758	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3788	11364	9/11/22	5:43 PM	FUSE_OH:D2528A-364 / ABC / 40 A	0.012272	3.24E-06	3,788
1309006	9/9/22	2:36 AM	WELCHES-ZIG ZAG	13	3781	49154.95	9/11/22	5:37 PM	FUSE_OH:D3711A-848 / AC / 40 A	0.053083	1.40E-05	3,781
1308985	9/9/22	2:36 AM	WELCHES-ZIG ZAG	7	3781	26468.05	9/11/22	5:37 PM	FUSE_OH:D3704A-1181 / ABC / 100 A	0.028583	7.56E-06	3,781
1308997	9/9/22	2:36 AM	WELCHES-ZIG ZAG	352	3781	1330959	9/11/22	5:37 PM	FUSE_OH:D2734C-109 / ABC / 100 A	1.437319	3.80E-04	3,781
1308986	9/9/22	2:36 AM	WELCHES-ZIG ZAG	14	3781	52935.4	9/11/22	5:37 PM	FUSE_OH:D3703B-998 / ABC / 25 A	0.057166	1.51E-05	3,781
1309010	9/9/22	2:36 AM	WELCHES-ZIG ZAG	8	3781	30248	9/11/22	5:37 PM	FUSE_OH:D3711A-237 / B / 25 A	0.032665	8.64E-06	3,781
1308256	9/9/22	2:36 AM	WELCHES-ZIG ZAG	213	3781	805345.9	9/11/22	5:36 PM	BKR:WELCHES R112	0.869703	2.30E-04	3,781
1312792	9/9/22	2:36 AM	WELCHES-ZIG ZAG	51	3781	192826.8	9/11/22	5:36 PM	FUSE_OH:D3713D-495 / B / 40 A	0.208236	5.51E-05	3,781
1309007	9/9/22	2:36 AM	WELCHES-ZIG ZAG	48	3781	181483.2	9/11/22	5:36 PM	FUSE_OH:D3711A-848 / B / 40 A	0.195986	5.18E-05	3,781
1308247	9/9/22	2:21 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3772	3772.167	9/11/22	5:14 PM	FUSE_OH:D2528A-367 / C / 40 A	0.004074	1.08E-06	3,772
1308751	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3772	7543.067	9/11/22	5:26 PM	FUSE_OH:D2521C-1128 / C / 40 A	0.008146	2.16E-06	3,772
1308754	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	5	3771	18855	9/11/22	5:26 PM	FUSE_OH:D2521C-346 / C / 40 A	0.020362	5.40E-06	3,771
1308750	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3770	3770.033	9/11/22	5:25 PM	FUSE_OH:D2521C-1128 / A / 40 A	0.004071	1.08E-06	3,770
1308757	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	14	3766	52718.4	9/11/22	5:20 PM	FUSE_OH:D2521C-1805 / A / 40 A	0.056931	1.51E-05	3,766
1309087	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3760	3759.9	9/11/22	7:41 PM	FUSE_OH:A1432D-1455 / C / 10 A	0.00406	1.08E-06	3,760
1308246	9/9/22	2:21 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3756	3756.167	9/11/22	4:58 PM	SP:46809 SE HWY 26	0.004056	1.08E-06	3,756
1308774	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	19	3756	71356.72	9/11/22	5:10 PM	FUSE_OH:D2533D-1403 / B / 40 A	0.077059	2.05E-05	3,756
1308810	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	6	3754	22524	9/11/22	5:09 PM	FUSE_OH:D2526B-414 / AC / 40 A	0.024324	6.48E-06	3,754
1310871	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	100	3752	375185	9/11/22	5:06 PM	FUSE_OH:D2525B-474 / BC / 65 A	0.405167	1.08E-04	3,752

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1319000	9/9/22	2:32 AM	SANDY-SANDY 13	1	3749	3749.133	9/11/22	5:02 PM	SP:46727 SE HWY 26	0.004049	1.08E-06	3,749
1308249	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	30	3747	112410	9/11/22	5:02 PM	FUSE_OH:D2527B-386 / C / 40 A	0.121393	3.24E-05	3,747
1308248	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	33	3745	123585	9/11/22	5:00 PM	TRIP_SAVER:D2526D-423 / B / 40 A	0.133461	3.56E-05	3,745
1310872	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	70	3745	262150	9/11/22	5:00 PM	FUSE_OH:D2525B-475 / ABC / 65 A	0.283099	7.56E-05	3,745
1310862	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	12	3743	44916	9/11/22	4:58 PM	FUSE_OH:D2619D-18 / ABC / 100 A	0.048505	1.30E-05	3,743
1319004	9/9/22	2:32 AM	SANDY-SANDY 13	2	3738	7476.267	9/11/22	4:51 PM	XFM_OH:A 10 31832	0.008074	2.16E-06	3,738
1308808	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	34	3736	127034.2	9/11/22	4:51 PM	FUSE_OH:D2526B-409 / ABC / 40 A	0.137186	3.67E-05	3,736
1308825	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	5	3726	18630	9/11/22	4:41 PM	FUSE_OH:D2526B-415 / AB / 40 A	0.020119	5.40E-06	3,726
1309205	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	31	3723	115413	9/11/22	4:38 PM	TRIP_SAVER:D2534B-1373 / B / 40 A	0.124636	3.35E-05	3,723
1308765	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	18	3722	66996	9/11/22	4:37 PM	FUSE_OH:D2534B-1373 / C / 40 A	0.07235	1.94E-05	3,722
1310873	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3720	11161.45	9/11/22	4:35 PM	FUSE_OH:D2525B-1855 / ABC / 10 A	0.012053	3.24E-06	3,720
1308773	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	14	3718	52052	9/11/22	4:33 PM	FUSE_OH:D2533D-1403 / AB / 40 A	0.056212	1.51E-05	3,718
1308827	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3715	14860	9/11/22	4:30 PM	FUSE_OH:D2526B-416 / A / 6 A	0.016047	4.32E-06	3,715
1308828	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3712	7424	9/11/22	4:27 PM	FUSE_OH:D2526C-420 / C / 6 A	0.008017	2.16E-06	3,712
1308830	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3712	7424	9/11/22	4:27 PM	FUSE_OH:D2526D-422 / C / 40 A	0.008017	2.16E-06	3,712
1309134	9/9/22	5:02 AM	HOGAN NORTH-LINKS	10	3709	37090	9/11/22	6:51 PM	FUSE_OH:A1435A-488 / AC / 25 A	0.040054	1.08E-05	3,709
1318999	9/9/22	2:32 AM	SANDY-SANDY 13	2	3708	7416.267	9/11/22	4:21 PM	XFM_UG:A 25 51941	0.008009	2.16E-06	3,708
1319001	9/9/22	2:32 AM	SANDY-SANDY 13	2	3708	7416.267	9/11/22	4:21 PM	XFM_UG:A 15 44170	0.008009	2.16E-06	3,708
1310864	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3705	7410	9/11/22	4:20 PM	FUSE_OH:D2630B-9 / AC / 15 A	0.008002	2.16E-06	3,705
1308835	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3702	14808	9/11/22	4:17 PM	FUSE_OH:D2526D-2478 / C / 40 A	0.015991	4.32E-06	3,702
1310869	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3698	3698	9/11/22	4:13 PM	FUSE_OH:D2525A-457 / B / 6 A	0.003994	1.08E-06	3,698
1310867	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3697	11091	9/11/22	4:12 PM	FUSE_OH:D2525A-459 / C / 15 A	0.011977	3.24E-06	3,697
1308805	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3695	14780	9/11/22	4:10 PM	FUSE_OH:D2534C-1812 / C / 10 A	0.015961	4.32E-06	3,695
1308806	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	24	3694	88656	9/11/22	4:09 PM	FUSE_OH:D2534C-1812 / C / 15 A	0.095741	2.59E-05	3,694
1308952	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	34	3694	125596	9/11/22	3:58 PM	FUSE_OH:D38.523B-134 / C / 40 A	0.135633	3.67E-05	3,694
1308762	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3686	11058	9/11/22	4:01 PM	FUSE_OH:D2527C-1364 / A / 25 A	0.011942	3.24E-06	3,686
1310857	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	10	3683	36829.33	9/11/22	3:57 PM	FUSE_OH:D2619D-28 / C / 25 A	0.039772	1.08E-05	3,683
1310859	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3672	14688	9/11/22	3:47 PM	FUSE_OH:D2619D-24 / C / 10 A	0.015862	4.32E-06	3,672
1308962	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	12	3668	44015.4	9/11/22	3:31 PM	FUSE_OH:D3824B-20 / ABC / 65 A	0.047533	1.3E-05	3,668
1308958	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	5	3667	18336.42	9/11/22	3:31 PM	FUSE_OH:D3824B-498 / AB / 40 A	0.019802	5.40E-06	3,667
1319002	9/9/22	2:32 AM	SANDY-SANDY 13	2	3666	7332.267	9/11/22	3:39 PM	XFM_OH:A 15 39095	0.007918	2.16E-06	3,666
1310844	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	81	3665	296865	9/11/22	3:40 PM	FUSE_OH:D2622C-88 / B / 200 A	0.320588	8.75E-05	3,665
1310854	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	5	3664	18320	9/11/22	3:39 PM	FUSE_OH:D2620C-277 / C / 6 A	0.019784	5.40E-06	3,664
1310858	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	6	3663	21980.4	9/11/22	3:38 PM	FUSE_OH:D2619D-25 / BC / 25 A	0.023737	6.48E-06	3,663
1309133	9/9/22	5:02 AM	HOGAN NORTH-LINKS	6	3663	21978	9/11/22	6:05 PM	FUSE_OH:A1425C-1168 / A / 25 A	0.023734	6.48E-06	3,663
1309306	9/9/22	8:15 AM	OAK GROVE-LAKE HARRIET	47	3662	172127.3	9/11/22	9:17 PM	FUSE_OH:D5635B-100 / ABC / 40 A	0.185882	5.08E-05	3,662
1309459	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	3661	3661	9/11/22	9:11 PM	FUSE_OH:D3533B-501 / C / 15 A	0.003954	1.08E-06	3,661
1310853	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3652	10956.9	9/11/22	3:27 PM	FUSE_OH:D2620C-45 / C / 6 A	0.011832	3.24E-06	3,652
1310851	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	49	3649	178801	9/11/22	3:24 PM	FUSE_OH:D2620D-916 / B / 40 A	0.193089	5.29E-05	3,649
1317064	9/9/22	2:32 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3648	7296.267	9/11/22	3:21 PM	XFM_UG:B 25 71184	0.007879	2.16E-06	3,648
1317065	9/9/22	2:32 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3645	7290.267	9/11/22	3:18 PM	FUSE_OH:D2620D-914 / B / 25 A	0.007873	2.16E-06	3,645
1309129	9/9/22	5:02 AM	HOGAN NORTH-LINKS	18	3645	65609.1	9/11/22	5:46 PM	FUSE_OH:A1436A-397 / AB / 65 A	0.070852	1.94E-05	3,645
1309305	9/9/22	8:15 AM	OAK GROVE-LAKE HARRIET	35	3644	127552.8	9/11/22	9:00 PM	FUSE_OH:D5635B-276 / ABC / 100 A	0.137746	3.78E-05	3,644
1310850	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3641	7281.833	9/11/22	3:15 PM	FUSE_OH:D2620D-57 / A / 6 A	0.007864	2.16E-06	3,641
1312786	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	8	3640	29120	9/11/22	3:04 PM	FUSE_OH:D38.523A-302 / ABC / 100 A	0.031447	8.64E-06	3,640
1310847	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	9	3634	32708.85	9/11/22	3:09 PM	FUSE_OH:D2621C-66 / B / 6 A	0.035323	9.72E-06	3,634
1310849	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3634	14537.27	9/11/22	3:09 PM	FUSE_OH:D2621C-64 / B / 25 A	0.015699	4.32E-06	3,634
1310846	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	14	3631	50831.9	9/11/22	3:05 PM	FUSE_OH:D2621C-1650 / BC / 15 A	0.054894	1.51E-05	3,631
1309390	9/9/22	8:10 AM	ESTACADA-NORTH FORK	5	3624	18120	9/11/22	8:34 PM	FUSE_OH:D3434B-2625 / C / 25 A	0.019568	5.40E-06	3,624
1309038	9/9/22	3:15 AM	SILVERTON-SOUTH	1	3623	3623	9/11/22	3:38 PM	FUSE_OH:D8112B-117 / C / 6 A	0.003913	1.08E-06	3,623

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1309040	9/9/22	3:15 AM	SILVERTON-SOUTH	1	3622	3622	9/11/22	3:37 PM	FUSE_OH:D8112A-128 / B / 6 A	0.003911	1.08E-06	3,622
1309086	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3622	3622	9/11/22	5:24 PM	FUSE_OH:A1429C-6 / B / 40 A	0.003911	1.08E-06	3,622
1308946	9/9/22	2:34 AM	WELCHES-WELCHES 13	1	3619	3619.4	9/11/22	2:53 PM	FUSE_OH:D3704B-1118 / B / 10 A	0.003909	1.08E-06	3,619
1309302	9/9/22	8:16 AM	OAK GROVE-WHITE WATER	3	3619	10856.45	9/11/22	8:35 PM	BKR:OAK GROVE R180	0.011724	3.24E-06	3,619
1309041	9/9/22	3:15 AM	SILVERTON-SOUTH	1	3618	3618	9/11/22	3:33 PM	FUSE_OH:D8112A-129 / B / 40 A	0.003907	1.08E-06	3,618
1309084	9/9/22	5:02 AM	HOGAN NORTH-LINKS	12	3617	43404	9/11/22	5:19 PM	FUSE_OH:A1429C-2 / A / 40 A	0.046873	1.30E-05	3,617
1312787	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	10	3608	36078.67	9/11/22	2:31 PM	FUSE_OH:D38.523A-283 / A / 25 A	0.038962	1.08E-05	3,608
1309082	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3606	3606.05	9/11/22	5:08 PM	FUSE_OH:A1432B-23 / A / 40 A	0.003894	1.08E-06	3,606
1309085	9/9/22	5:02 AM	HOGAN NORTH-LINKS	7	3601	25207	9/11/22	5:03 PM	FUSE_OH:A1429C-2 / B / 40 A	0.027221	7.56E-06	3,601
1310856	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	23	3598	82752.47	9/11/22	2:32 PM	TRIP_SAVER:D2620C-31 / B / 40 A	0.089365	2.48E-05	3,598
1309083	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3596	3596.383	9/11/22	4:58 PM	FUSE_OH:A1432B-26 / A / 6 A	0.003884	1.08E-06	3,596
1309081	9/9/22	5:02 AM	HOGAN NORTH-LINKS	22	3585	78868.17	9/11/22	4:46 PM	FUSE_OH:A1432B-19 / C / 40 A	0.085171	2.38E-05	3,585
1308957	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	8	3584	28671.2	9/11/22	2:07 PM	FUSE_OH:D38.523B-153 / ABC / 65 A	0.030962	8.64E-06	3,584
1309201	9/9/22	5:02 AM	HOGAN NORTH-LINKS	96	3583	343987.2	9/11/22	4:45 PM	TRIP_SAVER:A1436A-400 / AB / 40 A	0.371476	1.04E-04	3,583
1308956	9/9/22	2:24 AM	SUMMIT-SUMMIT 13	43	3581	153983	9/11/22	2:05 PM	FUSE_OH:D38.523B-195 / ABC / 65 A	0.166288	4.64E-05	3,581
1310250	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	3578	3578	9/11/22	10:20 PM	FUSE_OH:D6134B-539 / B / 6 A	0.003864	1.08E-06	3,578
1310855	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	42	3576	150189.9	9/11/22	2:10 PM	TRIP_SAVER:D2620C-41 / A / 40 A	0.162192	4.54E-05	3,576
1309080	9/9/22	5:02 AM	HOGAN NORTH-LINKS	58	3573	207234	9/11/22	4:35 PM	FUSE_OH:A1432C-14 / BC / 40 A	0.223795	6.26E-05	3,573
1308906	9/9/22	2:20 AM	SUMMIT-GOVERNMENT CAMP	8	3568	28546.27	9/11/22	1:48 PM	FUSE_OH:D3824A-26 / A / 40 A	0.030827	8.64E-06	3,568
1308833	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	3	3566	10698	9/11/22	1:59 PM	FUSE_OH:D2512D-1760 / A / 25 A	0.011553	3.24E-06	3,566
1308728	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	16	3565	57040	9/11/22	1:58 PM	TRIP_SAVER:D2623C-722 / A / 25 A	0.061598	1.73E-05	3,565
1308923	9/9/22	2:22 AM	SUMMIT-MEADOWS	1	3560	3560	9/11/22	1:42 PM	FUSE_OH:D38.513C-125 / AC / 40 A	0.003844	1.08E-06	3,560
1308834	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	3	3559	10677	9/11/22	1:52 PM	FUSE_OH:D2511D-1746 / A / 25 A	0.01153	3.24E-06	3,559
1309035	9/9/22	3:15 AM	SILVERTON-SOUTH	2	3555	7110	9/11/22	2:30 PM	FUSE_OH:D8112B-114 / B / 6 A	0.007678	2.16E-06	3,555
1308245	9/9/22	2:16 AM	SUMMIT-SUMMIT 13	158	3548	560557.7	9/11/22	1:24 PM	BKR:SUMMIT R104	0.605353	1.71E-04	3,548
1308947	9/9/22	2:34 AM	WELCHES-WELCHES 13	35	3533	123655	9/11/22	1:27 PM	FUSE_OH:D2732D-922 / C / 65 A	0.133537	3.78E-05	3,533
1309018	9/9/22	5:02 AM	HOGAN NORTH-LINKS	53	3531	187163.3	9/11/22	3:53 PM	RECL:5332	0.20212	5.72E-05	3,531
1308241	9/9/22	2:20 AM	SUMMIT-GOVERNMENT CAMP	480	3528	1693224	9/11/22	1:07 PM	BKR:SUMMIT R102	1.828534	5.18E-04	3,528
1308966	9/9/22	2:34 AM	WELCHES-WELCHES 13	2	3527	7054	9/11/22	1:21 PM	FUSE_OH:D2732D-918 / C / 25 A	0.007618	2.16E-06	3,527
1309090	9/9/22	5:02 AM	HOGAN NORTH-LINKS	4	3526	14104	9/11/22	3:48 PM	FUSE_OH:D1405A-358 / B / 40 A	0.015231	4.32E-06	3,526
1309226	9/9/22	2:34 AM	WELCHES-WELCHES 13	7	3526	24682	9/11/22	1:20 PM	TRIP_SAVER:D2732D-920 / A / 40 A	0.026654	7.56E-06	3,526
1308963	9/9/22	2:34 AM	WELCHES-WELCHES 13	14	3525	49350	9/11/22	1:19 PM	FUSE_OH:D2732D-920 / C / 65 A	0.053294	1.51E-05	3,525
1308968	9/9/22	2:34 AM	WELCHES-WELCHES 13	6	3522	21131.4	9/11/22	1:15 PM	FUSE_OH:D2732D-917 / A / 65 A	0.02282	6.48E-06	3,522
1309225	9/9/22	2:34 AM	WELCHES-WELCHES 13	5	3519	17595.42	9/11/22	1:13 PM	TRIP_SAVER:D2732D-919 / A / 40 A	0.019002	5.4E-06	3,519
1309091	9/9/22	5:02 AM	HOGAN NORTH-LINKS	12	3519	42228	9/11/22	3:41 PM	FUSE_OH:D1405A-197 / AB / 100 A	0.045603	1.30E-05	3,519
1308965	9/9/22	2:34 AM	WELCHES-WELCHES 13	17	3518	59806	9/11/22	1:12 PM	FUSE_OH:D2732D-919 / C / 65 A	0.064585	1.84E-05	3,518
1308832	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	1	3518	3518	9/11/22	1:11 PM	FUSE_OH:D2618B-479 / C / 25 A	0.003799	1.08E-06	3,518
1308922	9/9/22	2:22 AM	SUMMIT-MEADOWS	3	3517	10551	9/11/22	12:59 PM	FUSE_OH:D38.524B-112 / A / 40 A	0.011394	3.24E-06	3,517
1308969	9/9/22	2:34 AM	WELCHES-WELCHES 13	2	3516	7032	9/11/22	1:10 PM	FUSE_OH:D2732D-916 / C / 6 A	0.007594	2.16E-06	3,516
1310812	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	7	3516	24612	9/11/22	1:11 PM	FUSE_OH:D2626A-948 / B / 25 A	0.026579	7.56E-06	3,516
1310809	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	59	3512	207208	9/11/22	1:07 PM	TRIP_SAVER:D2625B-1083 / C / 65 A	0.223766	6.37E-05	3,512
1310810	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	20	3504	70080	9/11/22	12:59 PM	FUSE_OH:D2625B-324 / C / 65 A	0.07568	2.16E-05	3,504
1308975	9/9/22	2:34 AM	WELCHES-WELCHES 13	2	3504	7008	9/11/22	12:58 PM	FUSE_OH:D2732C-908 / C / 6 A	0.007568	2.16E-06	3,504
1308746	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	2	3502	7004.5	9/11/22	12:55 PM	FUSE_OH:D2730D-959 / A / 40 A	0.007564	2.16E-06	3,502
1309079	9/9/22	5:02 AM	HOGAN NORTH-LINKS	55	3501	192555	9/11/22	3:23 PM	FUSE_OH:A1432C-437 / ABC / 65 A	0.207943	5.94E-05	3,501
1308976	9/9/22	2:34 AM	WELCHES-WELCHES 13	2	3496	6992	9/11/22	12:50 PM	FUSE_OH:D2732C-904 / C / 6 A	0.007551	2.16E-06	3,496
1309092	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3496	3495.717	9/11/22	3:17 PM	FUSE_OH:A1433C-865 / C / 65 A	0.003775	1.08E-06	3,496
1309299	9/9/22	8:15 AM	OAK GROVE-LAKE HARRIET	3	3488	10464.35	9/11/22	6:23 PM	BKR:OAK GROVE R176	0.011301	3.24E-06	3,488
1310254	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	3488	3488	9/11/22	8:50 PM	FUSE_OH:D6134D-544 / B / 6 A	0.003767	1.08E-06	3,488
1308747	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	5	3488	17439.25	9/11/22	12:40 PM	FUSE_OH:D2729C-429 / A / 10 A	0.018833	5.40E-06	3,488

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310246	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	3487	6974	9/11/22	8:49 PM	FUSE_OH:D6134B-526 / A / 10 A	0.007531	2.16E-06	3,487
1308977	9/9/22	2:34 AM	WELCHES-WELCHES 13	7	3485	24395	9/11/22	12:39 PM	FUSE_OH:D2732B-902 / C / 15 A	0.026344	7.56E-06	3,485
1308980	9/9/22	2:34 AM	WELCHES-WELCHES 13	75	3484	261300	9/11/22	12:38 PM	FUSE_OH:D2731A-844 / AC / 65 A	0.282181	8.10E-05	3,484
1308978	9/9/22	2:34 AM	WELCHES-WELCHES 13	45	3479	156555	9/11/22	12:33 PM	FUSE_OH:D2732B-901 / B / 40 A	0.169066	4.86E-05	3,479
1308979	9/9/22	2:34 AM	WELCHES-WELCHES 13	6	3479	20874	9/11/22	12:33 PM	FUSE_OH:D2732B-901 / C / 6 A	0.022542	6.48E-06	3,479
1308981	9/9/22	2:34 AM	WELCHES-WELCHES 13	4	3475	13900	9/11/22	12:29 PM	FUSE_OH:D2731A-21 / C / 65 A	0.015011	4.32E-06	3,475
1309077	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3473	3473.417	9/11/22	2:55 PM	FUSE_OH:A1432C-1760 / C / 65 A	0.003751	1.08E-06	3,473
1316994	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	89	3471	308960.5	9/11/22	12:26 PM	RECL:1461	0.33365	9.61E-05	3,471
1309219	9/9/22	2:34 AM	WELCHES-WELCHES 13	19	3471	65955.65	9/11/22	12:25 PM	TRIP_SAVER:D2732D-916 / A / 40 A	0.071226	2.05E-05	3,471
1308971	9/9/22	2:34 AM	WELCHES-WELCHES 13	33	3471	114543	9/11/22	12:25 PM	FUSE_OH:D2732D-911 / ABC / 65 A	0.123696	3.56E-05	3,471
1308749	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	9	3471	31235.25	9/11/22	12:23 PM	FUSE_OH:D2732B-435 / B / 40 A	0.033731	9.72E-06	3,471
1308748	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	2	3470	6940.333	9/11/22	12:23 PM	FUSE_OH:D2732B-435 / A / 15 A	0.007495	2.16E-06	3,470
1308973	9/9/22	2:34 AM	WELCHES-WELCHES 13	266	3469	922700.8	9/11/22	12:22 PM	FUSE_OH:D2732D-910 / ABC / 100 A	0.996436	2.87E-04	3,469
1308970	9/9/22	2:34 AM	WELCHES-WELCHES 13	6	3469	20812.4	9/11/22	12:22 PM	FUSE_OH:D2732D-911 / A / 15 A	0.022476	6.48E-06	3,469
1308831	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	3	3468	10402.65	9/11/22	12:20 PM	FUSE_OH:D2618D-489 / A / 25 A	0.011234	3.24E-06	3,468
1309076	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3466	3466	9/11/22	2:48 PM	FUSE_OH:A1432C-1110 / A / 6 A	0.003743	1.08E-06	3,466
1308829	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	8	3461	27684.8	9/11/22	12:13 PM	FUSE_OH:D2618D-490 / A / 25 A	0.029897	8.64E-06	3,461
1309078	9/9/22	5:02 AM	HOGAN NORTH-LINKS	7	3457	24199.12	9/11/22	2:39 PM	FUSE_OH:A1432C-437 / B / 65 A	0.026133	7.56E-06	3,457
1308741	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	10	3450	34500	9/11/22	12:03 PM	FUSE_OH:D2730B-156 / A / 15 A	0.037257	1.08E-05	3,450
1308243	9/9/22	2:22 AM	SUMMIT-MEADOWS	36	3448	124125	9/11/22	11:49 AM	BKR:SUMMIT R106	0.134044	3.89E-05	3,448
1308752	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	39	3445	134355	9/11/22	11:58 AM	FUSE_OH:D2732A-967 / AB / 40 A	0.145092	4.21E-05	3,445
1310826	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3445	10335	9/11/22	12:00 PM	FUSE_OH:D2730B-3 / A / 6 A	0.011161	3.24E-06	3,445
1308961	9/9/22	2:34 AM	WELCHES-WELCHES 13	49	3442	168658	9/11/22	11:56 AM	FUSE_OH:D3709B-109 / C / 25 A	0.182136	5.29E-05	3,442
1310828	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3441	3441	9/11/22	11:56 AM	FUSE_OH:D2730C-858 / ABC / 15 A	0.003716	1.08E-06	3,441
1309075	9/9/22	5:02 AM	HOGAN NORTH-LINKS	2	3437	6874.167	9/11/22	2:19 PM	FUSE_OH:A1432C-1108 / A / 65 A	0.007423	2.16E-06	3,437
1308959	9/9/22	2:34 AM	WELCHES-WELCHES 13	135	3433	463518	9/11/22	11:47 AM	FUSE_OH:D3709B-93 / AB / 65 A	0.500559	1.46E-04	3,433
1308826	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	1	3430	3430	9/11/22	11:43 AM	FUSE_OH:D2618D-500 / A / 25 A	0.003704	1.08E-06	3,430
1310875	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3429	6858	9/11/22	11:44 AM	FUSE_OH:D2525B-445 / A / 6 A	0.007406	2.16E-06	3,429
1310842	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	11	3428	37708	9/11/22	11:43 AM	TRIP_SAVER:D2622C-95 / A / 25 A	0.040721	1.19E-05	3,428
1308736	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	16	3428	54848	9/11/22	11:41 AM	FUSE_OH:D2730B-691 / C / 65 A	0.059231	1.73E-05	3,428
1308753	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	2	3421	6842	9/11/22	11:34 AM	FUSE_OH:D2733B-447 / B / 40 A	0.007389	2.16E-06	3,421
1308413	9/9/22	2:34 AM	SANDY-SANDY 13	275	3419	940128.8	9/11/22	11:33 AM	RECL:3372	1.015257	2.97E-04	3,419
1308735	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	28	3417	95676	9/11/22	11:30 AM	FUSE_OH:D2719C-421 / A / 65 A	0.103322	3.02E-05	3,417
1308756	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	16	3417	54672	9/11/22	11:30 AM	FUSE_OH:D2733C-971 / B / 40 A	0.059041	1.73E-05	3,417
1308755	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	3	3416	10248	9/11/22	11:29 AM	FUSE_OH:D2733C-971 / B / 25 A	0.011067	3.24E-06	3,416
1308983	9/9/22	2:34 AM	WELCHES-WELCHES 13	1	3411	3411	9/11/22	11:25 AM	FUSE_OH:D2730C-16 / C / 40 A	0.003684	1.08E-06	3,411
1308809	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	3	3410	10230	9/11/22	11:23 AM	FUSE_OH:D2620A-517 / BC / 25 A	0.011048	3.24E-06	3,410
1310841	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3400	13600	9/11/22	11:15 AM	FUSE_OH:D2622C-96 / B / 15 A	0.014687	4.32E-06	3,400
1310877	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3400	6800	9/11/22	11:15 AM	FUSE_OH:D2526A-431 / B / 6 A	0.007343	2.16E-06	3,400
1310825	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3397	10191	9/11/22	11:12 AM	FUSE_OH:D2730B-2120 / C / 6 A	0.011005	3.24E-06	3,397
1309095	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3396	3396	9/11/22	1:38 PM	FUSE_OH:A1433D-559 / B / 6 A	0.003667	1.08E-06	3,396
1308759	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	5	3395	16975	9/11/22	11:08 AM	FUSE_OH:D2733C-451 / C / 40 A	0.018332	5.40E-06	3,395
1308807	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	24	3394	81456	9/11/22	11:07 AM	FUSE_OH:D2622B-538 / C / 15 A	0.087965	2.59E-05	3,394
1308732	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	1	3391	3391	9/11/22	11:04 AM	FUSE_OH:D2624D-334 / C / 6 A	0.003662	1.08E-06	3,391
1309316	9/9/22	7:56 AM	MOBILE 2-KILO	82	3389	277933.5	9/11/22	4:25 PM	FUSE_OH:D4302D-828 / C / 40 A	0.300144	8.86E-05	3,389
1310824	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3384	10152	9/11/22	10:59 AM	FUSE_OH:D2625A-684 / C / 25 A	0.010963	3.24E-06	3,384
1310839	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3384	3384	9/11/22	10:59 AM	FUSE_OH:D2622D-98 / A / 6 A	0.003654	1.08E-06	3,384
1308954	9/9/22	2:34 AM	WELCHES-WELCHES 13	20	3375	67499.67	9/11/22	10:48 AM	FUSE_OH:D3709B-1128 / A / 40 A	0.072894	2.16E-05	3,375
1308761	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	1	3373	3373	9/11/22	10:46 AM	FUSE_OH:D2733D-456 / C / 40 A	0.003643	1.08E-06	3,373
1308740	9/9/22	2:47 AM	EAGLE CREEK-BARTON	116	3372	391142.3	9/11/22	10:59 AM	FUSE_OH:D2428C-191 / ABC / 100 A	0.422399	1.25E-04	3,372

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1309096	9/9/22	5:02 AM	HOGAN NORTH-LINKS	103	3367	346828.5	9/11/22	1:09 PM	FUSE_OH:A1433A-255 / ABC / 65 A	0.374544	1.11E-04	3,367
1308951	9/9/22	2:34 AM	WELCHES-WELCHES 13	22	3365	74029.27	9/11/22	10:38 AM	FUSE_OH:D3709B-77 / B / 40 A	0.079945	2.38E-05	3,365
1308763	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	13	3363	43719	9/11/22	10:36 AM	FUSE_OH:D2733D-459 / A / 40 A	0.047213	1.40E-05	3,363
1308731	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	5	3360	16800	9/11/22	10:33 AM	FUSE_OH:D2624C-610 / ABC / 100 A	0.018143	5.4E-06	3,360
1309093	9/9/22	5:02 AM	HOGAN NORTH-LINKS	4	3360	13438.67	9/11/22	1:01 PM	FUSE_OH:A1433C-441 / A / 6 A	0.014513	4.32E-06	3,360
1309097	9/9/22	5:02 AM	HOGAN NORTH-LINKS	91	3359	305669	9/11/22	1:01 PM	FUSE_OH:A1434B-253 / AB / 65 A	0.330096	9.83E-05	3,359
1310838	9/9/22	2:30 AM	BRIGHTWOOD-BRIGHTWOOD 13	34	3357	114149.3	9/11/22	10:27 AM	FUSE_OH:D2622D-102 / B / 100 A	0.123271	3.67E-05	3,357
1310822	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	10	3348	33480	9/11/22	10:23 AM	TRIP_SAVER:D2624D-172 / A / 25 A	0.036155	1.08E-05	3,348
1310808	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	28	3346	93694.07	9/11/22	10:21 AM	FUSE_OH:D2623D-126 / B / 40 A	0.101181	3.02E-05	3,346
1310807	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	3	3346	10038	9/11/22	10:21 AM	FUSE_OH:D2623C-120 / B / 6 A	0.01084	3.24E-06	3,346
1308764	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	14	3346	46844	9/11/22	10:19 AM	FUSE_OH:D2733D-460 / B / 40 A	0.050587	1.51E-05	3,346
1308955	9/9/22	2:34 AM	WELCHES-WELCHES 13	27	3344	90288	9/11/22	10:18 AM	FUSE_OH:D3709B-1128 / C / 40 A	0.097503	2.92E-05	3,344
1308251	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	590	3343	1972105	9/11/22	10:15 AM	BKR:BRIGHTWOOD R110	2.1297	6.37E-04	3,343
1308729	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	5	3342	16710	9/11/22	10:15 AM	FUSE_OH:D2623B-351 / C / 65 A	0.018045	5.40E-06	3,342
1310785	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	5	3337	16685	9/11/22	10:12 AM	FUSE_OH:D2623C-116 / B / 6 A	0.018018	5.40E-06	3,337
1310837	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	7	3335	23345.7	9/11/22	10:10 AM	FUSE_OH:D2622D-408 / AB / 40 A	0.025211	7.56E-06	3,335
1308950	9/9/22	2:34 AM	WELCHES-WELCHES 13	80	3325	266000	9/11/22	9:59 AM	FUSE_OH:D3705D-43 / AC / 65 A	0.287257	8.64E-05	3,325
1309102	9/9/22	5:02 AM	HOGAN NORTH-LINKS	5	3325	16622.83	9/11/22	12:26 PM	FUSE_OH:A1434A-673 / AB / 65 A	0.017951	5.40E-06	3,325
1310830	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3324	3324	9/11/22	9:59 AM	FUSE_OH:D2622D-937 / B / 6 A	0.00359	1.08E-06	3,324
1310783	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	7	3321	23247.7	9/11/22	9:56 AM	FUSE_OH:D2623C-852 / C / 15 A	0.025105	7.56E-06	3,321
1308949	9/9/22	2:34 AM	WELCHES-WELCHES 13	26	3321	86346	9/11/22	9:55 AM	TRIP_SAVER:D3705A-952 / B / 40 A	0.093246	2.81E-05	3,321
1308739	9/9/22	2:47 AM	EAGLE CREEK-BARTON	188	3317	623574.1	9/11/22	10:03 AM	FUSE_OH:D2428B-3535 / ABC / 100 A	0.673405	0.000203	3,317
1310780	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	3313	3313.2	9/11/22	9:48 AM	FUSE_OH:D2623C-115 / B / 6 A	0.003578	1.08E-06	3,313
1309039	9/9/22	5:02 AM	ORIENT-OXBOW	1	3313	3312.9	9/11/22	12:15 PM	FUSE_OH:D1424B-992 / A / 25 A	0.003578	1.08E-06	3,313
1310280	9/9/22	10:26 AM	MOLALLA-MARQUAM	1	3306	3306.333	9/11/22	5:32 PM	FUSE_OH:D5229B-243 / A / 25 A	0.003571	1.08E-06	3,306
1310820	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	45	3303	148632	9/11/22	9:37 AM	FUSE_OH:D2624C-164 / ABC / 25 A	0.16051	4.86E-05	3,303
1309037	9/9/22	5:02 AM	ORIENT-OXBOW	1	3297	3296.9	9/11/22	11:59 AM	FUSE_OH:D1424B-998 / AB / 25 A	0.00356	1.08E-06	3,297
1309036	9/9/22	5:02 AM	ORIENT-OXBOW	4	3294	13175.6	9/11/22	11:56 AM	FUSE_OH:D1424B-1002 / BC / 25 A	0.014228	4.32E-06	3,294
1310818	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3291	6581.967	9/11/22	9:25 AM	FUSE_OH:D2624C-147 / B / 15 A	0.007108	2.16E-06	3,291
1309070	9/9/22	5:02 AM	HOGAN NORTH-LINKS	1	3288	3288	9/11/22	11:50 AM	FUSE_OH:D1406A-163 / A / 6 A	0.003551	1.08E-06	3,288
1309034	9/9/22	5:02 AM	ORIENT-OXBOW	2	3286	6571.8	9/11/22	11:48 AM	FUSE_OH:D1423A-1003 / A / 6 A	0.007097	2.16E-06	3,286
1310819	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3285	6570.967	9/11/22	9:20 AM	FUSE_OH:D2624C-147 / C / 15 A	0.007096	2.16E-06	3,285
1308253	9/9/22	2:34 AM	WELCHES-WELCHES 13	918	3283	3013993	9/11/22	9:17 AM	BKR:WELCHES R308	3.254848	9.91E-04	3,283
1310817	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	18	3280	59039.7	9/11/22	9:14 AM	TRIP_SAVER:D2624C-145 / B / 40 A	0.063758	1.94E-05	3,280
1310899	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	3277	3276.983	9/11/22	7:36 PM	FUSE_OH:B2435B-419 / AC / 6 A	0.003539	1.08E-06	3,277
1309033	9/9/22	5:02 AM	ORIENT-OXBOW	91	3274	297924.9	9/11/22	11:36 AM	FUSE_OH:D1423A-1004 / ABC / 25 A	0.321733	9.83E-05	3,274
1309261	9/9/22	7:56 AM	MOBILE 2-KILO	162	3274	530307	9/11/22	2:29 PM	FUSE_OH:D4305D-161 / ABC / 65 A	0.572685	1.75E-04	3,274
1310816	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	3272	13088.87	9/11/22	9:07 AM	FUSE_OH:D2624C-679 / C / 6 A	0.014135	4.32E-06	3,272
1311201	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	3266	3265.833	9/11/22	7:48 PM	FUSE_OH:B1434D-201 / A / 65 A	0.003527	1.08E-06	3,266
1310815	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	30	3259	97763	9/11/22	8:53 AM	FUSE_OH:D2624C-141 / ABC / 15 A	0.105575	3.24E-05	3,259
1309315	9/9/22	7:56 AM	MOBILE 2-KILO	1	3254	3253.75	9/11/22	2:09 PM	FUSE_OH:D4302C-826 / B / 15 A	0.003514	1.08E-06	3,254
1309430	9/9/22	8:10 AM	ESTACADA-NORTH FORK	25	3249	81225	9/11/22	2:19 PM	FUSE_OH:D3425C-801 / B / 40 A	0.087716	2.70E-05	3,249
1309311	9/9/22	7:56 AM	MOBILE 2-KILO	1	3248	3248.117	9/11/22	2:04 PM	FUSE_OH:D4302C-878 / B / 6 A	0.003508	1.08E-06	3,248
1310150	9/9/22	11:15 AM	MOLALLA-MARQUAM	121	3247	392872.9	9/11/22	5:22 PM	FUSE_OH:D5222D-362 / BC / 100 A	0.424268	1.31E-04	3,247
1309309	9/9/22	7:56 AM	MOBILE 2-KILO	2	3245	6490.633	9/11/22	2:01 PM	FUSE_OH:D4302C-879 / A / 6 A	0.007009	2.16E-06	3,245
1309308	9/9/22	7:56 AM	MOBILE 2-KILO	1	3243	3242.5	9/11/22	1:58 PM	FUSE_OH:D4302C-880 / A / 6 A	0.003502	1.08E-06	3,243
1309307	9/9/22	7:56 AM	MOBILE 2-KILO	2	3237	6473.4	9/11/22	1:52 PM	FUSE_OH:D4303D-881 / B / 6 A	0.006991	2.16E-06	3,237
1310530	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	3233	3232.783	9/11/22	6:01 PM	FUSE_OH:D3306A-6418 / C / 6 A	0.003491	1.08E-06	3,233
1309360	9/9/22	8:09 AM	ESTACADA-NORTH FORK	93	3227	300064.5	9/11/22	1:55 PM	FUSE_OH:D4403C-422 / B / 65 A	0.324043	1.00E-04	3,227
1313319	9/9/22	5:04 PM	GLENDOVEER-CLIFFGATE	1	3225	3225.267	9/11/22	10:50 PM	SP:13616 NE SACRAMENTO ST	0.003483	1.08E-06	3,225

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1309289	9/9/22	7:56 AM	MOBILE 2-KILO	2	3225	6450	9/11/22	1:41 PM	FUSE_OH:D4303D-2311 / C / 6 A	0.006965	2.16E-06	3,225
1310813	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	2	3223	6446.933	9/11/22	8:18 AM	FUSE_OH:D2623D-130 / C / 6 A	0.006962	2.16E-06	3,223
1309287	9/9/22	7:56 AM	MOBILE 2-KILO	1	3219	3218.567	9/11/22	1:34 PM	FUSE_OH:D4303D-1087 / C / 6 A	0.003476	1.08E-06	3,219
1309276	9/9/22	7:56 AM	MOBILE 2-KILO	137	3218	440866	9/11/22	1:34 PM	FUSE_OH:D4303C-154 / AC / 65 A	0.476097	1.48E-04	3,218
1309285	9/9/22	7:56 AM	MOBILE 2-KILO	1	3214	3214	9/11/22	1:30 PM	FUSE_OH:D4303C-297 / A / 6 A	0.003471	1.08E-06	3,214
1309026	9/9/22	5:02 AM	ORIENT-OXBOW	1	3208	3208.4	9/11/22	10:30 AM	FUSE_OH:D1411D-1028 / A / 6 A	0.003465	1.08E-06	3,208
1309278	9/9/22	7:56 AM	MOBILE 2-KILO	10	3201	32010	9/11/22	1:17 PM	FUSE_OH:D4303C-239 / B / 40 A	0.034568	1.08E-05	3,201
1309025	9/9/22	5:02 AM	ORIENT-OXBOW	5	3199	15992.5	9/11/22	10:20 AM	FUSE_OH:D1411B-101 / C / 25 A	0.01727	5.40E-06	3,199
1309028	9/9/22	5:02 AM	HOGAN NORTH-LINKS	421	3187	1341727	9/11/22	10:09 AM	SW_OHLB:7348	1.448948	4.55E-04	3,187
1309277	9/9/22	7:56 AM	MOBILE 2-KILO	1	3186	3186	9/11/22	1:02 PM	FUSE_OH:D4304D-2041 / A / 6 A	0.003441	1.08E-06	3,186
1308913	9/9/22	2:42 AM	SANDY-WILDCAT	7	3183	22281	9/11/22	7:45 AM	FUSE_OH:D3504D-121 / C / 25 A	0.024062	7.56E-06	3,183
1309275	9/9/22	7:56 AM	MOBILE 2-KILO	1	3182	3182	9/11/22	12:58 PM	FUSE_OH:D4304D-272 / A / 6 A	0.003436	1.08E-06	3,182
1310545	9/9/22	12:24 PM	MOLALLA-MARQUAM	121	3177	384419	9/11/22	5:22 PM	FUSE_OH:D5222D-362 / BC / 100 A	0.415139	1.31E-04	3,177
1309271	9/9/22	7:56 AM	MOBILE 2-KILO	11	3177	34947	9/11/22	12:53 PM	FUSE_OH:D4304D-602 / AB / 40 A	0.03774	1.19E-05	3,177
1309024	9/9/22	5:02 AM	ORIENT-OXBOW	4	3176	12705.93	9/11/22	9:58 AM	FUSE_OH:D1411B-1145 / C / 25 A	0.013721	4.32E-06	3,176
1311199	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	3174	3173.75	9/11/22	6:16 PM	FUSE_OH:B1434D-199 / ABC / 65 A	0.003427	1.08E-06	3,174
1309269	9/9/22	7:56 AM	MOBILE 2-KILO	3	3172	9516	9/11/22	12:48 PM	FUSE_OH:D4304C-1510 / A / 6 A	0.010276	3.24E-06	3,172
1310951	9/9/22	1:00 PM	BANKS-CEDAR CANYON	2	3165	6330	9/11/22	5:45 PM	FUSE_OH:B2423A-732 / A / 6 A	0.006836	2.16E-06	3,165
1308914	9/9/22	2:42 AM	SANDY-WILDCAT	28	3163	88555.13	9/11/22	7:24 AM	FUSE_OH:D3504D-132 / C / 65 A	0.095632	3.02E-05	3,163
1309359	9/9/22	8:09 AM	ESTACADA-NORTH FORK	2	3162	6324	9/11/22	12:51 PM	FUSE_OH:D4403C-1177 / AB / 6 A	0.006829	2.16E-06	3,162
1309358	9/9/22	8:09 AM	ESTACADA-NORTH FORK	3	3156	9467.95	9/11/22	12:44 PM	FUSE_OH:D4403C-417 / A / 6 A	0.010225	3.24E-06	3,156
1310950	9/9/22	1:00 PM	BANKS-CEDAR CANYON	2	3154	6308	9/11/22	5:34 PM	FUSE_OH:B2423A-727 / C / 65 A	0.006812	2.16E-06	3,154
1310550	9/9/22	11:54 AM	SILVERTON-SOUTH	27	3153	85135.5	9/11/22	4:27 PM	FUSE_OH:D7109D-260 / AB / 40 A	0.091939	2.92E-05	3,153
1316617	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	1	3148	3148.067	9/11/22	5:06 PM	FUSE_OH:B2325A-928 / B / 6 A	0.0034	1.08E-06	3,148
1309265	9/9/22	7:56 AM	MOBILE 2-KILO	2	3137	6274	9/11/22	12:13 PM	FUSE_OH:D4304C-905 / B / 25 A	0.006775	2.16E-06	3,137
1309266	9/9/22	7:56 AM	MOBILE 2-KILO	31	3137	97247	9/11/22	12:13 PM	FUSE_OH:D4304C-905 / B / 65 A	0.105018	3.35E-05	3,137
1309264	9/9/22	7:56 AM	MOBILE 2-KILO	1	3130	3130	9/11/22	12:06 PM	FUSE_OH:D4304C-907 / A / 25 A	0.00338	1.08E-06	3,130
1310247	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	3	3130	9390	9/11/22	2:52 PM	FUSE_OH:D6134B-527 / A / 25 A	0.01014	3.24E-06	3,130
1309357	9/9/22	8:09 AM	ESTACADA-NORTH FORK	13	3109	40417	9/11/22	11:58 AM	FUSE_OH:D4404D-97 / A / 40 A	0.043647	1.40E-05	3,109
1309458	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	3103	3103	9/11/22	11:53 AM	FUSE_OH:D3532A-583 / A / 6 A	0.003351	1.08E-06	3,103
1309457	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	3102	3102	9/11/22	11:52 AM	FUSE_OH:D3532A-583 / C / 6 A	0.00335	1.08E-06	3,102
1309013	9/9/22	4:52 AM	ORIENT-OXBOW	183	3099	567034.7	9/11/22	8:31 AM	RECL:9897	0.612348	1.98E-04	3,099
1309354	9/9/22	8:09 AM	ESTACADA-NORTH FORK	2	3098	6196	9/11/22	11:47 AM	FUSE_OH:D4404C-26 / A / 6 A	0.006691	2.16E-06	3,098
1309453	9/9/22	8:10 AM	ESTACADA-NORTH FORK	6	3096	18575.8	9/11/22	11:45 AM	FUSE_OH:D3531A-520 / B / 40 A	0.02006	6.48E-06	3,096
1311278	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	3095	3094.983	9/11/22	4:59 PM	FUSE_OH:B2536D-10 / BC / 6 A	0.003342	1.08E-06	3,095
1309454	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	3094	6188	9/11/22	11:44 AM	FUSE_OH:D3532B-1055 / A / 25 A	0.006682	2.16E-06	3,094
1309015	9/9/22	5:02 AM	ORIENT-OXBOW	29	3088	89556.35	9/11/22	8:30 AM	RECL:6466	0.096713	3.13E-05	3,088
1309449	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	3085	3085	9/11/22	11:35 AM	FUSE_OH:D3531A-536 / B / 15 A	0.003332	1.08E-06	3,085
1309260	9/9/22	7:56 AM	MOBILE 2-KILO	4	3084	12336	9/11/22	11:20 AM	FUSE_OH:D4305C-1179 / A / 10 A	0.013322	4.32E-06	3,084
1309258	9/9/22	7:56 AM	MOBILE 2-KILO	1	3081	3081	9/11/22	11:17 AM	FUSE_OH:D4305C-1604 / A / 6 A	0.003327	1.08E-06	3,081
1309445	9/9/22	8:10 AM	ESTACADA-NORTH FORK	3	3079	9237	9/11/22	11:29 AM	FUSE_OH:D3531A-543 / B / 15 A	0.009975	3.24E-06	3,079
1309366	9/9/22	8:09 AM	ESTACADA-NORTH FORK	9	3078	27700.05	9/11/22	11:26 AM	FUSE_OH:D4409B-607 / C / 15 A	0.029914	9.72E-06	3,078
1309444	9/9/22	8:10 AM	ESTACADA-NORTH FORK	5	3074	15370	9/11/22	11:24 AM	FUSE_OH:D3531A-547 / A / 15 A	0.016598	5.40E-06	3,074
1318177	9/9/22	1:20 PM	GALES CREEK-GALES CREEK 13	2	3070	6140.333	9/11/22	4:30 PM	FUSE_OH:B1428A-609 / BC / 10 A	0.006631	2.16E-06	3,070
1309314	9/9/22	7:56 AM	MOBILE 2-KILO	4	3070	12280	9/11/22	11:06 AM	FUSE_OH:D4302C-824 / B / 40 A	0.013261	4.32E-06	3,070
1309313	9/9/22	7:56 AM	MOBILE 2-KILO	169	3069	518661	9/11/22	11:05 AM	FUSE_OH:D4302C-824 / ABC / 65 A	0.560108	1.83E-04	3,069
1309435	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	3069	3069	9/11/22	11:19 AM	FUSE_OH:D3436A-792 / A / 15 A	0.003314	1.08E-06	3,069
1309243	9/9/22	7:56 AM	MOBILE 2-KILO	1	3069	3069	9/11/22	11:05 AM	SP:25675 S BEAVERCREEK RD	0.003314	1.08E-06	3,069
1309374	9/9/22	8:09 AM	ESTACADA-NORTH FORK	4	3069	12275.33	9/11/22	11:17 AM	FUSE_OH:D4409C-670 / B / 10 A	0.013256	4.32E-06	3,069
1309373	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	3064	3064	9/11/22	11:13 AM	FUSE_OH:D4409C-152 / B / 6 A	0.003309	1.08E-06	3,064

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1309434	9/9/22	8:10 AM	ESTACADA-NORTH FORK	3	3061	9183	9/11/22	11:11 AM	FUSE_OH:D3436A-1688 / B / 15 A	0.009917	3.24E-06	3,061
1308915	9/9/22	2:42 AM	SANDY-WILDCAT	34	3055	103880.2	9/11/22	5:37 AM	FUSE_OH:D3503C-726 / C / 40 A	0.112182	3.67E-05	3,055
1309370	9/9/22	8:09 AM	ESTACADA-NORTH FORK	3	3055	9165	9/11/22	11:04 AM	FUSE_OH:D4409B-149 / B / 6 A	0.009897	3.24E-06	3,055
1308916	9/9/22	2:42 AM	SANDY-WILDCAT	1	3054	3054	9/11/22	5:36 AM	FUSE_OH:D3503C-726 / A / 6 A	0.003298	1.08E-06	3,054
1309255	9/9/22	7:56 AM	MOBILE 2-KILO	4	3050	12200	9/11/22	10:46 AM	FUSE_OH:D4305C-1407 / C / 6 A	0.013175	4.32E-06	3,050
1309364	9/9/22	8:09 AM	ESTACADA-NORTH FORK	2	3048	6096	9/11/22	10:57 AM	FUSE_OH:D4408A-1239 / B / 6 A	0.006583	2.16E-06	3,048
1308919	9/9/22	2:42 AM	SANDY-WILDCAT	2	3047	6094	9/11/22	5:29 AM	FUSE_OH:D3507B-196 / C / 25 A	0.006581	2.16E-06	3,047
1308920	9/9/22	2:42 AM	SANDY-WILDCAT	1	3047	3047	9/11/22	5:29 AM	FUSE_OH:D3507B-201 / C / 6 A	0.00329	1.08E-06	3,047
1308921	9/9/22	2:42 AM	SANDY-WILDCAT	3	3047	9141	9/11/22	5:29 AM	FUSE_OH:D3412A-1717 / C / 25 A_1	0.009871	3.24E-06	3,047
1309253	9/9/22	7:56 AM	MOBILE 2-KILO	3	3045	9135	9/11/22	10:41 AM	FUSE_OH:D4306A-231 / A / 6 A	0.009865	3.24E-06	3,045
1309426	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	3044	3044	9/11/22	10:54 AM	FUSE_OH:D3425C-778 / A / 15 A	0.003287	1.08E-06	3,044
1309381	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	3032	3032	9/11/22	10:41 AM	FUSE_OH:D4417B-721 / C / 65 A	0.003274	1.08E-06	3,032
1310245	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	3028	6056.367	9/11/22	1:10 PM	FUSE_OH:D6134B-525 / AC / 10 A	0.00654	2.16E-06	3,028
1309380	9/9/22	8:09 AM	ESTACADA-NORTH FORK	5	3025	15125	9/11/22	10:34 AM	FUSE_OH:D4408C-56 / A / 25 A	0.016334	5.40E-06	3,025
1309420	9/9/22	8:10 AM	ESTACADA-NORTH FORK	50	3023	151150	9/11/22	10:33 AM	FUSE_OH:D3426D-1877 / AC / 40 A	0.163229	5.40E-05	3,023
1312644	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	3017	6034	9/11/22	4:47 PM	FUSE_OH:C1426B-2619 / BC / 40 A	0.006516	2.16E-06	3,017
1308912	9/9/22	2:42 AM	SANDY-WILDCAT	5	3011	15055	9/11/22	4:53 AM	FUSE_OH:D3504C-817 / B / 25 A	0.016258	5.40E-06	3,011
1311281	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	152	3010	457530.1	9/11/22	3:35 PM	FUSE_OH:B2536B-16 / ABC / 65 A	0.494092	1.64E-04	3,010
1308911	9/9/22	2:42 AM	SANDY-WILDCAT	11	3010	33110	9/11/22	4:52 AM	FUSE_OH:D3504C-817 / B / 25 A_1	0.035756	1.19E-05	3,010
1308933	9/9/22	2:42 AM	SANDY-WILDCAT	7	3009	21063	9/11/22	4:51 AM	FUSE_OH:D3508B-161 / ABC / 100 A	0.022746	7.56E-06	3,009
1309254	9/9/22	7:56 AM	MOBILE 2-KILO	3	3008	9024	9/11/22	10:04 AM	FUSE_OH:D4306A-230 / AB / 6 A	0.009745	3.24E-06	3,008
1309383	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	3008	3008	9/11/22	10:17 AM	FUSE_OH:D4407D-663 / AC / 10 A	0.003248	1.08E-06	3,008
1309388	9/9/22	8:09 AM	ESTACADA-NORTH FORK	15	3008	45116.5	9/11/22	10:16 AM	FUSE_OH:D4407D-663 / A / 15 A	0.048722	1.62E-05	3,008
1309252	9/9/22	7:56 AM	MOBILE 2-KILO	3	3004	9012	9/11/22	10:00 AM	FUSE_OH:D4306A-2338 / C / 10 A	0.009732	3.24E-06	3,004
1309384	9/9/22	8:09 AM	ESTACADA-NORTH FORK	3	3000	9000	9/11/22	10:09 AM	FUSE_OH:D4407D-661 / A / 25 A	0.009719	3.24E-06	3,000
1308910	9/9/22	2:42 AM	SANDY-WILDCAT	2	2997	5994	9/11/22	4:39 AM	FUSE_OH:D3504C-617 / AC / 6 A	0.006473	2.16E-06	2,997
1309249	9/9/22	7:56 AM	MOBILE 2-KILO	4	2995	11980	9/11/22	9:51 AM	FUSE_OH:D4306A-1120 / ABC / 15 A	0.012937	4.32E-06	2,995
1309382	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2995	2995	9/11/22	10:04 AM	FUSE_OH:D4407D-659 / C / 10 A	0.003234	1.08E-06	2,995
1309412	9/9/22	8:10 AM	ESTACADA-NORTH FORK	26	2993	77818	9/11/22	10:03 AM	TRIP_SAVER:D3427D-2507 / B / 40 A	0.084037	2.81E-05	2,993
1309379	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2990	2990	9/11/22	9:59 AM	FUSE_OH:D4408A-42 / C / 65 A	0.003229	1.08E-06	2,990
1308908	9/9/22	2:42 AM	SANDY-WILDCAT	9	2989	26901	9/11/22	4:31 AM	FUSE_OH:D3504C-116 / B / 25 A	0.029051	9.72E-06	2,989
1309419	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2988	2988	9/11/22	9:58 AM	FUSE_OH:D3426C-618 / A / 15 A	0.003227	1.08E-06	2,988
1309362	9/9/22	8:09 AM	ESTACADA-NORTH FORK	20	2986	59719	9/11/22	9:54 AM	TRIP_SAVER:D4408A-36 / C / 65 A	0.064491	2.16E-05	2,986
1309248	9/9/22	7:56 AM	MOBILE 2-KILO	1	2983	2983	9/11/22	9:39 AM	FUSE_OH:D4306D-226 / C / 6 A	0.003221	1.08E-06	2,983
1309247	9/9/22	7:56 AM	MOBILE 2-KILO	2	2982	5964	9/11/22	9:38 AM	FUSE_OH:D4306D-226 / A / 65 A	0.006441	2.16E-06	2,982
1309246	9/9/22	7:56 AM	MOBILE 2-KILO	2	2978	5955.9	9/11/22	9:33 AM	FUSE_OH:D4306C-224 / A / 6 A	0.006432	2.16E-06	2,978
1309416	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2977	2977	9/11/22	9:47 AM	FUSE_OH:D3426C-2767 / A / 15 A	0.003215	1.08E-06	2,977
1309417	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2977	2977	9/11/22	9:47 AM	FUSE_OH:D3426C-2767 / C / 15 A	0.003215	1.08E-06	2,977
1308907	9/9/22	2:42 AM	SANDY-WILDCAT	4	2973	11892	9/11/22	4:15 AM	FUSE_OH:D3504C-712 / B / 25 A	0.012842	4.32E-06	2,973
1309409	9/9/22	8:10 AM	ESTACADA-NORTH FORK	7	2971	20797	9/11/22	9:41 AM	FUSE_OH:D3427D-2997 / C / 10 A	0.022459	7.56E-06	2,971
1309410	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2971	2971	9/11/22	9:41 AM	FUSE_OH:D3427D-2997 / A / 6 A	0.003208	1.08E-06	2,971
1308905	9/9/22	2:42 AM	SANDY-WILDCAT	2	2970	5940	9/11/22	4:12 AM	FUSE_OH:D3504C-109 / C / 6 A	0.006415	2.16E-06	2,970
1308904	9/9/22	2:42 AM	SANDY-WILDCAT	1	2967	2967	9/11/22	4:09 AM	FUSE_OH:D3505D-108 / A / 6 A	0.003204	1.08E-06	2,967
1309296	9/9/22	7:56 AM	MOBILE 2-KILO	2	2966	5932	9/11/22	9:22 AM	FUSE_OH:D4303D-1397 / A / 40 A	0.006406	2.16E-06	2,966
1309239	9/9/22	7:56 AM	MOBILE 2-KILO	103	2966	305482.6	9/11/22	9:21 AM	RECL:2576	0.329894	1.11E-04	2,966
1309408	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	2965	5930	9/11/22	9:35 AM	FUSE_OH:D3427D-1842 / C / 10 A	0.006404	2.16E-06	2,965
1309404	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2960	2960	9/11/22	9:30 AM	FUSE_OH:D3427D-1861 / B / 15 A	0.003197	1.08E-06	2,960
1309351	9/9/22	8:09 AM	ESTACADA-NORTH FORK	2	2956	5912	9/11/22	9:25 AM	FUSE_OH:D4404C-796 / B / 6 A	0.006384	2.16E-06	2,956
1309350	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2952	2952	9/11/22	9:21 AM	FUSE_OH:D4404C-468 / B / 6 A	0.003188	1.08E-06	2,952
1309401	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	2949	5898	9/11/22	9:19 AM	FUSE_OH:D3427D-2498 / C / 15 A	0.006369	2.16E-06	2,949

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1308903	9/9/22	2:42 AM	SANDY-WILDCAT	17	2948	50116	9/11/22	3:50 AM	FUSE_OH:D3505D-95 / C / 25 A	0.054121	1.84E-05	2,948
1309402	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2947	2947	9/11/22	9:17 AM	FUSE_OH:D3427D-1864 / C / 10 A	0.003183	1.08E-06	2,947
1309397	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	2944	5888	9/11/22	9:14 AM	FUSE_OH:D3427C-2497 / C / 15 A	0.006359	2.16E-06	2,944
1309398	9/9/22	8:10 AM	ESTACADA-NORTH FORK	5	2943	14716.58	9/11/22	9:13 AM	FUSE_OH:D3427C-1865 / A / 15 A	0.015893	5.4E-06	2,943
1308902	9/9/22	2:42 AM	SANDY-WILDCAT	3	2942	8826	9/11/22	3:44 AM	FUSE_OH:D3505C-92 / C / 6 A	0.009531	3.24E-06	2,942
1311280	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	12	2942	35304	9/11/22	2:27 PM	TRIP_SAVER:B2536A-237 / B / 40 A	0.038125	1.30E-05	2,942
1309394	9/9/22	8:10 AM	ESTACADA-NORTH FORK	5	2940	14701.67	9/11/22	9:10 AM	FUSE_OH:D3427C-1866 / B / 15 A	0.015877	5.40E-06	2,940
1308932	9/9/22	2:42 AM	SANDY-WILDCAT	4	2939	11756	9/11/22	3:41 AM	FUSE_OH:D3508B-160 / C / 25 A	0.012695	4.32E-06	2,939
1309395	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	2938	5876	9/11/22	9:08 AM	FUSE_OH:D3427C-2496 / A / 15 A	0.006346	2.16E-06	2,938
1310321	9/9/22	10:37 AM	MOLALLA-MARQUAM	181	2933	530854.9	9/11/22	11:29 AM	FUSE_OH:D6203C-12 / ABC / 65 A	0.573277	1.95E-04	2,933
1308930	9/9/22	2:42 AM	SANDY-WILDCAT	6	2932	17592	9/11/22	3:34 AM	FUSE_OH:D3508B-772 / C / 25 A	0.018998	6.48E-06	2,932
1308931	9/9/22	2:42 AM	SANDY-WILDCAT	2	2932	5864	9/11/22	3:34 AM	FUSE_OH:D3508B-772 / C / 25 A_1	0.006333	2.16E-06	2,932
1309393	9/9/22	8:10 AM	ESTACADA-NORTH FORK	17	2932	49842.87	9/11/22	9:01 AM	FUSE_OH:D3434B-1528 / AB / 25 A	0.053826	1.84E-05	2,932
1308901	9/9/22	2:42 AM	SANDY-WILDCAT	2	2931	5862	9/11/22	3:33 AM	FUSE_OH:D3505C-814 / B / 25 A	0.00633	2.16E-06	2,931
1309392	9/9/22	8:10 AM	ESTACADA-NORTH FORK	7	2921	20448.87	9/11/22	8:51 AM	FUSE_OH:D3434B-1162 / A / 25 A	0.022083	7.56E-06	2,921
1311274	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	56	2919	163464	9/11/22	2:04 PM	FUSE_OH:B2536D-88 / BC / 65 A	0.176527	6.05E-05	2,919
1312650	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2918	5835.667	9/11/22	3:07 PM	FUSE_OH:C1435D-487 / AB / 65 A	0.006302	2.16E-06	2,918
1312678	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2916	2916.217	9/11/22	3:06 PM	FUSE_OH:C1436C-105 / ABC / 15 A	0.003149	1.08E-06	2,916
1308899	9/9/22	2:42 AM	SANDY-WILDCAT	3	2912	8736	9/11/22	3:14 AM	FUSE_OH:D3505C-811 / A / 40 A	0.009434	3.24E-06	2,912
1311277	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	9	2910	26193.3	9/11/22	1:55 PM	FUSE_OH:B2536D-6 / B / 40 A	0.028286	9.72E-06	2,910
1308898	9/9/22	2:42 AM	SANDY-WILDCAT	2	2904	5808	9/11/22	3:06 AM	FUSE_OH:D3506D-79 / C / 40 A	0.006272	2.16E-06	2,904
1309391	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	2903	5806.267	9/11/22	8:33 AM	FUSE_OH:D3434B-1159 / C / 6 A	0.00627	2.16E-06	2,903
1311255	9/9/22	1:23 PM	DILLEY-DILLEY 13	5	2899	14493	9/11/22	1:41 PM	FUSE_OH:B1427C-671 / AB / 65 A	0.015651	5.40E-06	2,899
1308918	9/9/22	2:42 AM	SANDY-WILDCAT	2	2898	5796	9/11/22	3:00 AM	FUSE_OH:D3505C-139 / C / 15 A	0.006259	2.16E-06	2,898
1310925	9/9/22	1:00 PM	BANKS-CEDAR CANYON	11	2893	31819.15	9/11/22	1:12 PM	FUSE_OH:B2319C-41 / A / 65 A	0.034362	1.19E-05	2,893
1308917	9/9/22	2:42 AM	SANDY-WILDCAT	6	2891	17346	9/11/22	2:53 AM	FUSE_OH:D3505C-972 / C / 25 A	0.018732	6.48E-06	2,891
1308897	9/9/22	2:42 AM	SANDY-WILDCAT	5	2891	14455	9/11/22	2:53 AM	FUSE_OH:D3506D-783 / AB / 6 A	0.01561	5.40E-06	2,891
1308895	9/9/22	2:42 AM	SANDY-WILDCAT	74	2884	213416	9/11/22	2:46 AM	FUSE_OH:D3506D-52 / BC / 40 A	0.230471	7.99E-05	2,884
1308894	9/9/22	2:42 AM	SANDY-WILDCAT	2	2866	5731.133	9/11/22	2:27 AM	FUSE_OH:D3506A-50 / C / 6 A	0.006189	2.16E-06	2,866
1308893	9/9/22	2:42 AM	SANDY-WILDCAT	8	2865	22921.33	9/11/22	2:27 AM	FUSE_OH:D3506A-869 / A / 25 A	0.024753	8.64E-06	2,865
1308892	9/9/22	2:42 AM	SANDY-WILDCAT	4	2849	11396.33	9/11/22	2:11 AM	FUSE_OH:D3506A-45 / AB / 65 A	0.012307	4.32E-06	2,849
1311018	9/9/22	1:00 PM	BANKS-CEDAR CANYON	198	2831	560538	9/11/22	12:11 PM	FUSE_OH:B2410C-454 / ABC / 100 A	0.605332	2.14E-04	2,831
1312869	9/9/22	1:09 PM	SHERIDAN-EAST	135	2827	381645	9/11/22	12:16 PM	FUSE_OH:C5529C-354 / ABC / 100 A	0.412143	1.46E-04	2,827
1309507	9/9/22	9:18 AM	SANDY-WILDCAT	1	2824	2824.217	9/11/22	8:23 AM	XFM_UG:ABC 300 1312	0.00305	1.08E-06	2,824
1311264	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	2822	2821.5	9/11/22	12:26 PM	FUSE_OH:B1406B-279 / A / 6 A	0.003047	1.08E-06	2,822
1311261	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	13	2818	36634	9/11/22	12:23 PM	FUSE_OH:B1406B-277 / C / 40 A	0.039562	1.40E-05	2,818
1312685	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	311	2793	868602.3	9/11/22	12:55 PM	FUSE_OH:C2306C-321 / ABC / 65 A	0.938014	3.36E-04	2,793
1310100	9/9/22	10:18 AM	SCOTTS MILLS-SCOTTS MILLS 13	22	2785	61261.2	9/11/22	8:42 AM	FUSE_OH:D6115D-493 / AC / 40 A	0.066157	2.38E-05	2,785
1310971	9/9/22	1:00 PM	BANKS-CEDAR CANYON	6	2765	16590	9/11/22	11:05 AM	FUSE_OH:B2410D-305 / A / 40 A	0.017916	6.48E-06	2,765
1310970	9/9/22	1:00 PM	BANKS-CEDAR CANYON	47	2765	129943.3	9/11/22	11:04 AM	FUSE_OH:B2410D-447 / ABC / 65 A	0.140327	5.08E-05	2,765
1310914	9/9/22	1:03 PM	BANKS-BANKS 13	1	2764	2764.2	9/11/22	11:07 AM	FUSE_OH:B2332A-85 / ABC / 15 A	0.002985	1.08E-06	2,764
1308876	9/9/22	2:42 AM	SANDY-WILDCAT	9	2746	24712.35	9/11/22	12:27 AM	FUSE_OH:D2531B-1737 / A / 40 A	0.026687	9.72E-06	2,746
1308875	9/9/22	2:42 AM	SANDY-WILDCAT	2	2740	5480	9/11/22	12:22 AM	FUSE_OH:D2531B-1737 / C / 6 A	0.005918	2.16E-06	2,740
1310919	9/9/22	1:00 PM	BANKS-CEDAR CANYON	68	2740	186308.7	9/11/22	10:39 AM	FUSE_OH:B2319C-759 / BC / 65 A	0.201197	7.34E-05	2,740
1310956	9/9/22	1:00 PM	BANKS-CEDAR CANYON	5	2739	13695	9/11/22	10:39 AM	TRIP_SAVER:B2414C-867 / C / 25 A	0.014789	5.40E-06	2,739
1311188	9/9/22	1:23 PM	DILLEY-DILLEY 13	64	2738	175230.9	9/11/22	11:00 AM	FUSE_OH:C1402C-590 / ABC / 65 A	0.189234	6.91E-05	2,738
1310967	9/9/22	1:00 PM	BANKS-CEDAR CANYON	4	2736	10944	9/11/22	10:36 AM	FUSE_OH:B2415A-435 / C / 40 A	0.011819	4.32E-06	2,736
1310569	9/9/22	12:09 PM	REDLAND-REDLAND 13	101	2734	276134	9/11/22	9:43 AM	FUSE_OH:D3303B-117 / C / 65 A	0.298201	1.09E-04	2,734
1312866	9/9/22	2:22 PM	SHERIDAN-EAST	3	2731	8193.9	9/11/22	11:53 AM	FUSE_OH:C5529C-343 / B / 10 A	0.008849	3.24E-06	2,731
1312680	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2724	2724.2	9/11/22	11:54 AM	FUSE_OH:C2401A-4443 / AC / 65 A	0.002942	1.08E-06	2,724

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310953	9/9/22	1:00 PM	BANKS-CEDAR CANYON	4	2724	10896	9/11/22	10:24 AM	FUSE_OH:B2414C-862 / BC / 65 A	0.011767	4.32E-06	2,724
1312691	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	12	2721	32651.6	9/11/22	11:44 AM	FUSE_OH:C2401A-95 / AC / 65 A	0.035261	1.3E-05	2,721
1312865	9/9/22	2:22 PM	SHERIDAN-EAST	16	2720	43525.6	9/11/22	11:42 AM	FUSE_OH:C5531A-119 / ABC / 65 A	0.047004	1.73E-05	2,720
1310313	9/9/22	10:37 AM	MOLALLA-MARQUAM	2	2720	5440	9/11/22	7:57 AM	FUSE_OH:D6203B-5 / C / 6 A	0.005875	2.16E-06	2,720
1310921	9/9/22	1:03 PM	BANKS-BANKS 13	1	2718	2718.4	9/11/22	10:21 AM	FUSE_OH:B2333B-1077 / A / 100 A	0.002936	1.08E-06	2,718
1312660	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	10	2718	27180	9/11/22	11:48 AM	FUSE_OH:C1435D-807 / C / 15 A	0.029352	1.08E-05	2,718
1312666	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	17	2718	46206	9/11/22	11:48 AM	FUSE_OH:C2402D-574 / ABC / 65 A	0.049898	1.84E-05	2,718
1316995	9/9/22	2:32 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	2718	10871.07	9/10/22	11:50 PM	XFM_OH:C 15 21002	0.01174	4.32E-06	2,718
1310942	9/9/22	1:00 PM	BANKS-CEDAR CANYON	109	2717	296165.7	9/11/22	10:17 AM	FUSE_OH:B2424C-219 / BC / 65 A	0.319833	1.18E-04	2,717
1312661	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	4	2714	10856	9/11/22	11:44 AM	FUSE_OH:C2402A-581 / AC / 65 A	0.011724	4.32E-06	2,714
1309046	9/9/22	3:15 AM	SILVERTON-SOUTH	11	2712	29831.63	9/11/22	12:26 AM	TRIP_SAVER:D8207C-15 / C / 25 A	0.032216	1.19E-05	2,712
1312684	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	2	2711	5422.867	9/11/22	11:34 AM	FUSE_OH:C2401A-4456 / C / 65 A	0.005856	2.16E-06	2,711
1308874	9/9/22	2:42 AM	SANDY-WILDCAT	5	2711	13552.83	9/10/22	11:52 PM	FUSE_OH:D2436A-2122 / A / 6 A	0.014636	5.40E-06	2,711
1308873	9/9/22	2:42 AM	SANDY-WILDCAT	1	2704	2703.767	9/10/22	11:45 PM	FUSE_OH:D2436A-1778 / C / 6 A	0.00292	1.08E-06	2,704
1308878	9/9/22	2:42 AM	SANDY-WILDCAT	4	2703	10813.67	9/10/22	11:45 PM	FUSE_OH:D2531B-1667 / B / 10 A	0.011678	4.32E-06	2,703
1310920	9/9/22	1:00 PM	BANKS-CEDAR CANYON	3	2702	8106	9/11/22	10:02 AM	FUSE_OH:B2319C-759 / BC / 15 A	0.008754	3.24E-06	2,702
1308877	9/9/22	2:42 AM	SANDY-WILDCAT	4	2701	10804	9/10/22	11:43 PM	FUSE_OH:D2531B-1667 / AC / 6 A	0.011667	4.32E-06	2,701
1308872	9/9/22	2:42 AM	SANDY-WILDCAT	2	2700	5400	9/10/22	11:42 PM	FUSE_OH:D2436A-1780 / C / 6 A	0.005832	2.16E-06	2,700
1308871	9/9/22	2:42 AM	SANDY-WILDCAT	7	2698	18883.08	9/10/22	11:39 PM	FUSE_OH:D2436A-1 / BC / 40 A	0.020392	7.56E-06	2,698
1310804	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	70	2693	188542.7	9/11/22	9:39 AM	FUSE_OH:B2131C-118 / ABC / 65 A	0.20361	7.56E-05	2,693
1308868	9/9/22	2:42 AM	SANDY-WILDCAT	3	2692	8074.55	9/10/22	11:33 PM	FUSE_OH:D2436B-1783 / AB / 40 A	0.00872	3.24E-06	2,692
1308869	9/9/22	2:42 AM	SANDY-WILDCAT	4	2691	10764	9/10/22	11:33 PM	FUSE_OH:D2436B-1783 / C / 40 A	0.011624	4.32E-06	2,691
1308870	9/9/22	2:42 AM	SANDY-WILDCAT	6	2690	16140	9/10/22	11:32 PM	FUSE_OH:D2436B-1783 / AC / 40 A	0.01743	6.48E-06	2,690
1312687	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2688	2687.967	9/11/22	11:17 AM	FUSE_OH:C2306C-321 / C / 6 A	0.002903	1.08E-06	2,688
1308255	9/9/22	2:27 AM	DUNNS CORNER-DUNNS CORNER 13	258	2685	692669.8	9/10/22	11:12 PM	RECL:1696	0.748023	2.79E-04	2,685
1313748	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	1	2682	2681.633	9/11/22	8:15 AM	FUSE_OH:B2231C-32 / AB / 65 A	0.002896	1.08E-06	2,682
1308879	9/9/22	2:42 AM	SANDY-WILDCAT	1	2681	2680.517	9/10/22	11:22 PM	FUSE_OH:D2531B-1665 / A / 6 A	0.002895	1.08E-06	2,681
1312679	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2677	5354	9/11/22	11:07 AM	FUSE_OH:C1436D-4439 / AB / 6 A	0.005782	2.16E-06	2,677
1312689	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	54	2677	144556.2	9/11/22	11:00 AM	FUSE_OH:C2306C-4476 / ABC / 65 A	0.156108	5.83E-05	2,677
1312668	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2676	2676.35	9/11/22	11:06 AM	FUSE_OH:C2412B-558 / AB / 65 A	0.00289	1.08E-06	2,676
1308880	9/9/22	2:42 AM	SANDY-WILDCAT	6	2676	16056	9/10/22	11:18 PM	FUSE_OH:D2531B-1662 / A / 40 A	0.017339	6.48E-06	2,676
1308881	9/9/22	2:42 AM	SANDY-WILDCAT	4	2676	10703.4	9/10/22	11:17 PM	FUSE_OH:D2531B-1662 / B / 6 A	0.011559	4.32E-06	2,676
1308882	9/9/22	2:42 AM	SANDY-WILDCAT	3	2669	8007.4	9/10/22	11:11 PM	FUSE_OH:D2531A-2510 / A / 40 A	0.008647	3.24E-06	2,669
1312648	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2665	2665.05	9/11/22	10:55 AM	FUSE_OH:C1435A-337 / C / 100 A	0.002878	1.08E-06	2,665
1312647	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2659	5318.967	9/11/22	10:49 AM	FUSE_OH:C1435A-331 / A / 100 A	0.005744	2.16E-06	2,659
1311192	9/9/22	1:23 PM	DILLEY-DILLEY 13	24	2659	63815.2	9/11/22	9:41 AM	FUSE_OH:C1402B-629 / AC / 65 A	0.068915	2.59E-05	2,659
1311254	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	18	2658	47844	9/11/22	9:43 AM	FUSE_OH:B1421D-403 / A / 40 A	0.051667	1.94E-05	2,658
1312358	9/9/22	1:49 PM	WILLAMINA-BRIDGE	134	2652	355397	9/11/22	10:01 AM	FUSE_OH:C5725A-454 / ABC / 40 A	0.383798	1.45E-04	2,652
1312672	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	3	2650	7950	9/11/22	10:40 AM	FUSE_OH:C2412B-545 / BC / 65 A	0.008585	3.24E-06	2,650
1312645	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	7	2650	18549.42	9/11/22	10:39 AM	FUSE_OH:C1426C-2625 / C / 100 A	0.020032	7.56E-06	2,650
1312677	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2649	2649.033	9/11/22	10:39 AM	FUSE_OH:C1436C-1925 / AC / 6 A	0.002861	1.08E-06	2,649
1312676	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	3	2649	7947	9/11/22	10:39 AM	FUSE_OH:C1436C-1925 / BC / 40 A	0.008582	3.24E-06	2,649
1308867	9/9/22	2:42 AM	SANDY-WILDCAT	8	2641	21126.4	9/10/22	10:42 PM	FUSE_OH:D2436A-2630 / A / 40 A	0.022815	8.64E-06	2,641
1312643	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2641	2640.733	9/11/22	10:30 AM	FUSE_OH:C1426B-2619 / B / 6 A	0.002852	1.08E-06	2,641
1308525	9/9/22	2:41 AM	EAGLE CREEK-BARTON	828	2638	2184250	9/10/22	10:38 PM	RECL:9436	2.358799	8.94E-04	2,638
1308891	9/9/22	2:42 AM	SANDY-WILDCAT	85	2636	224021.8	9/10/22	10:37 PM	FUSE_OH:D2531D-1889 / ABC / 65 A	0.241924	9.18E-05	2,636
1312681	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	39	2633	102668.8	9/11/22	10:15 AM	FUSE_OH:C1436D-876 / ABC / 40 A	0.110873	4.21E-05	2,633
1308866	9/9/22	2:42 AM	SANDY-WILDCAT	4	2630	10518.13	9/10/22	10:31 PM	FUSE_OH:D2425D-1787 / B / 40 A	0.011359	4.32E-06	2,630
1310285	9/9/22	10:26 AM	MOLALLA-MARQUAM	25	2627	65685	9/11/22	6:14 AM	TRIP_SAVER:D5232C-796 / B / 25 A	0.070934	2.70E-05	2,627
1312654	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	18	2625	47250	9/11/22	10:15 AM	TRIP_SAVER:C1427A-917 / A / 65 A	0.051026	1.94E-05	2,625

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1308865	9/9/22	2:42 AM	SANDY-WILDCAT	2	2617	5234	9/10/22	10:19 PM	FUSE_OH:D2425D-1790 / C / 6 A	0.005652	2.16E-06	2,617
1309031	9/9/22	3:15 AM	SILVERTON-SOUTH	15	2614	39215	9/10/22	10:49 PM	FUSE_OH:D8102D-161 / BC / 15 A	0.042349	1.62E-05	2,614
1308864	9/9/22	2:42 AM	SANDY-WILDCAT	12	2610	31318.2	9/10/22	10:11 PM	FUSE_OH:D2425D-2297 / B / 40 A	0.033821	1.30E-05	2,610
1311169	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	52	2607	135563.1	9/11/22	8:51 AM	FUSE_OH:B1408C-142 / BC / 65 A	0.146396	5.62E-05	2,607
1308890	9/9/22	2:42 AM	SANDY-WILDCAT	1	2604	2604	9/10/22	10:06 PM	FUSE_OH:D2531D-1607 / A / 6 A	0.002812	1.08E-06	2,604
1308888	9/9/22	2:42 AM	SANDY-WILDCAT	2	2597	5194	9/10/22	9:59 PM	FUSE_OH:D2531D-1610 / C / 6 A	0.005609	2.16E-06	2,597
1308886	9/9/22	2:42 AM	SANDY-WILDCAT	1	2592	2592	9/10/22	9:54 PM	FUSE_OH:D2531D-2531 / A / 40 A	0.002799	1.08E-06	2,592
1312694	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	27	2590	69929.1	9/11/22	9:33 AM	FUSE_OH:C1423C-1032 / ABC / 65 A	0.075517	2.92E-05	2,590
1311197	9/9/22	1:23 PM	DILLEY-DILLEY 13	17	2590	44025.18	9/11/22	8:32 AM	FUSE_OH:C1403A-16 / AC / 65 A	0.047543	1.84E-05	2,590
1308887	9/9/22	2:42 AM	SANDY-WILDCAT	1	2587	2587	9/10/22	9:49 PM	FUSE_OH:D2531D-2059 / A / 65 A	0.002794	1.08E-06	2,587
1312697	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	20	2587	51739.33	9/11/22	9:30 AM	TRIP_SAVER:C1423D-1026 / A / 40 A	0.055874	2.16E-05	2,587
1312692	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	14	2584	36176	9/11/22	9:34 AM	FUSE_OH:C1426B-1042 / A / 25 A	0.039067	1.51E-05	2,584
1312700	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	29	2582	74877.03	9/11/22	9:25 AM	FUSE_OH:C1423A-1019 / ABC / 40 A	0.080861	3.13E-05	2,582
1312695	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2581	2581	9/11/22	9:31 AM	FUSE_OH:C1423C-1030 / C / 6 A	0.002787	1.08E-06	2,581
1312696	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2581	5162	9/11/22	9:31 AM	FUSE_OH:C1423D-1026 / C / 10 A	0.005575	2.16E-06	2,581
1312699	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2577	2577	9/11/22	9:27 AM	FUSE_OH:C1423A-1020 / C / 40 A	0.002783	1.08E-06	2,577
1308862	9/9/22	2:42 AM	SANDY-WILDCAT	92	2577	237038	9/10/22	9:38 PM	FUSE_OH:D2425B-1812 / AB / 100 A	0.25598	9.94E-05	2,577
1309030	9/9/22	3:15 AM	SILVERTON-SOUTH	2	2576	5152	9/10/22	10:11 PM	FUSE_OH:D8102B-159 / C / 10 A	0.005564	2.16E-06	2,576
1312703	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	6	2575	15450.3	9/11/22	9:18 AM	FUSE_OH:C1423A-1011 / A / 65 A	0.016685	6.48E-06	2,575
1312702	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	8	2573	20584	9/11/22	9:23 AM	TRIP_SAVER:C1423A-1015 / C / 65 A	0.022229	8.64E-06	2,573
1312701	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2570	5140.533	9/11/22	9:20 AM	FUSE_OH:C1423A-1014 / ABC / 40 A	0.005551	2.16E-06	2,570
1309440	9/9/22	8:10 AM	ESTACADA-NORTH FORK	49	2570	125929.2	9/11/22	2:59 AM	FUSE_OH:D3531B-633 / A / 15 A	0.135992	5.29E-05	2,570
1308885	9/9/22	2:42 AM	SANDY-WILDCAT	1	2568	2568.167	9/10/22	9:30 PM	FUSE_OH:D2531D-2189 / A / 6 A	0.002773	1.08E-06	2,568
1311202	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	2566	2566	9/11/22	8:09 AM	FUSE_OH:B1434C-348 / C / 65 A	0.002771	1.08E-06	2,566
1312704	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2566	5131.2	9/11/22	9:15 AM	FUSE_OH:C1423A-1011 / C / 40 A	0.005541	2.16E-06	2,566
1312705	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	22	2562	56364	9/11/22	9:12 AM	FUSE_OH:C1414D-1007 / C / 40 A	0.060868	2.38E-05	2,562
1309029	9/9/22	3:15 AM	SILVERTON-SOUTH	5	2560	12800	9/10/22	9:55 PM	FUSE_OH:D7135C-449 / ABC / 15 A	0.013823	5.40E-06	2,560
1308883	9/9/22	2:42 AM	SANDY-WILDCAT	4	2559	10236	9/10/22	9:21 PM	FUSE_OH:D2531D-1621 / BC / 40 A	0.011054	4.32E-06	2,559
1308737	9/9/22	2:47 AM	EAGLE CREEK-BARTON	313	2558	800763.6	9/10/22	9:25 PM	FUSE_OH:D2429D-3295 / ABC / 100 A	0.864755	3.38E-04	2,558
1308863	9/9/22	2:42 AM	SANDY-WILDCAT	2	2557	5113.6	9/10/22	9:18 PM	FUSE_OH:D2425B-1812 / A / 6 A	0.005522	2.16E-06	2,557
1310865	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	4	2547	10187	9/10/22	9:01 PM	FUSE_OH:D2525A-461 / A / 6 A	0.011001	4.32E-06	2,547
1312707	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2543	2543	9/11/22	8:53 AM	FUSE_OH:C1414D-1006 / BC / 40 A	0.002746	1.08E-06	2,543
1312708	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	6	2540	15240.5	9/11/22	8:50 AM	TRIP_SAVER:C1414D-1005 / A / 25 A	0.016458	6.48E-06	2,540
1308884	9/9/22	2:42 AM	SANDY-WILDCAT	2	2538	5076	9/10/22	9:00 PM	FUSE_OH:D2531A-1624 / A / 65 A	0.005482	2.16E-06	2,538
1309027	9/9/22	3:15 AM	SILVERTON-SOUTH	6	2537	15219.9	9/10/22	9:31 PM	TRIP_SAVER:D7135B-421 / A / 25 A	0.016436	6.48E-06	2,537
1312655	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	1	2530	2529.817	9/11/22	8:39 AM	FUSE_OH:C1426A-1719 / C / 100 A	0.002732	1.08E-06	2,530
1308767	9/9/22	3:08 AM	SILVERTON-SOUTH	79	2527	199619.8	9/10/22	9:15 PM	FUSE_OH:D7126C-386 / A / 40 A	0.215572	8.53E-05	2,527
1308811	9/9/22	3:09 AM	SILVERTON-SOUTH	68	2520	171361.1	9/10/22	9:09 PM	RECL:1000	0.185055	7.34E-05	2,520
1308745	9/9/22	2:47 AM	EAGLE CREEK-BARTON	2	2520	5039.833	9/10/22	8:47 PM	FUSE_OH:D2428B-3532 / C / 100 A	0.005443	2.16E-06	2,520
1312656	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	8	2520	20157.6	9/11/22	8:29 AM	FUSE_OH:C1435A-140 / ABC / 65 A	0.021768	8.64E-06	2,520
1310829	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	1	2518	2518.05	9/10/22	8:33 PM	FUSE_OH:D2622D-108 / C / 6 A	0.002719	1.08E-06	2,518
1312798	9/9/22	3:59 PM	YAMHILL-CARLTON	234	2517	588939	9/11/22	9:55 AM	FUSE_OH:C3419C-913 / ABC / 65 A	0.636003	2.53E-04	2,517
1308744	9/9/22	2:47 AM	EAGLE CREEK-BARTON	8	2514	20110.13	9/10/22	8:40 PM	FUSE_OH:D2428B-532 / C / 100 A	0.021717	8.64E-06	2,514
1308861	9/9/22	2:42 AM	SANDY-WILDCAT	3	2512	7536	9/10/22	8:34 PM	FUSE_OH:D2425B-1874 / C / 6 A	0.008138	3.24E-06	2,512
1309032	9/9/22	3:15 AM	SILVERTON-SOUTH	1	2512	2511.75	9/10/22	9:06 PM	FUSE_OH:D8102D-170 / ABC / 10 A	0.002712	1.08E-06	2,512
1308743	9/9/22	2:47 AM	EAGLE CREEK-BARTON	2	2500	5000.667	9/10/22	8:27 PM	FUSE_OH:D2428B-534 / C / 100 A	0.0054	2.16E-06	2,500
1308254	9/9/22	2:35 AM	BRIGHTWOOD-BRIGHTWOOD 13	197	2498	492014.1	9/10/22	8:12 PM	BKR:BRIGHTWOOD R106	0.531332	2.13E-04	2,498
1308265	9/9/22	2:30 AM	DUNNS CORNER-DUNNS CORNER 13	1	2497	2496.683	9/10/22	8:06 PM	FUSE_OH:D2505D-738 / C / 6 A	0.002696	1.08E-06	2,497
1308250	9/9/22	2:30 AM	DUNNS CORNER-DUNNS CORNER 13	17	2497	42440.78	9/10/22	8:06 PM	RECL:1681	0.045832	1.84E-05	2,497
1308266	9/9/22	2:30 AM	DUNNS CORNER-DUNNS CORNER 13	10	2496	24960	9/10/22	8:06 PM	FUSE_OH:D2504C-1112 / C / 40 A	0.026955	1.08E-05	2,496

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1312657	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	3	2493	7479	9/11/22	8:03 AM	FUSE_OH:C1435D-872 / A / 15 A	0.008077	3.24E-06	2,493
1313249	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	59	2475	146025	9/11/22	9:55 AM	FUSE_OH:C2426B-482 / BC / 6 A	0.157694	6.37E-05	2,475
1317233	9/9/22	2:42 PM	ESTACADA-FARADAY	28	2475	69287.87	9/11/22	7:56 AM	SW_OHLB:9779	0.074825	3.02E-05	2,475
1308859	9/9/22	2:42 AM	SANDY-WILDCAT	52	2473	128584.7	9/10/22	7:54 PM	FUSE_OH:D2424C-1877 / BC / 40 A	0.13886	5.62E-05	2,473
1308742	9/9/22	2:47 AM	EAGLE CREEK-BARTON	1	2473	2472.733	9/10/22	7:59 PM	FUSE_OH:D2428B-190 / C / 100 A	0.00267	1.08E-06	2,473
1308733	9/9/22	2:50 AM	DUNNS CORNER-DUNNS CORNER 13	258	2465	635995.8	9/10/22	7:55 PM	RECL:1696	0.68682	2.79E-04	2,465
1308860	9/9/22	2:42 AM	SANDY-WILDCAT	93	2464	229175.3	9/10/22	7:46 PM	FUSE_OH:D2424C-1877 / ABC / 100 A	0.247489	1.00E-04	2,464
1313239	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	5	2458	12288	9/11/22	9:37 AM	FUSE_OH:C2434C-644 / C / 40 A	0.01327	5.40E-06	2,458
1308857	9/9/22	2:42 AM	SANDY-WILDCAT	1	2452	2452.333	9/10/22	7:34 PM	FUSE_OH:D2424C-1915 / C / 40 A	0.002648	1.08E-06	2,452
1308760	9/9/22	2:33 AM	BRIGHTWOOD-NORTH BANK	7	2422	16952.95	9/10/22	6:54 PM	FUSE_OH:D2733C-454 / B / 40 A	0.018308	7.56E-06	2,422
1308734	9/9/22	2:47 AM	EAGLE CREEK-BARTON	93	2416	224686.5	9/10/22	7:03 PM	FUSE_OH:D2429C-474 / AC / 100 A	0.242642	1.00E-04	2,416
1308889	9/9/22	2:42 AM	SANDY-WILDCAT	1	2409	2408.5	9/10/22	6:50 PM	FUSE_OH:D2531D-1608 / C / 65 A	0.002601	1.08E-06	2,409
1308524	9/9/22	2:35 AM	SANDY-WILDCAT	468	2404	1125072	9/10/22	6:39 PM	RECL:7829	1.214979	5.05E-04	2,404
1310266	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	42	2389	100356.2	9/11/22	2:31 AM	FUSE_OH:D7111A-696 / B / 25 A	0.108376	4.54E-05	2,389
1310263	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2388	2388	9/11/22	2:30 AM	FUSE_OH:D7111A-692 / B / 6 A	0.002579	1.08E-06	2,388
1310264	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	9	2388	21492	9/11/22	2:30 AM	FUSE_OH:D7111A-695 / B / 25 A	0.023209	9.72E-06	2,388
1309448	9/9/22	8:10 AM	ESTACADA-NORTH FORK	15	2387	35798.25	9/10/22	11:56 PM	FUSE_OH:D3531A-540 / B / 25 A	0.038659	1.62E-05	2,387
1313244	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	84	2387	200467.4	9/11/22	8:26 AM	FUSE_OH:C2427C-457 / ABC / 100 A	0.216487	9.07E-05	2,387
1310267	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	6	2384	14304.5	9/11/22	2:26 AM	FUSE_OH:D7112B-716 / A / 25 A	0.015448	6.48E-06	2,384
1310270	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	4	2384	9536	9/11/22	2:26 AM	FUSE_OH:D7112B-720 / A / 15 A	0.010298	4.32E-06	2,384
1310269	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	12	2384	28606.8	9/11/22	2:25 AM	FUSE_OH:D7112B-720 / A / 25 A	0.030893	1.3E-05	2,384
1308730	9/9/22	2:47 AM	EAGLE CREEK-BARTON	37	2380	88046.43	9/10/22	6:26 PM	SW_OHLB:3189	0.095082	4.00E-05	2,380
1310259	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2375	2375	9/11/22	2:17 AM	FUSE_OH:D6134D-550 / B / 10 A	0.002565	1.08E-06	2,375
1310260	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	2375	4750	9/11/22	2:17 AM	FUSE_OH:D7103A-1322 / AB / 40 A	0.00513	2.16E-06	2,375
1310261	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	2375	4749.767	9/11/22	2:16 AM	FUSE_OH:D7102B-100 / A / 6 A	0.005129	2.16E-06	2,375
1310262	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2374	2374	9/11/22	2:16 AM	FUSE_OH:D7102C-1140 / A / 6 A	0.002564	1.08E-06	2,374
1309436	9/9/22	8:10 AM	ESTACADA-NORTH FORK	2	2344	4688.567	9/10/22	11:14 PM	FUSE_OH:D3531B-629 / A / 15 A	0.005063	2.16E-06	2,344
1310968	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2343	2343	9/11/22	4:03 AM	FUSE_OH:B2415A-441 / C / 6 A	0.00253	1.08E-06	2,343
1310938	9/9/22	1:03 PM	BANKS-BANKS 13	1	2341	2341	9/11/22	4:04 AM	FUSE_OH:B1402C-18 / ABC / 6 A	0.002528	1.08E-06	2,341
1310969	9/9/22	1:00 PM	BANKS-CEDAR CANYON	8	2339	18715.2	9/11/22	3:59 AM	TRIP_SAVER:B2415A-1846 / A / 25 A	0.020211	8.64E-06	2,339
1310287	9/9/22	10:26 AM	MOLALLA-MARQUAM	93	2330	216727.2	9/11/22	1:17 AM	FUSE_OH:D5232C-793 / AC / 40 A	0.234046	1.00E-04	2,330
1310960	9/9/22	1:00 PM	BANKS-CEDAR CANYON	5	2329	11645	9/11/22	3:49 AM	FUSE_OH:B2415A-433 / AC / 10 A	0.012576	5.40E-06	2,329
1310964	9/9/22	1:00 PM	BANKS-CEDAR CANYON	47	2322	109134	9/11/22	3:42 AM	TRIP_SAVER:B2415A-430 / A / 65 A	0.117855	5.08E-05	2,322
1310358	9/9/22	10:54 AM	MOLALLA-MARQUAM	1	2319	2319.283	9/11/22	1:34 AM	FUSE_OH:D6306A-4 / AC / 10 A	0.002505	1.08E-06	2,319
1310945	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2305	2305	9/11/22	3:25 AM	FUSE_OH:B2424B-685 / C / 65 A	0.002489	1.08E-06	2,305
1310348	9/9/22	10:54 AM	MOLALLA-MARQUAM	2	2301	4602.567	9/11/22	1:16 AM	FUSE_OH:D6306B-2 / A / 15 A	0.00497	2.16E-06	2,301
1310349	9/9/22	10:54 AM	MOLALLA-MARQUAM	9	2300	20702.55	9/11/22	1:15 AM	FUSE_OH:D6306B-2 / C / 15 A	0.022357	9.72E-06	2,300
1310345	9/9/22	10:54 AM	MOLALLA-MARQUAM	2	2295	4590.633	9/11/22	1:10 AM	FUSE_OH:D5236A-184 / C / 15 A	0.004957	2.16E-06	2,295
1310940	9/9/22	1:00 PM	BANKS-CEDAR CANYON	37	2291	84767	9/11/22	3:11 AM	FUSE_OH:B2425B-200 / BC / 100 A	0.091541	4.00E-05	2,291
1310322	9/9/22	10:37 AM	MOLALLA-MARQUAM	22	2290	50383.67	9/11/22	12:47 AM	FUSE_OH:D6203C-101 / C / 25 A	0.05441	2.38E-05	2,290
1310323	9/9/22	10:37 AM	MOLALLA-MARQUAM	21	2290	48093.15	9/11/22	12:47 AM	TRIP_SAVER:D6203C-938 / C / 25 A	0.051936	2.27E-05	2,290
1310941	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2290	2290	9/11/22	3:10 AM	FUSE_OH:B2424C-204 / C / 10 A	0.002473	1.08E-06	2,290
1310240	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	39	2274	88674.95	9/11/22	12:35 AM	FUSE_OH:D6133A-1566 / AC / 40 A	0.095761	4.21E-05	2,274
1310347	9/9/22	10:54 AM	MOLALLA-MARQUAM	2	2273	4546.567	9/11/22	12:48 AM	FUSE_OH:D6306B-8 / B / 6 A	0.00491	2.16E-06	2,273
1314379	9/9/22	1:00 PM	BANKS-CEDAR CANYON	11	2273	24998.6	9/11/22	2:52 AM	RECL:6459	0.026996	1.19E-05	2,273
1309407	9/9/22	8:10 AM	ESTACADA-NORTH FORK	35	2272	79527	9/10/22	10:02 PM	FUSE_OH:D3427D-2504 / AB / 40 A	0.085882	3.78E-05	2,272
1309403	9/9/22	8:10 AM	ESTACADA-NORTH FORK	1	2272	2272	9/10/22	10:02 PM	FUSE_OH:D3427D-2986 / C / 15 A	0.002454	1.08E-06	2,272
1310937	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2272	2272	9/11/22	2:52 AM	FUSE_OH:B2425D-188 / AC / 15 A	0.002454	1.08E-06	2,272
1311017	9/9/22	1:00 PM	BANKS-CEDAR CANYON	5	2272	11360	9/11/22	2:52 AM	FUSE_OH:B2410C-716 / AC / 40 A	0.012268	5.40E-06	2,272
1310939	9/9/22	1:00 PM	BANKS-CEDAR CANYON	4	2272	9088	9/11/22	2:52 AM	FUSE_OH:B2425A-193 / AB / 65 A	0.009814	4.32E-06	2,272

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310932	9/9/22	1:00 PM	BANKS-CEDAR CANYON	2	2272	4544	9/11/22	2:52 AM	FUSE_OH:B2425D-186 / C / 6 A	0.004907	2.16E-06	2,272
1310934	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2272	2272	9/11/22	2:52 AM	FUSE_OH:B2425D-185 / C / 65 A	0.002454	1.08E-06	2,272
1310346	9/9/22	10:54 AM	MOLALLA-MARQUAM	2	2265	4529.233	9/11/22	12:39 AM	FUSE_OH:D5236A-186 / B / 6 A	0.004891	2.16E-06	2,265
1310318	9/9/22	10:37 AM	MOLALLA-MARQUAM	1	2257	2257	9/11/22	12:14 AM	FUSE_OH:D6203C-8 / A / 10 A	0.002437	1.08E-06	2,257
1310338	9/9/22	10:54 AM	MOLALLA-MARQUAM	1	2255	2255.283	9/11/22	12:30 AM	FUSE_OH:D5236B-755 / A / 6 A	0.002436	1.08E-06	2,255
1310959	9/9/22	1:03 PM	BANKS-BANKS 13	70	2247	157281.8	9/11/22	2:29 AM	FUSE_OH:B1308A-3185 / ABC / 40 A	0.169851	7.56E-05	2,247
1309425	9/9/22	8:10 AM	ESTACADA-NORTH FORK	216	2246	485172	9/10/22	9:36 PM	FUSE_OH:D3435A-1556 / AC / 65 A	0.523943	2.33E-04	2,246
1310314	9/9/22	10:37 AM	MOLALLA-MARQUAM	7	2243	15701.35	9/11/22	12:00 AM	FUSE_OH:D6203B-6 / B / 25 A	0.016956	7.56E-06	2,243
1310326	9/9/22	10:54 AM	MOLALLA-MARQUAM	8	2241	17928.67	9/11/22	12:15 AM	TRIP_SAVER:D5226D-812 / C / 25 A	0.019361	8.64E-06	2,241
1310961	9/9/22	1:03 PM	BANKS-BANKS 13	55	2239	123145	9/11/22	2:22 AM	FUSE_OH:B1305D-3196 / ABC / 40 A	0.132986	5.94E-05	2,239
1310337	9/9/22	10:54 AM	MOLALLA-MARQUAM	2	2234	4468.567	9/11/22	12:09 AM	FUSE_OH:D5226D-170 / A / 6 A	0.004826	2.16E-06	2,234
1309375	9/9/22	8:09 AM	ESTACADA-NORTH FORK	11	2232	24546.87	9/10/22	9:20 PM	FUSE_OH:D4409C-665 / C / 40 A	0.026508	1.19E-05	2,232
1310335	9/9/22	10:54 AM	MOLALLA-MARQUAM	1	2229	2229.283	9/11/22	12:04 AM	FUSE_OH:D5226D-1130 / A / 6 A	0.002407	1.08E-06	2,229
1310957	9/9/22	1:03 PM	BANKS-BANKS 13	1	2228	2228.067	9/11/22	2:11 AM	FUSE_OH:B1307B-2176 / A / 6 A	0.002406	1.08E-06	2,228
1310965	9/9/22	1:03 PM	BANKS-BANKS 13	7	2228	15596	9/11/22	2:11 AM	FUSE_OH:B1305D-2186 / A / 40 A	0.016842	7.56E-06	2,228
1314375	9/9/22	1:03 PM	BANKS-BANKS 13	59	2228	131452	9/11/22	2:11 AM	FUSE_OH:B1307B-3276 / ABC / 65 A	0.141957	6.37E-05	2,228
1310962	9/9/22	1:03 PM	BANKS-BANKS 13	14	2228	31190.6	9/11/22	2:10 AM	FUSE_OH:B1305D-73 / AC / 15 A	0.033683	1.51E-05	2,228
1310966	9/9/22	1:03 PM	BANKS-BANKS 13	20	2227	44540	9/11/22	2:10 AM	FUSE_OH:B1305D-3193 / AB / 40 A	0.048099	2.16E-05	2,227
1309378	9/9/22	8:09 AM	ESTACADA-NORTH FORK	3	2226	6678	9/10/22	9:15 PM	FUSE_OH:D4409C-156 / B / 25 A	0.007212	3.24E-06	2,226
1309376	9/9/22	8:09 AM	ESTACADA-NORTH FORK	207	2226	460740.6	9/10/22	9:14 PM	FUSE_OH:D4409C-156 / BC / 65 A	0.49756	2.24E-04	2,226
1309887	9/9/22	10:37 AM	MOLALLA-MARQUAM	26	2225	57844.37	9/10/22	11:41 PM	FUSE_OH:D5234C-526 / ABC / 25 A	0.062467	2.81E-05	2,225
1310255	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	36	2224	80057.4	9/10/22	11:45 PM	TRIP_SAVER:D6134D-186 / C / 40 A	0.086455	3.89E-05	2,224
1310064	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	134	2208	295831.8	9/10/22	11:15 PM	TRIP_SAVER:D6115D-2059 / A / 65 A	0.319472	1.45E-04	2,208
1309344	9/9/22	8:09 AM	ESTACADA-NORTH FORK	2	2207	4413.533	9/10/22	8:55 PM	FUSE_OH:D3432D-3221 / C / 6 A	0.004766	2.16E-06	2,207
1309341	9/9/22	8:09 AM	ESTACADA-NORTH FORK	16	2200	35204.27	9/10/22	8:49 PM	TRIP_SAVER:D3433C-981 / C / 65 A	0.038018	1.73E-05	2,200
1310336	9/9/22	10:54 AM	MOLALLA-MARQUAM	4	2196	8785.133	9/10/22	11:31 PM	FUSE_OH:D5226D-167 / A / 15 A	0.009487	4.32E-06	2,196
1312881	9/9/22	2:36 PM	AMITY-BELLEVUE	1	2193	2192.783	9/11/22	3:08 AM	FUSE_OH:C6531A-637 / ABC / 10 A	0.002368	1.08E-06	2,193
1310325	9/9/22	10:54 AM	MOLALLA-MARQUAM	2	2191	4382.233	9/10/22	11:25 PM	FUSE_OH:D5226D-162 / C / 6 A	0.004732	2.16E-06	2,191
1309338	9/9/22	8:09 AM	ESTACADA-NORTH FORK	33	2189	72235.35	9/10/22	8:37 PM	FUSE_OH:D3432A-796 / A / 65 A	0.078008	3.56E-05	2,189
1311287	9/9/22	1:43 PM	GRAND RONDE-AGENCY	1	2186	2185.617	9/11/22	2:08 AM	FUSE_OH:C6812A-39 / C / 40 A	0.00236	1.08E-06	2,186
1310324	9/9/22	10:54 AM	MOLALLA-MARQUAM	1	2185	2185.283	9/10/22	11:20 PM	FUSE_OH:D5226A-158 / B / 15 A	0.00236	1.08E-06	2,185
1310249	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2184	2183.783	9/10/22	11:05 PM	FUSE_OH:D6134B-534 / B / 10 A	0.002358	1.08E-06	2,184
1310248	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	13	2173	28252.03	9/10/22	10:55 PM	FUSE_OH:D6134B-527 / C / 40 A	0.03051	1.4E-05	2,173
1310069	9/9/22	10:54 AM	MOLALLA-MARQUAM	122	2166	264211.3	9/10/22	11:00 PM	RECL:9515	0.285325	0.000132	2,166
1309340	9/9/22	8:09 AM	ESTACADA-NORTH FORK	2	2163	4326	9/10/22	8:12 PM	FUSE_OH:D3432D-4034 / C / 6 A	0.004672	2.16E-06	2,163
1309337	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2163	2163	9/10/22	8:12 PM	FUSE_OH:D3432A-793 / A / 15 A	0.002336	1.08E-06	2,163
1310587	9/9/22	12:23 PM	SYLVAN-PATTON	2	2163	4325.6	9/11/22	12:25 AM	FUSE_OH:D1106A-1348 / A / 10 A	0.004671	2.16E-06	2,163
1310585	9/9/22	12:23 PM	SYLVAN-PATTON	3	2161	6483.8	9/11/22	12:24 AM	FUSE_OH:D1106A-1346 / B / 10 A	0.007002	3.24E-06	2,161
1310239	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	7	2161	15125.95	9/10/22	10:42 PM	FUSE_OH:D6128D-520 / B / 10 A	0.016335	7.56E-06	2,161
1311323	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	46	2160	99375.33	9/11/22	1:41 AM	FUSE_OH:C6709C-1088 / AB / 65 A	0.107317	4.97E-05	2,160
1310357	9/9/22	10:54 AM	MOLALLA-MARQUAM	3	2160	6480.85	9/10/22	10:55 PM	FUSE_OH:D6306A-3 / ABC / 25 A	0.006999	3.24E-06	2,160
1309336	9/9/22	8:09 AM	ESTACADA-NORTH FORK	5	2159	10797.33	9/10/22	8:08 PM	FUSE_OH:D3432A-766 / A / 65 A	0.01166	5.40E-06	2,159
1310578	9/9/22	12:23 PM	SYLVAN-PATTON	5	2158	10790.17	9/11/22	12:21 AM	FUSE_OH:D1106A-1346 / C / 100 A	0.011652	5.40E-06	2,158
1310911	9/9/22	1:00 PM	BANKS-CEDAR CANYON	120	2156	258744	9/11/22	12:56 AM	FUSE_OH:B2434A-605 / ABC / 100 A	0.279421	1.30E-04	2,156
1314690	9/9/22	10:52 PM	REDLAND-HENRICI	282	2154	607305.8	9/11/22	10:46 AM	SW_OHLB:6240	0.655837	3.05E-04	2,154
1310307	9/9/22	10:37 AM	MOLALLA-MARQUAM	9	2145	19303.2	9/10/22	10:21 PM	FUSE_OH:D5233D-524 / ABC / 25 A	0.020846	9.72E-06	2,145
1309333	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2143	2143	9/10/22	7:52 PM	FUSE_OH:D3429D-531 / B / 65 A	0.002314	1.08E-06	2,143
1310238	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	8	2143	17141.87	9/10/22	10:24 PM	FUSE_OH:D6128D-2040 / C / 40 A	0.018512	8.64E-06	2,143
1310237	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	18	2135	38427.9	9/10/22	10:16 PM	FUSE_OH:D6128D-519 / C / 40 A	0.041499	1.94E-05	2,135
1311320	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	6	2134	12802.3	9/11/22	1:14 AM	FUSE_OH:C6709C-898 / BC / 65 A	0.013825	6.48E-06	2,134

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310633	9/9/22	12:23 PM	SYLVAN-PATTON	14	2132	29851.03	9/10/22	11:55 PM	TRIP_SAVER:A1131D-1606 / C / 25 A	0.032237	1.51E-05	2,132
1310895	9/9/22	1:00 PM	BANKS-CEDAR CANYON	161	2130	342930	9/11/22	12:30 AM	FUSE_OH:B2436B-116 / ABC / 65 A	0.370334	0.000174	2,130
1310638	9/9/22	12:23 PM	SYLVAN-PATTON	11	2130	23425.6	9/10/22	11:52 PM	TRIP_SAVER:A1131D-5145 / C / 25 A	0.025298	1.19E-05	2,130
1310589	9/9/22	12:23 PM	SYLVAN-PATTON	23	2129	48977.73	9/10/22	11:52 PM	FUSE_OH:D1106A-8050 / ABC / 15 A	0.052892	2.48E-05	2,129
1313210	9/9/22	11:57 AM	YAMHILL-YAMHILL 13	413	2126	878100	9/10/22	11:23 PM	RECL:1925	0.948271	4.46E-04	2,126
1310127	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2122	2122	9/10/22	9:50 PM	FUSE_OH:D6123C-1107 / C / 6 A	0.002292	1.08E-06	2,122
1310132	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2122	2122	9/10/22	9:50 PM	FUSE_OH:D6123C-363 / C / 6 A	0.002292	1.08E-06	2,122
1310284	9/9/22	10:26 AM	MOLALLA-MARQUAM	2	2121	4242.8	9/10/22	9:48 PM	FUSE_OH:D5232B-783 / C / 10 A	0.004582	2.16E-06	2,121
1310236	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	4	2120	8481.733	9/10/22	10:02 PM	FUSE_OH:D6128C-1899 / A / 40 A	0.00916	4.32E-06	2,120
1311319	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	79	2120	167495.8	9/11/22	1:01 AM	FUSE_OH:C6709C-786 / ABC / 65 A	0.180881	8.53E-05	2,120
1310235	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2116	2116	9/10/22	9:58 PM	FUSE_OH:D6128C-517 / A / 6 A	0.002285	1.08E-06	2,116
1310946	9/9/22	1:03 PM	BANKS-BANKS 13	3	2113	6338.55	9/11/22	12:15 AM	FUSE_OH:B1403D-30 / ABC / 40 A	0.006845	3.24E-06	2,113
1310653	9/9/22	12:23 PM	SYLVAN-PATTON	8	2101	16806	9/10/22	11:23 PM	FUSE_OH:A1131D-5140 / A / 10 A	0.018149	8.64E-06	2,101
1310282	9/9/22	10:26 AM	MOLALLA-MARQUAM	1	2100	2100.4	9/10/22	9:27 PM	FUSE_OH:D5229D-761 / B / 6 A	0.002268	1.08E-06	2,100
1309331	9/9/22	8:09 AM	ESTACADA-NORTH FORK	4	2100	8399.867	9/10/22	7:08 PM	FUSE_OH:D3429D-63 / C / 6 A	0.009071	4.32E-06	2,100
1309346	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2100	2099.967	9/10/22	7:08 PM	FUSE_OH:D4405A-231 / B / 6 A	0.002268	1.08E-06	2,100
1309329	9/9/22	8:09 AM	ESTACADA-NORTH FORK	11	2100	23099.45	9/10/22	7:08 PM	FUSE_OH:D3429A-500 / AC / 65 A	0.024945	1.19E-05	2,100
1309349	9/9/22	8:09 AM	ESTACADA-NORTH FORK	19	2100	39898.73	9/10/22	7:08 PM	FUSE_OH:D4405D-162 / ABC / 40 A	0.043087	2.05E-05	2,100
1309386	9/9/22	8:09 AM	ESTACADA-NORTH FORK	1	2100	2099.917	9/10/22	7:08 PM	FUSE_OH:D4407D-4 / C / 6 A	0.002268	1.08E-06	2,100
1309281	9/9/22	8:08 AM	ESTACADA-NORTH FORK	188	2100	394768.7	9/10/22	7:08 PM	RECL:2679	0.426316	2.03E-04	2,100
1309345	9/9/22	8:09 AM	ESTACADA-NORTH FORK	3	2099	6297	9/10/22	7:08 PM	FUSE_OH:D4405A-1135 / A / 65 A	0.0068	3.24E-06	2,099
1310954	9/9/22	1:03 PM	BANKS-BANKS 13	8	2098	16786.93	9/11/22	12:01 AM	FUSE_OH:B1307C-797 / ABC / 65 A	0.018128	8.64E-06	2,098
1309284	9/9/22	8:07 AM	ESTACADA-NORTH FORK	181	2098	379656.6	9/10/22	7:05 PM	RECL:2371	0.409996	0.000195	2,098
1310936	9/9/22	1:03 PM	BANKS-BANKS 13	39	2086	81353.35	9/10/22	11:48 PM	FUSE_OH:B1402C-588 / ABC / 65 A	0.087854	4.21E-05	2,086
1310664	9/9/22	12:23 PM	SYLVAN-PATTON	3	2085	6253.9	9/10/22	11:07 PM	FUSE_OH:D1106A-25 / C / 10 A	0.006754	3.24E-06	2,085
1310231	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	2084	4167.033	9/10/22	9:25 PM	FUSE_OH:D6129D-1608 / A / 10 A	0.0045	2.16E-06	2,084
1310281	9/9/22	10:26 AM	MOLALLA-MARQUAM	1	2080	2080.4	9/10/22	9:07 PM	FUSE_OH:D5229A-757 / A / 6 A	0.002247	1.08E-06	2,080
1310230	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	2079	2079	9/10/22	9:21 PM	FUSE_OH:D6129D-2095 / C / 65 A	0.002245	1.08E-06	2,079
1310228	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	5	2077	10384.83	9/10/22	9:18 PM	FUSE_OH:D6129D-340 / B / 40 A	0.011215	5.40E-06	2,077
1310655	9/9/22	12:23 PM	SYLVAN-PATTON	3	2074	6220.6	9/10/22	10:56 PM	FUSE_OH:D1106A-6137 / C / 100 A	0.006718	3.24E-06	2,074
1310276	9/9/22	10:26 AM	MOLALLA-MARQUAM	21	2072	43520.4	9/10/22	8:59 PM	FUSE_OH:D5229B-243 / AB / 25 A	0.046998	2.27E-05	2,072
1317220	9/9/22	12:19 PM	SYLVAN-PATTON	2	2071	4142	9/10/22	10:50 PM	XFM_UG:A 25 83414	0.004473	2.16E-06	2,071
1310584	9/9/22	12:09 PM	REDLAND-REDLAND 13	3	2071	6212.8	9/10/22	10:39 PM	FUSE_OH:D3303A-456 / A / 6 A	0.006709	3.24E-06	2,071
1314377	9/9/22	1:00 PM	BANKS-CEDAR CANYON	15	2071	31059.25	9/10/22	11:30 PM	RECL:1945	0.033541	1.62E-05	2,071
1310893	9/9/22	1:00 PM	BANKS-CEDAR CANYON	2	2070	4140	9/10/22	11:30 PM	FUSE_OH:B2436A-11 / C / 6 A	0.004471	2.16E-06	2,070
1310890	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2070	2070	9/10/22	11:30 PM	FUSE_OH:B2436A-8 / BC / 10 A	0.002235	1.08E-06	2,070
1310909	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2070	2070	9/10/22	11:30 PM	FUSE_OH:B2435B-596 / AC / 10 A	0.002235	1.08E-06	2,070
1310898	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2070	2070	9/10/22	11:30 PM	FUSE_OH:B2435A-120 / C / 6 A	0.002235	1.08E-06	2,070
1310905	9/9/22	1:00 PM	BANKS-CEDAR CANYON	3	2070	6210	9/10/22	11:30 PM	FUSE_OH:B2435B-1657 / A / 10 A	0.006706	3.24E-06	2,070
1310906	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	2070	2070	9/10/22	11:30 PM	FUSE_OH:B2435A-123 / C / 6 A	0.002235	1.08E-06	2,070
1317112	9/9/22	12:23 PM	SYLVAN-PATTON	1	2067	2067	9/10/22	10:50 PM	SP:610 SW ARBORETUM CIR	0.002232	1.08E-06	2,067
1317161	9/9/22	12:23 PM	SYLVAN-PATTON	1	2067	2067	9/10/22	10:50 PM	SP:609 SW ARBORETUM CIR	0.002232	1.08E-06	2,067
1317092	9/9/22	12:23 PM	SYLVAN-PATTON	1	2067	2067	9/10/22	10:50 PM	SP:614 SW ARBORETUM CIR	0.002232	1.08E-06	2,067
1316936	9/9/22	12:24 PM	SYLVAN-PATTON	2	2066	4132	9/10/22	10:50 PM	XFM_UG:A 25 82439	0.004462	2.16E-06	2,066
1310577	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2062	2062.333	9/10/22	10:31 PM	FUSE_OH:D3303B-108 / A / 6 A	0.002227	1.08E-06	2,062
1318157	9/9/22	11:17 PM	ESTACADA-ESTACADA 13	148	2062	305205.6	9/11/22	9:39 AM	SW_OHLB:3367	0.329595	1.60E-04	2,062
1311315	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	22	2060	45329.53	9/11/22	12:01 AM	FUSE_OH:C6708D-446 / AB / 65 A	0.048952	2.38E-05	2,060
1310947	9/9/22	1:03 PM	BANKS-BANKS 13	4	2058	8232	9/10/22	11:21 PM	FUSE_OH:B1307B-2166 / ABC / 6 A	0.00889	4.32E-06	2,058
1313215	9/9/22	1:36 PM	YAMHILL-CARLTON	29	2055	59588.72	9/10/22	11:50 PM	FUSE_OH:C3407B-1292 / B / 65 A	0.064351	3.13E-05	2,055
1310303	9/9/22	10:37 AM	MOLALLA-MARQUAM	1	2055	2054.517	9/10/22	8:51 PM	FUSE_OH:D5233A-516 / A / 6 A	0.002219	1.08E-06	2,055

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1312670	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	35	2052	71835.75	9/11/22	12:35 AM	FUSE_OH:C2412B-556 / AB / 65 A	0.077576	3.78E-05	2,052
1310658	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2051	2050.7	9/10/22	10:19 PM	FUSE_OH:D2327A-1419 / A / 6 A	0.002215	1.08E-06	2,051
1310565	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2049	2048.65	9/10/22	10:17 PM	FUSE_OH:D3304D-119 / C / 6 A	0.002212	1.08E-06	2,049
1310302	9/9/22	10:37 AM	MOLALLA-MARQUAM	3	2048	6143.95	9/10/22	8:44 PM	FUSE_OH:D5233A-514 / A / 6 A	0.006635	3.24E-06	2,048
1312665	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	54	2046	110489.4	9/11/22	12:29 AM	FUSE_OH:C2402A-579 / C / 100 A	0.119319	5.83E-05	2,046
1310661	9/9/22	12:09 PM	REDLAND-REDLAND 13	5	2046	10227.58	9/10/22	10:14 PM	FUSE_OH:D2322D-664 / B / 65 A	0.011045	5.40E-06	2,046
1311312	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	51	2044	104243.2	9/10/22	11:44 PM	FUSE_OH:C6708D-751 / BC / 65 A	0.112573	5.51E-05	2,044
1312667	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	6	2043	12260.6	9/11/22	12:26 AM	FUSE_OH:C2402D-568 / C / 65 A	0.01324	6.48E-06	2,043
1310656	9/9/22	12:09 PM	REDLAND-REDLAND 13	9	2038	18345.6	9/10/22	10:07 PM	FUSE_OH:D2327A-124 / A / 65 A	0.019812	9.72E-06	2,038
1313282	9/9/22	1:25 PM	NORTH PLAINS-NORTH PLAINS 13	1	2038	2038.117	9/10/22	11:23 PM	FUSE_OH:B2335C-103 / A / 40 A	0.002201	1.08E-06	2,038
1310564	9/9/22	12:09 PM	REDLAND-REDLAND 13	2	2038	4076	9/10/22	10:07 PM	FUSE_OH:D3304D-120 / AB / 6 A	0.004402	2.16E-06	2,038
1310301	9/9/22	10:37 AM	MOLALLA-MARQUAM	1	2036	2035.9	9/10/22	8:32 PM	FUSE_OH:D5233A-511 / A / 25 A	0.002199	1.08E-06	2,036
1310654	9/9/22	12:09 PM	REDLAND-REDLAND 13	5	2035	10176.42	9/10/22	10:04 PM	FUSE_OH:D2327A-1436 / AC / 65 A	0.01099	5.40E-06	2,035
1311497	9/9/22	1:47 PM	WILLAMINA-BUELL	1	2035	2035	9/10/22	11:42 PM	FUSE_OH:C6605D-1030 / C / 6 A	0.002198	1.08E-06	2,035
1309422	9/9/22	8:48 AM	ESTACADA-NORTH FORK	1	2034	2034.283	9/10/22	6:43 PM	SP:40505 SE HWY 224_3	0.002197	1.08E-06	2,034
1316766	9/9/22	10:52 PM	ESTACADA-ESTACADA 13	38	2034	77300.87	9/11/22	8:47 AM	SW_OHLB:5254	0.083478	4.10E-05	2,034
1310575	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2033	2033	9/10/22	10:02 PM	FUSE_OH:D3304D-463 / A / 6 A	0.002195	1.08E-06	2,033
1309424	9/9/22	8:52 AM	ESTACADA-NORTH FORK	1	2031	2030.6	9/10/22	6:43 PM	XFM_UG:B 50 71383	0.002193	1.08E-06	2,031
1309427	9/9/22	8:52 AM	ESTACADA-NORTH FORK	1	2031	2030.6	9/10/22	6:43 PM	XFM_UG:C 15 43872	0.002193	1.08E-06	2,031
1309428	9/9/22	8:52 AM	ESTACADA-NORTH FORK	1	2031	2030.583	9/10/22	6:43 PM	SP:33831 SE FARADAY RD_1	0.002193	1.08E-06	2,031
1309415	9/9/22	8:52 AM	ESTACADA-NORTH FORK	6	2031	12183.3	9/10/22	6:43 PM	FUSE_OH:D4518C-222 / BC / 25 A	0.013157	6.48E-06	2,031
1309414	9/9/22	8:52 AM	ESTACADA-NORTH FORK	1	2031	2030.5	9/10/22	6:43 PM	XFM_UG:C 50 141236	0.002193	1.08E-06	2,031
1310652	9/9/22	12:09 PM	REDLAND-REDLAND 13	4	2030	8119.933	9/10/22	9:58 PM	FUSE_OH:D2327D-1454 / A / 65 A	0.008769	4.32E-06	2,030
1309429	9/9/22	8:52 AM	ESTACADA-NORTH FORK	3	2030	6088.6	9/10/22	6:42 PM	XFM_OH:C 10 22275 B 10 19789	0.006575	3.24E-06	2,030
1310924	9/9/22	1:03 PM	BANKS-BANKS 13	7	2029	14200.08	9/10/22	10:51 PM	FUSE_OH:B1306B-3175 / B / 65 A	0.015335	7.56E-06	2,029
1310124	9/9/22	10:26 AM	MOLALLA-MARQUAM	14	2028	28395.27	9/10/22	8:14 PM	RECL:3470	0.030664	1.51E-05	2,028
1310926	9/9/22	1:03 PM	BANKS-BANKS 13	14	2027	28384.3	9/10/22	10:50 PM	FUSE_OH:B1306B-2195 / AC / 65 A	0.030653	1.51E-05	2,027
1310935	9/9/22	1:03 PM	BANKS-BANKS 13	3	2027	6081	9/10/22	10:50 PM	FUSE_OH:B1402D-2259 / ABC / 40 A	0.006567	3.24E-06	2,027
1310563	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2026	2026	9/10/22	9:55 PM	FUSE_OH:D3304D-322 / A / 6 A	0.002188	1.08E-06	2,026
1310933	9/9/22	1:03 PM	BANKS-BANKS 13	3	2024	6072	9/10/22	10:47 PM	FUSE_OH:B1402D-646 / AB / 40 A	0.006557	3.24E-06	2,024
1310286	9/9/22	10:26 AM	MOLALLA-MARQUAM	49	2022	99082.9	9/10/22	8:08 PM	FUSE_OH:D5232C-110 / ABC / 25 A	0.107001	5.29E-05	2,022
1310299	9/9/22	10:37 AM	MOLALLA-MARQUAM	2	2022	4043.233	9/10/22	8:18 PM	FUSE_OH:D5233A-510 / C / 25 A	0.004366	2.16E-06	2,022
1310561	9/9/22	12:09 PM	REDLAND-REDLAND 13	2	2018	4036.433	9/10/22	9:47 PM	FUSE_OH:D3304D-326 / C / 6 A	0.004359	2.16E-06	2,018
1313214	9/9/22	1:36 PM	YAMHILL-CARLTON	3	2018	6053.9	9/10/22	11:13 PM	FUSE_OH:C3513B-295 / B / 10 A	0.006538	3.24E-06	2,018
1310641	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2016	2015.5	9/10/22	9:44 PM	FUSE_OH:D2327D-821 / B / 6 A_1	0.002177	1.08E-06	2,016
1310640	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2015	2014.783	9/10/22	9:43 PM	FUSE_OH:D2327D-821 / B / 6 A	0.002176	1.08E-06	2,015
1310642	9/9/22	12:09 PM	REDLAND-REDLAND 13	4	2014	8057.267	9/10/22	9:43 PM	FUSE_OH:D2327D-1474 / A / 6 A	0.008701	4.32E-06	2,014
1312671	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	2	2014	4028	9/11/22	12:04 AM	FUSE_OH:C2412B-546 / AC / 100 A	0.00435	2.16E-06	2,014
1310554	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2013	2013.15	9/10/22	9:42 PM	FUSE_OH:D3304C-330 / B / 6 A	0.002174	1.08E-06	2,013
1310295	9/9/22	10:37 AM	MOLALLA-MARQUAM	3	2013	6039	9/10/22	8:10 PM	FUSE_OH:D5233A-506 / A / 15 A	0.006522	3.24E-06	2,013
1310665	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2011	2011.45	9/10/22	9:40 PM	FUSE_OH:D2322D-1625 / A / 65 A	0.002172	1.08E-06	2,011
1313665	9/9/22	2:57 PM	YAMHILL-YAMHILL 13	13	2006	26078	9/11/22	12:23 AM	FUSE_OH:C2526A-2 / AC / 25 A	0.028162	1.40E-05	2,006
1310635	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	2006	2005.6	9/10/22	9:34 PM	FUSE_OH:D2334A-571 / A / 6 A	0.002166	1.08E-06	2,006
1310553	9/9/22	12:09 PM	REDLAND-REDLAND 13	9	2005	18047.7	9/10/22	9:34 PM	FUSE_OH:D3304C-890 / ABC / 140 A	0.01949	9.72E-06	2,005
1310636	9/9/22	12:09 PM	REDLAND-REDLAND 13	11	2005	22055.55	9/10/22	9:34 PM	FUSE_OH:D2334A-816 / C / 40 A	0.023818	1.19E-05	2,005
1313213	9/9/22	1:36 PM	YAMHILL-CARLTON	1	2004	2004	9/10/22	11:00 PM	FUSE_OH:C3513A-287 / C / 6 A	0.002164	1.08E-06	2,004
1310291	9/9/22	10:37 AM	MOLALLA-MARQUAM	2	2003	4006	9/10/22	8:00 PM	FUSE_OH:D5233A-44 / C / 25 A	0.004326	2.16E-06	2,003
1313211	9/9/22	1:36 PM	YAMHILL-CARLTON	24	1993	47840.4	9/10/22	10:49 PM	FUSE_OH:C3512D-274 / ABC / 65 A	0.051663	2.59E-05	1,993
1310552	9/9/22	12:09 PM	REDLAND-REDLAND 13	2	1993	3986.433	9/10/22	9:22 PM	FUSE_OH:D3304C-337 / A / 65 A	0.004305	2.16E-06	1,993
1310290	9/9/22	10:37 AM	MOLALLA-MARQUAM	13	1992	25900.12	9/10/22	7:49 PM	FUSE_OH:D5228D-41 / AB / 25 A	0.02797	1.40E-05	1,992

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310632	9/9/22	12:09 PM	REDLAND-REDLAND 13	36	1991	71688.6	9/10/22	9:20 PM	FUSE_OH:D3303A-1069 / B / 65 A	0.077417	3.89E-05	1,991
1310931	9/9/22	1:03 PM	BANKS-BANKS 13	1	1989	1989.35	9/10/22	10:12 PM	FUSE_OH:B1401C-5 / AB / 40 A	0.002148	1.08E-06	1,989
1310123	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	16	1986	31775.47	9/10/22	7:33 PM	FUSE_OH:D6122A-60 / C / 40 A	0.034315	1.73E-05	1,986
1310761	9/9/22	12:10 PM	REDLAND-REDLAND 13	187	1985	371198.1	9/10/22	9:15 PM	FUSE_OH:D2224B-3340 / ABC / 65 A	0.400861	0.000202	1,985
1310551	9/9/22	12:09 PM	REDLAND-REDLAND 13	2	1984	3967.1	9/10/22	9:12 PM	FUSE_OH:D3305D-338 / C / 6 A	0.004284	2.16E-06	1,984
1310663	9/9/22	12:09 PM	REDLAND-REDLAND 13	3	1983	5948.6	9/10/22	9:11 PM	FUSE_OH:D2322D-663 / C / 65 A	0.006424	3.24E-06	1,983
1310125	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	8	1978	15824.13	9/10/22	7:26 PM	FUSE_OH:D6123C-1104 / A / 40 A	0.017089	8.64E-06	1,978
1310289	9/9/22	10:37 AM	MOLALLA-MARQUAM	1	1977	1977.367	9/10/22	7:34 PM	FUSE_OH:D5228D-40 / A / 6 A	0.002135	1.08E-06	1,977
1312915	9/9/22	4:12 PM	ESTACADA-FARADAY	1	1977	1976.783	9/11/22	1:09 AM	SP:29760 SE OLD RANCH DR	0.002135	1.08E-06	1,977
1310748	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1975	3950.433	9/10/22	9:05 PM	FUSE_OH:D2227A-91 / C / 6 A	0.004266	2.16E-06	1,975
1310128	9/9/22	10:37 AM	MOLALLA-MARQUAM	79	1975	155994.7	9/10/22	7:31 PM	RECL:3006	0.168461	8.53E-05	1,975
1310546	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1974	1973.7	9/10/22	9:02 PM	FUSE_OH:D3305D-339 / C / 6 A	0.002131	1.08E-06	1,974
1310226	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	16	1973	31562.4	9/10/22	7:34 PM	TRIP_SAVER:D6129B-328 / C / 40 A	0.034085	1.73E-05	1,973
1313666	9/9/22	2:57 PM	YAMHILL-YAMHILL 13	2	1972	3944.367	9/10/22	11:49 PM	FUSE_OH:C2526A-170 / A / 6 A	0.00426	2.16E-06	1,972
1310547	9/9/22	12:09 PM	REDLAND-REDLAND 13	4	1969	7875.667	9/10/22	8:57 PM	FUSE_OH:D3305D-339 / A / 6 A	0.008505	4.32E-06	1,969
1310140	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	1968	1968.333	9/10/22	7:16 PM	FUSE_OH:D6136C-1402 / B / 6 A	0.002126	1.08E-06	1,968
1310141	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	9	1968	17714.7	9/10/22	7:16 PM	FUSE_OH:D6136C-1405 / BC / 25 A	0.01913	9.72E-06	1,968
1310747	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1968	3936.533	9/10/22	8:58 PM	FUSE_OH:D2226B-3050 / B / 6 A	0.004251	2.16E-06	1,968
1310143	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	108	1968	212553	9/10/22	7:16 PM	FUSE_OH:D6136C-1405 / BC / 40 A	0.229539	1.17E-04	1,968
1310929	9/9/22	1:03 PM	BANKS-BANKS 13	2	1968	3936.1	9/10/22	9:51 PM	FUSE_OH:B1412A-2234 / AC / 40 A	0.004251	2.16E-06	1,968
1310217	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	1968	1968.033	9/10/22	7:16 PM	FUSE_OH:D6136C-1381 / C / 6 A	0.002125	1.08E-06	1,968
1310137	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	3	1968	5904	9/10/22	7:16 PM	FUSE_OH:D6135A-1242 / C / 25 A	0.006376	3.24E-06	1,968
1310634	9/9/22	12:09 PM	REDLAND-REDLAND 13	87	1968	171195.7	9/10/22	8:56 PM	FUSE_OH:D3303A-862 / ABC / 100 A	0.184876	9.40E-05	1,968
1310737	9/9/22	12:10 PM	REDLAND-REDLAND 13	3	1967	5901.2	9/10/22	8:57 PM	FUSE_OH:D2226A-7241 / A / 65 A	0.006373	3.24E-06	1,967
1310288	9/9/22	10:37 AM	MOLALLA-MARQUAM	5	1966	9832.25	9/10/22	7:23 PM	FUSE_OH:D5228B-31 / AC / 25 A	0.010618	5.40E-06	1,966
1310227	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	5	1966	9830.5	9/10/22	7:28 PM	FUSE_OH:D6129A-333 / C / 40 A	0.010616	5.40E-06	1,966
1310544	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1964	1964.217	9/10/22	8:53 PM	FUSE_OH:D3305A-828 / B / 6 A	0.002121	1.08E-06	1,964
1310740	9/9/22	12:10 PM	REDLAND-REDLAND 13	17	1964	33388.57	9/10/22	8:54 PM	FUSE_OH:D2226A-7241 / C / 65 A	0.036057	1.84E-05	1,964
1310662	9/9/22	12:09 PM	REDLAND-REDLAND 13	44	1962	86344.13	9/10/22	8:51 PM	FUSE_OH:D2322D-1463 / AB / 65 A	0.093244	4.75E-05	1,962
1313206	9/9/22	1:36 PM	YAMHILL-CARLTON	2	1961	3921.4	9/10/22	10:16 PM	FUSE_OH:C3512D-28 / ABC / 15 A	0.004235	2.16E-06	1,961
1313664	9/9/22	2:57 PM	YAMHILL-YAMHILL 13	73	1958	142923.1	9/10/22	11:34 PM	FUSE_OH:C2523D-74 / BC / 25 A	0.154344	7.88E-05	1,958
1313209	9/9/22	1:36 PM	YAMHILL-CARLTON	1	1957	1956.967	9/10/22	10:12 PM	FUSE_OH:C3512D-74 / A / 6 A	0.002113	1.08E-06	1,957
1313207	9/9/22	1:36 PM	YAMHILL-CARLTON	2	1954	3908.833	9/10/22	10:10 PM	FUSE_OH:C3407C-2467 / B / 40 A	0.004221	2.16E-06	1,954
1317094	9/9/22	12:23 PM	SYLVAN-PATTON	1	1952	1952	9/10/22	8:55 PM	SP:5020 SW FAIRHAVEN LN	0.002108	1.08E-06	1,952
1310223	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	3	1951	5851.8	9/10/22	7:12 PM	FUSE_OH:D6130A-316 / ABC / 40 A	0.006319	3.24E-06	1,951
1313205	9/9/22	1:36 PM	YAMHILL-CARLTON	1	1947	1947.3	9/10/22	10:03 PM	FUSE_OH:C3407C-2466 / A / 6 A	0.002103	1.08E-06	1,947
1310542	9/9/22	12:09 PM	REDLAND-REDLAND 13	4	1947	7786.933	9/10/22	8:35 PM	FUSE_OH:D3305A-830 / B / 6 A	0.008409	4.32E-06	1,947
1310746	9/9/22	12:10 PM	REDLAND-REDLAND 13	5	1941	9705.5	9/10/22	8:31 PM	FUSE_OH:D2226C-47 / C / 10 A	0.010481	5.40E-06	1,941
1313202	9/9/22	1:36 PM	YAMHILL-CARLTON	2	1941	3881.067	9/10/22	9:56 PM	FUSE_OH:C3407B-792 / BC / 40 A	0.004191	2.16E-06	1,941
1310053	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	64	1939	124115.2	9/10/22	6:47 PM	RECL:2507	0.134034	6.91E-05	1,939
1310541	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1939	1939	9/10/22	8:28 PM	FUSE_OH:D3305A-894 / A / 6 A	0.002094	1.08E-06	1,939
1310736	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1937	3874.367	9/10/22	8:27 PM	FUSE_OH:D2226D-7641 / A / 65 A	0.004184	2.16E-06	1,937
1311307	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	3	1936	5809.05	9/10/22	9:57 PM	FUSE_OH:C6707D-766 / AB / 65 A	0.006273	3.24E-06	1,936
1313216	9/9/22	1:36 PM	YAMHILL-CARLTON	2	1936	3871.933	9/10/22	9:51 PM	FUSE_OH:C3406D-1347 / B / 6 A	0.004181	2.16E-06	1,936
1311189	9/9/22	1:36 PM	YAMHILL-CARLTON	174	1936	336835	9/10/22	9:51 PM	RECL:4683	0.363752	1.88E-04	1,936
1313770	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	1	1935	1934.867	9/10/22	7:48 PM	FUSE_OH:B2230A-125 / A / 6 A	0.002089	1.08E-06	1,935
1310567	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1934	1934	9/10/22	8:23 PM	FUSE_OH:D3303C-132 / AC / 10 A	0.002089	1.08E-06	1,934
1309904	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	112	1928	215904.3	9/10/22	6:49 PM	RECL:7852	0.233158	1.21E-04	1,928
1310225	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	3	1925	5775.65	9/10/22	6:47 PM	FUSE_OH:D6130A-323 / C / 10 A	0.006237	3.24E-06	1,925
1311308	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	5	1922	9611.583	9/10/22	9:43 PM	FUSE_OH:C6707D-769 / A / 65 A	0.01038	5.40E-06	1,922

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310540	9/9/22	12:09 PM	REDLAND-REDLAND 13	4	1922	7686.133	9/10/22	8:10 PM	FUSE_OH:D3305A-894 / AC / 40 A	0.0083	4.32E-06	1,922
1310576	9/9/22	12:23 PM	SYLVAN-PATTON	29	1918	55627.32	9/10/22	8:21 PM	TRIP_SAVER:D1106A-1547 / C / 25 A	0.060073	3.13E-05	1,918
1310745	9/9/22	12:10 PM	REDLAND-REDLAND 13	9	1918	17263.05	9/10/22	8:08 PM	FUSE_OH:D2226D-53 / A / 10 A	0.018643	9.72E-06	1,918
1311306	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	16	1913	30611.47	9/10/22	9:34 PM	FUSE_OH:C6707C-775 / BC / 65 A	0.033058	1.73E-05	1,913
1310743	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1911	3821.8	9/10/22	8:00 PM	FUSE_OH:D2226A-3931 / C / 6 A	0.004127	2.16E-06	1,911
1310524	9/9/22	12:09 PM	REDLAND-REDLAND 13	36	1910	68769.6	9/10/22	7:59 PM	FUSE_OH:D2330B-6379 / B / 65 A	0.074265	3.89E-05	1,910
1310659	9/9/22	12:23 PM	SYLVAN-PATTON	83	1909	158465	9/10/22	8:12 PM	FUSE_OH:A1132C-36 / B / 100 A	0.171128	8.96E-05	1,909
1310702	9/9/22	12:24 PM	SYLVAN-BARNES	148	1909	282551.7	9/10/22	8:13 PM	FUSE_OH:B1136B-332 / AC / 65 A	0.305131	1.60E-04	1,909
1310224	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	7	1909	13359.73	9/10/22	6:30 PM	FUSE_OH:D6130A-320 / A / 25 A	0.014427	7.56E-06	1,909
1310556	9/9/22	12:24 PM	SYLVAN-BARNES	10	1907	19074.83	9/10/22	8:12 PM	XFM_UG:C 75 9399	0.020599	1.08E-05	1,907
1312453	9/9/22	2:42 PM	ESTACADA-FARADAY	203	1907	387110.9	9/10/22	10:28 PM	RECL:1593	0.418046	2.19E-04	1,907
1310539	9/9/22	12:09 PM	REDLAND-REDLAND 13	6	1903	11419.6	9/10/22	7:52 PM	FUSE_OH:D3305A-969 / A / 6 A	0.012332	6.48E-06	1,903
1311305	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	44	1902	83683.6	9/10/22	9:22 PM	FUSE_OH:C6812D-49 / ABC / 100 A	0.090371	4.75E-05	1,902
1310219	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	1898	3796.1	9/10/22	6:20 PM	FUSE_OH:D6130A-315 / B / 6 A	0.004099	2.16E-06	1,898
1310525	9/9/22	12:09 PM	REDLAND-REDLAND 13	5	1894	9470	9/10/22	7:43 PM	FUSE_OH:D2330B-6380 / A / 6 A	0.010227	5.40E-06	1,894
1310574	9/9/22	12:23 PM	SYLVAN-PATTON	38	1894	71965.03	9/10/22	7:56 PM	FUSE_OH:D1106A-1546 / C / 15 A	0.077716	4.10E-05	1,894
1310135	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	22	1893	41645.27	9/10/22	6:00 PM	FUSE_OH:D6126B-1218 / A / 40 A	0.044973	2.38E-05	1,893
1310145	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	1892	3783.467	9/10/22	5:59 PM	FUSE_OH:D6126C-1454 / B / 6 A	0.004086	2.16E-06	1,892
1316142	9/9/22	6:38 PM	BANKS-BANKS 13	18	1891	34046.4	9/11/22	2:10 AM	FUSE_OH:B1307B-3276 / ABC / 65 A	0.036767	1.94E-05	1,891
1310133	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	43	1891	81325.9	9/10/22	5:59 PM	FUSE_OH:D6126B-1218 / ABC / 40 A	0.087825	4.64E-05	1,891
1310146	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	1891	3782	9/10/22	5:59 PM	FUSE_OH:D6126C-2174 / B / 6 A	0.004084	2.16E-06	1,891
1310476	9/9/22	12:09 PM	REDLAND-REDLAND 13	2	1885	3770	9/10/22	7:34 PM	FUSE_OH:D2330C-6388 / AC / 65 A	0.004071	2.16E-06	1,885
1310538	9/9/22	12:09 PM	REDLAND-REDLAND 13	10	1885	18848.67	9/10/22	7:33 PM	FUSE_OH:D3305A-2216 / B / 6 A	0.020355	1.08E-05	1,885
1310673	9/9/22	12:25 PM	SYLVAN-BARNES	46	1882	86572	9/10/22	7:47 PM	FUSE_OH:B1136D-1554 / ABC / 40 A	0.09349	4.97E-05	1,882
1310537	9/9/22	12:09 PM	REDLAND-REDLAND 13	6	1882	11291.3	9/10/22	7:30 PM	FUSE_OH:D3305A-1079 / A / 65 A	0.012194	6.48E-06	1,882
1310732	9/9/22	12:10 PM	REDLAND-REDLAND 13	1	1880	1880.283	9/10/22	7:30 PM	FUSE_OH:D2226D-891 / A / 65 A	0.002031	1.08E-06	1,880
1310741	9/9/22	12:10 PM	REDLAND-REDLAND 13	58	1880	109035.2	9/10/22	7:29 PM	TRIP_SAVER:D2226A-61 / B / 65 A	0.117748	6.26E-05	1,880
1313283	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	3	1877	5631	9/10/22	11:57 PM	FUSE_OH:C2412D-540 / B / 40 A	0.006081	3.24E-06	1,877
1311259	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	45	1877	84453	9/10/22	8:41 PM	FUSE_OH:B1427C-494 / BC / 40 A	0.091202	4.86E-05	1,877
1310730	9/9/22	12:10 PM	REDLAND-REDLAND 13	16	1873	29974.4	9/10/22	7:23 PM	FUSE_OH:D2235A-893 / AC / 65 A	0.03237	1.73E-05	1,873
1313273	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	4	1873	7493.067	9/10/22	11:53 PM	FUSE_OH:C2413C-516 / B / 40 A	0.008092	4.32E-06	1,873
1311151	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1873	1873	9/10/22	8:38 PM	FUSE_OH:B1405C-104 / BC / 25 A	0.002023	1.08E-06	1,873
1310674	9/9/22	12:25 PM	SYLVAN-BARNES	2	1873	3745.567	9/10/22	7:37 PM	FUSE_OH:B1136D-1581 / ABC / 25 A	0.004045	2.16E-06	1,873
1310536	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1873	1872.533	9/10/22	7:21 PM	FUSE_OH:D3305B-547 / C / 6 A	0.002022	1.08E-06	1,873
1312874	9/9/22	2:36 PM	AMITY-BELLEVUE	1	1870	1870	9/10/22	9:46 PM	FUSE_OH:C6529B-944 / BC / 15 A	0.002019	1.08E-06	1,870
1310571	9/9/22	12:23 PM	SYLVAN-PATTON	17	1869	31773.28	9/10/22	7:32 PM	FUSE_OH:D1106D-1432 / A / 15 A	0.034312	1.84E-05	1,869
1310533	9/9/22	12:09 PM	REDLAND-REDLAND 13	6	1869	11211.2	9/10/22	7:17 PM	FUSE_OH:D3305B-6428 / C / 10 A	0.012107	6.48E-06	1,869
1310928	9/9/22	1:00 PM	BANKS-CEDAR CANYON	123	1868	229737.4	9/10/22	8:07 PM	FUSE_OH:B2319B-45 / ABC / 65 A	0.248096	1.33E-04	1,868
1310472	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1863	1862.967	9/10/22	7:11 PM	FUSE_OH:D2330C-6390 / A / 6 A	0.002012	1.08E-06	1,863
1310532	9/9/22	12:09 PM	REDLAND-REDLAND 13	3	1861	5583	9/10/22	7:10 PM	FUSE_OH:D3305B-6423 / AC / 40 A	0.006029	3.24E-06	1,861
1310729	9/9/22	12:10 PM	REDLAND-REDLAND 13	5	1860	9300.583	9/10/22	7:10 PM	FUSE_OH:D2226D-892 / C / 65 A	0.010044	5.40E-06	1,860
1313275	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	2	1859	3718.867	9/10/22	11:39 PM	FUSE_OH:C2414D-514 / B / 40 A	0.004016	2.16E-06	1,859
1310531	9/9/22	12:09 PM	REDLAND-REDLAND 13	11	1859	20449.18	9/10/22	7:08 PM	FUSE_OH:D3306A-6422 / AC / 65 A	0.022083	1.19E-05	1,859
1310750	9/9/22	12:10 PM	REDLAND-REDLAND 13	18	1857	33429	9/10/22	7:07 PM	FUSE_OH:D2226A-62 / C / 65 A	0.0361	1.94E-05	1,857
1313270	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	3	1854	5562	9/10/22	11:34 PM	FUSE_OH:C2414D-509 / B / 40 A	0.006006	3.24E-06	1,854
1310731	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1854	3707.033	9/10/22	7:03 PM	FUSE_OH:D2225C-3662 / A / 65 A	0.004003	2.16E-06	1,854
1310470	9/9/22	12:09 PM	REDLAND-REDLAND 13	4	1853	7413.467	9/10/22	7:02 PM	FUSE_OH:D2330C-1735 / C / 6 A	0.008006	4.32E-06	1,853
1310672	9/9/22	12:25 PM	SYLVAN-BARNES	1	1849	1849.017	9/10/22	7:14 PM	FUSE_OH:B1136D-1025 / A / 6 A	0.001997	1.08E-06	1,849
1310706	9/9/22	12:10 PM	REDLAND-REDLAND 13	3	1848	5545.3	9/10/22	6:58 PM	FUSE_OH:D2236B-2653 / A / 65 A	0.005988	3.24E-06	1,848
1310469	9/9/22	12:09 PM	REDLAND-REDLAND 13	9	1848	16628.85	9/10/22	6:56 PM	FUSE_OH:D2331B-1036 / C / 65 A	0.017958	9.72E-06	1,848

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310752	9/9/22	12:10 PM	REDLAND-REDLAND 13	26	1847	48020.7	9/10/22	6:56 PM	FUSE_OH:D2226A-2435 / ABC / 65 A	0.051858	2.81E-05	1,847
1310242	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	1845	3689.267	9/10/22	5:26 PM	FUSE_OH:D6133A-427 / A / 10 A	0.003984	2.16E-06	1,845
1310570	9/9/22	12:23 PM	SYLVAN-PATTON	4	1844	7375.133	9/10/22	7:06 PM	FUSE_OH:D1106C-680 / A / 10 A	0.007964	4.32E-06	1,844
1310234	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	1843	3686	9/10/22	5:25 PM	FUSE_OH:D6128C-516 / A / 6 A	0.003981	2.16E-06	1,843
1310251	9/9/22	10:42 AM	SCOTTS MILLS-SCOTTS MILLS 13	3	1843	5528.65	9/10/22	5:24 PM	FUSE_OH:D6134C-540 / A / 40 A	0.00597	3.24E-06	1,843
1313266	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	11	1842	20262	9/10/22	11:22 PM	TRIP_SAVER:C2423A-501 / B / 40 A	0.021881	1.19E-05	1,842
1310705	9/9/22	12:10 PM	REDLAND-REDLAND 13	6	1839	11036.5	9/10/22	6:49 PM	FUSE_OH:D2236B-3359 / C / 65 A	0.011918	6.48E-06	1,839
1310703	9/9/22	12:10 PM	REDLAND-REDLAND 13	3	1839	5516	9/10/22	6:48 PM	FUSE_OH:D2236B-3359 / AC / 65 A	0.005957	3.24E-06	1,839
1310671	9/9/22	12:25 PM	SYLVAN-BARNES	15	1838	27567.5	9/10/22	7:02 PM	FUSE_OH:B1136D-751 / AC / 40 A	0.02977	1.62E-05	1,838
1310468	9/9/22	12:09 PM	REDLAND-REDLAND 13	3	1837	5511	9/10/22	6:46 PM	FUSE_OH:D2331C-1042 / AC / 6 A	0.005951	3.24E-06	1,837
1311304	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	248	1836	455340.4	9/10/22	8:17 PM	FUSE_OH:C6812D-156 / ABC / 100 A	0.491728	0.000268	1,836
1310670	9/9/22	12:25 PM	SYLVAN-BARNES	25	1835	45879.17	9/10/22	7:00 PM	FUSE_OH:B1136D-637 / AC / 40 A	0.049545	2.7E-05	1,835
1310529	9/9/22	12:09 PM	REDLAND-REDLAND 13	1	1835	1834.75	9/10/22	6:43 PM	FUSE_OH:D3306A-6418 / A / 6 A	0.001981	1.08E-06	1,835
1310465	9/9/22	12:09 PM	REDLAND-REDLAND 13	22	1833	40326.37	9/10/22	6:42 PM	FUSE_OH:D2331C-1025 / ABC / 100 A	0.043549	2.38E-05	1,833
1310754	9/9/22	12:10 PM	REDLAND-REDLAND 13	9	1832	16488.75	9/10/22	6:42 PM	FUSE_OH:D2223D-8967 / ABC / 65 A	0.017806	9.72E-06	1,832
1310669	9/9/22	12:25 PM	SYLVAN-BARNES	11	1831	20138.8	9/10/22	6:55 PM	FUSE_OH:B1136D-636 / BC / 40 A	0.021748	1.19E-05	1,831
1311258	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1829	1828.833	9/10/22	7:53 PM	FUSE_OH:B1427B-211 / BC / 6 A	0.001975	1.08E-06	1,829
1311247	9/9/22	1:23 PM	DILLEY-DILLEY 13	6	1828	10966.9	9/10/22	7:50 PM	TRIP_SAVER:B1434B-351 / C / 40 A	0.011843	6.48E-06	1,828
1310568	9/9/22	12:23 PM	SYLVAN-PATTON	23	1826	41994.17	9/10/22	6:48 PM	FUSE_OH:D1106C-675 / ABC / 100 A	0.04535	2.48E-05	1,826
1310757	9/9/22	12:10 PM	REDLAND-REDLAND 13	43	1823	78401.9	9/10/22	6:33 PM	FUSE_OH:D2224C-1765 / A / 65 A	0.084667	4.64E-05	1,823
1310756	9/9/22	12:10 PM	REDLAND-REDLAND 13	87	1823	158625.7	9/10/22	6:33 PM	FUSE_OH:D2223D-1063 / ABC / 100 A	0.171302	9.4E-05	1,823
1311256	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	4	1823	7291.933	9/10/22	7:47 PM	FUSE_OH:B1427B-212 / A / 40 A	0.007875	4.32E-06	1,823
1310789	9/9/22	12:55 PM	WILLAMINA-BUELL	380	1821	692030.7	9/10/22	7:16 PM	FUSE_OH:C6604B-99 / ABC / 65 A	0.747333	0.00041	1,821
1310701	9/9/22	12:10 PM	REDLAND-REDLAND 13	1	1820	1820.05	9/10/22	6:30 PM	FUSE_OH:D2236B-7205 / A / 65 A	0.001965	1.08E-06	1,820
1313256	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	6	1819	10914	9/10/22	10:59 PM	TRIP_SAVER:C2423C-490 / B / 40 A	0.011786	6.48E-06	1,819
1310200	9/9/22	1:03 PM	BANKS-BANKS 13	83	1819	150977	9/10/22	7:22 PM	FUSE_OH:B2332A-95 / ABC / 65 A	0.163042	8.96E-05	1,819
1310678	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1816	3632.333	9/10/22	6:26 PM	FUSE_OH:D2236B-786 / C / 65 A	0.003923	2.16E-06	1,816
1311414	9/9/22	1:47 PM	WILLAMINA-BUELL	17	1815	30856.98	9/10/22	8:02 PM	FUSE_OH:C6620C-301 / A / 40 A	0.033323	1.84E-05	1,815
1311257	9/9/22	1:23 PM	DILLEY-DILLEY 13	12	1815	21781.2	9/10/22	7:38 PM	TRIP_SAVER:B1427C-601 / B / 65 A	0.023522	1.3E-05	1,815
1311252	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	25	1814	45361.25	9/10/22	7:39 PM	FUSE_OH:B1421D-234 / ABC / 40 A	0.048986	2.7E-05	1,814
1310923	9/9/22	1:00 PM	BANKS-CEDAR CANYON	3	1813	5438.15	9/10/22	7:12 PM	FUSE_OH:B2424D-581 / BC / 40 A	0.005873	3.24E-06	1,813
1310677	9/9/22	12:10 PM	REDLAND-REDLAND 13	3	1811	5432.5	9/10/22	6:20 PM	FUSE_OH:D2236C-785 / C / 65 A	0.005867	3.24E-06	1,811
1311250	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	1811	1810.75	9/10/22	7:33 PM	FUSE_OH:B1434B-355 / C / 65 A	0.001955	1.08E-06	1,811
1310065	9/9/22	10:18 AM	SCOTTS MILLS-SCOTTS MILLS 13	66	1810	119454.5	9/10/22	4:28 PM	TRIP_SAVER:D6115D-2059 / B / 65 A	0.129	7.13E-05	1,810
1310679	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1808	3615.5	9/10/22	6:17 PM	FUSE_OH:D2236C-785 / A / 65 A	0.003904	2.16E-06	1,808
1311249	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1806	1806.267	9/10/22	7:31 PM	FUSE_OH:B1421B-190 / A / 40 A	0.001951	1.08E-06	1,806
1311411	9/9/22	1:47 PM	WILLAMINA-BUELL	4	1805	7219.8	9/10/22	7:51 PM	FUSE_OH:C6619A-282 / C / 40 A	0.007797	4.32E-06	1,805
1311251	9/9/22	1:23 PM	DILLEY-DILLEY 13	6	1804	10824.1	9/10/22	7:27 PM	FUSE_OH:B1434B-359 / AC / 65 A	0.011689	6.48E-06	1,804
1311253	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	1804	1803.983	9/10/22	7:26 PM	FUSE_OH:B1434B-359 / C / 40 A	0.001948	1.08E-06	1,804
1313768	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	16	1804	28862.67	9/10/22	5:37 PM	FUSE_OH:B2230A-113 / AB / 65 A	0.031169	1.73E-05	1,804
1311410	9/9/22	1:47 PM	WILLAMINA-BUELL	5	1803	9017.167	9/10/22	7:50 PM	FUSE_OH:C6619A-282 / A / 40 A	0.009738	5.4E-06	1,803
1311358	9/9/22	1:45 PM	SHERIDAN-KADELL	1	1803	1802.917	9/10/22	7:47 PM	FUSE_OH:C5633A-686 / AC / 10 A	0.001947	1.08E-06	1,803
1310068	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	1	1803	1802.7	9/10/22	4:30 PM	FUSE_OH:D6115D-255 / A / 6 A	0.001947	1.08E-06	1,803
1313201	9/9/22	3:59 PM	YAMHILL-CARLTON	31	1802	55865.1	9/10/22	10:01 PM	RECL:8207	0.060329	3.35E-05	1,802
1313769	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	201	1801	362054.6	9/10/22	5:35 PM	FUSE_OH:B2230A-124 / ABC / 65 A	0.390987	0.000217	1,801
1310115	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	3	1800	5400.6	9/10/22	4:28 PM	FUSE_OH:D6122A-50 / B / 40 A	0.005832	3.24E-06	1,800
1313291	9/9/22	1:15 PM	NORTH PLAINS-NORTH PLAINS 13	387	1800	696658.1	9/10/22	7:15 PM	FUSE_OH:B2327D-149 / ABC / 65 A	0.75233	0.000418	1,800
1310102	9/9/22	10:28 AM	SCOTTS MILLS-SCOTTS MILLS 13	2	1800	3600.267	9/10/22	4:28 PM	FUSE_OH:D6115D-923 / B / 15 A	0.003888	2.16E-06	1,800
1310388	9/9/22	12:09 PM	REDLAND-REDLAND 13	241	1796	432916.3	9/10/22	6:05 PM	RECL:7299	0.467512	0.00026	1,796
1313259	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	2	1795	3590	9/10/22	10:35 PM	FUSE_OH:C2423C-493 / C / 40 A	0.003877	2.16E-06	1,795

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1313778	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	42	1792	75272.4	9/10/22	5:26 PM	FUSE_OH:B2221B-653 / A / 40 A	0.081288	4.54E-05	1,792
1311246	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	5	1792	8961	9/10/22	7:17 PM	FUSE_OH:B1421B-749 / BC / 40 A	0.009677	5.4E-06	1,792
1313251	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	2	1791	3582.867	9/10/22	10:31 PM	FUSE_OH:C2423C-484 / C / 40 A	0.003869	2.16E-06	1,791
1310675	9/9/22	12:10 PM	REDLAND-REDLAND 13	1	1787	1786.667	9/10/22	5:56 PM	FUSE_OH:D2236C-783 / C / 10 A	0.001929	1.08E-06	1,787
1310389	9/9/22	12:10 PM	REDLAND-REDLAND 13	313	1786	559164.1	9/10/22	5:56 PM	RECL:1232	0.603848	0.000338	1,786
1310759	9/9/22	12:10 PM	REDLAND-REDLAND 13	5	1786	8930	9/10/22	5:56 PM	FUSE_OH:D2223A-621 / B / 65 A	0.009644	5.4E-06	1,786
1310753	9/9/22	12:10 PM	REDLAND-REDLAND 13	2	1786	3572	9/10/22	5:56 PM	FUSE_OH:D2223D-4779 / A / 65 A	0.003857	2.16E-06	1,786
1316140	9/9/22	8:24 PM	BANKS-BANKS 13	18	1786	32142.3	9/11/22	2:10 AM	FUSE_OH:B1307B-3276 / ABC / 65 A	0.034711	1.94E-05	1,786
1312249	9/9/22	1:49 PM	WILLAMINA-BRIDGE	16	1785	28565.07	9/10/22	7:34 PM	FUSE_OH:C5726D-399 / AC / 40 A	0.030848	1.73E-05	1,785
1311405	9/9/22	1:47 PM	WILLAMINA-BUELL	62	1783	110542.9	9/10/22	7:29 PM	FUSE_OH:C6713B-1689 / ABC / 65 A	0.119377	6.7E-05	1,783
1311245	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	5	1781	8904.833	9/10/22	7:05 PM	FUSE_OH:B1416C-183 / AB / 25 A	0.009616	5.4E-06	1,781
1311294	9/9/22	1:45 PM	SHERIDAN-EAST	13	1779	23130.25	9/10/22	7:24 PM	XFM_OH:C 15 3928	0.024979	1.4E-05	1,779
1311333	9/9/22	1:45 PM	SHERIDAN-KADELL	106	1779	188584.6	9/10/22	7:24 PM	FUSE_OH:C5634C-280 / AC / 65 A	0.203655	0.000114	1,779
1310667	9/9/22	12:25 PM	SYLVAN-BARNES	28	1777	49742	9/10/22	6:01 PM	FUSE_OH:B1136C-690 / B / 25 A	0.053717	3.02E-05	1,777
1311191	9/9/22	1:23 PM	DILLEY-DILLEY 13	14	1773	24825.03	9/10/22	6:56 PM	FUSE_OH:C1402C-771 / ABC / 65 A	0.026809	1.51E-05	1,773
1311200	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	11	1770	19469.45	9/10/22	6:54 PM	FUSE_OH:B1417D-173 / ABC / 40 A	0.021025	1.19E-05	1,770
1312247	9/9/22	1:49 PM	WILLAMINA-BRIDGE	4	1769	7076.8	9/10/22	7:18 PM	FUSE_OH:C5726D-399 / C / 25 A	0.007642	4.32E-06	1,769
1313247	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	2	1769	3538	9/10/22	10:09 PM	FUSE_OH:C2427A-471 / C / 6 A	0.003821	2.16E-06	1,769
1311185	9/9/22	1:23 PM	DILLEY-DILLEY 13	4	1769	7075.733	9/10/22	6:51 PM	FUSE_OH:C1411A-242 / AB / 40 A	0.007641	4.32E-06	1,769
1313762	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	131	1767	231520.7	9/10/22	5:01 PM	FUSE_OH:B2229B-80 / ABC / 65 A	0.250022	0.000141	1,767
1313245	9/9/22	4:40 PM	YAMHILL-YAMHILL 13	3	1764	5293.35	9/10/22	10:04 PM	FUSE_OH:C2427D-468 / C / 25 A	0.005716	3.24E-06	1,764
1311183	9/9/22	1:23 PM	DILLEY-DILLEY 13	21	1763	37022.65	9/10/22	6:45 PM	FUSE_OH:C1412B-602 / ABC / 65 A	0.039981	2.27E-05	1,763
1312246	9/9/22	1:49 PM	WILLAMINA-BRIDGE	1	1763	1762.733	9/10/22	7:11 PM	FUSE_OH:C5725C-389 / AC / 15 A	0.001904	1.08E-06	1,763
1310666	9/9/22	12:25 PM	SYLVAN-BARNES	8	1760	14082.53	9/10/22	5:45 PM	FUSE_OH:B1136C-1320 / B / 25 A	0.015208	8.64E-06	1,760
1311165	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	20	1757	35147	9/10/22	6:42 PM	FUSE_OH:B1403C-312 / AC / 40 A	0.037956	2.16E-05	1,757
1312197	9/9/22	1:49 PM	WILLAMINA-BRIDGE	4	1756	7025.667	9/10/22	7:05 PM	FUSE_OH:C5725C-382 / AB / 40 A	0.007587	4.32E-06	1,756
1310800	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	3	1754	5262.15	9/10/22	6:00 PM	FUSE_OH:B1106B-17 / A / 25 A	0.005683	3.24E-06	1,754
1310801	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	7	1754	12275.9	9/10/22	5:59 PM	FUSE_OH:B1106B-17 / C / 25 A	0.013257	7.56E-06	1,754
1310803	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	18	1753	31550.4	9/10/22	5:58 PM	FUSE_OH:B2131C-969 / C / 65 A	0.034072	1.94E-05	1,753
1312195	9/9/22	1:49 PM	WILLAMINA-BRIDGE	8	1750	13997.2	9/10/22	6:58 PM	FUSE_OH:C5736B-126 / BC / 40 A	0.015116	8.64E-06	1,750
1312194	9/9/22	1:49 PM	WILLAMINA-BRIDGE	1	1748	1748.117	9/10/22	6:57 PM	FUSE_OH:C5736C-376 / B / 6 A	0.001888	1.08E-06	1,748
1311181	9/9/22	1:23 PM	DILLEY-DILLEY 13	7	1745	12216.17	9/10/22	6:28 PM	FUSE_OH:C1412C-534 / ABC / 65 A	0.013192	7.56E-06	1,745
1310764	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	205	1744	357472.2	9/10/22	5:49 PM	RECL:4451	0.386039	0.000221	1,744
1310802	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	3	1743	5229	9/10/22	5:49 PM	FUSE_OH:B1106B-1863 / A / 6 A	0.005647	3.24E-06	1,743
1311164	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	2	1742	3483.4	9/10/22	6:26 PM	FUSE_OH:B1404D-63 / A / 25 A	0.003762	2.16E-06	1,742
1311198	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1742	1741.55	9/10/22	6:26 PM	FUSE_OH:B1417A-170 / A / 6 A	0.001881	1.08E-06	1,742
1310543	9/9/22	12:23 PM	SYLVAN-PATTON	145	1741	252464.3	9/10/22	5:24 PM	RECL:7464	0.272639	0.000157	1,741
1313777	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	4	1741	6964.467	9/10/22	4:35 PM	FUSE_OH:B2221B-651 / A / 40 A	0.007521	4.32E-06	1,741
1311402	9/9/22	1:47 PM	WILLAMINA-BUELL	5	1740	8701.25	9/10/22	6:47 PM	FUSE_OH:C6714A-3 / A / 40 A	0.009397	5.4E-06	1,740
1312111	9/9/22	1:49 PM	WILLAMINA-BRIDGE	1	1740	1739.767	9/10/22	6:48 PM	FUSE_OH:C5736D-372 / ABC / 40 A	0.001879	1.08E-06	1,740
1311341	9/9/22	1:45 PM	SHERIDAN-KADELL	2	1739	3478.333	9/10/22	6:44 PM	FUSE_OH:C6604A-1025 / C / 6 A	0.003756	2.16E-06	1,739
1310548	9/9/22	12:24 PM	SYLVAN-BARNES	75	1739	130418.8	9/10/22	5:22 PM	RECL:9883	0.140841	8.1E-05	1,739
1311196	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1738	1737.683	9/10/22	6:22 PM	FUSE_OH:B1417A-167 / A / 40 A	0.001877	1.08E-06	1,738
1313306	9/9/22	1:15 PM	NORTH PLAINS-NORTH PLAINS 13	19	1738	33014.72	9/10/22	6:13 PM	FUSE_OH:B2327D-138 / ABC / 40 A	0.035653	2.05E-05	1,738
1310560	9/9/22	12:25 PM	SYLVAN-BARNES	26	1736	45137.73	9/10/22	5:21 PM	RECL:9881	0.048745	2.81E-05	1,736
1311160	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	2	1735	3469.667	9/10/22	6:19 PM	FUSE_OH:B1409B-69 / B / 25 A	0.003747	2.16E-06	1,735
1311340	9/9/22	1:45 PM	SHERIDAN-KADELL	2	1734	3468.067	9/10/22	6:39 PM	FUSE_OH:C5634C-424 / A / 6 A	0.003745	2.16E-06	1,734
1310927	9/9/22	1:00 PM	BANKS-CEDAR CANYON	2	1733	3466.767	9/10/22	5:53 PM	FUSE_OH:B2319C-38 / C / 65 A	0.003744	2.16E-06	1,733
1313221	9/9/22	2:57 PM	YAMHILL-YAMHILL 13	133	1732	230373.7	9/10/22	7:49 PM	RECL:1816	0.248783	0.000144	1,732
1311194	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1731	1730.8	9/10/22	6:15 PM	FUSE_OH:B1417A-162 / A / 6 A	0.001869	1.08E-06	1,731

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1311336	9/9/22	1:45 PM	SHERIDAN-KADELL	1	1730	1730.083	9/10/22	6:35 PM	FUSE_OH:C5634C-1307 / AB / 65 A	0.001868	1.08E-06	1,730
1311179	9/9/22	1:23 PM	DILLEY-DILLEY 13	58	1730	100341	9/10/22	6:13 PM	FUSE_OH:C1413A-2471 / ABC / 65 A	0.108359	6.26E-05	1,730
1311161	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	8	1729	13835.33	9/10/22	6:14 PM	FUSE_OH:B1409B-520 / AC / 25 A	0.014941	8.64E-06	1,729
1311159	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1729	1729.233	9/10/22	6:14 PM	FUSE_OH:B1409B-76 / A / 6 A	0.001867	1.08E-06	1,729
1311190	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1728	1728.3	9/10/22	6:13 PM	FUSE_OH:B1417A-1294 / C / 40 A	0.001866	1.08E-06	1,728
1311397	9/9/22	1:47 PM	WILLAMINA-BUELL	18	1728	31096.2	9/10/22	6:34 PM	FUSE_OH:C6712C-19 / ABC / 100 A	0.033581	1.94E-05	1,728
1312110	9/9/22	1:49 PM	WILLAMINA-BRIDGE	148	1727	255600.9	9/10/22	6:36 PM	FUSE_OH:C5736D-832 / ABC / 65 A	0.276027	0.00016	1,727
1311335	9/9/22	1:45 PM	SHERIDAN-KADELL	1	1723	1722.65	9/10/22	6:27 PM	FUSE_OH:C5634C-1299 / BC / 65 A	0.00186	1.08E-06	1,723
1310773	9/9/22	12:39 PM	DURHAM-DURHAM 13	1	1720	1720.033	9/10/22	5:19 PM	SP:14140 SW 72ND AVE	0.001857	1.08E-06	1,720
1312446	9/9/22	12:39 PM	DURHAM-DURHAM 13	71	1720	122099.9	9/10/22	5:18 PM	SW_OHLB:6744	0.131857	7.67E-05	1,720
1311184	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	3	1719	5157	9/10/22	6:04 PM	FUSE_OH:B1408D-155 / ABC / 6 A	0.005569	3.24E-06	1,719
1313772	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	5	1719	8594.917	9/10/22	4:12 PM	FUSE_OH:B2220C-138 / C / 25 A	0.009282	5.4E-06	1,719
1311332	9/9/22	1:45 PM	SHERIDAN-KADELL	4	1718	6870.333	9/10/22	6:22 PM	FUSE_OH:C5634D-1201 / C / 65 A	0.007419	4.32E-06	1,718
1311157	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	2	1715	3429.533	9/10/22	5:59 PM	FUSE_OH:B1409B-78 / BC / 25 A	0.003704	2.16E-06	1,715
1311330	9/9/22	1:45 PM	SHERIDAN-KADELL	4	1711	6845.733	9/10/22	6:16 PM	FUSE_OH:C5634A-1114 / C / 6 A	0.007393	4.32E-06	1,711
1313771	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	1	1711	1711.017	9/10/22	4:05 PM	FUSE_OH:B2220C-129 / C / 6 A	0.001848	1.08E-06	1,711
1311156	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	3	1711	5132.5	9/10/22	5:55 PM	FUSE_OH:B1409B-81 / BC / 25 A	0.005543	3.24E-06	1,711
1311182	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	2	1710	3420.067	9/10/22	5:55 PM	FUSE_OH:B1408C-152 / A / 40 A	0.003693	2.16E-06	1,710
1311178	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	7	1707	11951.33	9/10/22	5:52 PM	FUSE_OH:B1408C-146 / AB / 40 A	0.012906	7.56E-06	1,707
1311177	9/9/22	1:23 PM	DILLEY-DILLEY 13	8	1706	13650.13	9/10/22	5:49 PM	FUSE_OH:C1413B-2466 / AB / 25 A	0.014741	8.64E-06	1,706
1311175	9/9/22	1:23 PM	DILLEY-DILLEY 13	3	1706	5117.1	9/10/22	5:48 PM	FUSE_OH:C1413B-2466 / B / 40 A	0.005526	3.24E-06	1,706
1311155	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	36	1705	61371.6	9/10/22	5:49 PM	FUSE_OH:B1405D-87 / AB / 25 A	0.066276	3.89E-05	1,705
1311176	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1703	1703.3	9/10/22	5:48 PM	FUSE_OH:B1408C-143 / C / 6 A	0.001839	1.08E-06	1,703
1311174	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1703	1703	9/10/22	5:48 PM	FUSE_OH:B1408C-143 / BC / 6 A	0.001839	1.08E-06	1,703
1311146	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	9	1695	15253.35	9/10/22	5:39 PM	FUSE_OH:B1408B-118 / AC / 40 A	0.016472	9.72E-06	1,695
1311172	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	1693	1693.033	9/10/22	5:36 PM	FUSE_OH:C1413C-259 / ABC / 40 A	0.001828	1.08E-06	1,693
1310868	9/9/22	1:08 PM	WILLAMINA-BRIDGE	269	1693	455403.6	9/10/22	5:21 PM	FUSE_OH:C6701D-514 / ABC / 100 A	0.491796	0.00029	1,693
1311154	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	3	1691	5072.7	9/10/22	5:35 PM	FUSE_OH:B1405C-99 / A / 25 A	0.005478	3.24E-06	1,691
1313760	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	10	1688	16882.17	9/10/22	3:42 PM	FUSE_OH:B2230D-53 / B / 65 A	0.018231	1.08E-05	1,688
1311170	9/9/22	1:23 PM	DILLEY-DILLEY 13	45	1687	75933.75	9/10/22	5:30 PM	FUSE_OH:C1413C-1001 / ABC / 100 A	0.082002	4.86E-05	1,687
1314378	9/9/22	1:00 PM	BANKS-CEDAR CANYON	53	1681	89085.05	9/10/22	5:00 PM	FUSE_OH:B2330C-547 / ABC / 100 A	0.096204	5.72E-05	1,681
1311417	9/9/22	1:47 PM	WILLAMINA-BUELL	3	1677	5031.45	9/10/22	5:44 PM	FUSE_OH:C6606B-376 / C / 10 A	0.005434	3.24E-06	1,677
1311499	9/9/22	2:17 PM	SHERIDAN-EAST	16	1674	26785.87	9/10/22	6:11 PM	XFM_OH:B 25 62946	0.028926	1.73E-05	1,674
1313730	9/9/22	1:03 PM	BANKS-BANKS 13	123	1672	205656	9/10/22	4:55 PM	SW_OHLB:3812	0.22209	0.000133	1,672
1311465	9/9/22	2:17 PM	SHERIDAN-EAST	2	1672	3343.533	9/10/22	6:09 PM	FUSE_OH:C5601A-107 / B / 15 A	0.003611	2.16E-06	1,672
1311458	9/9/22	2:17 PM	SHERIDAN-EAST	2	1672	3343.5	9/10/22	6:09 PM	FUSE_OH:C5601A-109 / B / 6 A	0.003611	2.16E-06	1,672
1313759	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	1	1671	1671.3	9/10/22	3:25 PM	FUSE_OH:B2230D-47 / AC / 6 A	0.001805	1.08E-06	1,671
1311628	9/9/22	1:49 PM	WILLAMINA-BRIDGE	2	1669	3338.333	9/10/22	5:38 PM	FUSE_OH:C6701A-1052 / B / 100 A	0.003605	2.16E-06	1,669
1312827	9/9/22	3:58 PM	YAMHILL-CARLTON	6	1669	10011.6	9/10/22	7:47 PM	FUSE_OH:C3429C-2324 / A / 6 A	0.010812	6.48E-06	1,669
1312646	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	334	1664	555848.4	9/10/22	6:14 PM	FUSE_OH:C1426C-2636 / ABC / 100 A	0.600268	0.000361	1,664
1310915	9/9/22	1:03 PM	BANKS-BANKS 13	3	1664	4992.35	9/10/22	4:47 PM	FUSE_OH:B2332A-93 / C / 65 A	0.005391	3.24E-06	1,664
1311275	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	7	1664	11646.13	9/10/22	5:08 PM	FUSE_OH:B2536D-8 / AC / 40 A	0.012577	7.56E-06	1,664
1311624	9/9/22	1:49 PM	WILLAMINA-BRIDGE	80	1663	133078.7	9/10/22	5:32 PM	FUSE_OH:C6701D-1055 / ABC / 100 A	0.143713	8.64E-05	1,663
1313224	9/9/22	3:59 PM	YAMHILL-CARLTON	1	1663	1662.7	9/10/22	7:41 PM	FUSE_OH:C3419D-628 / B / 6 A	0.001796	1.08E-06	1,663
1311723	9/9/22	1:49 PM	WILLAMINA-BRIDGE	1	1662	1662.267	9/10/22	5:31 PM	FUSE_OH:C6606B-40 / A / 40 A	0.001795	1.08E-06	1,662
1311420	9/9/22	1:47 PM	WILLAMINA-BUELL	17	1662	28246.35	9/10/22	5:28 PM	FUSE_OH:C6606A-1039 / ABC / 65 A	0.030504	1.84E-05	1,662
1313223	9/9/22	3:59 PM	YAMHILL-CARLTON	1	1659	1658.983	9/10/22	7:37 PM	FUSE_OH:C3419D-903 / C / 65 A	0.001792	1.08E-06	1,659
1313285	9/9/22	1:15 PM	NORTH PLAINS-NORTH PLAINS 13	2	1659	3317.667	9/10/22	4:54 PM	FUSE_OH:B2335B-121 / A / 40 A	0.003583	2.16E-06	1,659
1310908	9/9/22	1:03 PM	BANKS-BANKS 13	5	1656	8280	9/10/22	4:39 PM	FUSE_OH:B2331B-525 / A / 10 A	0.008942	5.4E-06	1,656
1310916	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	1656	1655.8	9/10/22	4:35 PM	FUSE_OH:B2330C-7 / BC / 65 A	0.001788	1.08E-06	1,656

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1311622	9/9/22	1:49 PM	WILLAMINA-BRIDGE	33	1654	54588.05	9/10/22	5:23 PM	FUSE_OH:C6701D-1057 / BC / 40 A	0.05895	3.56E-05	1,654
1313220	9/9/22	3:59 PM	YAMHILL-CARLTON	1	1654	1654.033	9/10/22	7:33 PM	FUSE_OH:C3420C-896 / C / 65 A	0.001786	1.08E-06	1,654
1313217	9/9/22	1:59 PM	YAMHILL-YAMHILL 13	73	1652	120569.2	9/10/22	5:31 PM	RECL:5611	0.130204	7.88E-05	1,652
1311292	9/9/22	1:43 PM	GRAND RONDE-AGENCY	143	1650	236009.6	9/10/22	5:13 PM	FUSE_OH:C6801D-216 / ABC / 65 A	0.25487	0.000154	1,650
1310907	9/9/22	1:03 PM	BANKS-BANKS 13	2	1648	3295.633	9/10/22	4:30 PM	FUSE_OH:B2331A-1693 / AC / 65 A	0.003559	2.16E-06	1,648
1311503	9/9/22	1:47 PM	WILLAMINA-BUELL	4	1647	6588.733	9/10/22	5:14 PM	FUSE_OH:C6604B-1028 / AC / 65 A	0.007115	4.32E-06	1,647
1313287	9/9/22	1:25 PM	NORTH PLAINS-NORTH PLAINS 13	2	1647	3294.233	9/10/22	4:52 PM	FUSE_OH:B2335B-121 / AB / 40 A	0.003557	2.16E-06	1,647
1311620	9/9/22	1:49 PM	WILLAMINA-BRIDGE	139	1645	228590.1	9/10/22	5:13 PM	FUSE_OH:C6701D-186 / AC / 100 A	0.246857	0.00015	1,645
1310896	9/9/22	1:03 PM	BANKS-BANKS 13	14	1643	23005.03	9/10/22	4:26 PM	FUSE_OH:B2331D-1191 / ABC / 65 A	0.024843	1.51E-05	1,643
1310910	9/9/22	1:03 PM	BANKS-BANKS 13	3	1641	4924.25	9/10/22	4:24 PM	FUSE_OH:B2332B-1694 / A / 10 A	0.005318	3.24E-06	1,641
1313284	9/9/22	1:25 PM	NORTH PLAINS-NORTH PLAINS 13	1	1641	1641.233	9/10/22	4:46 PM	FUSE_OH:B2335B-113 / ABC / 10 A	0.001772	1.08E-06	1,641
1311149	9/9/22	1:23 PM	DILLEY-DILLEY 13	118	1641	193594.7	9/10/22	4:43 PM	FUSE_OH:C1424A-983 / ABC / 65 A	0.209065	0.000127	1,641
1311427	9/9/22	1:47 PM	WILLAMINA-BUELL	1	1638	1638.167	9/10/22	5:05 PM	FUSE_OH:C5632C-1254 / C / 10 A	0.001769	1.08E-06	1,638
1310791	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	5	1636	8181.75	9/10/22	3:54 PM	FUSE_OH:B2324C-559 / AC / 15 A	0.008836	5.4E-06	1,636
1311498	9/9/22	1:47 PM	WILLAMINA-BUELL	4	1636	6544.933	9/10/22	5:03 PM	FUSE_OH:C6605A-728 / BC / 25 A	0.007068	4.32E-06	1,636
1310904	9/9/22	1:03 PM	BANKS-BANKS 13	3	1634	4902.45	9/10/22	4:17 PM	FUSE_OH:B2331A-284 / A / 6 A	0.005294	3.24E-06	1,634
1313280	9/9/22	1:25 PM	NORTH PLAINS-NORTH PLAINS 13	5	1630	8151.917	9/10/22	4:35 PM	FUSE_OH:B2335C-970 / AC / 40 A	0.008803	5.4E-06	1,630
1311494	9/9/22	1:47 PM	WILLAMINA-BUELL	6	1629	9776.5	9/10/22	4:56 PM	FUSE_OH:C6605D-1031 / C / 65 A	0.010558	6.48E-06	1,629
1311429	9/9/22	1:47 PM	WILLAMINA-BUELL	10	1627	16269.83	9/10/22	4:53 PM	FUSE_OH:C5632D-301 / B / 65 A	0.01757	1.08E-05	1,627
1311496	9/9/22	1:47 PM	WILLAMINA-BUELL	2	1624	3248.333	9/10/22	4:51 PM	FUSE_OH:C6605D-1032 / C / 6 A	0.003508	2.16E-06	1,624
1310788	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	15	1624	24362	9/10/22	3:42 PM	FUSE_OH:B2325A-562 / B / 25 A	0.026309	1.62E-05	1,624
1311618	9/9/22	1:49 PM	WILLAMINA-BRIDGE	12	1622	19467.8	9/10/22	4:51 PM	FUSE_OH:C6701D-182 / ABC / 40 A	0.021024	1.3E-05	1,622
1310922	9/9/22	1:03 PM	BANKS-BANKS 13	1	1621	1621.35	9/10/22	4:04 PM	FUSE_OH:B2333B-801 / ABC / 6 A	0.001751	1.08E-06	1,621
1311492	9/9/22	1:47 PM	WILLAMINA-BUELL	1	1620	1619.6	9/10/22	4:46 PM	FUSE_OH:C6605D-450 / C / 6 A	0.001749	1.08E-06	1,620
1312651	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	87	1619	140834.2	9/10/22	5:21 PM	FUSE_OH:C1435D-625 / BC / 65 A	0.152089	9.4E-05	1,619
1311486	9/9/22	1:47 PM	WILLAMINA-BUELL	1	1617	1616.867	9/10/22	4:43 PM	FUSE_OH:C6605C-1033 / C / 65 A	0.001746	1.08E-06	1,617
1311619	9/9/22	1:49 PM	WILLAMINA-BRIDGE	7	1617	11316.43	9/10/22	4:45 PM	FUSE_OH:C6701D-240 / B / 40 A	0.012221	7.56E-06	1,617
1311193	9/9/22	1:23 PM	DILLEY-DILLEY 13	2	1616	3231.5	9/10/22	4:18 PM	FUSE_OH:C1402B-3 / C / 40 A	0.00349	2.16E-06	1,616
1311615	9/9/22	1:49 PM	WILLAMINA-BRIDGE	15	1616	24235.25	9/10/22	4:44 PM	FUSE_OH:C6701D-588 / A / 65 A	0.026172	1.62E-05	1,616
1310787	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	9	1614	14522.25	9/10/22	3:31 PM	FUSE_OH:B2325A-578 / AB / 40 A	0.015683	9.72E-06	1,614
1311484	9/9/22	1:47 PM	WILLAMINA-BUELL	6	1612	9669.9	9/10/22	4:38 PM	FUSE_OH:C6605C-716 / ABC / 65 A	0.010443	6.48E-06	1,612
1311432	9/9/22	1:47 PM	WILLAMINA-BUELL	2	1612	3223	9/10/22	4:38 PM	FUSE_OH:C5632D-1244 / A / 10 A	0.003481	2.16E-06	1,612
1311614	9/9/22	1:49 PM	WILLAMINA-BRIDGE	41	1611	66037.33	9/10/22	4:39 PM	FUSE_OH:C6701D-704 / ABC / 65 A	0.071315	4.43E-05	1,611
1310796	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	27	1610	43457.85	9/10/22	3:27 PM	FUSE_OH:B2324C-36 / ABC / 65 A	0.046931	2.92E-05	1,610
1313276	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	3	1610	4828.5	9/10/22	3:27 PM	FUSE_OH:B2326D-416 / BC / 40 A	0.005214	3.24E-06	1,610
1313277	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	6	1609	9656.7	9/10/22	3:27 PM	FUSE_OH:B2325B-422 / C / 40 A	0.010428	6.48E-06	1,609
1311187	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	1609	1608.967	9/10/22	4:11 PM	FUSE_OH:C1411A-436 / B / 65 A	0.001738	1.08E-06	1,609
1310786	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	14	1607	22495.43	9/10/22	3:24 PM	FUSE_OH:B2325D-582 / C / 40 A	0.024293	1.51E-05	1,607
1310327	9/9/22	11:54 AM	SHERIDAN-EAST	1	1605	1604.7	9/10/22	2:39 PM	XFM_OH:B 15 11759	0.001733	1.08E-06	1,605
1311260	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	139	1603	222877.2	9/10/22	4:08 PM	FUSE_OH:B1406D-267 / AC / 65 A	0.240688	0.00015	1,603
1311485	9/9/22	1:47 PM	WILLAMINA-BUELL	1	1602	1602.2	9/10/22	4:29 PM	FUSE_OH:C6605C-719 / A / 65 A	0.00173	1.08E-06	1,602
1311038	9/9/22	1:15 PM	NORTH PLAINS-NORTH PLAINS 13	440	1600	703985.3	9/10/22	3:55 PM	RECL:3140	0.760243	0.000475	1,600
1310781	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	1	1598	1597.933	9/10/22	3:15 PM	FUSE_OH:B2336A-597 / A / 6 A	0.001726	1.08E-06	1,598
1311612	9/9/22	1:49 PM	WILLAMINA-BRIDGE	19	1595	30308.8	9/10/22	4:24 PM	FUSE_OH:C6701D-1008 / C / 65 A	0.032731	2.05E-05	1,595
1311180	9/9/22	1:23 PM	DILLEY-DILLEY 13	8	1592	12739.6	9/10/22	3:55 PM	FUSE_OH:C1413B-500 / ABC / 65 A	0.013758	8.64E-06	1,592
1313274	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	66	1592	105063.2	9/10/22	4:06 PM	FUSE_OH:B2326D-414 / ABC / 40 A	0.113459	7.13E-05	1,592
1316549	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	6	1592	9550.5	9/10/22	4:54 PM	XFM_OH:A 15 18975	0.010314	6.48E-06	1,592
1311611	9/9/22	1:49 PM	WILLAMINA-BRIDGE	6	1588	9525	9/10/22	4:16 PM	FUSE_OH:C6712A-171 / C / 65 A	0.010286	6.48E-06	1,588
1310241	9/9/22	11:32 AM	NORTH PLAINS-MASON HILL	75	1584	118818.8	9/10/22	1:56 PM	RECL:4529	0.128314	8.1E-05	1,584
1310784	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	124	1576	195374.4	9/10/22	4:45 PM	FUSE_OH:C1435D-627 / ABC / 65 A	0.210987	0.000134	1,576

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1311439	9/9/22	2:16 PM	SHERIDAN-EAST	28	1575	44103.27	9/10/22	4:32 PM	FUSE_OH:C5519B-226 / B / 40 A	0.047628	3.02E-05	1,575
1311171	9/9/22	1:23 PM	DILLEY-DILLEY 13	2	1571	3141.433	9/10/22	3:33 PM	FUSE_OH:C1413C-260 / C / 65 A	0.003392	2.16E-06	1,571
1312664	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	25	1570	39255.83	9/10/22	4:33 PM	TRIP_SAVER:C2402A-1 / B / 65 A	0.042393	2.7E-05	1,570
1313237	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	36	1569	56491.8	9/10/22	3:44 PM	RECL:3014	0.061006	3.89E-05	1,569
1311163	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	1	1569	1568.9	9/10/22	3:33 PM	FUSE_OH:B1409B-68 / AC / 25 A	0.001694	1.08E-06	1,569
1311186	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	5	1569	7844.5	9/10/22	3:33 PM	FUSE_OH:B1408D-155 / A / 40 A	0.008471	5.4E-06	1,569
1311034	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	114	1569	178839.4	9/10/22	3:33 PM	BKR:GALES CREEK R104	0.193131	0.000123	1,569
1311158	9/9/22	1:25 PM	GALES CREEK-GALES CREEK 13	2	1569	3137.5	9/10/22	3:33 PM	FUSE_OH:B1409B-77 / BC / 6 A	0.003388	2.16E-06	1,569
1312910	9/9/22	2:36 PM	AMITY-BELLEVUE	4	1564	6255.6	9/10/22	4:39 PM	FUSE_OH:C7601A-175 / B / 10 A	0.006756	4.32E-06	1,564
1312917	9/9/22	2:36 PM	AMITY-BELLEVUE	71	1563	111001.4	9/10/22	4:39 PM	FUSE_OH:C7601B-179 / ABC / 15 A	0.119872	7.67E-05	1,563
1312912	9/9/22	2:36 PM	AMITY-BELLEVUE	11	1563	17197.03	9/10/22	4:39 PM	FUSE_OH:C7601A-242 / AC / 15 A	0.018571	1.19E-05	1,563
1312918	9/9/22	2:36 PM	AMITY-BELLEVUE	2	1563	3125.467	9/10/22	4:38 PM	FUSE_OH:C7601B-287 / C / 10 A	0.003375	2.16E-06	1,563
1312911	9/9/22	2:36 PM	AMITY-BELLEVUE	1	1562	1562	9/10/22	4:38 PM	FUSE_OH:C7601A-141 / C / 15 A	0.001687	1.08E-06	1,562
1312909	9/9/22	2:36 PM	AMITY-BELLEVUE	1	1562	1562	9/10/22	4:38 PM	FUSE_OH:C7601A-7 / C / 6 A	0.001687	1.08E-06	1,562
1313279	9/9/22	1:25 PM	NORTH PLAINS-NORTH PLAINS 13	1	1562	1561.783	9/10/22	3:26 PM	FUSE_OH:B1302B-99 / C / 40 A	0.001687	1.08E-06	1,562
1313289	9/9/22	1:25 PM	NORTH PLAINS-NORTH PLAINS 13	2	1562	3123.567	9/10/22	3:26 PM	FUSE_OH:B2326C-946 / BC / 15 A	0.003373	2.16E-06	1,562
1311152	9/9/22	1:23 PM	DILLEY-DILLEY 13	7	1556	10894.92	9/10/22	3:19 PM	FUSE_OH:C1413C-542 / B / 40 A	0.011766	7.56E-06	1,556
1311606	9/9/22	1:49 PM	WILLAMINA-BRIDGE	2	1556	3111.4	9/10/22	3:44 PM	FUSE_OH:C6712A-98 / AB / 10 A	0.00336	2.16E-06	1,556
1313572	9/9/22	5:07 PM	ESTACADA-NORTH FORK	26	1555	40423.93	9/10/22	7:02 PM	RECL:2492	0.043654	2.81E-05	1,555
1310798	9/9/22	12:29 PM	NORTH PLAINS-MASON HILL	137	1552	212637.7	9/10/22	2:21 PM	FUSE_OH:B2324C-601 / AC / 100 A	0.22963	0.000148	1,552
1310473	9/9/22	12:18 PM	SPRINGBROOK-FERNWOOD	82	1551	127210.7	9/10/22	2:09 PM	FUSE_OH:C3201A-2042 / ABC / 65 A	0.137376	8.86E-05	1,551
1313261	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	7	1550	10847.32	9/10/22	3:24 PM	FUSE_OH:B2325C-406 / AC / 40 A	0.011714	7.56E-06	1,550
1313272	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	1	1550	1549.55	9/10/22	3:24 PM	FUSE_OH:B2325C-411 / ABC / 10 A	0.001673	1.08E-06	1,550
1313252	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	1	1549	1549.467	9/10/22	3:24 PM	FUSE_OH:B2336B-394 / B / 40 A	0.001673	1.08E-06	1,549
1313271	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	4	1549	6197.267	9/10/22	3:24 PM	FUSE_OH:B2325C-409 / A / 40 A	0.006693	4.32E-06	1,549
1313250	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	2	1549	3098.533	9/10/22	3:24 PM	FUSE_OH:B1301B-716 / ABC / 40 A	0.003346	2.16E-06	1,549
1313269	9/9/22	1:35 PM	NORTH PLAINS-NORTH PLAINS 13	1	1549	1549.167	9/10/22	3:24 PM	FUSE_OH:B2325C-409 / AC / 6 A	0.001673	1.08E-06	1,549
1310549	9/9/22	12:25 PM	SPRINGBROOK-FERNWOOD	1	1544	1543.883	9/10/22	2:09 PM	SP:16490 SW Brookman Rd	0.001667	1.08E-06	1,544
1311343	9/9/22	1:45 PM	SHERIDAN-KADELL	25	1543	38576.67	9/10/22	3:28 PM	FUSE_OH:C5635B-595 / ABC / 100 A	0.041659	2.7E-05	1,543
1311398	9/9/22	1:47 PM	WILLAMINA-BUELL	2	1543	3086.033	9/10/22	3:30 PM	FUSE_OH:C6713B-1563 / ABC / 100 A	0.003333	2.16E-06	1,543
1311408	9/9/22	1:47 PM	WILLAMINA-BUELL	18	1543	27773.7	9/10/22	3:29 PM	TRIP_SAVER:C6618C-275 / B / 40 A	0.029993	1.94E-05	1,543
1311394	9/9/22	1:47 PM	WILLAMINA-BUELL	5	1543	7714.917	9/10/22	3:29 PM	FUSE_OH:C6607C-229 / C / 65 A	0.008331	5.4E-06	1,543
1311426	9/9/22	1:47 PM	WILLAMINA-BUELL	2	1543	3085.9	9/10/22	3:29 PM	FUSE_OH:C6606A-1044 / ABC / 65 A	0.003333	2.16E-06	1,543
1311418	9/9/22	1:47 PM	WILLAMINA-BUELL	2	1543	3085.767	9/10/22	3:29 PM	FUSE_OH:C6606B-459 / BC / 10 A	0.003332	2.16E-06	1,543
1311413	9/9/22	1:47 PM	WILLAMINA-BUELL	2	1543	3085.767	9/10/22	3:29 PM	FUSE_OH:C6620C-301 / ABC / 65 A	0.003332	2.16E-06	1,543
1311299	9/9/22	1:47 PM	WILLAMINA-BUELL	81	1543	124969.5	9/10/22	3:29 PM	BKR:WILLAMINA R174	0.134956	8.75E-05	1,543
1311616	9/9/22	1:49 PM	WILLAMINA-BRIDGE	227	1543	350208	9/10/22	3:31 PM	FUSE_OH:C6701D-588 / ABC / 100 A	0.378194	0.000245	1,543
1311303	9/9/22	1:49 PM	WILLAMINA-BRIDGE	215	1543	331662.6	9/10/22	3:31 PM	BKR:WILLAMINA R178	0.358167	0.000232	1,543
1311147	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	1530	1530.167	9/10/22	2:53 PM	FUSE_OH:C1413D-978 / BC / 6 A	0.001652	1.08E-06	1,530
1311291	9/9/22	1:43 PM	GRAND RONDE-AGENCY	30	1526	45773.5	9/10/22	3:08 PM	FUSE_OH:C6801D-216 / B / 65 A	0.049431	3.24E-05	1,526
1311148	9/9/22	1:23 PM	DILLEY-DILLEY 13	1	1522	1521.933	9/10/22	2:44 PM	FUSE_OH:C1413D-978 / A / 65 A	0.001644	1.08E-06	1,522
1310790	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	2	1521	3042.2	9/10/22	1:59 PM	FUSE_OH:B2324C-560 / A / 40 A	0.003285	2.16E-06	1,521
1310779	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	1	1521	1520.883	9/10/22	1:58 PM	FUSE_OH:B2231C-29 / A / 6 A	0.001642	1.08E-06	1,521
1310792	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	1	1521	1520.867	9/10/22	1:58 PM	FUSE_OH:B2324C-560 / C / 6 A	0.001642	1.08E-06	1,521
1310704	9/9/22	12:38 PM	NORTH PLAINS-MASON HILL	47	1521	71475.25	9/10/22	1:58 PM	RECL:4528	0.077187	5.08E-05	1,521
1311145	9/9/22	1:23 PM	DILLEY-DILLEY 13	13	1519	19744.18	9/10/22	2:41 PM	FUSE_OH:C1318D-1433 / AB / 65 A	0.021322	1.4E-05	1,519
1312683	9/9/22	2:30 PM	SCOGGINS-LAURELWOOD	55	1511	83120.58	9/10/22	3:41 PM	FUSE_OH:C2306B-1 / BC / 65 A	0.089763	5.94E-05	1,511
1311143	9/9/22	1:23 PM	DILLEY-DILLEY 13	2	1510	3020.333	9/10/22	2:33 PM	FUSE_OH:C1318D-1433 / C / 65 A	0.003262	2.16E-06	1,510
1311348	9/9/22	1:45 PM	SHERIDAN-KADELL	34	1508	51256.13	9/10/22	2:52 PM	FUSE_OH:C5634A-502 / A / 100 A	0.055352	3.67E-05	1,508
1311195	9/9/22	1:23 PM	DILLEY-DILLEY 13	2	1501	3002.2	9/10/22	2:24 PM	FUSE_OH:C1403A-9 / C / 65 A	0.003242	2.16E-06	1,501

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1310977	9/9/22	1:23 PM	DILLEY-DILLEY 13	116	1501	174104.4	9/10/22	2:23 PM	RECL:4098	0.188018	0.000125	1,501
1311350	9/9/22	1:45 PM	SHERIDAN-KADELL	22	1500	32996.7	9/10/22	2:44 PM	FUSE_OH:C5634A-52 / ABC / 100 A	0.035634	2.38E-05	1,500
1310306	9/9/22	1:45 PM	SHERIDAN-KADELL	332	1500	497883.8	9/10/22	2:44 PM	FUSE_OH:C5635B-906 / ABC / 100 A	0.537671	0.000359	1,500
1312906	9/9/22	2:36 PM	AMITY-BELLEVUE	1	1483	1482.733	9/10/22	3:18 PM	FUSE_OH:C7506B-167 / A / 10 A	0.001601	1.08E-06	1,483
1312908	9/9/22	2:36 PM	AMITY-BELLEVUE	6	1480	8877.4	9/10/22	3:15 PM	TRIP_SAVER:C7506B-167 / B / 25 A	0.009587	6.48E-06	1,480
1312904	9/9/22	2:36 PM	AMITY-BELLEVUE	3	1472	4416.35	9/10/22	3:08 PM	TRIP_SAVER:C7506B-117 / A / 25 A	0.004769	3.24E-06	1,472
1316482	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	35	1469	51410.92	9/10/22	2:51 PM	OPEN POINT:C1435D-51 / ABC	0.055519	3.78E-05	1,469
1312653	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	33	1468	48457.2	9/10/22	2:51 PM	FUSE_OH:C1427A-661 / ABC / 65 A	0.05233	3.56E-05	1,468
1312517	9/9/22	2:23 PM	SCOGGINS-LAURELWOOD	169	1468	248128.6	9/10/22	2:51 PM	BKR:SCOGGINS R120	0.267957	0.000183	1,468
1312902	9/9/22	2:36 PM	AMITY-BELLEVUE	1	1463	1463.433	9/10/22	2:59 PM	FUSE_OH:C7506B-124 / A / 6 A	0.00158	1.08E-06	1,463
1312890	9/9/22	2:36 PM	AMITY-BELLEVUE	6	1455	8728.2	9/10/22	2:50 PM	FUSE_OH:C6531B-1172 / B / 25 A	0.009426	6.48E-06	1,455
1312887	9/9/22	2:36 PM	AMITY-BELLEVUE	2	1454	2907.967	9/10/22	2:49 PM	FUSE_OH:C6531B-341 / C / 6 A	0.00314	2.16E-06	1,454
1312884	9/9/22	2:36 PM	AMITY-BELLEVUE	2	1447	2894.267	9/10/22	2:43 PM	FUSE_OH:C6531A-360 / C / 15 A	0.003126	2.16E-06	1,447
1312877	9/9/22	2:36 PM	AMITY-BELLEVUE	3	1439	4316.25	9/10/22	2:34 PM	FUSE_OH:C6529B-622 / C / 6 A	0.004661	3.24E-06	1,439
1310901	9/9/22	1:10 PM	MIDWAY-DOUGLAS	4	1430	5721.533	9/10/22	1:01 PM	FUSE_OH:A1236C-1948 / C / 6 A	0.006179	4.32E-06	1,430
1313758	9/9/22	11:34 AM	NORTH PLAINS-MASON HILL	1	1424	1424.217	9/10/22	11:18 AM	FUSE_OH:B2231A-37 / C / 6 A	0.001538	1.08E-06	1,424
1311346	9/9/22	1:45 PM	SHERIDAN-KADELL	136	1424	193627.7	9/10/22	1:28 PM	FUSE_OH:C5635B-461 / ABC / 65 A	0.209101	0.000147	1,424
1312788	9/9/22	2:36 PM	AMITY-BELLEVUE	55	1423	78265	9/10/22	2:19 PM	RECL:7869	0.084519	5.94E-05	1,423
1311368	9/9/22	1:45 PM	SHERIDAN-KADELL	14	1405	19670	9/10/22	1:10 PM	FUSE_OH:C5635A-892 / A / 65 A	0.021242	1.51E-05	1,405
1311296	9/9/22	1:43 PM	GRAND RONDE-AGENCY	42	1398	58713.2	9/10/22	1:00 PM	FUSE_OH:C6801A-107 / B / 65 A	0.063405	4.54E-05	1,398
1311371	9/9/22	1:45 PM	SHERIDAN-KADELL	66	1397	92226.2	9/10/22	1:02 PM	FUSE_OH:C5635A-888 / ABC / 65 A	0.099596	7.13E-05	1,397
1311372	9/9/22	1:45 PM	SHERIDAN-KADELL	191	1397	266827	9/10/22	1:02 PM	FUSE_OH:C5635A-886 / ABC / 65 A	0.28815	0.000206	1,397
1311288	9/9/22	1:43 PM	GRAND RONDE-AGENCY	4	1367	5468	9/10/22	12:30 PM	FUSE_OH:C6812A-42 / B / 40 A	0.005905	4.32E-06	1,367
1311289	9/9/22	1:43 PM	GRAND RONDE-AGENCY	15	1365	20475	9/10/22	12:28 PM	FUSE_OH:C6812A-42 / AB / 40 A	0.022111	1.62E-05	1,365
1311370	9/9/22	1:45 PM	SHERIDAN-KADELL	1	1365	1365	9/10/22	12:30 PM	FUSE_OH:C5636B-265 / ABC / 40 A	0.001474	1.08E-06	1,365
1311361	9/9/22	1:45 PM	SHERIDAN-KADELL	163	1364	222386.3	9/10/22	12:29 PM	FUSE_OH:C5628D-145 / ABC / 100 A	0.240158	0.000176	1,364
1311366	9/9/22	1:45 PM	SHERIDAN-KADELL	2	1364	2728	9/10/22	12:29 PM	FUSE_OH:C5635A-894 / A / UNKNOWN	0.002946	2.16E-06	1,364
1311364	9/9/22	1:45 PM	SHERIDAN-KADELL	197	1364	268704.7	9/10/22	12:28 PM	FUSE_OH:C5635A-438 / BC / 65 A	0.290178	0.000213	1,364
1311285	9/9/22	1:45 PM	SHERIDAN-KADELL	352	1364	480057.6	9/10/22	12:28 PM	BKR:SHERIDAN R138	0.51842	0.00038	1,364
1311351	9/9/22	1:45 PM	SHERIDAN-KADELL	15	1363	20445	9/10/22	12:28 PM	FUSE_OH:C5634A-1012 / A / 65 A	0.022079	1.62E-05	1,363
1311352	9/9/22	1:45 PM	SHERIDAN-KADELL	9	1363	12267	9/10/22	12:28 PM	FUSE_OH:C5634B-1018 / A / 65 A	0.013247	9.72E-06	1,363
1311354	9/9/22	1:45 PM	SHERIDAN-KADELL	1	1363	1363	9/10/22	12:28 PM	FUSE_OH:C5634B-55 / ABC / 100 A	0.001472	1.08E-06	1,363
1311356	9/9/22	1:45 PM	SHERIDAN-KADELL	2	1363	2726	9/10/22	12:28 PM	FUSE_OH:C5633A-1197 / ABC / 15 A	0.002944	2.16E-06	1,363
1311331	9/9/22	1:45 PM	SHERIDAN-KADELL	1	1363	1363	9/10/22	12:28 PM	FUSE_OH:C5634D-688 / A / 6 A	0.001472	1.08E-06	1,363
1311286	9/9/22	1:43 PM	GRAND RONDE-AGENCY	28	1360	38080	9/10/22	12:23 PM	FUSE_OH:C6812A-36 / A / 40 A	0.041123	3.02E-05	1,360
1311510	9/9/22	2:13 PM	SHERIDAN-EAST	154	1359	209288.6	9/10/22	12:52 PM	RECL:3781	0.226013	0.000166	1,359
1311273	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	85	1359	115472.5	9/10/22	12:19 PM	BKR:GRAND RONDE R110	0.1247	9.18E-05	1,359
1311316	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	5	1358	6790	9/10/22	12:19 PM	FUSE_OH:C6708D-970 / AB / 65 A	0.007333	5.4E-06	1,358
1311317	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	1	1358	1358	9/10/22	12:19 PM	FUSE_OH:C6709C-444 / A / 6 A	0.001467	1.08E-06	1,358
1311318	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	1	1358	1358	9/10/22	12:19 PM	FUSE_OH:C6709C-443 / A / 6 A	0.001467	1.08E-06	1,358
1311325	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	4	1358	5432	9/10/22	12:19 PM	FUSE_OH:C6716A-1266 / A / 65 A	0.005866	4.32E-06	1,358
1311326	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	1	1358	1358	9/10/22	12:19 PM	FUSE_OH:C6715B-1260 / B / 6 A	0.001467	1.08E-06	1,358
1311327	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	2	1358	2716	9/10/22	12:19 PM	FUSE_OH:C6715A-1184 / A / 65 A	0.002933	2.16E-06	1,358
1311301	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	45	1358	61110	9/10/22	12:19 PM	FUSE_OH:C6812D-55 / AC / 65 A	0.065993	4.86E-05	1,358
1311302	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	7	1358	9506	9/10/22	12:19 PM	FUSE_OH:C6812D-52 / AC / 25 A	0.010266	7.56E-06	1,358
1311313	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	7	1358	9506	9/10/22	12:19 PM	FUSE_OH:C6708D-932 / C / 6 A	0.010266	7.56E-06	1,358
1311314	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	1	1358	1358	9/10/22	12:19 PM	FUSE_OH:C6708D-932 / C / 10 A	0.001467	1.08E-06	1,358
1311309	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	2	1358	2716	9/10/22	12:19 PM	FUSE_OH:C6707D-764 / A / 6 A	0.002933	2.16E-06	1,358
1311310	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	4	1358	5432	9/10/22	12:19 PM	FUSE_OH:C6708C-760 / ABC / 100 A	0.005866	4.32E-06	1,358
1311311	9/9/22	1:41 PM	GRAND RONDE-FORTHILL	2	1358	2716	9/10/22	12:19 PM	FUSE_OH:C6708C-758 / A / 40 A	0.002933	2.16E-06	1,358

**Attachment A Summary
of Outages 5 hours and longer PGE Service Territory
September 9, 2022**

Outage #	Outage Date	Outage Time	Feeder Name	Customers Affected	Duration	Customer Minutes	Return Date	Return Time	Interrupt Location	SAIDI	SAIFI	CAIDI
1311284	9/9/22	1:42 PM	GRAND RONDE-AGENCY	306	1351	413482.5	9/10/22	12:14 PM	BKR:GRAND RONDE R114	0.446525	0.00033	1,351
1312862	9/9/22	2:22 PM	SHERIDAN-EAST	16	1350	21600	9/10/22	12:52 PM	RECL:3781	0.023326	1.73E-05	1,350
1316012	9/9/22	2:09 PM	SHERIDAN-KADELL	1	1339	1338.933	9/10/22	12:28 PM	SP:22150 SW ROCK CREEK RD	0.001446	1.08E-06	1,339
1310680	9/9/22	12:36 PM	SIX CORNERS-13359	235	1326	311582.6	9/10/22	10:42 AM	FUSE_OH:C2132B-5031 / ABC / 140 A	0.336482	0.000254	1,326
1310799	9/9/22	12:56 PM	SIX CORNERS-13359	1	1306	1305.7	9/10/22	10:42 AM	SP:16387 SW VILLA RD	0.00141	1.08E-06	1,306
1313634	9/9/22	5:08 PM	WACONDA-RIVER	7	1282	8972.25	9/10/22	2:30 PM	FUSE_OH:C6302B-1359 / BC / 40 A	0.009689	7.56E-06	1,282
1310805	9/9/22	12:46 PM	ROCK CREEK-NEWBERRY	349	1203	420004.1	9/10/22	8:49 AM	FUSE_OH:B2131C-1410 / ABC / 65 A	0.453568	0.000377	1,203
1312882	9/9/22	4:07 PM	YAMHILL-YAMHILL 13	1	1164	1163.5	9/10/22	11:31 AM	SP:5222 NW Bridge Farmer Rd	0.001256	1.08E-06	1,164
1314715	9/9/22	11:17 PM	ESTACADA-ESTACADA 13	19	1132	21508	9/10/22	6:09 PM	RECL:1996	0.023227	2.05E-05	1,132
1312738	9/9/22	3:36 PM	WILSONVILLE-WEST	14	1016	14224.93	9/10/22	8:32 AM	FUSE_OH:C3225A-1729 / C / 25 A	0.015362	1.51E-05	1,016
1314060	9/9/22	5:43 PM	ROCK CREEK-FOREST PARK	2	964	1928.833	9/10/22	9:48 AM	XFM_OH:A 15 6850	0.002083	2.16E-06	964
1314064	9/9/22	5:48 PM	ROCK CREEK-FOREST PARK	1	961	960.5833	9/10/22	9:49 AM	SP:12525 NW Germantown Rd	0.001037	1.08E-06	961
1314326	9/9/22	6:12 PM	LIBERTY-ROSEDALE	70	948	66360	9/10/22	10:00 AM	FUSE_OH:C8333A-592 / ABC / 65 A	0.071663	7.56E-05	948
1310292	9/9/22	11:49 AM	WOODBURN-TOMLIN	3	947	2841.1	9/10/22	3:36 AM	FUSE_OH:C5118A-1976 / ABC / 100 A	0.003068	3.24E-06	947
1314500	9/9/22	8:26 PM	DUNNS CORNER-DUNNS CORNER 13	1	899	899.2333	9/10/22	11:26 AM	SP:32055 SE COMPTON RD	0.000971	1.08E-06	899
1314570	9/9/22	6:04 PM	SILVERTON-WEST	4	842	3367	9/10/22	8:05 AM	FUSE_OH:C7103C-621 / C / 6 A	0.003636	4.32E-06	842
1314480	9/9/22	7:44 PM	DENNY-WEST	1	836	835.9667	9/10/22	9:40 AM	SP:11975 SW CLIFFORD ST	0.000903	1.08E-06	836
1313750	9/9/22	5:23 PM	HILLSBORO-DAIRY CREEK	159	810	128819.2	9/10/22	6:53 AM	FUSE_OH:B1231C-578 / AB / 65 A	0.139113	0.000172	810
1313779	9/9/22	5:30 PM	HILLSBORO-DAIRY CREEK	1	804	803.6167	9/10/22	6:53 AM	SP:540 NE 2ND AVE	0.000868	1.08E-06	804
1312714	9/9/22	7:12 AM	SYLVAN-PATTON	68	792	53875.27	9/9/22	8:24 PM	FUSE_OH:D1107C-7679 / C / 100 A	0.058181	7.34E-05	792
1314835	9/9/22	10:55 PM	ROCK CREEK-FOREST PARK	3	792	2376.75	9/10/22	12:07 PM	FUSE_OH:B1109B-495 / A / 15 A	0.002567	3.24E-06	792
1312741	9/9/22	3:37 PM	RALEIGH HILLS-MONTCLAIR	77	711	54750.85	9/10/22	3:28 AM	TRIP_SAVER:C1114D-3701 / C / 65 A	0.059126	8.32E-05	711
1314525	9/9/22	5:23 PM	LIBERAL-LIBERAL 13	618	594	367164.1	9/10/22	3:17 AM	RECL:2027	0.396505	0.000667	594
1313789	9/9/22	5:36 PM	LIBERAL-LIBERAL 13	1	580	580.15	9/10/22	3:17 AM	SP:11563 S BARNARDS RD	0.000627	1.08E-06	580
1314680	9/9/22	10:39 PM	KELLY BUTTE-BINNSMEAD	2	571	1142.1	9/10/22	8:10 AM	SP:8827 SE TAYLOR ST	0.001233	2.16E-06	571
1312793	9/9/22	3:57 PM	CARVER-NORTH	1	558	558.1167	9/10/22	1:15 AM	SP:13461 SE HUBBARD TER	0.000603	1.08E-06	558
1309159	9/9/22	7:12 AM	SYLVAN-PATTON	67	454	30416.88	9/9/22	2:46 PM	FUSE_OH:D1107C-7679 / C / 100 A	0.032848	7.24E-05	454
1310979	9/9/22	1:22 PM	WALLACE-WALLACE 13	100	448	44800	9/9/22	8:50 PM	FUSE_OH:C7318C-5575 / ABC / 100 A	0.04838	0.000108	448
1310373	9/9/22	12:03 PM	SCHOLLS FERRY-RAINBOW	1	438	438.3167	9/9/22	7:21 PM	SP:19800 SW TILE FLAT RD	0.000473	1.08E-06	438
1312470	9/9/22	2:48 PM	REDLAND-HENRICI	14	429	6003.667	9/9/22	9:57 PM	FUSE_OH:D3212B-3336 / B / 25 A	0.006483	1.51E-05	429
1309047	9/9/22	5:15 AM	DAYTON-EAST	42	417	17527.3	9/9/22	12:12 PM	FUSE_OH:C4310B-965 / ABC / 65 A	0.018928	4.54E-05	417
1308851	9/9/22	3:28 AM	HARMONY-INTERNATIONAL	56	417	23364.13	9/9/22	10:25 AM	FUSE_OH:D1136C-2600 / C / 65 A	0.025231	6.05E-05	417
1310572	9/9/22	12:27 PM	CANBY-13644	18	383	6887.7	9/9/22	6:50 PM	FUSE_OH:D3122B-1863 / B / 25 A	0.007438	1.94E-05	383
1311596	9/9/22	2:24 PM	ESTACADA-ESTACADA 13	16	379	6066.933	9/9/22	8:43 PM	FUSE_OH:D3429A-1247 / B / 25 A	0.006552	1.73E-05	379
1311595	9/9/22	2:24 PM	ESTACADA-ESTACADA 13	3	379	1137.4	9/9/22	8:43 PM	XFM_OH:B 25 9801	0.001228	3.24E-06	379
1312456	9/9/22	2:45 PM	HOGAN NORTH-HOGAN NORTH 13	21	358	7515.9	9/9/22	8:43 PM	FUSE_OH:D1326C-953 / C / 40 A	0.008117	2.27E-05	358
1310405	9/9/22	12:03 PM	TWILIGHT-BREMER	2	357	714.4	9/9/22	6:00 PM	FUSE_OH:D3125D-1345 / AB / 15 A	0.000771	2.16E-06	357
1309251	9/9/22	8:00 AM	BEAVERTON-ALLEN	3	354	1062	9/9/22	1:54 PM	SP:12850 SW ALLEN BLVD_1	0.001147	3.24E-06	354
1314407	9/9/22	7:12 PM	HOLGATE-HOLGATE 13	1	343	343.2833	9/10/22	12:55 AM	SP:3366 SE WAVERLEIGH BLVD	0.000371	1.08E-06	343
1310391	9/9/22	12:10 PM	MAIN-RIVER	135	338	45630	9/9/22	5:48 PM	FUSE_OH:C1208C-6546 / ABC / 65 A	0.049276	0.000146	338
1309211	9/9/22	8:00 AM	BEAVERTON-ALLEN	18	334	6012	9/9/22	1:34 PM	XFM_OH:A 75 903	0.006492	1.94E-05	334
1310823	9/9/22	1:00 PM	BANKS-CEDAR CANYON	592	331	196109.9	9/9/22	6:31 PM	BKR:BANKS R116	0.211781	0.000639	331
1310891	9/9/22	1:00 PM	BANKS-CEDAR CANYON	1	331	331	9/9/22	6:31 PM	FUSE_OH:B2436A-3 / ABC / 6 A	0.000357	1.08E-06	331
1310892	9/9/22	1:00 PM	BANKS-CEDAR CANYON	2	331	662	9/9/22	6:31 PM	FUSE_OH:B2436A-2 / ABC / 25 A	0.000715	2.16E-06	331
1310879	9/9/22	1:00 PM	BANKS-CEDAR CANYON	8	331	2648	9/9/22	6:31 PM	FUSE_OH:B2331C-2209 / C / 100 A	0.00286	8.64E-06	331
1310880	9/9/22	1:00 PM	BANKS-CEDAR CANYON	4	331	1324	9/9/22	6:31 PM	FUSE_OH:B2331B-485 / ABC / 100 A	0.00143	4.32E-06	331
1310881	9/9/22	1:00 PM	BANKS-CEDAR CANYON	82	331	27142	9/9/22	6:31 PM	TRIP_SAVER:B2331B-488 / C / 65 A	0.029311	8.86E-05	331
1310887	9/9/22	1:00 PM	BANKS-CEDAR CANYON	14	331	4634	9/9/22	6:31 PM	FUSE_OH:B2331B-496 / AB / 100 A	0.005004	1.51E-05	331
1314321	9/9/22	6:09 PM	DELAWARE-LOMBARD	1	330	329.9833	9/9/22	11:39 PM	SP:7347 N PORTSMOUTH AVE	0.000356	1.08E-06	330
1311508	9/9/22	12:23 PM	MAIN-RIVER	1	325	324.75	9/9/22	5:48 PM	SP:1959 SE MORGAN RD	0.000351	1.08E-06	325