

RE 113 e-FILING REPORT COVER SHEET

REPORT NAME:

PGE 2014 Annual Reliability Report

COMPANY NAME:

Portland General Electric

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION?

Yes, will provide a CD to the OPUC of the designated material.

If known, please select designation:

RE (Electric)

Report is required by:

OAR 860-023-0151

Is this report associated with a specific docket/case?

No

Key words:

2014 Annual Reliability Report

If known, please select the PUC Section to which the report should be directed:

Electric Rates and Planning



**Portland General Electric Company**  
121 SW Salmon Street • Portland, Oregon 97204  
[PortlandGeneral.com](http://PortlandGeneral.com)

April 30, 2015

Public Utility Commission of Oregon  
Attn: Filing Center  
3930 Fairview Industrial Drive SE  
P.O. Box 1088  
Salem, OR 97308-1088

**RE: PGE 2014 Annual Reliability Report**

Pursuant to OAR 860-023-0151, PGE hereby submits the Company's annual report via electronic only; the 2014 Annual Reliability Report.

Attachment A provides Section III, Feeder Performance Summary and Section VIII 2014 Feeder Information which will be sent on a CD. Attachment A should be treated as a confidential submission under OAR 860-001-0070 and is provided in a separate sealed envelope marked "Confidential."

Should you have any questions or comments regarding this filing, please contact George Jones at (503) 570-4554.

Please direct all formal correspondence and requests to the following email address  
[pge.opuc.filings@pgn.com](mailto:pge.opuc.filings@pgn.com)

Sincerely,

A handwritten signature in black ink, appearing to read "Karla Wenzel".

Karla Wenzel  
Manager, Pricing and Tariffs

Enclosure  
cc: Lori Koho, OPUC



**Portland General Electric**  
**2014 Annual Reliability Report**



**January 1, 2014 through December 31, 2014**

## Section I

### Report Summary

The Annual Reliability Report provides distribution system performance information based on service interruptions to PGE customers. The report is utilized to understand the overall reliability of the distribution system and to identify areas of improvement and excellence. The information in this report is also used to inform the system performance values in the Service Quality Measure Report provided to the Oregon Public Utility Commission.

The overall performance of PGE's distribution system is represented by the following indices<sup>1</sup>: System Average Interruption Duration Index (SAIDI), System Average Interruption Frequency Index (SAIFI), and Momentary Average Interruption event Frequency Index <sup>2</sup> (MAIFIle).

PGE's distribution system performance calculations are based on the IEEE 1366 TMED (Threshold Major Event Day) methodology. The data utilized for the calculations is captured from PGE's Outage Management System (OMS) and confirmed via a multi-step evaluation process. The results of the calculations are evaluated on a monthly basis and confirmed via a standardized review process.

Per the PGE IEEE 1366 TMED methodology, PGE excluded the following dates <sup>3</sup> from the 2104 distribution system performance indices: January 11th, March 6th, September 24th, October 13th, October 25th - 26th, November 11th -13th, and December 11th, 2014.

---

<sup>1</sup> Details regarding the performance indices can be found in Reliability Measure Definitions section of the Appendix

<sup>2</sup> MAIFIle calculations are limited to feeders with remote monitoring equipment

<sup>3</sup> Details for the IEEE 1366 TMED methodology can be found in the Appendix section.

## Corporate Annual Summary Without Major Events

Year	Reported Outages	SAIFI Outages per Customer Served	SAIDI Average Annual Outage Duration per Customer (min)	MAIFIe Momentary Average Interruption Frequency Index
2014	5,832	0.69	93	1.3
2013	4,495	0.45	62	0.9
2012	5,093	0.55	72	1.1
2011	4,535	0.51	66	0.9

## Corporate Annual Summary With Major Events

Major Events	Year	Reported Outages	SAIFI Outages per Customer Served	SAIDI Average Annual Outage Duration per Customer (min)	MAIFIe Momentary Average Interruption Frequency Index
Yes	2014	7,696	1.20	245	1.3
Yes	2013	5,069	0.57	205	0.9
Yes	2012	6,051	0.72	136	1.1
Yes	2011	4,692	0.57	95	0.9

SAIDI numbers are rounded to the nearest whole number.

## 2014 Regional Annual Summary Without Major Events

Region	Reported Outages	SAIFI Outages per Customer Served	IEEE 1366/SAIDI Average Annual Outage Duration per Customer (min)	MAIFIle Momentary Average Interruption Frequency Index
CENTRAL	1,118	0.65	91	1.5
EASTERN	1,561	1.05	145	1.9
SOUTHERN	1,651	0.40	67	0.9
WESTERN	1,502	0.67	78	1.1
PGE:	<b>5,832</b>	<b>0.69</b>	<b>93</b>	<b>1.3</b>

## 2014 Regional Annual Summary With Major Events

Region	Reported Outages	SAIFI Outages per Customer Served	IEEE 1366/SAIDI Average Annual Outage Duration per Customer (min)	MAIFIle Momentary Average Interruption Frequency Index
CENTRAL	1,423	1.04	215	1.5
EASTERN	2,129	1.98	364	1.9
SOUTHERN	2,173	0.82	224	0.9
WESTERN	1,973	1.08	208	1.1
PGE:	<b>7,696</b>	<b>1.20</b>	<b>245</b>	<b>1.3</b>

Major Event = "Major Event" designates an event that exceeds the reasonable design and or operational limits of the electric power system. A "Major Event" includes at least one Major Event Day in which the daily SAIDI exceeds a threshold value, TMED.


NOTE: Major Event Days were: January 11th, March 6th, September 24th, October 13th, October 25th-26th, November 11th - 13th, and December 11th, 2014,

## Section II

### Outage Analysis

This section provides graphical representation of 2014 outage causes by both customer hours and event type. The intent of this section is to provide high-level analysis of the outages that result in the highest number of customer hours and the type of events with the highest frequency.

# Outages by Cause - Count -2014




<b>Equipment</b>	2416	41.4%
<b>Lightning</b>	112	1.9%
<b>Loss of Supply -</b>	83	1.4%
<b>Loss of Supply -</b>	20	0.3%
<b>Other</b>	12	0.2%
<b>Planned</b>	78	1.3%
<b>Public</b>	418	7.2%
<b>Unknown</b>	112	1.9%
<b>Vegetation</b>	1089	18.7%
<b>Weather</b>	682	11.7%
<b>Wildlife</b>	810	13.9%
<b>Total:</b>	5832	100.0%

<b>Equipment:</b>	<b>Total:</b>	<b>2416</b>	
Cutout/Fuse/Arrestor Failure	755	31.3%	
Meter Problem Failure	12	0.5%	
OH Clamp Failure	76	3.1%	
OH Conductor Failure	253	10.5%	
OH Transformer Failure	255	10.6%	
Pole Failure	4	0.2%	
Pole Hardware Failure	39	1.6%	
Protective Fuse Operation	245	10.1%	
Switch/Recloser Failure	20	0.8%	
UG Clamp Failure	1	0.0%	
UG Conductor Failure	577	23.9%	
UG Hardware Failure	30	1.2%	
UG Transformer Failure	149	6.2%	
<b>Vegetation:</b>	<b>Total:</b>	<b>1089</b>	
Equip Damage/Tree Cut/Felled	17	1.6%	
Hay On Line	2	0.2%	
Tree-Broken Limb/Top	992	91.1%	
Tree Uprooted	65	6.0%	
Tree-Burning	13	1.2%	

01/01/14 - 12/31/14

©Copyright, Portland General Electric, All Rights Reserved

## Outages by Cause Count -With MED -2014




Equipment	Count	Percentage
Cutout/Fuse/Arrestor Failure	769	30.9%
Meter Problem Failure	12	0.5%
OH Clamp Failure	79	3.2%
OH Conductor Failure	274	11.0%
OH Transformer Failure	258	10.4%
Pole Failure	5	0.2%
Pole Hardware Failure	41	1.6%
Protective Fuse Operation	252	10.1%
Switch/Recloser Failure	23	0.9%
UG Clamp Failure	1	0.0%
UG Conductor Failure	592	23.8%
UG Hardware Failure	30	1.2%
UG Transformer Failure	149	6.0%
<b>Total:</b>	<b>2485</b>	

Equipment:	Total:	2485	
Cutout/Fuse/Arrestor Failure	769	30.9%	
Meter Problem Failure	12	0.5%	
OH Clamp Failure	79	3.2%	
OH Conductor Failure	274	11.0%	
OH Transformer Failure	258	10.4%	
Pole Failure	5	0.2%	
Pole Hardware Failure	41	1.6%	
Protective Fuse Operation	252	10.1%	
Switch/Recloser Failure	23	0.9%	
UG Clamp Failure	1	0.0%	
UG Conductor Failure	592	23.8%	
UG Hardware Failure	30	1.2%	
UG Transformer Failure	149	6.0%	
Vegetation:	Total:	1259	
Equip Damage/Tree Cut/Felled	18	1.4%	
Hay On Line	2	0.2%	
Tree-Broken Limb/Top	1144	90.9%	
Tree-Uprooted	80	6.0%	
Tree-Burning	15	1.2%	

01/01/14 - 12/31/14

©Copyright, Portland General Electric, All Rights Reserved

## Outages by Cause - Customer Hours -2014




<b>Equipment</b>	334,559	24.8%
<b>Lightning</b>	38,912	2.9%
<b>Loss of Supply -</b>	217,118	16.1%
<b>Loss of Supply -</b>	49,130	3.6%
<b>Other</b>	6,221	0.5%
<b>Planned</b>	6,644	0.5%
<b>Public</b>	146,170	10.8%
<b>Unknown</b>	22,810	1.7%
<b>Vegetation</b>	281,929	20.9%
<b>Weather</b>	205,412	15.2%
<b>Wildlife</b>	39,403	2.9%
<b>Total:</b>	1,348,308	100.0%

<b>Equipment:</b>	<b>Total:</b>	<b>334,559</b>
Cutout/Fuse/Arrestor Failure	21,061	6.3%
Meter Problem Failure	164	0.0%
OH Clamp Failure	4,008	1.2%
OH Conductor Failure	92,905	27.8%
OH Transformer Failure	10,334	3.1%
Pole Failure	18	0.0%
Pole Hardware Failure	19,041	5.7%
Protective Fuse Operation	5,525	1.7%
Switch/Recloser Failure	13,964	4.2%
UG Clamp Failure	2	0.0%
UG Conductor Failure	133,327	39.9%
UG Hardware Failure	6,972	2.1%
UG Transformer Failure	27,238	8.1%
<b>Vegetation:</b>	<b>Total:</b>	<b>281,929</b>
Equip Damage/Tree Cut/Felled	3,390	1.2%
Hay On Line	35	0.0%
Tree-Broken Limb/Top	248,703	88.2%
Tree-Uprooted	27,019	10.0%
Tree-Burning	2,781	1.0%

01/01/14 - 12/31/14

©Copyright, Portland General Electric, All Rights Reserved

## Outages by Cause - Customer Hours -With MED - 2014



<b>Equipment</b>	420,902	11.9%
<b>Lightning</b>	41,939	1.2%
<b>Loss of Supply</b>	303,688	8.6%
<b>Loss of Supply</b>	49,130	1.4%
<b>Other</b>	6,137	0.2%
<b>Planned</b>	7,811	0.2%
<b>Public</b>	149,701	4.2%
<b>Unknown</b>	71,453	2.0%
<b>Vegetation</b>	459,416	13.0%
<b>Weather</b>	1,990,931	56.2%
<b>Wildlife</b>	39,520	1.1%
<b>Total:</b>	3,540,628	100.0%

<b>Equipment:</b>	<b>Total:</b>	<b>420,902</b>
Cutout/Fuse/Arrestor Failure	25,553	6.1%
Meter Problem Failure	164	0.0%
OH Clamp Failure	4,252	1.0%
OH Conductor Failure	113,457	27.0%
OH Transformer Failure	10,806	2.6%
Pole Failure	27	0.0%
Pole Hardware Failure	19,669	4.7%
Protective Fuse Operation	17,008	4.0%
Switch/Recloser Failure	60,890	14.5%
UG Clamp Failure	2	0.0%
UG Conductor Failure	134,886	32.0%
UG Hardware Failure	6,972	1.7%
UG Transformer Failure	27,238	6.5%
<b>Vegetation:</b>	<b>Total:</b>	<b>459,416</b>
Equip Damage/Tree Cut/Felled	3,551	0.8%
Hay On Line	35	0.0%
Tree-Uprooted	49,304	11.0%
Tree-Broken Limb/Top	394,499	85.9%
Tree-Burning	12,026	2.6%

01/01/14 - 12/31/14

©Copyright, Portland General Electric, All Rights Reserved

## SECTION III

### FEEDER PERFORMANCE SUMMARY

This section provides a summary of reliability indices by Region and Feeder. The list is sorted in alphabetical order by Region and Feeder Name. Each feeder is classified as one of the following:

P/R    Remote  
R      Rural  
U      Urban

#### Definition of Feeder Classifications

A feeder is designated Urban if 50% or more of the load is inside the Urban Growth Boundary (UGB)

A feeder is designated Rural if one or more of the following apply:

- The load on a feeder is greater than 0.5 MVA per square mile.
- A feeder has more than 100 customers per mile.
- A feeder is serving load inside an incorporated city.
- A feeder is directly adjacent to the UGB with feeder ties into the UGB.

A feeder is Remote if all conditions above do not apply.

The table below displays the individual feeder performance thresholds based on classification

Feeder Classification	SAIDI	SAIFI	MAIFIle
P/R Remote	7 hours (420 Minutes)	2.6 Occurrences	15
R – Rural	5 hours (300 Minutes)	2.6 Occurrences	10
U – Urban	2 hours (120 Minutes)	2.0 Occurrences	5

Attachment A  
PGE 2014 Annual Reliability Report

Confidential - Provided on CD Only  
Section III, Feeder Performance Summary  
Section VIII, 2014 Feeder Information

## **SECTION IV**

### **Outages by Cause-Natural**

This section provides the number of customer outages (frequency) and customer outage hours (duration) caused by natural events. The information is presented by feeder and attributed to one of the following causes:

- Adverse Weather
- Lightning
- Animals
- Tree Contacts (Preventable and Non-Preventable)
- Unknown

## 2014 Outages by Cause Natural

Page 1 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
1 ABERN-CLACK HTS															
2 ABERN-ORE CITY	9	590		1	5	1	36	3	14		4	535			
3 ABERNETHY-TRANSIT	6	1,613						4	1,577		2	36			
4 ALDER CT-ANKENY	3	133						3	133						
5 ALDER CT-IRVING															
6 ALDER CT-LINCOLN	7	1,956						5	554		2	1,401			
7 ALDER CT-STARK	2	2						2	2						
8 ALDER CT-TAYLOR	2	171									2	171			
9 ALDER CT-YAMHILL															
10 AMITY 13KV	18	821		6	697	4	10	2	3		4	101		2	10
11 AMITY-BELLEVUE	17	15,223		3	1,283	5	5,399	1	2		7	8,537		1	1
12 ARLETA-52ND ST	11	8,441		3	1,289			4	158		3	6,992		1	2
13 ARLETA-FOSTER	2	17						2	17						
14 ARLETA-HAROLD	4	165		2	77						2	88			
15 ARLETA-POWELL	2	587		1	546			1	42						
16 ARLETA-STEELE	7	625				1	35	5	205		1	385			
17 B LAKE-SUNDIAL	1	468												1	468
18 B LAKE-TOYOTNSO															
19 BANKS 13KV	10	367		2	100	3	29	1	1		4	238			
20 BANKS-CEDAR CYN	16	808		5	234			1	4		10	570			
21 BARNES-BATLCLKR	2	106						1	96		1	10			
22 BARNES-BOONE	1	108									1	108			
23 BARNES-COMMERCL	7	285		4	27	1	7	1	3		1	247			
24 BARNES-SUNNYSID	6	531		5	529			1	1						
25 BELL-FLAVEL	3	69						1	9		2	60			
26 BELL-JOHNSN CRK															
27 BELL-KENDALL	4	86						3	79					1	7
28 BELL-KING	4	7,775		2	7,012						1	741		1	22
29 BELL-SOUTHGATE	1	95									1	95			
30 BELL-WICHITA	2	139									2	139			
31 BELMONT 4KV															
32 BETHANY-BURTON	5	401						2	17		3	384			
33 BETHANY-GERMANTOWN	6	2,291		2	106			1	32		3	2,153			

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 2 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
34 BETHANY-KAISER	2	10						2	10						
35 BETHANY-LAIDLAW	3	226	1	151						2	75				
36 BETHANY-SPRINGVILLE	2	196								2	196				
37 BETHANY-THOMPSON	2	176						2	176						
38 BETHEL-FRUTLAND	5	98				1	31	2	64	1	3			1	1
39 BETHEL-GEER	8	229	2	14	2	10				4	206				
40 BETHEL-MCLAY	1	1						1	1						
41 BLUE LAKE 13 KV	4	5,096	1	5				2	136					1	4,956
42 BOONS-GOODALL	1	375								1	375				
43 BOONS-KRUSEWAY	3	258						2	210	1	48				
44 BOONS-LK GROVE	10	1,108	2	553				3	49	5	506				
45 BOONS-MT PARK															
46 BOONS-WMBLY PK	12	1,949	2	1,138				4	24	6	787				
47 BORING-282ND AV	15	7,752	5	7,208				4	20	6	524				
48 BORING-CITY	4	116	1	26				2	29	1	61				
49 BORING-TELFORD	14	1,068	5	683				2	2	6	370			1	12
50 BRIGHTWD 13KV	38	11,252	10	8,634				2	87	25	2,477			1	54
51 BRIGHTWD-N BANK	12	9,430	3	2,933						9	6,496				
52 BROOKWOOD 13KV															
53 BROOKWOOD-BRWCK															
54 BROOKWOOD-SUNRS	4	3,733						2	2	2	3,731				
55 BVRTN-ALLEN	10	1,630						7	534	3	1,096				
56 BVRTN-JAMIESON	1	29						1	29						
57 BVRTN-NORTHWEST	3	26						3	26						
58 BVRTN-W SLOPE	1	16						1	16						
59 CANBY-13643	12	148	2	13				4	70	5	64			1	1
60 CANBY-13644	5	42	1	27						4	15				
61 CANBY-BUTTEVLE	3	90	1	3						2	87				
62 CANYON 13KV	11	1,467	1	908				4	156	5	370			1	33
63 CANYON-13114															
64 CANYON-13115															
65 CANYON-13116															
66 CANYON-13117															

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause Natural

Page 3 of 19

Feeder Name	Total Nat Outs Hrs		Adverse Envir Outs Hrs		Lightning Outs Hrs		Animal Outs Hrs		Non-Preventable Tree Contacts* Outs Hrs		Preventable Tree Contacts* Outs Hrs		Unknown Outs Hrs			
	Total Outs	Nat Hrs	Adverse Outs	Envir Hrs	Lightning Outs	Hrs	Animal Outs	Hrs	Non-Preventable Outs	Tree Contacts*	Outs	Hrs	Preventable Outs	Tree Contacts*	Outs	Hrs
67 CANYON-13118PSU																
68 CANYON-13119PSU																
69 CANYON-13120																
70 CANYON-13121																
71 CANYON-13122																
72 CANYON-13123																
73 CANYON-13124																
74 CANYON-13125																
75 CANYON-13133																
76 CANYON-13134																
77 CANYON-13135																
78 CANYON-13136																
79 CANYON-21ST AVE																
80 CANYON-23RD AVE	18	4,465	5	1,061					5	136	7	3,063	1	205		
81 CANYON-BURNSIDE	1	1							1	1						
82 CARVER 13 KV	9	634	1	55	1	29	4	5	2	543				1	1	
83 CARVER-ALMOND																
84 CARVER-NORTH	1	8	1	8												
85 CARVER-RIVRBEND																
86 CARVER-SOUTH																
87 CARVER-WOODS	4	1,059	3	1,058							1	1				
88 CEDAR HILLS 13KV																
89 CEDAR-LEAHY	6	1,693	2	1,576					2	26	2	91				
90 CEDAR-SHOP CEN	12	1,648	4	1,156					4	163	4	329				
91 CEDAR-SKYLINE	2	10									2	10				
92 CEDAR-ST VINCNT	2	27	1	24					1	3						
93 CEDAR-SYLVAN	4	638	1	101					1	10	1	1			1	526
94 CLACK-EVELYN																
95 CLACK-GLADSTONE	4	171	1	5					3	166						
96 CLACK-JENNIFER																
97 CLACK-TOLBERT	1	10									1	10				
98 CLAXTAR 13KV	2	423			2	423										
99 CLAXTAR-HAYSVIL	2	22							2	22						

Total Nat = Total Natural Caused Outages  
Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

# 2014 Outages by Cause

## Natural

Page 4 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
100 CLAXTAR-RIDGE	3	53						2	48	1	5				
101 CNTNNIL 13KV	9	1,898	1	75				4	142	4	1,682				
102 CNTNNIL-BARKER	9	445	5	425				1	3	3	18				
103 CNTNNIL-BRACRFT	7	842	2	241						5	601				
104 CNTNNIL-TREEAND	9	1,059	1	70				7	211	1	778				
105 COFFEE CREEK-FREEMAN															
106 COFFEE CREEK-HOLIDAY															
107 COLTON-DHOOGHE	10	508	2	111				1	2	7	396				
108 COLTON-GRAYS HL	24	2,064	7	441	2	735		2	6	13	883				
109 CORNELIUS 13KV	13	760	1	348				6	170	6	241				
110 CORNELIUS-ADAIR	1	67								1	67				
111 CORNELIUS-VRBRT	12	3,671			1	17	8	180		2	3,119			1	355
112 CORNELL-BLUFFS	2	65					1	61		1	4				
113 CORNELL-SALTZMAN	8	336			1	142				4	191			3	2
114 CORNELL-WESTLAWN	9	1,389					5	573		4	816				
115 CULVER 13KV															
116 CULVER-GAFFIN															
117 CULVER-SANYO #1															
118 CULVER-SANYO #2															
119 CURTIS 13KV	4	266						3	230	1	36				
120 CURTIS-11077															
121 DAYTON-EAST	9	242	3	202						4	33	1	4	1	3
122 DAYTON-LAFAYETT	12	498	2	142	4	43	2	155		3	89			1	69
123 DAYTON-S AND W	3	110			1	2				2	108				
124 DELAWARE-DENVER	2	45					1	14		1	31				
125 DELAWARE-INTER	4	303					4	303							
126 DELAWARE-LOMBRD	5	14,450	1	272						4	14,178				
127 DENNY-EAST	9	194	3	96				3	29	2	65			1	3
128 DENNY-NORTH															
129 DENNY-SOUTH	2	135					1	134		1	0				
130 DENNY-WEST	10	1,223					3	139		7	1,084				
131 DILLEY-13KV	7	453	1	161			2	4	4	288					
132 DILLEY-SPRINGHL															

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 5 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
133 DUNNS C 13 KV	31	4,243		11	547	4	8	2	40		12	2,726		1	716
134 DUNNS C-KELSO														1	206
135 DURHAM 13KV															
136 DURHAM-BONITA															
137 DURHAM-BRIDGEPORT	2	497		1	496					1	1				
138 DURHAM-SATTLER	2	16								2	16				
139 DURHAM-SOUTH															
140 E-11021															
141 E-11039															
142 E-11040															
143 E-11041															
144 E-11042															
145 E-11043															
146 E-11047															
147 E-11064															
148 E-13139	3	126								2	67		1	59	
149 E-13140	8	804		1	61								7	743	
150 E-13141															
151 E-13144	3	100								2	32		1	68	
152 E-13145	1	2								1	2				
153 E-13148															
154 E-13149															
155 E-13150															
156 EAGLE CR-BARTON	10	846		1	16								8	826	1
157 EAGLE CR-RIVRML	6	1,293		3	1,069								3	223	
158 EASTPORT-76TH	2	3,839											1	3,742	1
159 EASTPORT-PLAZA	1	57								1	57				97
160 ELMA 13KV															
161 ELMA-4 CORNERS															
162 ELMA-HUDSON	2	163		1	31					1	132				
163 ELMA-STATE 13KV															
164 ESTACADA 13KV	13	4,536				1	51	1	7				9	4,391	2
165 ESTACADA-FARADY	49	6,986	16	3,186				5	363				26	3,426	2
Total Nat = Total Natural Caused Outages	Hrs - # of customers * duration hrs												*For detailed Tree Contacts, see Outages by Tree Contacts report		
Outs = Outages															

## 2014 Outages by Cause

### Natural

Page 6 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
166 FAIRMT-CNDLARIA	3	347		1	90			1	16	1	241				
167 FAIRMT-MISSION	9	5,626		3	5,384			1	94	3	133			1	1
168 FAIRVIEW 13 KV	1	1								1	1				14
169 FAIRVIEW-CLRCK															
170 FAIRVIEW-K CLUB	4	60						2	42	2	18				
171 FAIRVIEW-TROUTD	1	24													1
172 FAIRVIEW-W VILL															24
173 FARGO 13KV	9	762		4	165			2	17	3	579				
174 G HOME-MCKAY	8	2,682		4	2,261					4	421				
175 G HOME-METZGER	10	1,705		3	951			1	8	6	745				
176 GALES CRK 13KV	27	3,091		5	257	1	2,005			20	791			1	39
177 GLENCOE-GLISAN				5	223	1	120	1	2	3	101				
178 GLENCOE-PROVID															
179 GLENCOE-SUNNY	7	4,260						5	291	2	3,969				
180 GLISAN-FAB 2A															
181 GLISAN-UTIL 1B															
182 GLNCLN-BRIDLMIL	14	984		4	242			4	345	6	397				
183 GLNCLN-SUNSET	11	5,868		3	5,286			4	167	4	415				
184 GLNDOVEER-13596	2	73		1	21					1	52				
185 GLNDOVEER-13597	2	270		1	269					1	1				
186 GLNDOVEER-13598	1	40								1	40				
187 GLNDOVEER-13599	3	112		2	99			1	13						
188 GLNDOVEER-CLFGT	5	155						3	126	2	29				
189 GLNDOVEER-NEAST	2	9						2	9						
190 GRAND AV 4KV															
191 GRND RND-AGENCY	2	371		1	307					1	64				
192 GRND RND-FORTL	23	3,026		9	1,934			1	2	10	1,045			3	46
193 HABRTN-BURLINTN	14	2,845		4	33			1	1	8	241			1	2,570
194 HABRTN-LINNTON	6	1,697		1	4					4	491			1	1,202
195 HARBORTON 13KV	1	40													1
196 HARMONY 13KV	13	669		3	334			7	166	3	169				40
197 HARMONY-INTERNATIONAL	4	469						2	84	1	11			1	375
198 HARMONY-LAKE	3	177		1	27			1	33	1	116				

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 7 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown				
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs		
199 HARMONY-LINNWOD	7	505		4	205			1	1		1	187			1	112	
200 HARMONY-MILWAKI	10	2,636		2	183			4	150		4	2,303					
201 HARMONY-THIESEN																	
202 HARRISON 13KV	2	25						2	25								
203 HARRISON-DAVIS	1	17						1	17								
204 HARRISON-IVON	3	348						3	348								
205 HEMLOCK 13KV	2	10						2	10								
206 HEMLOCK-FREMONT	4	114						1	51		3	63					
207 HEMLOCK-MASON	4	368		4	368						1	95					
208 HILLCREST 13KV	1	95															
209 HILLCREST-CASCADIA																	
210 HILLCREST-REED																	
211 HILLCREST-SOUTH																	
212 HILLS-DAIRY CREEK	8	1,253		1	676		1	305	4	67		1	204			1	1
213 HILLS-DENNIS																	
214 HILLS-JACKSON	2	8						2	8								
215 HILLS-LAUREL	20	3,336		9	2,732		4	32	3	212		3	303		1	57	
216 HILLS-SCHOLLS	1	101							1	101							
217 HOGAN N 13KV	11	1,954		3	1,910				1	15		7	28				
218 HOGAN N-BRGDOON	1	22		1	22												
219 HOGAN N-LINKS	26	5,887		9	2,616						17	3,271					
220 HOGAN N-SLQUIST	3	3,759		1	2,963				1	16		1	780				
221 HOGAN S-CLEVND	3	2						3	2								
222 HOGAN S-LAWRNCE	11	5,192		7	447			2	156		1	4,513		1	77		
223 HOGAN S-MAIN	2	146		1	90			1	56								
224 HOGAN S-PAROPA	2	67		2	67												
225 HOGAN S-WALLULA	6	644		1	311			2	171		2	63				1	100
226 HOLGATE 13KV	3	14		3	14												
227 HOLGATE-BYBEE	1	6						1	6								
228 HOLGATE-GIDEON	1	2						1	2								
229 HOLGATE-KENLWOR	10	505		1	170		1	25	8	310							
230 HOLGATE-RHONE	4	54							4	54							
231 HUBER 13KV	3	122		1	104			2	18								

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 8 of 19

Feeder Name	Total Nat Outs		Adverse Envir Outs		Lightning Outs		Animal Outs		Non-Preventable Tree Contacts*		Preventable Tree Contacts*		Unknown Outs	
		Hrs		Hrs		Hrs		Hrs		Hrs		Hrs		Hrs
232 HUBER-BANY	3	35	1	6						2	29			
233 HUBER-FRMINGTON	5	102							4	69	1	33		
234 HUBER-KINNAMON	4	16							3	15			1	1
235 HUBER-MARYVILLE	2	463	1	438					1	25				
236 HYDN IS-MALAND	1	8									1	8		
237 HYDN IS-N SHORE	2	19	2	19										
238 HYDN IS-S SHORE														
239 INDIAN-KEIZER	3	87							3	87				
240 INDIAN-LABISH	7	39							3	19	2	14		2
241 INDIAN-NORTH	5	10							2	4	2	4		1
242 INDIAN-STATION	1	1							1	1				3
243 INDIAN-WEST	5	490			2	196	1	3			2	291		
244 ISLAND 13KV														
245 ISLAND-13180	11	10,049	3	217	2	5,131	5	180	1	4,521				
246 ISLAND-13187	15	7,370	4	2,131			5	424	4	292			2	4,523
247 ISLAND-13188	7	1,637					3	106	3	1,523			1	7
248 JEN LDG 13KV	4	517					2	16	2	502				
249 JEN LDG-MELDRUM	10	1,979	4	309			3	36	3	1,634				
250 JEN LDG-O GROVE	12	4,440	3	737			5	67	4	3,636				
251 JEN LDG-WEBSTER	5	733	1	697			3	29	1	7				
252 KELLEY POINT-LEDBETTER	1	269					1	269						
253 KELLEY POINT-SOLAR1														
254 KELLEY POINT-SOLAR2														
255 KELLEY PT 13 KV	1	2	1	2										
256 KING CTY-BULL MT	3	6,443	2	6,442					1	1				
257 KING CTY-FISCHER	3	3,188	1	42							2	3,146		
258 KING CTY-HAZEL B	2	69	2	69										
259 KING CTY-NORTH														
260 KING CTY-SUMERFL														
261 KLY BU-BINNSMED														
262 KLY BU-FAIRLAWN	2	248	1	34						1	215			
263 KLY BU-MALL 205	15	1,218	4	535			6	279	5	404				
264 KLY BU-MC GREW	4	1,009	2	968			1	37	1	4				

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 9 of 19

Feeder Name	Total Nat Outs		Adverse Envir Outs		Lightning Outs		Animal Outs		Non-Preventable Tree Contacts*		Preventable Tree Contacts*		Unknown Outs		
		Hrs		Hrs		Hrs		Hrs		Hrs		Hrs		Hrs	
265 KLY PT-MARINEDR															
266 KLY PT-SIMMONS	2	59							2	59					
267 LAKE LABISH 4KV															
268 LELAND-BEAVERC	14	3,204	5	3,121					2	3	5	68		2	12
269 LELAND-CARUS	42	29,640	15	13,195					9	5,215	14	11,173		4	58
270 LELAND-KELM	2	46									2	46			
271 LENTS-13101	9	1,643	2	1,342					3	161	4	140			
272 LENTS-HAPPY VAL	5	12,821	2	85							3	12,735			
273 LENTS-MT SCOTT	5	610							2	310	3	300			
274 LENTS-NORTH	4	93	1	31					2	35	1	27			
275 LIB-BROWNING	6	107							4	73	1	8		1	26
276 LIB-LONE OAK	2	159							1	131				1	28
277 LIB-MORNINGSIDE	2	33							2	33					
278 LIB-ROSEDALE	13	200	3	134	1	8	3	29			6	29			
279 LIB-VISTA	3	137	1	52					1	32	1	54			
280 LIBERAL 13KV	5	687			2	251	1	3			1	2		1	430
281 LIBERAL-SAWMILL															
282 LIBERTY-SKYLINE	16	3,557	5	2,001	1	1,051	6	253			4	252			
283 MAIN-AIRPORT	6	337			4	144					2	194			
284 MAIN-BENTLEY	1	1,066									1	1,066			
285 MAIN-EXPRESS	8	726	2	121					6	604					
286 MAIN-GRIFFIN															
287 MAIN-JFS1															
288 MAIN-JONES FARM															
289 MAIN-RVR RD	3	11							1	3	2	8			
290 MC CL-COTTAGE	2	11							2	11					
291 MC CL-FRONT ST	2	40							1	25				1	15
292 MC CL-HOLLYWOOD	7	234							6	104				1	129
293 MCGILL-LSIAIR1A															
294 MCMINNVILLE W AND L															
295 MERIDIAN 13KV	13	1,922	5	1,709					2	22	6	191			
296 MERIDIAN-65TH															
297 MERIDIAN-BORLND	5	6,574							1	8	4	6,566			

Total Nat = Total Natural Caused Outages

Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 10 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown			
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Contacts*	Outs	Hrs	
298 MERIDIAN-CHILDS	1	53						1	53							
299 MERIDIAN-LAKEVIEW	1	6						1	6							
300 MERIDIAN-NYBERG																
301 MERIDIAN-PLKNGTN	13	1,952		2	750			6	343		5	860				
302 MERIDIAN-SAGERT	1	280						1	280							
303 MIDGROVE-BROWN	2	39						2	39							
304 MIDGROVE-CHEMEK	1	1						1	1							
305 MIDGROVE-CORDON	6	7,792				4	7,790	1	2		1	1				
306 MIDGROVE-SWEGLE	1	6						1	6							
307 MIDGROVE-WEST	2	102		1	45			1	58							
308 MIDWAY-DIVISION	6	1,441		2	1,194			2	29		2	217				
309 MIDWAY-DOUGLAS	4	73		1	30			1	14		2	29				
310 MIDWAY-LYNCH	3	603		2	518			1	84							
311 MIDWAY-POWLHST	2	109						1	1		1	108				
312 MILL CREEK 13KV																
313 MILL CREEK-EASTLAND	9	37		2	17			5	14		2	6				
314 MILL CREEK-KUEBLER																
315 MOLALLA-BUCKAROO	1	180		1	180											
316 MOLALLA-FOREST	11	121		4	80	1	10	2	3		3	6			1	23
317 MOLALLA-MARQUAM	24	4,416		11	1,096			1	7		12	3,314				
318 MOLALLA-YODER	5	201		2	76			1	2		2	123				
319 MRKT ST-ENGLEWD	4	146									1	8			3	138
320 MRKT ST-FAIRGND	3	7						1	3		2	4				
321 MRKT ST-HAWTHNE	4	2,846						1	168		3	2,678				
322 MRKT ST-PARK	1	48						1	48							
323 MT ANGEL-EAST	6	59				6	59									
324 MT ANGEL-WEST	13	310		3	195	6	82	1	8		3	25				
325 MT PLS-CLAIRMONT	4	3,073		2	3,021			1	49		1	3				
326 MT PLS-MT VIEW	3	40						1	1		1	9			1	31
327 MT PLS-RIVRCRST	5	5,154						4	205		1	4,949				
328 MT PLS-SOUTHEND	5	1,529		1	1,506			3	7		1	17				
329 MULINO-NORTH	6	47		1	7			1	21		4	18				
330 MULINO-SOUTH	11	3,158		1	2			1	138		9	3,018				

Total Nat = Total Natural Caused Outages

Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 11 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree	Contacts*	Outs	Hrs	Outs	Hrs
331 MULTNOMAH 13KV	6	1,683		1	240			1	23	4	1,421				
332 MULTNOMAH-13176	10	5,738		4	5,510			5	162	1	66				
333 MULTNOMAH-13177	17	1,329		3	238			11	1,012	3	79				
334 MULTNOMAH-13181	8	1,840		1	138			6	602	1	1,099				
335 MURRAYHILL 13KV															
336 MURRAYHL-KINTON	1	99						1	99						
337 MURRAYHL-QUARRY															
338 MURRAYHL-REUSER	2	2,494						1	2,181					1	314
339 MURRAYHL-TEAL	3	88						2	48					1	40
340 N MARION FRONT	1	1												1	1
341 N MARION-CROSBY	4	77						3	74	1	3				
342 N MARION-HUBBRD	3	76						2	73	1	3				
343 N MARION-MCLARN	6	761		4	628					2	133				
344 N PLAINS 13KV	23	7,370		5	851		2	37		16	6,482				
345 N PLAINS-M HILL	28	5,284		7	744		4	1,988		3	125		12	752	2 1,676
346 NEWBERG-CHEHALM	13	5,764		2	2,984		1	1,719		5	91		5	970	
347 NEWBERG-COLLEGE	1	1						1	1						
348 NEWBERG-DUNDEE	9	1,059		1	50			1	2	5	954			2	53
349 NEWBERG-HOOVR PK	4	122		1	86					3	36				
350 NORTHERN-11009	3	336		2	313			1	23						
351 NORTHERN-11016															
352 NORTHERN-11071	3	108						1	14	2	94				
353 OAK HILLS 13KV															
354 OAK HILLS-5 OAK	1	3												1	3
355 OAK HILLS-BRIER															
356 OAK HILLS-SMRST	2	670		1	166					1	504				
357 OAK HILLS-WLKRD															
358 OCKLEY GRN 4KV															
359 OK GRV-LK HARRT	4	464		1	48					3	416				
360 OK GRV-WT WATER															
361 ORENCO 13KV	1	14						1	14						
362 ORENCO PRIMATE															
363 ORENCO-231ST															

Total Nat = Total Natural Caused Outages

Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 12 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
364 ORENCO-AMBRGLEN															
365 ORENCO-BASELINE	3	93						3	93						
366 ORENCO-WILKINS															
367 ORIENT 13KV	35	9,454	15	548						20	8,906				
368 ORIENT-BARLOW	21	4,874	6	372				4	11	11	4,492				
369 OSWEGO-IRON MTN	4	227	1	131				1	10	2	86				
370 OSWEGO-MARYLHST	11	818	3	614				6	190	2	14				
371 OSWEGO-PALATINE	13	740	2	130				1	3	10	608				
372 OSWEGO-STAFFORD	5	1,856	1	1,797				3	31	1	28				
373 OXFORD 13KV	5	91	1	1				4	89						
374 OXFORD-FAIRVIEW	4	86						3	6	1	80				
375 OXFORD-LEE	2	117	1	22				1	95						
376 OXFORD-MADRONA															
377 OXFORD-RURAL															
378 OXFORD-SHELTON	6	280						6	280						
379 PELTON-ROUND BUTTE															
380 PENIN PARK 4KV	1	70						1	70						
381 PLSNT VALY 13KV	16	1,930	4	1,004						12	927				
382 PLSNT VALY-BXTR	3	2,524						2	11	1	2,513				
383 PLSNT VALY-MOON	6	3,608	3	3,600				1	1	2	7				
384 PLSNT VALY-SUN	8	2,636	3	276				3	110	2	2,250				
385 PORTLAND GRD W PUMPING															
386 PORTSMTH-CARB	6	913	1	62	3	746	2	105							
387 PORTSMTH-DISP															
388 PORTSMTH-WILL	7	458	1	288	1	40	4	88					1	42	
389 PRGRS-GREENBURG	7	45			2	1	5	43							
390 PRGRS-HALL															
391 PRGRS-ROBINSON															
392 PRGRS-SAWYER	1	1								1	1				
393 PRGRS-WSH SQ #1															
394 PRGRS-WSH SQ #2															
395 RAL H-DOGWOOD	17	2,779	5	1,660				3	13	5	849			4	256
396 RAL H-MONTCLAIR	7	732	1	476				4	128	2	129				

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 13 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown					
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree	Contacts*	Outs	Hrs	Outs	Hrs			
397 RAL H-OLESON RD	8	834		1	631			4	48		3	155						
398 RAMAPO 13KV	8	190		1	12			6	77		1	101						
399 RAMAPO-GILBERT	2	624		1	615						1	9						
400 REDLAND 13KV	23	4,992		5	1,920	1	1,079	3	40		13	1,877			1	76		
401 REDLAND-HENRICI	24	2,142		6	1,042			7	48		10	680		1	372			
402 REED-BLANTON	2	185		1	172			1	13									
403 REED-HAZELDALE	7	343		1	231			3	7		2	96				1	10	
404 REED-INTEL #1																		
405 REED-INTEL #2																		
406 REED-INTEL #3																		
407 REED-INTEL #4																		
408 REED-TV HWY	3	55								1	1		2	54				
409 REEDVILLE-AUGUSTA	3	401								2	345		1	56				
410 ROCKWD 13KV	9	638		3	333					1	40		4	231			1	34
411 ROCKWD-AIRPT WY																		
412 ROCKWD-BOEING																		
413 ROCKWD-INDUSTR																		
414 ROCKWD-REYNOLDS	4	1,248		3	1,218					1	30							
415 ROCKWD-WILKES																		
416 ROSEMONT-HIDDEN SPRINGS	8	323		2	48					3	151		2	7			1	117
417 ROSEMONT-MOSSY BRAE	8	510		1	83					4	87		3	341				
418 ROSEMONT-OVERLOOK	2	126		1	101								1	26				
419 ROSEWAY 13 KV	1	11											1	11				
420 ROSEWAY-ALEXNDR	1	2								1	2							
421 ROSEWAY-ESPLANA	4	472								2	30		1	323			1	119
422 ROUND BUTTE SPILLWAY																		
423 RUBY-13502	2	100								2	100							
424 RUBY-13503	3	372		2	57								1	315				
425 RVRGATE-11010																		
426 RVRGATE-11011	1	8								1	8							
427 RVRGATE-PEARCY																		
428 RVRGATE-SWIFT																		
429 RVRVIW-FULTON	10	1,529		1	473					5	552		4	504				

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 14 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Contacts*	Outs	Hrs
430 RVRVIW-MACADAM	1	784												1	784
431 RVRVIW-TWILLIGR	10	542	2	286	1	168	1	25	6	63					
432 SALEM-13260															
433 SALEM-13261															
434 SALEM-13262															
435 SALEM-13263															
436 SALEM-13264															
437 SALEM-UNION															
438 SANDY 13KV	56	13,234	24	11,433				9	117	23	1,685				
439 SANDY-362ND	12	3,476	7	2,988				1	7	3	383			1	98
440 SANDY-BLUFF	8	381	4	279				3	68					1	34
441 SANDY-WILDCAT	32	9,534	8	2,254				5	88	18	7,191			1	1
442 SCHOLLS FERRY-KEMMER RD	2	134	2	134											
443 SCHOLLS FERRY-RAINBOW	33	4,364	13	2,098				9	125	11	2,141				
444 SCHOLLS FERRY-ROY ROGERS	2	27						1	2					1	25
445 SCOGG-CHERRY G	6	1,062	2	23				1	71	2	690			1	277
446 SCOGG-LAUREL W	26	657	3	256				16	385	7	16				
447 SCOTTS MILL 13KV	33	11,182	17	5,791				1	2	15	5,388				
448 SELLWD 13KV	7	1,894	1	157				5	158	1	1,580				
449 SELLWD-KELOG PK	6	684	1	245	1	111	2	136	2	191					
450 SELLWD-WAVERLY															
451 SHERIDAN EAST	6	878	1	132	1	565				4	181				
452 SHERIDAN-KADELL	4	450	1	1	3	449									
453 SILVERTON-NORTH	7	185	4	136				3	49						
454 SILVERTON-SOUTH	6	3,374	2	499						4	2,875				
455 SILVERTON-WEST	23	1,207	9	600				3	9	11	598				
456 SIX COR-13359	17	678	2	21	3	115	8	379	4	163					
457 SIX COR-13360	1	1	1	1											
458 SIX COR-BORCHER	9	1,513	2	234				2	120	4	471	1	689		
459 SIX COR-CHAPMAN	3	176	1	20	1	102	1	53							
460 SIX CORNER-13KV	1	14						1	14						
461 SMURFIT-NEWBERG															
462 SPRINGBK-FERNWD	5	270						2	4	3	265				

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 15 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
463 SPRINGBK-STPAUL	9	1,614		4	816			2	2		3	796			
464 SPRINGBK-VILLA	4	193						4	193						
465 SPRINGBK-ZIMRI	11	690		1	349	1	1	4	63		4	238		1	40
466 ST LOUIS-EAST															
467 ST LOUIS-NORTH	4	160		1	7	1	150				2	4			
468 ST LOUIS-WEST	8	127				1	4	1	21		2	9		4	94
469 ST MARY 13KV															
470 ST MARY-BETHANY															
471 ST MARY-BUTNER	14	1,412		3	285			3	226		6	406		2	494
472 ST MARY-ELMONIC															
473 ST MARY-JENKINS															
474 ST MARY-MILLIKN															
475 STEPHN-11001															
476 STEPHN-11020															
477 STEPHN-11054															
478 STEPHN-11055															
479 STEPHN-11092															
480 STEPHN-11093															
481 STEPHN-11094															
482 STEPHN-11095															
483 STEPHN-11097															
484 STEPHN-11098															
485 STEPHN-11099															
486 SULL-ROBINWOOD	12	1,061						9	201		3	860			
487 SULL-SALAMO	5	119		3	37						2	82			
488 SULL-SUSSEX	5	436		1	403	2	17	2	15						
489 SULL-WILLAMETTE	10	9,073		3	262	3	7,477	2	117		2	1,217			
490 SULLIVAN-TANNER	1	1						1	1						
491 SULZER 115A															
492 SULZER 115B															
493 SULZER BINGHAM															
494 SUMMIT-GOVT CAMP	1	1									1	1			
495 SUMMIT-MEADOWS	1	7		1	7										

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 16 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown			
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs	
496 SUMMIT-SUMMIT	2	68		1	41					1	27					
497 SUNSET-BLANCHET																
498 SUNSET-COLFAX																
499 SUNSET-CORNELL																
500 SUNSET-D1X1																
501 SUNSET-DORION																
502 SUNSET-IDTB																
503 SUNSET-INTEL D1B1																
504 SUNSET-KOMATSU #1																
505 SUNSET-KOMATSU #2																
506 SUNSET-KOMATSU #3																
507 SUNSET-LANE																
508 SUNSET-LINDE PHASE 1																
509 SUNSET-MCCALL																
510 SUNSET-MEEK																
511 SUNSET-PAULING																
512 SUNSET-SPALDING																
513 SUNSET-WHITMAN	1	2												1	2	
514 SUNSET-YOUNG																
515 SWAN IS-BASIN																
516 SWAN IS-DOLPHIN																
517 SWAN IS-FREIGHTLINER																
518 SWAN IS-GOING																
519 SWAN IS-SHIPYRD																
520 SYLVAN-BARNES	23	5,238		8	514					1	13	13	4,679		1	32
521 SYLVAN-PATTON	18	3,423		3	1,734					8	348	6	1,327		1	14
522 TABOR 13KV	1	180								1	180					
523 TABOR-82ND AV	1	69								1	69					
524 TABOR-HOSPITAL																
525 TEK 13KV																
526 TEK-HOCKEN																
527 TEK-NORTH																
528 TEK-SHANNON	9	1,312		2	414					2	43	4	506		1	348

Total Nat = Total Natural Caused Outages

Hrs - # of customers \* duration hrs

Outs = Outages

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause

### Natural

Page 17 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown			
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs	
529 TEK-SOUTH	2	15						2	15							
530 TEK-WEST																
531 TEMP-NORTH																
532 TEMP-SOUTH																
533 TIGARD - 13 KV	4	799						3	337		1	462				
534 TIGARD-13336	3	80	2	52				1	28							
535 TIGARD-13337	1	1,058											1	1,058		
536 TIGARD-13361	2	138						2	138							
537 TIGARD-13362	4	186	1	179				2	6					1	2	
538 TNCTR-LAWNFIELD																
539 TNCTR-MONTEREY	1	34								1	34					
540 TNCTR-NORTH 13KV																
541 TNCTR-PRECISION																
542 TNCTR-SOUTH 13KV																
543 TNCTR-SUNNYBROOK	1	43						1	43							
544 TNCTR-VALLEY VW																
545 TROJAN PLNT E																
546 TUALATIN 13KV																
547 TUALATIN-AVERY	2	24						1	10					1	14	
548 TUALATIN-CIPOLE	2	4								2	4					
549 TUALATIN-HERMAN																
550 TUALATIN-IBACH	1	1,542								1	1,542					
551 TUALATIN-LEVETON																
552 TURNER 13KV	4	517	1	374				1	1		1	111			1	31
553 TURNER-CASCADE	2	4				1	2				1	2				
554 TWILIGHT-BREMER	12	826	3	620				4	12		5	194				
555 UNIONVALE 13KV	19	1,907	2	6	4	10	1	79		11	1,806			1	6	
556 UNIVRSITY-MILL																
557 UNIVRSITY-TRADE	5	64						3	27		1	1			1	37
558 URBAN-BARBUR	3	25						2	24						1	1
559 URBAN-CAMPUS																
560 URBAN-CORBETT	4	9,112	1	6,877				1	2,232		2	3				
561 URBAN-GAINES	2	14								2	14					

Total Nat = Total Natural Caused Outages

Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause Natural

Page 18 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Tree Contacts*	Outs	Hrs
562 URBAN-GIBBS	6	163						6	163						
563 URBAN-KELLY	2	15						2	15						
564 URBAN-LANDING															
565 URBAN-MEDICAL	1	17						1	17						
566 URBAN-OHSU															
567 W PTLD 13KV	10	2,718	3	314						7	2,403				
568 W PTLD-72ND	2	1,099								1	1,099			1	1
569 W PTLD-NORTH	9	601	1	110				4	117	4	374				
570 W PTLD-PACIFIC	9	3,427	4	2,962				5	465						
571 W UNION 13KV															
572 W UNION-CORNELS	22	4,262	6	1,628	2	14	6	181	7	2,420			1	20	
573 WACKER															
574 WACONDA 13KV	13	50	4	31				3	4	5	12			1	2
575 WACONDA-NORPAC															
576 WACONDA-RIVER RD	5	531	2	528						3	3				
577 WALLACE RD 13KV	7	580	3	71				1	8	3	500				
578 WALLACE-WILLOW LAKE	2	5						1	5	1	1				
579 WELCHES 13KV	32	5,484	4	371				10	127	18	4,986				
580 WELCHES-ZIG ZAG	42	20,403	10	2,390				1	5	30	17,740	1	268		
581 WILLAMINA-BRIDGE	5	45	1	1				2	3	2	41				
582 WILLAMINA-BUELL	9	1,714	6	1,699				1	2	2	12				
583 WILLAMINA-LUMBER															
584 WILLBRDG #1															
585 WILLBRDG #4															
586 WILSV-BOECKMAN	6	250	3	118				1	3	2	129				
587 WILSV-CHARBNEAU	5	20						2	16	3	3				
588 WILSV-CITY	2	651	1	540				1	111						
589 WILSV-MENTORTEK															
590 WILSV-PARKWAY															
591 WILSV-VILLEBOIS															
592 WILSV-WEST	4	166			1	20	3	145							
593 WOODBURN-CANNERY	2	84						1	83					1	1
594 WOODBURN-EAST	10	1,219	4	873						3	188	1	1	2	156

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## 2014 Outages by Cause Natural

Page 19 of 19

Feeder Name	Total Nat		Adverse		Lightning		Animal		Non-Preventable		Preventable Tree		Unknown		
	Outs	Hrs	Envir	Outs	Hrs	Outs	Hrs	Outs	Hrs	Tree Contacts*	Outs	Hrs	Contacts*	Outs	Hrs
595 WOODBURN-TOMLIN	2	3						1	1	1	3				
596 WOODBURN-WEST	4	159	1	77				2	78					1	3
597 YAMHILL 13KV	13	695	2	405				7	28	4	262				
598 YAMHILL-CARLTON	17	1,816	3	1,458				4	18	9	336			1	4
<b>Grand Totals:</b>	<b>2,783</b>	<b>586,024</b>	<b>681</b>	<b>205,107</b>	<b>112</b>	<b>38,912</b>	<b>789</b>	<b>37,266</b>	<b>1,076</b>	<b>279,148</b>	<b>13</b>	<b>2,781</b>	<b>112</b>	<b>22,810</b>	

Total Nat = Total Natural Caused Outages  
 Outs = Outages

Hrs - # of customers \* duration hrs

\*For detailed Tree Contacts, see Outages by Tree Contacts report

## **SECTION V**

### **Outages by Cause-System**

This section provides the number of customer outages (frequency) and customer outage hours (duration) caused by system (failure of equipment or loss of source) events. The information is presented by feeder and attributed to one of the following causes:

- PGE Equipment
- Cutout/Fuse/Arrestor Failure
- Loss of Substation
- Loss of Transmission
- Human Element
- Public
- Planned

# 2014 Outages by Cause System

Page 1 of 18

Feeder Name	Equipment												Public		Planned	
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Outs	Hrs	Outs	Hrs
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
1 ABERN-CLACK HTS																
2 ABERN-ORE CITY	15	1,159	3	26	3	63							10	1,070		
3 ABERNETHY-TRANSIT	4	77			3	47									1	30
4 ALDER CT-ANKENY																
5 ALDER CT-IRVING	6	731	2	468									5	313		
6 ALDER CT-LINCOLN	2	389			2	389							1	19		
7 ALDER CT-STARK																
8 ALDER CT-TAYLOR	4	327	1	84	2	52							2	215		
9 ALDER CT-YAMHILL																
10 AMITY 13KV	16	364	8	49	4	64							6	256		
11 AMITY-BELLEVUE	16	3,013	8	175	7	22							3	2,821		
12 ARLETA-52ND ST	5	460	2	30	3	430							1	1		
13 ARLETA-FOSTER	2	5	1	4	1	1										
14 ARLETA-HAROLD	5	139	3	127	2	12										
15 ARLETA-POWELL	6	520	4	285	1	222							3	27		
16 ARLETA-STEELE	3	347	2	305									1	6	1	42
17 B LAKE-SUNDIAL	6	1,758	6	1,758			1	1,711								
18 B LAKE-TOYOTNSO	1	75	1	75			1	75								
19 BANKS 13KV	10	1,946	5	1,878	3	62	1	1,557					3	50		
20 BANKS-CEDAR CYN	9	5,282	7	5,228	2	54	1	4,690					1	2		
21 BARNES-BATTLCRK	2	115	1	11											1	104
22 BARNES-BOONE	3	217	2	215	1	2										
23 BARNES-COMMERCL	10	1,259	5	840	1	1							3	146	1	272
24 BARNES-SUNNYSID	14	1,904	9	1,752	1	2							5	154		
25 BELL-FLAVEL	3	62	1	48	2	14										
26 BELL-JOHNSN CRK	2	95	2	95												
27 BELL-KENDALL	4	580	2	539									2	168	1	2
28 BELL-KING	3	91	2	78	1	13										
29 BELL-SOUTHGATE																
30 BELL-WICHITA	4	90	3	84	1	6							1	12		
31 BELMONT 4KV																
32 BETHANY-BURTON	5	335	1	197	1	33	1	197					1	7	2	99
33 BETHANY-GERMANTOWN	4	441	3	377			1	349					1	5	1	63
34 BETHANY-KAISER	5	629	3	494			1	339					1	124	1	11
35 BETHANY-LAIDLAW	4	9,864	4	9,864			1	267					2	2		

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 2 of 18

Feeder Name	Equipment													
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Public	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
36 BETHANY-SPRINGVILLE	1	209	1	209			1	209			2	18		
37 BETHANY-THOMPSON	3	544	3	544			1	168					2	153
38 BETHEL-FRUTLAND	8	3,035	3	2,874	3	8								
39 BETHEL-GEER	8	467	3	362	5	105								
40 BETHEL-MCLAY	5	337	3	335	1	1							1	1
41 BLUE LAKE 13 KV	5	10,473	3	10,465	1	3	1	10,144			1	5		
42 BOONS-GOODALL	10	4,381	9	4,377							2	24	1	4
43 BOONS-KRUSEWAY	1	39	1	39										
44 BOONS-LK GROVE	7	374	6	367	1	8								
45 BOONS-MT PARK	7	7,938	6	7,918	1	20								
46 BOONS-WMBLY PK	4	466	4	466									1	236
47 BORING-282ND AV	10	589	4	65	5	118			1	2,241			2	407
48 BORING-CITY	9	3,370	6	3,135	3	235							1	1
49 BORING-TELFORD	13	1,608	5	113	3	5							11	1,880
50 BRIGHTWD 13KV	8	214	5	189	2	3							9	456
51 BRIGHTWD-N BANK	2	66	1	62	1	4							2	405
52 BROOKWOOD 13KV	1	4,072	1	4,072										
53 BROOKWOOD-BRWCK	2	16	2	16										
54 BROOKWOOD-SUNRS	1	54											1	54
55 BVRTN-ALLEN	3	53	2	32	1	21								
56 BVRTN-JAMIESON														
57 BVRTN-NORTHWEST	1	8			1	8								
58 BVRTN-W SLOPE	7	491	6	490	1	1								
59 CANBY-13643	14	4,613	6	2,451	4	76	1	2,382			4	1,921	1	167
60 CANBY-13644	6	879	1	870	4	7	1	870			2	5		
61 CANBY-BUTTEVLE	5	56	3	52	2	5							1	1
62 CANYON 13KV	3	1,053	1	14					1	879			1	160
63 CANYON-13114														
64 CANYON-13115														
65 CANYON-13116														
66 CANYON-13117														
67 CANYON-13118PSU														
68 CANYON-13119PSU														
69 CANYON-13120	1	20									1	20		
70 CANYON-13121														

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 3 of 18

Feeder Name	Equipment																
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Public		Planned		
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	
71 CANYON-13122																	
72 CANYON-13123																	
73 CANYON-13124																	
74 CANYON-13125																	
75 CANYON-13133																	
76 CANYON-13134																	
77 CANYON-13135																	
78 CANYON-13136																	
79 CANYON-21ST AVE	2	128					2	128									
80 CANYON-23RD AVE	9	292	4	133	3	8									2	151	
81 CANYON-BURNSIDE	4	793	2	667	2	126											
82 CARVER 13 KV	10	622	7	515	3	108											
83 CARVER-ALMOND	1	4			1	4											
84 CARVER-NORTH																	
85 CARVER-RIVRBEND																	
86 CARVER-SOUTH	1	3			1	3											
87 CARVER-WOODS	8	2,860	2	462	3	10								3	2,388		
88 CEDAR HILLS 13KV																	
89 CEDAR-LEAHY	4	388	1	190	1	4								1	38	1	155
90 CEDAR-SHOP CEN	8	464	5	380	1	3								3	84		
91 CEDAR-SKYLINE	1	45	1	45													
92 CEDAR-ST VINCNT	3	146	2	86										1	60		
93 CEDAR-SYLVAN	3	343	1	328	2	15											
94 CLACK-EVELYN	2	1,181	1	1,180	1	1											
95 CLACK-GLADSTONE	19	2,669	8	470	2	91								5	2,013	4	94
96 CLACK-JENNIFER	4	37	3	35	1	2											
97 CLACK-TOLBERT	7	6,287	5	5,894										3	415		
98 CLAXTAR 13KV	1	3												1	3		
99 CLAXTAR-HAYSVIL	2	233												2	233		
100 CLAXTAR-RIDGE	7	663	7	663													
101 CNTNNIL 13KV	5	193	4	189	1	4								1	25		
102 CNTNNIL-BARKER	6	180	2	27	4	153								1	76		
103 CNTNNIL-BRACRFT	4	229			2	81								5	286		
104 CNTNNIL-TREEAND	11	13,359	4	565	2	12								4	12,791	2	10
105 COFFEE CREEK-FREEMAN	2	8	1	4	1	5											

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 4 of 18

Feeder Name	Equipment											
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
106 COFFEE CREEK-HOLIDAY	10	871	8	869	1	1					1	1
107 COLTON-DHOOGHE	5	471	3	14	1	4					1	454
108 COLTON-GRAYS HL	6	471	3	427	2	5					1	38
109 CORNELIUS 13KV	18	783	8	627	4	21					4	113
110 CORNELIUS-ADAIR	2	8	1	7	1	1						23
111 CORNELIUS-VRBRT	8	9,949	3	9,892	4	53					2	9
112 CORNELL-BLUFFS	6	10,544	5	2,161			1	1,455			1	8,383
113 CORNELL-SALTZMAN	7	2,457	6	2,450			1	675			1	7
114 CORNELL-WESTLAWN	8	3,213	5	2,242	3	971	1	852				
115 CULVER 13KV												
116 CULVER-GAFFIN												
117 CULVER-SANYO #1												
118 CULVER-SANYO #2												
119 CURTIS 13KV	2	98	1	0							3	441
120 CURTIS-11077												
121 DAYTON-EAST	5	189	4	187	1	2						
122 DAYTON-LAFAYETT	5	243	3	240	2	3						
123 DAYTON-S AND W	8	32	4	19	3	6					1	7
124 DELAWARE-DENVER	5	7,573	3	7,519	1	36	1	7,160			1	17
125 DELAWARE-INTER	2	1,865	1	1,721	1	143	1	1,721				
126 DELAWARE-LOMBRD	7	10,376	2	9,943	4	320	1	9,941				113
127 DENNY-EAST	7	470	3	350	3	76					2	99
128 DENNY-NORTH	1	105	1	105								
129 DENNY-SOUTH	4	4,594	2	650							2	3,421
130 DENNY-WEST	7	4,412	6	4,046							1	366
131 DILLEY-13KV	9	71	3	51	6	20						
132 DILLEY-SPRINGHL												
133 DUNNS C 13 KV	8	37	1	2	4	8					10	1,155
134 DUNNS C-KELSO	2	60	1	2							1	57
135 DURHAM 13KV												
136 DURHAM-BONITA	1	11	1	11								
137 DURHAM-BRIDGEPORT	1	187										187
138 DURHAM-SATTLER	10	1,181	8	1,114	1	14					1	164
139 DURHAM-SOUTH	2	179									2	179
140 E-11021	1	15	1	15			1	15				

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 5 of 18

Feeder Name	Equipment										Public Outs	Planned Outs	
	Total System Outs		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs
141 E-11039													
142 E-11040	2	114	1	113	1	2	1	113					
143 E-11041	3	114	2	107			1	105			2	9	
144 E-11042													
145 E-11043	1	30	1	30			1	30					
146 E-11047	3	127	1	92	1	1	1	92			1	33	
147 E-11064	1	10	1	10			1	10					
148 E-13139	1	3	1	3									
149 E-13140	2	50	1	46	1	4					1	91	
150 E-13141													
151 E-13144	3	54	2	45	1	9					1	1	
152 E-13145													
153 E-13148													
154 E-13149													
155 E-13150	1	148	1	148									
156 EAGLE CR-BARTON	5	595	3	557	1	31					2	282	
157 EAGLE CR-RIVRML	2	18	2	18									
158 EASTPORT-76TH	6	129	2	49	2	55					1	14	1
159 EASTPORT-PLAZA	2	22	1	6	1	16							10
160 ELMA 13KV	1	116	1	116									
161 ELMA-4 CORNERS	3	5,380	1	108	1	2					2	5,271	
162 ELMA-HUDSON	6	381	3	211							2	38	1
163 ELMA-STATE 13KV													
164 ESTACADA 13KV	4	802	1	748	2	53					3	191	
165 ESTACADA-FARADY	19	851	7	113	8	32					5	705	
166 FAIRMT-CNDLARIA	3	236	2	233	1	3							
167 FAIRMT-MISSION	12	3,035	11	2,820	1	215					1	1	
168 FAIRVIEW 13 KV	1	59	1	59							1	1	
169 FAIRVIEW-CLRCK													
170 FAIRVIEW-K CLUB	5	1,254	4	1,252							1	2	
171 FAIRVIEW-TROUTD	9	843	5	112	4	731							
172 FAIRVIEW-W VILL	4	443	4	443									
173 FARGO 13KV	17	1,155	6	801	7	26					4	21	3
174 G HOME-MCKAY	3	204	2	145							1	1	59
175 G HOME-METZGER	10	2,180	9	2,101	1	78							

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 6 of 18

Feeder Name	Equipment										Public		Planned			
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Outs	Hrs	Outs	Hrs
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
176 GALES CRK 13KV	8	92	4	81	4	11							3	328		
177 GLENCOE-GLISAN	5	484	2	2	1	94					1	367	3	238		
178 GLENCOE-PROVID																
179 GLENCOE-SUNNY	3	1,236	1	20	1	19							1	1,198		
180 GLISAN-FAB 2A																
181 GLISAN-UTIL 1B																
182 GLNCLN-BRIDLMIL	12	12,187	10	12,044	1	3	1	5,347					3	245		
183 GLNCLN-SUNSET	4	197			3	116							2	87		
184 GLNDOVEER-13596	4	3,180	2	3,156	2	24							1	7		
185 GLNDOVEER-13597	5	208	1	142	2	32							3	39		
186 GLNDOVEER-13598	2	30			2	30							1	1		
187 GLNDOVEER-13599	2	507	1	484									1	23		
188 GLNDOVEER-CLFGT	2	396	1	382	1	14										
189 GLNDOVEER-NEAST																
190 GRAND AV 4KV																
191 GRND RND-AGENCY	2	106	1	56	1	50							1	2		
192 GRND RND-FORTHL	12	535	7	453	5	82										
193 HABRTN-BURLINTN	26	34,384	10	33,901	14	481	1	27,443					4	7		
194 HABRTN-LINNTON	3	9,600	1	7,963	1	7	1	7,963					2	1,632		
195 HARBORTON 13KV	1	242	1	242			1	242								
196 HARMONY 13KV	5	240	3	171	2	68										
197 HARMONY-INTERNATIONAL																
198 HARMONY-LAKE	6	2,219	3	2,003	1	72							3	144		
199 HARMONY-LINNWOD	7	1,120	3	938	3	55							1	127		
200 HARMONY-MILWAKI	7	1,581	6	1,576	1	5										
201 HARMONY-THIESEN	1	2			1	2										
202 HARRISON 13KV	3	5	1	3	2	1										
203 HARRISON-DAVIS	4	51			2	39							3	36		
204 HARRISON-IVON	2	6	1	3	1	2										
205 HEMLOCK 13KV	13	2,004	11	1,882	1	1							1	120		
206 HEMLOCK-FREMONT	2	595											2	595		
207 HEMLOCK-MASON	2	499											3	501		
208 HILLCREST 13KV																
209 HILLCREST-CASCADIA																
210 HILLCREST-REED																

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

# 2014 Outages by Cause System

Page 7 of 18

Feeder Name	Equipment										Public		Planned			
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Outs	Hrs	Outs	Hrs
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
211 HILLCREST-SOUTH																
212 HILLS-DAIRY CREEK	4	635	3	574	1	61							4	563		
213 HILLS-DENNIS																
214 HILLS-JACKSON	6	330	5	328	1	2										
215 HILLS-LAUREL	18	1,047	8	633	8	300							2	101	1	17
216 HILLS-SCHOLLS	2	8	2	8												
217 HOGAN N 13KV	6	248	3	102	1	1							2	144		
218 HOGAN N-BRGDOON	7	2,045	6	2,031									1	14		
219 HOGAN N-LINKS	18	11,110	9	413	2	6							8	10,695		
220 HOGAN N-SLQUIST	6	146	6	146									1	1		
221 HOGAN S-CLEVIND	7	5,635	3	445	1	1							2	5,173	1	16
222 HOGAN S-LAWRNCE	11	1,093	10	1,091	1	1										
223 HOGAN S-MAIN	7	1,679	7	1,679												
224 HOGAN S-PAROPA	10	1,454	9	1,387	1	68										
225 HOGAN S-WALLULA	7	1,580	6	1,534									2	72		
226 HOLGATE 13KV	3	249	2	155	1	94										
227 HOLGATE-BYBEE	5	1,023	3	985	2	38										
228 HOLGATE-GIDEON																
229 HOLGATE-KENLWOR	6	956	3	628	3	327							1	165		
230 HOLGATE-RHONE	7	118	1	8	5	76							1	34		
231 HUBER 13KV	7	834	6	820	1	14										
232 HUBER-BANY	12	969	10	956	2	14										
233 HUBER-FRMINGTON	1	49	1	49									1	28		
234 HUBER-KINNAMON	11	5,069	9	4,815	1	9							1	246		
235 HUBER-MARYVILLE	10	1,378	8	1,331	1	2							2	70		
236 HYDN IS-MALAND																
237 HYDN IS-N SHORE	1	149	1	149									2	101		
238 HYDN IS-S SHORE	1	54											1	54		
239 INDIAN-KEIZER	3	39	1	1	1	33							1	6		
240 INDIAN-LABISH	13	1,064	3	347	7	38							2	677	1	2
241 INDIAN-NORTH	12	1,198	4	1,168	6	25							2	5		
242 INDIAN-STATION	8	1,386	7	1,384									2	3		
243 INDIAN-WEST	9	64	2	41	5	13							3	17		
244 ISLAND 13KV																
245 ISLAND-13180	7	848	3	751	2	12							2	85		

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 8 of 18

Feeder Name	Equipment											
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
246 ISLAND-13187	2	519	2	519								
247 ISLAND-13188	11	1,114	9	1,104	1	1					2	17
248 JEN LDG 13KV	8	562	2	253	4	54					1	3
249 JEN LDG-MELDRUM	5	162	3	128	2	35						
250 JEN LDG-O GROVE	2	26	1	5	1	21						
251 JEN LDG-WEBSTER	5	1,023	5	1,023								
252 KELLEY POINT-LEDBETTER	1	350	1	350			1	350				
253 KELLEY POINT-SOLAR1	1	2	1	2			1	2				
254 KELLEY POINT-SOLAR2	1	6	1	6			1	6				
255 KELLEY PT 13 KV	2	37	2	37			1	28			1	2
256 KING CTY-BULL MT	2	727	2	727							1	19
257 KING CTY-FISCHER	3	142	1	9							2	134
258 KING CTY-HAZEL B												
259 KING CTY-NORTH												
260 KING CTY-SUMERFL	3	133	3	133								
261 KLY BU-BINNSMED	4	591			4	591						
262 KLY BU-FAIRLAWN	4	353	3	348	1	6					2	8
263 KLY BU-MALL 205	11	5,323	2	3,702	2	253	1	2,011			7	1,369
264 KLY BU-MC GREW	7	2,358	2	314	2	90					3	1,954
265 KLY PT-MARINEDR	1	12	1	12			1	12				
266 KLY PT-SIMMONS	7	629	4	591	2	38	1	80			1	1
267 LAKE LABISH 4KV												
268 LELAND-BEAVERC	18	15,450	11	7,224	4	162	1	5,827			3	8,063
269 LELAND-CARUS	18	14,816	10	1,947	5	16					8	12,815
270 LELAND-KELM	2	3,617	2	3,617			1	3,609			2	3,808
271 LENTS-13101	12	1,004	5	590	6	389					2	32
272 LENTS-HAPPY VAL	3	1,272	2	1,270	1	2					2	34
273 LENTS-MT SCOTT	1	10	1	10							2	789
274 LENTS-NORTH	1	268									1	268
275 LIB-BROWNING	1	281	1	281								
276 LIB-LONE OAK	10	1,449	10	1,449							1	1
277 LIB-MORNINGSIDE	6	238	3	210	3	28						
278 LIB-ROSEDALE	7	1,362	3	1,336	2	4					2	22
279 LIB-VISTA	2	36	1	6	1	30						
280 LIBERAL 13KV	8	148	3	124	3	14					2	11

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 9 of 18

Feeder Name	Equipment											
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
281 LIBERAL-SAWMILL	1	0	1	0								
282 LIBERTY-SKYLINE	15	3,111	9	2,995	4	103					3	441
283 MAIN-AIRPORT	6	685	5	638	1	47					1	43
284 MAIN-BENTLEY	8	475	5	385	2	40					1	50
285 MAIN-EXPRESS	3	354	2	315	1	39						
286 MAIN-GRIFFIN												
287 MAIN-JFS1												
288 MAIN-JONES FARM												
289 MAIN-RVR RD	9	482	5	466	4	16					2	7
290 MC CL-COTTAGE	3	3,736	2	3,714	1	22					1	43
291 MC CL-FRONT ST											1	1
292 MC CL-HOLLYWOOD	2	60	1	32							3	206
293 MCGILL-LSIAIR1A												
294 MCMINNVILLE W AND L												
295 MERIDIAN 13KV	10	283	4	32	4	12					2	239
296 MERIDIAN-65TH												
297 MERIDIAN-BORLND	3	240	3	240								
298 MERIDIAN-CHILDS	1	54	1	54								
299 MERIDIAN-LAKEVIEW	1	2			1	2						
300 MERIDIAN-NYBERG												
301 MERIDIAN-PLKNGTN	6	776	4	424							1	285
302 MERIDIAN-SAGERT	5	1,648	3	774	1	238					2	653
303 MIDGROVE-BROWN	1	7	1	7								
304 MIDGROVE-CHEMEK	1	72	1	72							1	213
305 MIDGROVE-CORDON	13	628	9	620	3	5					1	4
306 MIDGROVE-SWEGLE	1	8	1	8							1	3
307 MIDGROVE-WEST	2	8	2	8								
308 MIDWAY-DIVISION	9	297	6	274	2	11					3	34
309 MIDWAY-DOUGLAS	5	468	4	466							2	175
310 MIDWAY-LYNCH	13	1,310	7	235	6	1,074					2	180
311 MIDWAY-POWEHLST	4	157	3	125	1	32						
312 MILL CREEK 13KV	1	1			1	1						
313 MILL CREEK-EASTLAND	11	586	5	453	3	10					3	123
314 MILL CREEK-KUEBLER	2	329	2	329								
315 MOLALLA-BUCKAROO	4	46	1	1	3	45						

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

# 2014 Outages by Cause System

Page 10 of 18

Feeder Name	Equipment															
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Public		Planned	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
316 MOLALLA-FOREST	13	563	4	35	1	2					1	89	8	438		
317 MOLALLA-MARQUAM	21	81	12	62	6	11							3	7		
318 MOLALLA-YODER	15	570	1	15	9	39							7	540		
319 MRKT ST-ENGLEWD	1	9											2	12		
320 MRKT ST-FAIRGND	3	555	1	10									2	544		
321 MRKT ST-HAWTHNE	2	40	1	23	1	17							1	11		
322 MRKT ST-PARK																
323 MT ANGEL-EAST	3	77	1	16	2	61										
324 MT ANGEL-WEST	22	1,035	11	889	9	19							2	127		
325 MT PLS-CLAIRMONT	11	1,030	3	20									6	840	2	170
326 MT PLS-MT VIEW																
327 MT PLS-RIVRCRST	2	36	2	36												
328 MT PLS-SOUTHEND	3	175			1	2							1	85	1	89
329 MULINO-NORTH	1	4									1	310	1	4		
330 MULINO-SOUTH	8	131	3	46	2	46					1	2,412	6	42		
331 MULTNOMAH 13KV	7	10,535	6	10,496	1	39							1	18		
332 MULTNOMAH-13176	2	588	1	583	1	5										
333 MULTNOMAH-13177	10	1,737	6	1,358	4	379							2	7		
334 MULTNOMAH-13181	8	913	5	710	3	203										
335 MURRAYHILL 13KV	1	1	1	1												
336 MURRAYHL-KINTON	2	6,463	1	6,342			1	6,342					1	2	1	121
337 MURRAYHL-QUARRY																
338 MURRAYHL-REUSER																
339 MURRAYHL-TEAL	3	686	3	686									1	17		
340 N MARION FRONT	2	1,338	2	1,338			1	380								
341 N MARION-CROSBY	1	1	1	1												
342 N MARION-HUBBRD	1	369	1	369												
343 N MARION-MCLARN	13	849	10	780	2	68							3	50		
344 N PLAINS 13KV	23	2,220	15	2,044	6	167							2	10		
345 N PLAINS-M HILL	18	1,795	5	1,520	6	169							10	110		
346 NEWBERG-CHEHALM	19	981	9	786	6	79							4	21	2	103
347 NEWBERG-COLLEGE	2	81	2	81												
348 NEWBERG-DUNDEE	13	454	12	441	1	13										
349 NEWBERG-HOOVR PK	6	968	2	11	1	1							2	792	1	163
350 NORTHERN-11009	7	110	2	15	5	95							1	4		

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 11 of 18

Feeder Name	Equipment												Public Outs	Planned Outs
	Total System Outs		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element			
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
351 NORTHERN-11016														
352 NORTHERN-11071	4	336	1	142	1	31							2	164
353 OAK HILLS 13KV	8	6,337	7	6,305	1	31	3	5,328						
354 OAK HILLS-5 OAK	4	9,843	4	9,843			3	9,470						
355 OAK HILLS-BRIER	3	2,417	3	2,417			3	2,417					1	1
356 OAK HILLS-SMRST	6	7,885	6	7,885			3	7,846					1	10
357 OAK HILLS-WLKRD	5	11,269	5	11,269			3	10,912					1	1
358 OCKLEY GRN 4KV														
359 OK GRV-LK HARRT	6	154	1	9	1	3			1	17	2	130	1	12
360 OK GRV-WT WATER									1	18				1
361 ORENCO 13KV														
362 ORENCO PRIMATE	1	123	1	123									1	25
363 ORENCO-231ST	1	2,473	1	2,473										
364 ORENCO-AMBRLGLEN	4	69											4	69
365 ORENCO-BASELINE	5	215	1	7									3	49
366 ORENCO-WILKINS	3	18	3	18										2
367 ORIENT 13KV	19	3,711	14	2,385	2	6							4	1,320
368 ORIENT-BARLOW	11	4,263	6	3,713	4	138							2	451
369 OSWEGO-IRON MTN														
370 OSWEGO-MARYLHST	8	1,710	5	620									3	1,089
371 OSWEGO-PALATINE	5	35	1	5	3	30							1	0
372 OSWEGO-STAFFORD														
373 OXFORD 13KV	2	35			2	35								
374 OXFORD-FAIRVIEW	5	1,174	2	815	3	359								
375 OXFORD-LEE	4	223	2	220	2	3								
376 OXFORD-MADRONA	4	442	1	14	2	3							1	425
377 OXFORD-RURAL	1	9	1	9										
378 OXFORD-SHELTON														
379 PELTON-ROUND BUTTE														
380 PENIN PARK 4KV	3	75	2	73									1	2
381 PLSNT VALY 13KV	6	308	6	308										
382 PLSNT VALY-BXTR	6	175	1	95	4	66							1	14
383 PLSNT VALY-MOON	3	3,877	3	3,877										
384 PLSNT VALY-SUN	6	130	4	39	2	91							2	6
385 PORTLAND GRD W PUMPING														

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 12 of 18

Feeder Name	Equipment											
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
386 PORTSMTH-CARB	9	3,602	5	3,567	3	29					1	6
387 PORTSMTH-DISP												
388 PORTSMTH-WILL	9	3,927	6	3,868	3	60					2	537
389 PRGRS-GREENBURG	13	1,130	9	1,098	1	29					1	1
390 PRGRS-HALL											2	2
391 PRGRS-ROBINSON	9	8,700	7	8,624	1	19					2	146
392 PRGRS-SAWYER	4	367	1	360	3	7						
393 PRGRS-WSH SQ #1												
394 PRGRS-WSH SQ #2												
395 RAL H-DOGWOOD	2	6			2	6						
396 RAL H-MONTCLAIR	5	848	3	365	1	330					1	153
397 RAL H-OLESON RD	9	1,890	4	565	4	970					1	356
398 RAMAPO 13KV	7	1,600	3	1,546	3	53					1	1
399 RAMAPO-GILBERT	6	425	3	309	2	31					1	86
400 REDLAND 13KV	21	2,604	15	347	5	68					4	2,192
401 REDLAND-HENRICI	16	658	9	645	6	10					3	162
402 REED-BLANTON	14	1,935	10	578	2	18					2	1,339
403 REED-HAZELDALE	10	3,822	7	726	1	4					3	3,092
404 REED-INTEL #1												
405 REED-INTEL #2												
406 REED-INTEL #3												
407 REED-INTEL #4												
408 REED-TV HWY	4	2,128	3	2,126	1	2						
409 REEDVILLE-AUGUSTA	6	1,906	6	1,906								
410 ROCKWD 13KV	10	1,019	8	1,001	2	18					2	40
411 ROCKWD-AIRPT WY	1	14	1	14								
412 ROCKWD-BOEING												
413 ROCKWD-INDUSTR												
414 ROCKWD-REYNOLDS	4	521	1	6	2	21					1	495
415 ROCKWD-WILKES	1	6	1	6								
416 ROSEMONT-HIDDEN SPRINGS	8	1,175	8	1,175								
417 ROSEMONT-MOSSY BRAE	4	739	4	739							2	3
418 ROSEMONT-OVERLOOK	2	267	2	267								
419 ROSEWAY 13 KV	2	9	2	9								
420 ROSEWAY-ALEXNDR												

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 13 of 18

Feeder Name	Equipment										Public Outs	Planned Outs		
	Total System Outs		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation Outs		Loss of Transmission Outs		Human Element Outs	Hrs		
421 ROSEWAY-ESPLANA	3	419	3	419										
422 ROUND BUTTE SPILLWAY														
423 RUBY-13502	7	492	3	477	3	7			2	8,054	1	9		
424 RUBY-13503	8	3,908	7	3,905					2	1,743	2	18		
425 RVRGATE-11010														
426 RVRGATE-11011	6	3,522	2	3,059							5	1,174		
427 RVRGATE-PEARCY														
428 RVRGATE-SWIFT	1	2			1	2								
429 RVRVIW-FULTON	7	668	2	152	2	16					1	13		2 487
430 RVRVIW-MACADAM	5	477	5	477										
431 RVRVIW-TWILLIGR	1	106			1	106								
432 SALEM-13260	1	73	1	73			1	73						
433 SALEM-13261	1	88	1	88			1	88						
434 SALEM-13262	1	116	1	116			1	116						
435 SALEM-13263	2	570	2	570			1	248						
436 SALEM-13264	1	10	1	10			1	10						
437 SALEM-UNION	1	262	1	262			1	262			1	8		
438 SANDY 13KV	13	2,954	5	1,130	5	723					8	1,592		
439 SANDY-362ND	11	2,128	7	2,116	4	12					1	1		
440 SANDY-BLUFF	8	625	2	93	2	1					3	442	1	89
441 SANDY-WILDCAT	4	156	2	55	1	93					2	85		
442 SCHOLLS FERRY-KEMMER RD	1	41									1	41		
443 SCHOLLS FERRY-RAINBOW	11	611	5	29	3	8					6	580		
444 SCHOLLS FERRY-ROY ROGERS	3	243	3	243										
445 SCOGG-CHERRY G	5	3,339	1	8	3	516					2	2,821		
446 SCOGG-LAUREL W	13	140	5	22	8	119					2	2		
447 SCOTTSMILL 13KV	30	3,269	17	2,117	7	21					9	1,136		
448 SELLWD 13KV	5	14,768	2	14,756	1	2	1	14,686			3	62	1	1
449 SELLWD-KELOG PK	7	15,955	6	15,950	1	5	1	8,935			1	102		
450 SELLWD-WAVERLY	4	4,633	3	4,629			1	3,752			1	5		
451 SHERIDAN EAST	17	3,115	9	390	5	268					4	2,458		
452 SHERIDAN-KADELL	9	2,560	6	2,517	1	40	1	1,713			2	1	1	3
453 SILVERTON-NORTH	9	125	3	44	5	65					1	17		
454 SILVERTON-SOUTH	6	181	3	43	2	21					1	118		
455 SILVERTON-WEST	24	1,351	11	124	6	19					13	1,223		

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 14 of 18

Feeder Name	Equipment											
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
456 SIX COR-13359	16	15,321	9	15,107	6	153	1	12,176			1	62
457 SIX COR-13360	2	2,235	2	2,235			1	2,229				
458 SIX COR-BORCHER	7	5,683	5	5,609	2	74	1	5,583				
459 SIX COR-CHAPMAN	9	10,185	6	9,877	2	74	1	9,567			1	233
460 SIX CORNER-13KV	5	6,975	3	6,686	1	23	1	3,876			1	266
461 SMURFIT-NEWBERG												
462 SPRINGBK-FERNWWD	3	736	1	720	1	16					1	0
463 SPRINGBK-STPAUL	14	141	5	113	6	18					3	9
464 SPRINGBK-VILLA	2	423	2	423							1	2
465 SPRINGBK-ZIMRI	18	710	10	262	5	444					3	264
466 ST LOUIS-EAST	6	452			1	2					3	74
467 ST LOUIS-NORTH	14	57	8	37	6	20					2	375
468 ST LOUIS-WEST	13	2,592	5	37	6	32					4	2,529
469 ST MARY 13KV												
470 ST MARY-BETHANY												
471 ST MARY-BUTNER	7	6,113	2	738	4	70					1	5,306
472 ST MARY-ELMONIC	6	373	6	373								
473 ST MARY-JENKINS												
474 ST MARY-MILLIKN	4	64	2	63	2	1						
475 STEPHN-11001												
476 STEPHN-11020	1	39			1	39						
477 STEPHN-11054												
478 STEPHN-11055												
479 STEPHN-11092												
480 STEPHN-11093												
481 STEPHN-11094												
482 STEPHN-11095												
483 STEPHN-11097												
484 STEPHN-11098												
485 STEPHN-11099												
486 SULL-ROBINWOOD	3	64			3	64					1	3
487 SULL-SALAMO	6	1,763	6	1,763								
488 SULL-SUSSEX	5	68			4	25					1	43
489 SULL-WILLAMETTE	9	629	6	334	1	3					2	292
490 SULLIVAN-TANNER	2	171									2	171

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 15 of 18

Feeder Name	Equipment															
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Public Outs	Planned Outs	Hrs	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs				
491 SULZER 115A																
492 SULZER 115B																
493 SULZER BINGHAM																
494 SUMMIT-GOVT CAMP	3	74	1	59	2	15	1	59	2	1,399			1		0	
495 SUMMIT-MEADOWS	2	8	2	8			1	2	2	39						
496 SUMMIT-SUMMIT	7	775	7	775			1	33	2	737						
497 SUNSET-BLANCHET	2	34											2		34	
498 SUNSET-COLFAX																
499 SUNSET-CORNELL																
500 SUNSET-DIX1																
501 SUNSET-DORION																
502 SUNSET-IDTB																
503 SUNSET-INTEL D1B1																
504 SUNSET-KOMATSU #1																
505 SUNSET-KOMATSU #2																
506 SUNSET-KOMATSU #3	2	398	2	398			2	398								
507 SUNSET-LANE																
508 SUNSET-LINDE PHASE 1																
509 SUNSET-MCCALL	1	8	1	8			1	8								
510 SUNSET-MEEK	1	83	1	83			1	83								
511 SUNSET-PAULING	2	392	2	392												
512 SUNSET-SPALDING																
513 SUNSET-WHITMAN																
514 SUNSET-YOUNG	1	1											1		1	
515 SWAN IS-BASIN																
516 SWAN IS-DOLPHIN	1	10	1	10												
517 SWAN IS-FREIGHTLINER																
518 SWAN IS-GOING	1	4			1	4										
519 SWAN IS-SHIPYRD																
520 SYLVAN-BARNES	6	606	2	592	3	12							1	5	1	3
521 SYLVAN-PATTON	8	750	1	102	5	487							2	63	1	115
522 TABOR 13KV	1	61													1	61
523 TABOR-82ND AV	5	62			4	59							1	3		
524 TABOR-HOSPITAL	1	64												1		64
525 TEK 13KV																

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 16 of 18

Feeder Name	Equipment										Public Outs	Planned Outs	
	Total System Outs		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs
526 TEK-HOCKEN													
527 TEK-NORTH													
528 TEK-SHANNON	4	323	3	276	1	47							
529 TEK-SOUTH	5	648	4	638	1	10							
530 TEK-WEST													
531 TEMP-NORTH													
532 TEMP-SOUTH	1	1,335	1	1,335									
533 TIGARD - 13 KV	5	4,551	5	4,551									
534 TIGARD-13336	1	4	1	4									
535 TIGARD-13337	4	381	1	3	3	378							
536 TIGARD-13361													
537 TIGARD-13362	12	3,025	11	2,979							1	45	
538 TNCTR-LAWNFIELD	3	146	3	146									
539 TNCTR-MONTEREY	5	105	1	3	4	101							
540 TNCTR-NORTH 13KV													
541 TNCTR-PRECISION													
542 TNCTR-SOUTH 13KV													
543 TNCTR-SUNNYBROOK													
544 TNCTR-VALLEY VW													
545 TROJAN PLNT E													
546 TUALATIN 13KV	1	11	1	11									
547 TUALATIN-AVERY	6	1,592	5	1,552							1	41	
548 TUALATIN-CIPOLE	1	25			1	25							
549 TUALATIN-HERMAN													
550 TUALATIN-IBACH	6	2,908	4	695	1	62					2	2,151	
551 TUALATIN-LEVETON													
552 TURNER 13KV	9	60	2	44	4	6					3	9	
553 TURNER-CASCADE	9	216	2	4	6	184					1	29	
554 TWILIGHT-BREMER	11	5,684	8	5,082	1	279	1	5,048			2	323	
555 UNIONVALE 13KV	25	239	8	47	15	52					5	93	1
556 UNIVRSITY-MILL	3	76	3	76									55
557 UNIVRSITY-TRADE	5	372	2	197	3	175					1	2	
558 URBAN-BARBUR	1	14			1	14							
559 URBAN-CAMPUS													
560 URBAN-CORBETT	2	1,060	1	1,033							1	27	

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 17 of 18

Feeder Name	Equipment											
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
561 URBAN-GAINES	3	18	1	1	1	3					1	14
562 URBAN-GIBBS												
563 URBAN-KELLY	3	13,750	3	13,750								
564 URBAN-LANDING												
565 URBAN-MEDICAL	1	1,017	1	1,017								
566 URBAN-OHSU												
567 W PTLD 13KV	3	5			2	3					2	285
568 W PTLD-72ND	4	329	2	316	1	2					1	12
569 W PTLD-NORTH	3	624	3	624								
570 W PTLD-PACIFIC	15	3,840	6	955	5	127					3	2,721
571 W UNION 13KV	7	974	5	763							1	2
572 W UNION-CORNELS	8	372	5	355	2	13					3	9
573 WACKER												
574 WACONDA 13KV	16	72	4	22	12	51					3	9
575 WACONDA-NORPAC												
576 WACONDA-RIVER RD	8	29	4	23	3	6					4	5
577 WALLACE RD 13KV	19	4,944	10	4,675	6	50	1	3,771			3	184
578 WALLACE-WILLOW LAKE											1	4
579 WELCHES 13KV	7	3,233	4	3,117	3	116	1	1,768	1	3,039	3	103
580 WELCHES-ZIG ZAG	19	4,355	12	4,299	4	22	1	1,953	1	2,645	4	36
581 WILLAMINA-BRIDGE	5	21	1	6	4	15						
582 WILLAMINA-BUELL	6	70	2	13	2	49					2	5
583 WILLAMINA-LUMBER	2	7	1	6	1	2					1	34
584 WILLBRDG #1	3	491	1	13			1	13			2	478
585 WILLBRDG #4	6	31	3	26	3	5	1	10				
586 WILSV-BOECKMAN												
587 WILSV-CHARBNEAU	6	1,580	5	1,567	1	13						
588 WILSV-CITY	2	705	1	686							2	21
589 WILSV-MENTORTEK												
590 WILSV-PARKWAY												
591 WILSV-VILLEBOIS												
592 WILSV-WEST	11	249	6	217	3	6					2	26
593 WOODBURN-CANNERY	1	1			1	1						
594 WOODBURN-EAST	9	101	4	91	5	10					1	2
595 WOODBURN-TOMLIN	9	92	5	73	1	4					4	21

Equip - Equipment Failures

Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## 2014 Outages by Cause System

Page 18 of 18

Feeder Name	Equipment															
	Total System		PGE Equip *		Cutout/Fuse /Arrestor Failure		Loss of Substation		Loss of Transmission		Human Element		Public		Planned	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
596 WOODBURN-WEST	5	29	1	21	3	5							1	3		
597 YAMHILL 13KV	17	983	6	552	6	42							5	388		
598 YAMHILL-CARLTON	19	3,315	4	379	7	31							8	2,905		
<b>Grand Total:</b>	<b>2,714</b>	<b>691,686</b>	<b>2,254</b>	<b>546,236</b>	<b>755</b>	<b>21,061</b>	<b>83</b>	<b>217,202</b>	<b>20</b>	<b>49,130</b>	<b>8</b>	<b>1,546</b>	<b>630</b>	<b>152,706</b>	<b>78</b>	<b>6,644</b>

Equip - Equipment Failures  
Hrs - # of customers \* duration hrs

Outs = Outages

\* For detailed PGE equipment, see Outage by PGE Equipment report

## **SECTION VI**

### **Outages by Cause-PGE Equipment**

This section provides the number of customer outages (frequency) and customer outage hours (duration) caused by PGE equipment failure events. The information is presented by feeder and attributed to one of nine categories of equipment failure. Definitions for the outages caused categories are shown below:

- UG Cond: Failure of underground conductor (NOTE: this does not include failure of splices or terminations)
- UG Clamp: Failure of underground splice or termination
- UG Xfmr: Failure of underground or pad mounted transformer
- OH Cond: Failure of overhead conductor (NOTE: this does not include failure of splices or terminations)
- OH Clamp: Failure of overhead splice or termination
- OH Xfmr: Failure of pole mounted transformer
- Sub: Failure of substation equipment
- Pole: Failure of pole
- PGE Cutout/Fuse Arrestor: Failure of fused cutout, fuse, or lightning arrestor

## 2014 Outages by PGE Equipment

Page 1 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole		
	* Sub-Total		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	
1 ABERN-CLACK HTS									3	63							3	26			
2 ABERN-ORE CITY	6	89							3	47											
3 ABERNETHY-TRANSIT	3	47																			
4 ALDER CT-ANKENY																					
5 ALDER CT-IRVING	2	468							2	389							2	468			
6 ALDER CT-LINCOLN	2	389																			
7 ALDER CT-STARK																					
8 ALDER CT-TAYLOR	3	137							2	52							1	84			
9 ALDER CT-YAMHILL																					
10 AMITY 13KV	12	112	1	6				2	14	4	64	1	7	1	2	3	19				
11 AMITY-BELLEVUE	15	197	3	42				2	10	7	22	2	105			1	18				
12 ARLETA-52ND ST	5	460	1	4						3	430						1	25			
13 ARLETA-FOSTER	2	5								1	1						1	4			
14 ARLETA-HAROLD	5	139								2	12						3	127			
15 ARLETA-POWELL	5	507								1	222	1	2	1	78	2	205				
16 ARLETA-STEELE	2	305						1	192								1	113			
17 B LAKE-SUNDIAL	6	1,758	5	46															1	1,711	
18 B LAKE-TOYOTNSO	1	75																		1	75
19 BANKS 13KV	8	1,940								3	62	4	321							1	1,557
20 BANKS-CEDAR CYN	9	5,282	1	48				1	296	2	54	1	176	1	5	2	13	1	4,690		
21 BARNES-BATLCLKR	1	11										1	11								
22 BARNES-BOONE	3	217	1	211						1	2	1	3								
23 BARNES-COMMERCL	6	841	3	421				1	57	1	1	1	362								
24 BARNES-SUNNYSID	10	1,754	5	1,147				3	264	1	2	1	340								
25 BELL-FLAEL	3	62								2	14	1	48								
26 BELL-JOHNSN CRK	1	1										1	1								
27 BELL-KENDALL	1	5															1	5			
28 BELL-KING	3	91								1	13	1	47							1	31
29 BELL-SOUTHGATE																					
30 BELL-WICHITA	4	90								1	6						3	84			
31 BELMONT 4KV																					
32 BETHANY-BURTON	2	229								1	33								1	197	
33 BETHANY-GERMANTOWN	3	377	1	24													1	4	1	349	
34 BETHANY-KAISER	3	494	2	155															1	339	
35 BETHANY-LAIDLAW	4	9,864						1	18			2	9,579						1	267	

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead  
 Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 2 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole	
	* Sub-Total	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs								
36 BETHANY-SPRINGVILLE	1	209															1	209		
37 BETHANY-THOMPSON	3	544	2	376					1	401	3	8					1	168		
38 BETHEL-FRUTLAND	6	2,882	1	7														1	2,467	
39 BETHEL-GEER	8	467	1	13							5	105	1	343			1	6		
40 BETHEL-MCLAY	3	65	1	56							1	1					1	8		
41 BLUE LAKE 13 KV	4	10,467	1	6					1	315	1	3					1	10,144		
42 BOONS-GOODALL	9	4,377	7	4,131									1	245					1	1
43 BOONS-KRUSEWAY	1	39	1	39																
44 BOONS-LK GROVE	7	374	1	249					1	57	1	8	1	3	1	4	2	54		
45 BOONS-MT PARK	7	7,938	5	7,823					1	96	1	20								
46 BOONS-WMBLY PK	4	466											3	465			1	1		
47 BORING-282ND AV	9	183									5	118	1	39	1	0	2	27		
48 BORING-CITY	9	3,370	2	3,119							3	235					4	17		
49 BORING-TELFORD	8	118									3	5	2	63	1	3	2	47		
50 BRIGHTWD 13KV	7	192	2	178							2	3	1	4			2	7		
51 BRIGHTWD-N BANK	2	66	1	62							1	4								
52 BROOKWOOD 13KV	1	4,072											1	4,072						
53 BROOKWOOD-BRWCK	2	16	1	13									1	3						
54 BROOKWOOD-SUNRS																				
55 BVRTN-ALLEN	3	53							1	21					1	20	1	12		
56 BVRTN-JAMIESON																				
57 BVRTN-NORTHWEST	1	8							1	8										
58 BVRTN-W SLOPE	4	461	1	8				1	10	1	1	1	442							
59 CANBY-13643	9	2,523	1	20						4	76	1	42	1	0	1	3	1	2,382	
60 CANBY-13644	5	878								4	7							1	870	
61 CANBY-BUTTEVLE	5	56	1	28						2	5					2	24			
62 CANYON 13KV	1	14										1	14							
63 CANYON-13114																				
64 CANYON-13115																				
65 CANYON-13116																				
66 CANYON-13117																				
67 CANYON-13118PSU																				
68 CANYON-13119PSU																				
69 CANYON-13120																				
70 CANYON-13121																				

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 3 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole	
	* Sub-Total	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs								
71 CANYON-13122																				
72 CANYON-13123																				
73 CANYON-13124																				
74 CANYON-13125																				
75 CANYON-13133																				
76 CANYON-13134																				
77 CANYON-13135																				
78 CANYON-13136																				
79 CANYON-21ST AVE	2	128								2 128										
80 CANYON-23RD AVE	6	140								3 8	1 96				2 36					
81 CANYON-BURNSIDE	4	793							1 516	2 126	1 151									
82 CARVER 13 KV	10	622	2 428						4 29	3 108	1 58									
83 CARVER-ALMOND	1	4								1 4										
84 CARVER-NORTH																				
85 CARVER-RIVRBEND																				
86 CARVER-SOUTH	1	3								1 3										
87 CARVER-WOODS	5	472	1 460							3 10	1 2									
88 CEDAR HILLS 13KV																				
89 CEDAR-LEAHY	2	194								1 4	1 190									
90 CEDAR-SHOP CEN	6	382	5 380							1 3										
91 CEDAR-SKYLINE	1	45						1 45												
92 CEDAR-ST VINCNT	2	86									2 86									
93 CEDAR-SYLVAN	3	343								2 15					1 328					
94 CLACK-EVELYN	2	1,181								1 1	1 1,180									
95 CLACK-GLADSTONE	10	562	5 453					1 3	2 91						2 14					
96 CLACK-JENNIFER	4	37						3 35	1 2											
97 CLACK-TOLBERT	4	5,872	3 5,854								1 18									
98 CLAXTAR 13KV																				
99 CLAXTAR-HAYSVIL																				
100 CLAXTAR-RIDGE	7	663	5 469					2 195		1 4					1 5					
101 CNTNNIL 13KV	5	193	3 184							4 153	1 2									
102 CNTNNIL-BARKER	6	180						1 25												
103 CNTNNIL-BRACRFT	2	81								2 81										
104 CNTNNIL-TREEAND	6	577						1 176	2 12	1 17	1 12	1 359								
105 COFFEE CREEK-FREEMAN	2	8							1 5						1 4					

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 4 of 18

Feeder Name	Equipment																																				
	<u>* Sub-Total</u>		Outs	Hrs	UG Cond	Outs	Hrs	UG Clamp	Outs	Hrs	UG Xfmr	Outs	Hrs	PGE Cutout/Fuse /Arrestor Failure	Outs	Hrs	OH Cond	Outs	Hrs	OH Clamp	Outs	Hrs	OH Xfmr	Outs	Hrs	Sub	Outs	Hrs	Pole	Outs	Hrs						
106 COFFEE CREEK-HOLIDAY	<b>9</b>	<b>870</b>			8	869								1	1																						
107 COLTON-DHOOGHE	<b>4</b>	<b>17</b>												1	4			2	7			1	7														
108 COLTON-GRAYS HL	<b>5</b>	<b>432</b>												2	5					1	2		2	425													
109 CORNELIUS 13KV	<b>12</b>	<b>647</b>			4	105					3	469		4	21		1	53																			
110 CORNELIUS-ADAIR	<b>1</b>	<b>1</b>												1	1																						
111 CORNELIUS-VRBRT	<b>7</b>	<b>9,944</b>			1	4,033								4	53		1	5,486											<b>1</b>	<b>372</b>							
112 CORNELL-BLUFFS	<b>5</b>	<b>2,161</b>			3	698					1	8																									
113 CORNELL-SALTZMAN	<b>5</b>	<b>2,423</b>			2	585					2	1,163																		<b>1</b>	<b>675</b>						
114 CORNELL-WESTLAWN	<b>8</b>	<b>3,213</b>			1	458					1	105		3	971		1	38		1	790									<b>1</b>	<b>852</b>						
115 CULVER 13KV																																					
116 CULVER-GAFFIN																																					
117 CULVER-SANYO #1																																					
118 CULVER-SANYO #2																																					
119 CURTIS 13KV	<b>1</b>	<b>0</b>																														<b>1</b>	<b>0</b>				
120 CURTIS-11077																																					
121 DAYTON-EAST	<b>5</b>	<b>189</b>			2	71								1	2		1	113				1	4														
122 DAYTON-LAFAYETT	<b>4</b>	<b>72</b>			1	63								2	3							1	7														
123 DAYTON-S AND W	<b>7</b>	<b>26</b>												3	6				2	7		2	13														
124 DELAWARE-DENVER	<b>4</b>	<b>7,556</b>												1	36				2	359		1	7,160														
125 DELAWARE-INTER	<b>2</b>	<b>1,865</b>												1	143																	<b>1</b>	<b>1,721</b>				
126 DELAWARE-LOMBRD	<b>6</b>	<b>10,263</b>												4	320		1	2														<b>1</b>	<b>9,941</b>				
127 DENNY-EAST	<b>6</b>	<b>426</b>			3	350								3	76																						
128 DENNY-NORTH	<b>1</b>	<b>105</b>			1	105																															
129 DENNY-SOUTH	<b>2</b>	<b>650</b>			2	650																															
130 DENNY-WEST	<b>6</b>	<b>4,046</b>			3	222					1	365						1	3,422				1	37													
131 DILLEY-13KV	<b>9</b>	<b>71</b>												6	20								1	7								<b>2</b>	<b>44</b>				
132 DILLEY-SPRINGHL																																					
133 DUNNS C 13 KV	<b>5</b>	<b>10</b>												4	8		1	2																			
134 DUNNS C-KELSO	<b>1</b>	<b>2</b>			1	2																															
135 DURHAM 13KV																																					
136 DURHAM-BONITA	<b>1</b>	<b>11</b>			1	11																															
137 DURHAM-BRIDGEPORT																																					
138 DURHAM-SATTLER	<b>9</b>	<b>1,129</b>			7	1,110					1	5		1	14																						
139 DURHAM-SOUTH																																					
140 E-11021					<b>1</b>	<b>15</b>																												<b>1</b>	<b>15</b>		

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfrm = Transformer  
 Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 5 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole			
	<u>* Sub-Total</u>		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs		
141 E-11039																						
142 E-11040	2	114							1	2								1	113			
143 E-11041	2	107											1	2				1	105			
144 E-11042																						
145 E-11043	1	30																1	30			
146 E-11047	2	94							1	1								1	92			
147 E-11064	1	10																1	10			
148 E-13139	1	3																		1	3	
149 E-13140	2	50							1	4							1	46				
150 E-13141																						
151 E-13144	3	54	2	45					1	9												
152 E-13145																						
153 E-13148																						
154 E-13149																						
155 E-13150	1	148						1	148													
156 EAGLE CR-BARTON	4	588									1	31	2	487			1	70				
157 EAGLE CR-RIVRML	2	18										2	55			1	9	1	8			
158 EASTPORT-76TH	4	105											1	16				1	47		1	2
159 EASTPORT-PLAZA	2	22															1	6				
160 ELMA 13KV	1	116	1	116																		
161 ELMA-4 CORNERS	2	110									1	2			1	108						
162 ELMA-HUDSON	3	211	2	210																		
163 ELMA-STATE 13KV																						
164 ESTACADA 13KV	3	801						1	748	2	53											
165 ESTACADA-FARADY	14	142	3	106						8	32	2	2	1	2							
166 FAIRMT-CNDLARIA	3	236	1	227						1	3						1	6				
167 FAIRMT-MISSION	12	3,035	4	1,581					1	215	5	1,172					2	67				
168 FAIRVIEW 13 KV	1	59									1	59										
169 FAIRVIEW-CLRCK																						
170 FAIRVIEW-K CLUB	2	102						1	39			1	63									
171 FAIRVIEW-TROUTD	9	843							1	90	4	731					3	18			1	4
172 FAIRVIEW-W VILL	4	443	1	174					1	80			1	184			1	5				
173 FARGO 13KV	13	827	5	800						7	26				1	2						
174 G HOME-MCKAY	2	145	1	75				1	70													
175 G HOME-METZGER	10	2,180	3	908					2	987	1	78	4	207								

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead  
 Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 6 of 18

Feeder Name	Equipment													
	<u>* Sub-Total</u>		UG Cond	UG Clamp	UG Xfmr	PGE Cutout/Fuse /Arrestor Failure	OH Cond	OH Clamp	OH Xfmr	Sub	Pole			
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Outs	Hrs	Outs	Outs	Hrs
176 GALES CRK 13KV	8	92	1	8			4	11	2	71	1	2		
177 GLENCOE-GLISAN	3	97					1	94	2	2				
178 GLENCOE-PROVID														
179 GLENCOE-SUNNY	2	39					1	19	1	20				
180 GLISAN-FAB 2A														
181 GLISAN-UTIL 1B														
182 GLNCLN-BRIDLMIL	11	12,046	1	114			1	3	5	5,807			3	776
183 GLNCLN-SUNSET	3	116					3	116						
184 GLNDOVEER-13596	4	3,180	2	3,156			2	24						
185 GLNDOVEER-13597	3	174					2	32	1	142				
186 GLNDOVEER-13598	2	30					2	30						
187 GLNDOVEER-13599	1	484			1	484								
188 GLNDOVEER-CLFGT	2	396	1	382			1	14						
189 GLNDOVEER-NEAST														
190 GRAND AV 4KV														
191 GRND RND-AGENCY	2	106					1	50						1
192 GRND RND-FORTHL	11	493					5	82	3	390	1	4	2	17
193 HABRTN-BURLINTN	23	30,981	2	2,887			14	481	1	3	3	36	2	131
194 HABRTN-LINNTON	2	7,970					1	7						1
195 HARBORTON 13KV	2	244												2
196 HARMONY 13KV	5	240					2	68	3	171				244
197 HARMONY-INTERNATIONA L														
198 HARMONY-LAKE	3	1,627	1	104			1	72	1	1,451				
199 HARMONY-LINNWOD	6	993	2	935			3	55	1	3				
200 HARMONY-MILWAKI	7	1,581	6	1,576			1	5						
201 HARMONY-THIESEN	1	2					1	2						
202 HARRISON 13KV	2	1					2	1						
203 HARRISON-DAVIS	2	39					2	39						
204 HARRISON-IVON	2	6					1	2			1	3		
205 HEMLOCK 13KV	12	1,883	8	1,524		1	350	1	1		1	2	1	6
206 HEMLOCK-FREMONT														
207 HEMLOCK-MASON														
208 HILLCREST 13KV														
209 HILLCREST-CASCADIA														
210 HILLCREST-REED														

Hrs - # of customers \* duration hrs  
Outs = Outages

UG = Underground  
OH = Overhead

Xfmr = Transformer  
Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 7 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole		
	* Sub-Total		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	
211 HILLCREST-SOUTH																					
212 HILLS-DAIRY CREEK	4	635							1	61	2	552	1	23							
213 HILLS-DENNIS																					
214 HILLS-JACKSON	6	330	3	181			1	143	1	2							1	4			
215 HILLS-LAUREL	16	933	3	24			1	8	8	300	1	588	1	1	1	1	6			1	5
216 HILLS-SCHOLLS	2	8														2	8				
217 HOGAN N 13KV	4	104	2	100					1	1										1	2
218 HOGAN N-BRGDOON	6	2,031	5	1,654			1	377													
219 HOGAN N-LINKS	11	419	3	223					2	6	3	3	1	1	2	186					
220 HOGAN N-SLQUIST	6	146	4	65			1	71							1	10					
221 HOGAN S-CLEVND	4	447	3	445					1	1											
222 HOGAN S-LAWRNCE	11	1,093	10	1,091					1	1											
223 HOGAN S-MAIN	7	1,679	6	1,601			1	78													
224 HOGAN S-PAROPA	10	1,454	8	1,339			1	48	1	68											
225 HOGAN S-WALLULA	6	1,534	3	469				1	838								2	227			
226 HOLGATE 13KV	3	249								1	94			1	16	1	138				
227 HOLGATE-BYBEE	5	1,023	1	572			1	301	2	38						1	112				
228 HOLGATE-GIDEON																					
229 HOLGATE-KENLWOR	6	956	2	421					3	327	1	207									
230 HOLGATE-RHONE	6	84	1	8					5	76											
231 HUBER 13KV	7	834	3	422			1	362	1	14	1	5				1	31				
232 HUBER-BANY	12	969	7	455			3	501	2	14											
233 HUBER-FRMINGTON	1	49	1	49																	
234 HUBER-KINNAMON	9	1,675	5	517					1	9	2	1,128				1	21				
235 HUBER-MARYVILLE	8	1,041	5	876			1	3	1	2						1	160				
236 HYDN IS-MALAND																					
237 HYDN IS-N SHORE	1	149	1	149																	
238 HYDN IS-S SHORE																					
239 INDIAN-KEIZER	1	33							1	33											
240 INDIAN-LABISH	10	385						1	333	7	38					2	13				
241 INDIAN-NORTH	10	1,193	1	14						6	25				2	1,148	1	5			
242 INDIAN-STATION	6	1,383	5	773				1	610												
243 INDIAN-WEST	6	51						1	38	5	13										
244 ISLAND 13KV																					
245 ISLAND-13180	4	229							2	12	2	217									

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 8 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole		
	* Sub-Total		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	
246 ISLAND-13187	2	519									2	519									
247 ISLAND-13188	9	968	3	794					1	1	1	102	2	58	2	14					
248 JEN LDG 13KV	6	307	2	253					4	54											
249 JEN LDG-MELDRUM	5	162	3	128					2	35											
250 JEN LDG-O GROVE	2	26							1	21							1	5			
251 JEN LDG-WEBSTER	5	1,023	3	776			1	211								1	36				
252 KELLEY POINT-LEDBETTER	1	350															1	350			
253 KELLEY POINT-SOLAR1	1	2																1	2		
254 KELLEY POINT-SOLAR2	1	6																1	6		
255 KELLEY PT 13 KV	1	28																1	28		
256 KING CTY-BULL MT	2	727	1	639													1	88			
257 KING CTY-FISCHER	1	9															1	9			
258 KING CTY-HAZEL B																					
259 KING CTY-NORTH																					
260 KING CTY-SUMERFL	2	128	1	84			1	44													
261 KLY BU-BINNSMED	4	591							4	591											
262 KLY BU-FAIRLAWN	4	353	1	293					1	6	1	52							1	3	
263 KLY BU-MALL 205	3	1,944	1	1,691					2	253											
264 KLY BU-MC GREW	4	404	1	132					2	90						1	183				
265 KLY PT-MARINEDR	1	12																1	12		
266 KLY PT-SIMMONS	4	411	1	293					2	38								1	80		
267 LAKE LABISH 4KV																					
268 LELAND-BEAVERC	15	7,387	6	1,060					4	162	1	324				2	9	1	5,827	1	4
269 LELAND-CARUS	15	1,963	2	20					5	16	5	1,915				1	2			2	11
270 LELAND-KELM	2	3,617	1	8					6	389			1	22	4	568			1	3,609	
271 LENTS-13101	11	979							1	2											
272 LENTS-HAPPY VAL	3	1,272					2	1,270													
273 LENTS-MT SCOTT	1	10														1	10				
274 LENTS-NORTH																					
275 LIB-BROWNING	1	281	1	281																	
276 LIB-LONE OAK	8	1,068	6	672			2	395													
277 LIB-MORNINGSIDE	6	238	1	66					3	28						2	144				
278 LIB-ROSEDALE	5	1,340	2	1,319					2	4						1	17				
279 LIB-VISTA	2	36	1	6					1	30						1	1				
280 LIBERAL 13KV	6	138	1	12					3	14									1	111	

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 9 of 18

Feeder Name	Equipment																															
	<u>* Sub-Total</u>		Outs	Hrs	UG Cond	Outs	Hrs	UG Clamp	Outs	Hrs	UG Xfmr	Outs	Hrs	PGE Cutout/Fuse /Arrestor Failure	Outs	Hrs	OH Cond	Outs	Hrs	OH Clamp	Outs	Hrs	OH Xfmr	Outs	Hrs	Sub	Outs	Hrs	Pole	Outs	Hrs	
281 LIBERAL-SAWMILL	1	0																											1	0		
282 LIBERTY-SKYLINE	13	3,098	7	1,873										4	103	2	1,123												1	67		
283 MAIN-AIRPORT	6	685	2	203							2	368		1	47																	
284 MAIN-BENTLEY	7	426	3	193							2	192		2	40																	
285 MAIN-EXPRESS	3	354	1	162							1	153		1	39																	
286 MAIN-GRIFFIN																																
287 MAIN-JFS1																																
288 MAIN-JONES FARM																																
289 MAIN-RVR RD	9	482	3	459							1	5		4	16												1	3				
290 MC CL-COTTAGE	3	3,736												1	22													1	102	1	3,612	
291 MC CL-FRONT ST																																
292 MC CL-HOLLYWOOD	1	32																										1	32			
293 MCGILL-LSAIR1A																																
294 MCMINNVILLE W AND L																																
295 MERIDIAN 13KV	8	44									1	8		4	12		2	20								1	5					
296 MERIDIAN-65TH																																
297 MERIDIAN-BORLND	3	240	1	223							1	14															1	3				
298 MERIDIAN-CHILDS	1	54																														
299 MERIDIAN-LAKEVIEW	1	2												1	2																	
300 MERIDIAN-NYBERG																																
301 MERIDIAN-PLKNGTN	4	424	4	424																												
302 MERIDIAN-SAGERT	3	594	2	356										1	238																	
303 MIDGROVE-BROWN	1	7	1	7																												
304 MIDGROVE-CHEMEK	1	72	1	72																												
305 MIDGROVE-CORDON	12	624	4	600										3	5	2	9	2	5	1	5											
306 MIDGROVE-SWEGLE	1	8	1	8																												
307 MIDGROVE-WEST	2	8																			1	1					1	7				
308 MIDWAY-DIVISION	8	285	1	41										2	11	2	227	3	6													
309 MIDWAY-DOUGLAS	4	466	3	448																	1	18										
310 MIDWAY-LYNCH	13	1,310	1	105							1	66		6	1,074	1	3								4	61						
311 MIDWAY-POWLHST	4	157									1	49		1	32					2	76											
312 MILL CREEK 13KV	1	1												1	1																	
313 MILL CREEK-EASTLAND	8	463	4	450										3	10	1	4															
314 MILL CREEK-KUEBLER	2	329	2	329																												
315 MOLALLA-BUCKAROO	4	46												3	45					1	1											

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead  
 Xfrm = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 10 of 18

Feeder Name	Equipment																																	
	<u>* Sub-Total</u>		Outs	Hrs	UG Cond	Outs	Hrs	UG Clamp	Outs	Hrs	UG Xfmr	Outs	Hrs	PGE Cutout/Fuse /Arrestor Failure	Outs	Hrs	OH Cond	Outs	Hrs	OH Clamp	Outs	Hrs	OH Xfmr	Outs	Hrs	Sub	Outs	Hrs	Pole	Outs	Hrs			
316 MOLALLA-FOREST	<b>5</b>	<b>37</b>			1	12								1	2							3	24											
317 MOLALLA-MARQUAM	<b>18</b>	<b>74</b>			1	8								6	11	6	36	1	3			4	16											
318 MOLALLA-YODER	<b>10</b>	<b>54</b>			1	15								9	39																			
319 MRKT ST-ENGLEWD																																		
320 MRKT ST-FAIRGND	<b>1</b>	<b>10</b>			1	10																												
321 MRKT ST-HAWTHNE	<b>2</b>	<b>40</b>												1	17	1	23																	
322 MRKT ST-PARK																																		
323 MT ANGEL-EAST	<b>3</b>	<b>77</b>												2	61							1	16											
324 MT ANGEL-WEST	<b>19</b>	<b>905</b>												1	7	9	19	4	850			4	24						<b>1</b>	<b>5</b>				
325 MT PLS-CLAIRMONT	<b>3</b>	<b>20</b>			3	20																												
326 MT PLS-MT VIEW																																		
327 MT PLS-RIVRCRST	<b>2</b>	<b>36</b>			1	16												1	20															
328 MT PLS-SOUTHEND	<b>1</b>	<b>2</b>												1	2																			
329 MULINO-NORTH																																		
330 MULINO-SOUTH	<b>5</b>	<b>92</b>												2	46	1	3					2	43											
331 MULTNOMAH 13KV	<b>7</b>	<b>10,535</b>			3	881								1	14	1	39	2	9,601															
332 MULTNOMAH-13176	<b>2</b>	<b>588</b>			1	583								1	5																			
333 MULTNOMAH-13177	<b>9</b>	<b>1,700</b>			5	1,320								4	379																			
334 MULTNOMAH-13181	<b>8</b>	<b>913</b>			1	9								3	203	1	225	1	230	2	246													
335 MURRAYHILL 13KV	<b>1</b>	<b>1</b>												1	1																			
336 MURRAYHL-KINTON	<b>1</b>	<b>6,342</b>																											<b>1</b>	<b>6,342</b>				
337 MURRAYHL-QUARRY																																		
338 MURRAYHL-REUSER																																		
339 MURRAYHL-TEAL	<b>3</b>	<b>686</b>												3	686																			
340 N MARION FRONT	<b>2</b>	<b>1,338</b>			1	958																							<b>1</b>	<b>380</b>				
341 N MARION-CROSBY	<b>1</b>	<b>1</b>																																
342 N MARION-HUBBRD	<b>1</b>	<b>369</b>																																
343 N MARION-MCLARN	<b>12</b>	<b>848</b>			4	721								2	68	1	13	2	4	3	42													
344 N PLAINS 13KV	<b>21</b>	<b>2,210</b>			4	23								6	167	7	1,799	1	198	3	23													
345 N PLAINS-M HILL	<b>11</b>	<b>1,690</b>												6	169	4	1,518					1	3											
346 NEWBERG-CHEHALM	<b>14</b>	<b>841</b>			5	619								6	79	1	131					2	12											
347 NEWBERG-COLLEGE	<b>2</b>	<b>81</b>												1	13							2	81											
348 NEWBERG-DUNDEE	<b>12</b>	<b>450</b>			8	432																1	1							<b>2</b>	<b>4</b>			
349 NEWBERG-HOOVR PK	<b>3</b>	<b>13</b>			1	7								1	1						1	4												
350 NORTHERN-11009	<b>7</b>	<b>110</b>												1	7			5	95															

Hrs - # of customers \* duration hrs

UG = Underground

Xfmr = Transformer

Cond = Conductor

Outs = Outages

OH = Overhead

Sub = Substation

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 11 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole	
	* Sub-Total	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs								
351 NORTHERN-11016																				
352 NORTHERN-11071	2	172							1	31					1	142				
353 OAK HILLS 13KV	8	6,337	1	107			3	870	1	31							3	5,328		
354 OAK HILLS-5 OAK	4	9,843					1	373									3	9,470		
355 OAK HILLS-BRIER	3	2,417															3	2,417		
356 OAK HILLS-SMRST	6	7,885	3	39													3	7,846		
357 OAK HILLS-WLKRD	5	11,269	2	358													3	10,912		
358 OCKLEY GRN 4KV																				
359 OK GRV-LK HARRT	2	12							1	3					1	9				
360 OK GRV-WT WATER																				
361 ORENCO 13KV																				
362 ORENCO PRIMATE	1	123	1	123																
363 ORENCO-231ST	1	2,473	1	2,473																
364 ORENCO-AMBRLGLEN																				
365 ORENCO-BASELINE	1	7									1	7								
366 ORENCO-WILKINS	1	6					1	6												
367 ORIENT 13KV	16	2,391	6	657			2	8	2	6	4	1,715	2	5						
368 ORIENT-BARLOW	10	3,851					1	5	4	138	2	3,664			3	43				
369 OSWEGO-IRON MTN																				
370 OSWEGO-MARYLHST	5	620									2	402			3	219				
371 OSWEGO-PALATINE	3	30							3	30										
372 OSWEGO-STAFFORD																				
373 OXFORD 13KV	2	35							2	35										
374 OXFORD-FAIRVIEW	5	1,174	1	800					3	359					1	15				
375 OXFORD-LEE	4	223							2	3					2	220				
376 OXFORD-MADRONA	3	17	1	14					2	3										
377 OXFORD-RURAL	1	9									1	9								
378 OXFORD-SHELTON																				
379 PELTON-ROUND BUTTE																				
380 PENIN PARK 4KV	2	73												1	67	1	6			
381 PLSNT VALY 13KV	6	308					1	2							4	30			1	
382 PLSNT VALY-BXTR	5	161	1	95					4	66									275	
383 PLSNT VALY-MOON	2	3,837					1	3,834			1	3								
384 PLSNT VALY-SUN	6	130	3	34			1	5	2	91										
385 PORTLAND GRD W PUMPING																				

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 12 of 18

Feeder Name	Equipment																																	
	<u>* Sub-Total</u>		Outs	Hrs	UG Cond	Outs	Hrs	UG Clamp	Outs	Hrs	UG Xfmr	Outs	Hrs	PGE Cutout/Fuse /Arrestor Failure	Outs	Hrs	OH Cond	Outs	Hrs	OH Clamp	Outs	Hrs	OH Xfmr	Outs	Hrs	Sub	Outs	Hrs	Pole	Outs	Hrs			
386 PORTSMTH-CARB	8	3,596			1	90						3	29		2	151							1	54					1	3,272				
387 PORTSMTH-DISP																																		
388 PORTSMTH-WILL	9	3,927			3	259						3	60										2	30					1	3,579				
389 PRGRS-GREENBURG	10	1,127			8	806						1	29																1	292				
390 PRGRS-HALL																																		
391 PRGRS-ROBINSON	8	8,642			7	8,624						1	19																					
392 PRGRS-SAWYER	4	367			1	360						3	7																					
393 PRGRS-WSH SQ #1																																		
394 PRGRS-WSH SQ #2																																		
395 RAL H-DOGWOOD	2	6												2	6																			
396 RAL H-MONTCLAIR	4	695			1	108								1	330								2	257										
397 RAL H-OLESON RD	8	1,535			3	461								4	970								1	104										
398 RAMAPO 13KV	6	1,599			2	1,528								3	53								1	19										
399 RAMAPO-GILBERT	5	339												2	31	1	300						2	8										
400 REDLAND 13KV	20	415			5	243						3	49	5	68	2	7	3	25				2	23										
401 REDLAND-HENRICI	15	655			2	615						2	11	6	10	3	13						2	6										
402 REED-BLANTON	11	584			8	469						1	96	2	18																			
403 REED-HAZELDALE	8	730			5	682								1	4	2	43																	
404 REED-INTEL #1																																		
405 REED-INTEL #2																																		
406 REED-INTEL #3																																		
407 REED-INTEL #4																																		
408 REED-TV HWY	4	2,128			1	50									1	2	2	2,075																
409 REEDVILLE-AUGUSTA	6	1,906			2	431								2	1,459								1	15			1	1						
410 ROCKWD 13KV	10	1,019			7	606								2	18	1	395																	
411 ROCKWD-AIRPT WY																																		
412 ROCKWD-BOEING																																		
413 ROCKWD-INDUSTR																																		
414 ROCKWD-REYNOLDS	3	26			1	6									2	21																		
415 ROCKWD-WILKES	1	6			1	6																												
416 ROSEMONT-HIDDEN SPRINGS	8	1,175			5	97								2	738								1	340										
417 ROSEMONT-MOSSY BRAE	4	739			2	708									2	267							1	24				1	7					
418 ROSEMONT-OVERLOOK	2	267																					1	2										
419 ROSEWAY 13 KV	2	9			1	7																												
420 ROSEWAY-ALEXNDR																																		

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead  
 Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 13 of 18

Feeder Name	Equipment																
	* Sub-Total		UG Cond	UG Clamp	UG Xfmr	PGE Cutout/Fuse /Arrestor Failure	OH Cond	OH Clamp	OH Xfmr	Sub	Pole						
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Outs	Hrs	Outs	Outs	Hrs	Outs	Hrs	
421 ROSEWAY-ESPLANA	3	419	2	359		1	59										
422 ROUND BUTTE SPILLWAY																	
423 RUBY-13502	8	18,537	2	83		3	7	1	393			2	18,054				
424 RUBY-13503	9	15,648	5	393	1	202						2	11,743	1	3,311		
425 RVRGATE-11010																	
426 RVRGATE-11011	2	3,059					1	3,055		1	4						
427 RVRGATE-PEARCY																	
428 RVRGATE-SWIFT	1	2				1	2										
429 RVRVIW-FULTON	4	169	1	150		2	16	1	3								
430 RVRVIW-MACADAM	4	397	2	389						2	8						
431 RVRVIW-TWILLIGR	1	106				1	106										
432 SALEM-13260	1	73										1	73				
433 SALEM-13261	1	88										1	88				
434 SALEM-13262	1	116										1	116				
435 SALEM-13263	2	570			1	322						1	248				
436 SALEM-13264	1	10										1	10				
437 SALEM-UNION	1	262										1	262				
438 SANDY 13KV	10	1,853	2	1,059			5	723	1	61	1	2			1	8	
439 SANDY-362ND	11	2,128	5	2,007		1	74	4	12			1	35				
440 SANDY-BLUFF	4	94				2	93	2	1								
441 SANDY-WILDCAT	3	148					1	93				1	10			1	45
442 SCHOLLS FERRY-KEMMER RD																	
443 SCHOLLS FERRY-RAINBOW	8	36	1	6		3	8	1	5			2	9			1	9
444 SCHOLLS FERRY-ROY ROGERS	3	243	2	13		1	230										
445 SCOGG-CHERRY G	4	523	1	8			3	516									
446 SCOGG-LAUREL W	13	140					8	119	2	12	1	2			2	8	
447 SCOTTS MILL 13KV	24	2,138	3	88		3	154	7	21	5	1,849	1	2	5	24		
448 SELLWD 13KV	3	14,758						1	2			1	70	1	14,686		
449 SELLWD-KELOG PK	7	15,955						1	5	3	6,605	1	332	1	78	1	8,935
450 SELLWD-WAVERLY	3	4,629	2	876										1	3,752		
451 SHERIDAN EAST	14	659	5	283		5	268	2	94	1	4	1	9				
452 SHERIDAN-KADELL	7	2,557	2	13		1	40	2	786			1	5	1	1,713		
453 SILVERTON-NORTH	8	109	1	34		1	9	5	65		1	1					

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 14 of 18

Feeder Name	Equipment																																	
	<u>* Sub-Total</u>		Outs	Hrs	UG Cond	Outs	Hrs	UG Clamp	Outs	Hrs	UG Xfmr	Outs	Hrs	PGE Cutout/Fuse /Arrestor Failure	Outs	Hrs	OH Cond	Outs	Hrs	OH Clamp	Outs	Hrs	OH Xfmr	Outs	Hrs	Sub	Outs	Hrs	Pole	Outs	Hrs			
454 SILVERTON-SOUTH	4	39	2	18								2	21																					
455 SILVERTON-WEST	17	143	2	25					2	11		6	19	1	2							5	81					1	5					
456 SIX COR-13359	14	12,798	1	224					3	189		6	153	1	17							2	39			1	12,176							
457 SIX COR-13360	2	2,235	1	7										2	74												1	2,229						
458 SIX COR-BORCHER	7	5,683	2	15										1	23	1	36	2	288	3	22	1	9,567			2	11	1	5,583					
459 SIX COR-CHAPMAN	8	9,951												2	74																			
460 SIX CORNER-13KV	4	6,709	1	2,774										1	16	1	720																	
461 SMURFIT-NEWBERG														6	18	2	91	1	2															
462 SPRINGBK-FERNWD	2	735												1	2																1	2		
463 SPRINGBK-STPAUL	11	131	1	18										5	444	1	13						1	5										
464 SPRINGBK-VILLA	1	105	1	105										1	2																			
465 SPRINGBK-ZIMRI	15	705	6	229					2	15		6	20	1	2	2	2	2	2	2	2	1	16											
466 ST LOUIS-EAST	1	2												6	32	1	4																	
467 ST LOUIS-NORTH	13	55	2	27										4	70																			
468 ST LOUIS-WEST	9	61	1	9										1	39																			
469 ST MARY 13KV																																		
470 ST MARY-BETHANY																																		
471 ST MARY-BUTNER	6	807	4	194					2	179		2	1									1	434					1	304					
472 ST MARY-ELMONIC	6	373												1	39																			
473 ST MARY-JENKINS																																		
474 ST MARY-MILLIKN	4	64	2	63										2	1																			
475 STEPHN-11001																																		
476 STEPHN-11020	1	39												1	39																			
477 STEPHN-11054																																		
478 STEPHN-11055																																		
479 STEPHN-11092																																		
480 STEPHN-11093																																		
481 STEPHN-11094																																		
482 STEPHN-11095																																		
483 STEPHN-11097																																		
484 STEPHN-11098																																		
485 STEPHN-11099																																		
486 SULL-ROBINWOOD	3	64												3	64																			
487 SULL-SALAMO	6	1,763	5	1,713					1	50		4	25																					
488 SULL-SUSSEX	4	25																																

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead  
 Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 15 of 18

Feeder Name	Equipment														
	<u>* Sub-Total</u>		<u>UG Cond</u>	<u>UG Clamp</u>	<u>UG Xfmr</u>	<u>PGE Cutout/Fuse /Arrestor Failure</u>		<u>OH Cond</u>	<u>OH Clamp</u>	<u>OH Xfmr</u>	<u>Sub</u>	<u>Pole</u>			
	Outs	Hrs	Outs	Hrs	Outs	Outs	Hrs	Outs	Hrs	Outs	Outs	Hrs	Outs	Hrs	
489 SULL-WILLAMETTE	7	337	1	147		1	3	3	159	2	28				
490 SULLIVAN-TANNER															
491 SULZER 115A															
492 SULZER 115B															
493 SULZER BINGHAM															
494 SUMMIT-GOVT CAMP	3	74				2	15					1	59		
495 SUMMIT-MEADOWS	2	8						1	7			1	2		
496 SUMMIT-SUMMIT	7	775	3	377				1	265	1	4	1	33	1	97
497 SUNSET-BLANCHET															
498 SUNSET-COLFAX															
499 SUNSET-CORNELL															
500 SUNSET-D1X1															
501 SUNSET-DORION															
502 SUNSET-IDTB															
503 SUNSET-INTEL D1B1															
504 SUNSET-KOMATSU #1															
505 SUNSET-KOMATSU #2															
506 SUNSET-KOMATSU #3	2	398											2	398	
507 SUNSET-LANE															
508 SUNSET-LINDE PHASE 1															
509 SUNSET-MCCALL	1	8											1	8	
510 SUNSET-MEEK															
511 SUNSET-PAULING	1	242	1	242											
512 SUNSET-SPALDING															
513 SUNSET-WHITMAN															
514 SUNSET-YOUNG															
515 SWAN IS-BASIN															
516 SWAN IS-DOLPHIN	1	10										1	10		
517 SWAN IS-FREIGHTLINER															
518 SWAN IS-GOING	1	4					1	4							
519 SWAN IS-SHIPYRD															
520 SYLVAN-BARNES	5	604					3	12	2	592					
521 SYLVAN-PATTON	5	487					5	487							
522 TABOR 13KV															
523 TABOR-82ND AV	4	59					4	59							

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 16 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole			
	* Sub-Total		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs		
524 TABOR-HOSPITAL																						
525 TEK 13KV																						
526 TEK-HOCKEN																						
527 TEK-NORTH																						
528 TEK-SHANNON	4	323	1	51				1	6	1	47	1	218									
529 TEK-SOUTH	5	648						3	256	1	10	1	382									
530 TEK-WEST																						
531 TEMP-NORTH																						
532 TEMP-SOUTH																						
533 TIGARD - 13 KV	5	4,551	1	378								2	3,801			2	373					
534 TIGARD-13336	1	4										1	4									
535 TIGARD-13337	4	381								3	378					1	3					
536 TIGARD-13361																						
537 TIGARD-13362	11	2,979	10	2,766				1	214													
538 TNCTR-LAWNFIELD	3	146	1	142								2	4									
539 TNCTR-MONTEREY	5	105	1	3						4	101											
540 TNCTR-NORTH 13KV																						
541 TNCTR-PRECISION																						
542 TNCTR-SOUTH 13KV																						
543 TNCTR-SUNNYBROOK																						
544 TNCTR-VALLEY VW																						
545 TROJAN PLNT E																						
546 TUALATIN 13KV	1	11						1	11													
547 TUALATIN-AVERY	5	1,552	3	1,080				2	472			1	25									
548 TUALATIN-CIPOLE	1	25																				
549 TUALATIN-HERMAN																						
550 TUALATIN-IBACH	5	757	4	695						1	62											
551 TUALATIN-LEVETON																						
552 TURNER 13KV	6	50								4	6					2	44					
553 TURNER-CASCADE	8	188								6	184	1	3							1	1	
554 TWILIGHT-BREMER	9	5,361	3	18						1	279	2	4			2	13	1	5,048			
555 UNIONVALE 13KV	23	99	2	17				1	10	15	52	4	14			1	6					
556 UNIVRSITY-MILL	1	57														1	57					
557 UNIVRSITY-TRADE	5	372								3	175	1	104			1	93					
558 URBAN-BARBUR	1	14								1	14											

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead  
 Xfmr = Transformer  
 Sub = Substation

Cond = Conductor

\* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 17 of 18

Feeder Name	Equipment		UG Cond		UG Clamp		UG Xfmr		PGE Cutout/Fuse /Arrestor Failure		OH Cond		OH Clamp		OH Xfmr		Sub		Pole		
	* Sub-Total	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs	Outs Hrs								
559 URBAN-CAMPUS																					
560 URBAN-CORBETT	1	1,033																		1 1,033	
561 URBAN-GAINES	2	4							1 3		1 1										
562 URBAN-GIBBS																					
563 URBAN-KELLY	1	9,709	1 9,709																		
564 URBAN-LANDING																					
565 URBAN-MEDICAL																					
566 URBAN-OHSU																					
567 W PTLD 13KV	2	3							2 3												
568 W PTLD-72ND	3	318	1 285						1 2							1 31					
569 W PTLD-NORTH	3	624						2 611													
570 W PTLD-PACIFIC	11	1,082	1 26						5 127	1 908	1 7	1 4							2 10		
571 W UNION 13KV	5	763	4 581				1 182		2 13							2 8					
572 W UNION-CORNELS	7	368	3 347																		
573 WACKER																					
574 WACONDA 13KV	15	67	1 12	1 2					12 51	1 2											
575 WACONDA-NORPAC																					
576 WACONDA-RIVER RD	7	28						1 5	3 6	1 4	1 3	1 11									
577 WALLACE RD 13KV	16	4,726	5 426					1 6	6 50	1 467	1 3	1 4	1 3,771								
578 WALLACE-WILLOW LAKE																					
579 WELCHES 13KV	6	3,220							3 116	1 1,191			1 145	1 1,768							
580 WELCHES-ZIG ZAG	16	4,321	1 269						4 22	8 2,057			2 20	1 1,953							
581 WILLAMINA-BRIDGE	5	21							4 15				1 6								
582 WILLAMINA-BUELL	4	62							2 49				2 13								
583 WILLAMINA-LUMBER	2	7							1 2	1 6								1 13			
584 WILLBRDG #1	1	13																	2 28		
585 WILLBRDG #4	5	34							3 5												
586 WILSV-BOECKMAN																					
587 WILSV-CHARBNEAU	6	1,580	3 491				2 1,076	1 13													
588 WILSV-CITY	1	686	1 686																		
589 WILSV-MENTORTEK																					
590 WILSV-PARKWAY																					
591 WILSV-VILLEBOIS																					
592 WILSV-WEST	9	223	1 201						3 6	2 5			3 10								
593 WOODBURN-CANNERY	1	1							1 1												

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## 2014 Outages by PGE Equipment

Page 18 of 18

Feeder Name	Equipment															
	<u>* Sub-Total</u>		<u>UG Cond</u>	<u>UG Clamp</u>	<u>UG Xfmr</u>	<u>PGE Cutout/Fuse /Arrestor Failure</u>		<u>OH Cond</u>	<u>OH Clamp</u>	<u>OH Xfmr</u>		<u>Sub</u>	<u>Pole</u>			
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs		
594 WOODBURN-EAST	<b>9</b>	<b>101</b>	1	8		1	16	5	10	1	60		1	7		
595 WOODBURN-TOMLIN	<b>6</b>	<b>77</b>	1	7				1	4			3	61			
596 WOODBURN-WEST	<b>4</b>	<b>26</b>	1	21				3	5					1	5	
597 YAMHILL 13KV	<b>12</b>	<b>595</b>	3	27				6	42	3	526					
598 YAMHILL-CARLTON	<b>11</b>	<b>410</b>						7	31	2	368	1	7	1	4	
<b>Grand Total:</b>	<b>2,196</b>	<b>552,860</b>	<b>577</b>	<b>133,327</b>	<b>1</b>	<b>2</b>	<b>149</b>	<b>27,238</b>	<b>755</b>	<b>21,061</b>	<b>253</b>	<b>92,905</b>	<b>76</b>	<b>4,008</b>	<b>255</b>	<b>10,334</b>
															<b>87</b>	<b>244,926</b>
															<b>43</b>	<b>19,059</b>

Hrs - # of customers \* duration hrs  
 Outs = Outages

UG = Underground  
 OH = Overhead

Xfmr = Transformer  
 Sub = Substation

Cond = Conductor  
 \* Sub-Total Equipment - is sub-total of equipment identified by component type

## **SECTION VII**

### **Outages by Vegetation**

This section provides the number of customer outages (frequency) and customer outage hours (duration) caused by vegetation events. The information is presented by feeder and attributed to one of three primary categories and one of three subcategories, if applicable, of vegetation related events. Definitions for the primary and sub-categories are shown below:

- Total Trees: Total number of vegetation (i.e. tree) related outages. This category is the sum of Non-Preventable and Preventable outages.
- Total Non-Preventable: Total number uprooted trees, tree limbs, and broken/felled trees that resulted in an outage.
  - Uprooted: Outages caused by the whole tree uprooting. This does not include broken tree parts (e.g. limb or tree top)
  - Limb: Outages caused by broken tree tops or limbs
  - Tree Broken or Felled into: Outages caused by a member of the public falling a tree or working in a tree. This type of event is considered negligence and is addressed through PGE's safety campaign (in lieu of the PGE tree trimming program).
- Total Preventable (Tree Contacts): Total number of outages caused by a tree growing into the conductor. This also includes tree burning events.

## 2014 Outages by Vegetation

Page 1 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
1 ABERN-CLACK HTS												
2 ABERN-ORE CITY	4	535	4	535			4	535				
3 ABERNETHY-TRANSIT	2	36	2	36			2	36				
4 ALDER CT-ANKENY												
5 ALDER CT-IRVING												
6 ALDER CT-LINCOLN	2	1,401	2	1,401			2	1,401				
7 ALDER CT-STARK												
8 ALDER CT-TAYLOR	2	171	2	171	1	169	1	2				
9 ALDER CT-YAMHILL												
10 AMITY 13KV	4	101	4	101			4	101				
11 AMITY-BELLEVUE	7	8,537	7	8,537	2	8,457	5	80				
12 ARLETA-52ND ST	3	6,992	3	6,992			3	6,992				
13 ARLETA-FOSTER												
14 ARLETA-HAROLD	2	88	2	88			2	88				
15 ARLETA-POWELL												
16 ARLETA-STEELE	1	385	1	385			1	385				
17 B LAKE-SUNDIAL												
18 B LAKE-TOYOTNSO												
19 BANKS 13KV	4	238	4	238			4	238				
20 BANKS-CEDAR CYN	10	570	10	570			10	570				
21 BARNES-BATTLCKR	1	10	1	10			1	10				
22 BARNES-BOONE	1	108	1	108			1	108				
23 BARNES-COMMERCL	1	247	1	247			1	247				
24 BARNES-SUNNYSID												
25 BELL-FLAVEL	2	60	2	60			2	60				
26 BELL-JOHNSN CRK												
27 BELL-KENDALL												
28 BELL-KING	1	741	1	741			1	741				
29 BELL-SOUTHGATE	1	95	1	95	1	95						
30 BELL-WICHITA	2	139	2	139			1	45	1	94		
31 BELMONT 4KV												
32 BETHANY-BURTON	3	384	3	384	1	76	2	308				
33 BETHANY-GERMANTOWN	3	2,153	3	2,153	1	155	2	1,998				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 2 of 19

	Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
34	BETHANY-KAISER												
35	BETHANY-LAIDLAW	2	75	2	75			2	75				
36	BETHANY-SPRINGVILLE	2	196	2	196	1	2	1	194				
37	BETHANY-THOMPSON												
38	BETHEL-FRUTLAND	1	3	1	3			1	3				
39	BETHEL-GEER	4	206	4	206	2	166	2	40				
40	BETHEL-MCLAY												
41	BLUE LAKE 13 KV												
42	BOONS-GOODALL	1	375	1	375			1	375				
43	BOONS-KRUSEWAY	1	48	1	48			1	48				
44	BOONS-LK GROVE	5	506	5	506			4	490	1	16		
45	BOONS-MT PARK												
46	BOONS-WMBLY PK	6	787	6	787			6	787				
47	BORING-282ND AV	6	524	6	524			6	524				
48	BORING-CITY	1	61	1	61			1	61				
49	BORING-TELFORD	6	370	6	370			4	146	2	224		
50	BRIGHTWD 13KV	25	2,477	25	2,477	2	291	23	2,187				
51	BRIGHTWD-N BANK	9	6,496	9	6,496	1	96	8	6,400				
52	BROOKWOOD 13KV												
53	BROOKWOOD-BRWCK												
54	BROOKWOOD-SUNRS	2	3,731	2	3,731			2	3,731				
55	BVRTN-ALLEN	3	1,096	3	1,096			3	1,096				
56	BVRTN-JAMIESON												
57	BVRTN-NORTHWEST												
58	BVRTN-W SLOPE												
59	CANBY-13643	5	64	5	64			5	64				
60	CANBY-13644	4	15	4	15			4	15				
61	CANBY-BUTTEVLE	2	87	2	87			2	87				
62	CANYON 13KV	5	370	5	370			5	370				
63	CANYON-13114												
64	CANYON-13115												
65	CANYON-13116												
66	CANYON-13117												

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 3 of 19

Feeder Name	Total Trees			Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
67 CANYON-13118PSU													
68 CANYON-13119PSU													
69 CANYON-13120													
70 CANYON-13121													
71 CANYON-13122													
72 CANYON-13123													
73 CANYON-13124													
74 CANYON-13125													
75 CANYON-13133													
76 CANYON-13134													
77 CANYON-13135													
78 CANYON-13136													
79 CANYON-21ST AVE													
80 CANYON-23RD AVE	8	3,268		7	3,063	1	9	6	3,054		1	205	
81 CANYON-BURNSIDE													
82 CARVER 13 KV	2	543		2	543			1	495	1	48		
83 CARVER-ALMOND													
84 CARVER-NORTH													
85 CARVER-RIVRBEND													
86 CARVER-SOUTH													
87 CARVER-WOODS	1	1		1	1			1	1				
88 CEDAR HILLS 13KV													
89 CEDAR-LEAHY	2	91		2	91			2	91				
90 CEDAR-SHOP CEN	4	329		4	329			4	329				
91 CEDAR-SKYLINE	2	10		2	10	1	8	1	2				
92 CEDAR-ST VINCNT													
93 CEDAR-SYLVAN	1	1		1	1			1	1				
94 CLACK-EVELYN													
95 CLACK-GLADSTONE													
96 CLACK-JENNIFER													
97 CLACK-TOLBERT	1	10		1	10			1	10				
98 CLAXTAR 13KV													
99 CLAXTAR-HAYSVIL													

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 4 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
100 CLAXTAR-RIDGE	1	5	1	5			1	5				
101 CNTNNIL 13KV	4	1,682	4	1,682			4	1,682				
102 CNTNNIL-BARKER	3	18	3	18			3	18				
103 CNTNNIL-BRACRFT	5	601	5	601			5	601				
104 CNTNNIL-TREEAND	1	778	1	778			1	778				
105 COFFEE CREEK-FREEMAN												
106 COFFEE CREEK-HOLIDAY												
107 COLTON-DHOOGHE	7	396	7	396			7	396				
108 COLTON-GRAYS HL	13	883	13	883			13	883				
109 CORNELIUS 13KV	6	241	6	241			6	241				
110 CORNELIUS-ADAIR	1	67	1	67			1	67				
111 CORNELIUS-VRBRT	2	3,119	2	3,119			2	3,119				
112 CORNELL-BLUFFS	1	4	1	4			1	4				
113 CORNELL-SALTZMAN	4	191	4	191			4	191				
114 CORNELL-WESTLAWN	4	816	4	816	1	27	3	789				
115 CULVER 13KV												
116 CULVER-GAFFIN												
117 CULVER-SANYO #1												
118 CULVER-SANYO #2												
119 CURTIS 13KV	1	36	1	36			1	36				
120 CURTIS-11077												
121 DAYTON-EAST	5	37	4	33			4	33			1	4
122 DAYTON-LAFAYETT	3	89	3	89			3	89				
123 DAYTON-S AND W	2	108	2	108			2	108				
124 DELAWARE-DENVER	1	31	1	31			1	31				
125 DELAWARE-INTER												
126 DELAWARE-LOMBRD	4	14,178	4	14,178			4	14,178				
127 DENNY-EAST	2	65	2	65			2	65				
128 DENNY-NORTH												
129 DENNY-SOUTH	1	0	1	0			1	0				
130 DENNY-WEST	7	1,084	7	1,084			7	1,084				
131 DILLEY-13KV	4	288	4	288			4	288				
132 DILLEY-SPRINGHL												

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 5 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
133 DUNNS C 13 KV	13	3,442	12	2,726	3	36	9	2,690			1	716
134 DUNNS C-KELSO												
135 DURHAM 13KV												
136 DURHAM-BONITA												
137 DURHAM-BRIDGEPORT												
138 DURHAM-SATTLER												
139 DURHAM-SOUTH												
140 E-11021												
141 E-11039												
142 E-11040												
143 E-11041												
144 E-11042												
145 E-11043												
146 E-11047												
147 E-11064												
148 E-13139	1	59	1	59			1	59				
149 E-13140	7	743	7	743	1	7	6	736				
150 E-13141												
151 E-13144	1	68	1	68			1	68				
152 E-13145												
153 E-13148												
154 E-13149												
155 E-13150												
156 EAGLE CR-BARTON	9	830	8	826			8	826			1	4
157 EAGLE CR-RIVRML	3	223	3	223	2	91	1	133				
158 EASTPORT-76TH	1	3,742	1	3,742			1	3,742				
159 EASTPORT-PLAZA												
160 ELMA 13KV												
161 ELMA-4 CORNERS												
162 ELMA-HUDSON												
163 ELMA-STATE 13KV												
164 ESTACADA 13KV	9	4,391	9	4,391	1	3,830	8	562				
165 ESTACADA-FARADY	26	3,426	26	3,426			25	3,406	1	20		

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 6 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
166 FAIRMT-CNDLARIA	1	241	1	241			1	241	1	241	1	1
167 FAIRMT-MISSION	4	134	3	133			2	5	1	128		
168 FAIRVIEW 13 KV	1	1	1	1			1	1				
169 FAIRVIEW-CLRCK												
170 FAIRVIEW-K CLUB	2	18	2	18			2	18				
171 FAIRVIEW-TROUTD												
172 FAIRVIEW-W VILL												
173 FARGO 13KV	3	579	3	579			3	579				
174 G HOME-MCKAY	4	421	4	421			4	421				
175 G HOME-METZGER	6	745	6	745			6	745				
176 GALES CRK 13KV	21	829	20	791	1	16	19	774			1	39
177 GLENCOE-GLISAN												
178 GLENCOE-PROVID												
179 GLENCOE-SUNNY	2	3,969	2	3,969			2	3,969				
180 GLISAN-FAB 2A												
181 GLISAN-UTIL 1B												
182 GLNCLN-BRIDLMIL	6	397	6	397			6	397				
183 GLNCLN-SUNSET	4	415	4	415			4	415				
184 GLNDOVEER-13596	1	52	1	52			1	52				
185 GLNDOVEER-13597	1	1	1	1			1	1				
186 GLNDOVEER-13598	1	40	1	40			1	40				
187 GLNDOVEER-13599												
188 GLNDOVEER-CLFGT	2	29	2	29	1	6	1	23				
189 GLNDOVEER-NEAST												
190 GRAND AV 4KV												
191 GRND RND-AGENCY	1	64	1	64			1	64				
192 GRND RND-FORTHL	10	1,045	10	1,045			9	969	1	75		
193 HABRTN-BURLINTN	8	241	8	241	1	11	7	230				
194 HABRTN-LINNTON	4	491	4	491	2	467	2	24				
195 HARBORTON 13KV												
196 HARMONY 13KV	3	169	3	169			3	169				
197 HARMONY-INTERNATIONAL	1	11	1	11			1	11				
198 HARMONY-LAKE	1	116	1	116			1	116				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 7 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
199 HARMONY-LINNWOD	1	187	1	187			1	187				
200 HARMONY-MILWAKI	4	2,303	4	2,303			4	2,303				
201 HARMONY-THIESEN												
202 HARRISON 13KV												
203 HARRISON-DAVIS												
204 HARRISON-IVON												
205 HEMLOCK 13KV												
206 HEMLOCK-FREMONT	3	63	3	63			3	63				
207 HEMLOCK-MASON												
208 HILLCREST 13KV	1	95	1	95			1	95				
209 HILLCREST-CASCADIA												
210 HILLCREST-REED												
211 HILLCREST-SOUTH												
212 HILLS-DAIRY CREEK	1	204	1	204			1	204				
213 HILLS-DENNIS												
214 HILLS-JACKSON												
215 HILLS-LAUREL	4	360	3	303			3	303			1	57
216 HILLS-SCHOLLS												
217 HOGAN N 13KV	7	28	7	28			6	26	1	2		
218 HOGAN N-BRGDOON												
219 HOGAN N-LINKS	17	3,271	17	3,271	2	2,182	15	1,089				
220 HOGAN N-SLQUIST	1	780	1	780	1	780						
221 HOGAN S-CLEVND												
222 HOGAN S-LAWRNCE	2	4,589	1	4,513	1	4,513					1	77
223 HOGAN S-MAIN												
224 HOGAN S-PAROPA												
225 HOGAN S-WALLULA	2	63	2	63			2	63				
226 HOLGATE 13KV												
227 HOLGATE-BYBEE												
228 HOLGATE-GIDEON												
229 HOLGATE-KENLWOR												
230 HOLGATE-RHONE												
231 HUBER 13KV												

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 8 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
232 HUBER-BANY	2	29	2	29			1	6	1	23		
233 HUBER-FRMINGTON	1	33	1	33			1	33				
234 HUBER-KINNAMON												
235 HUBER-MARYVILLE												
236 HYDN IS-MALAND	1	8	1	8	1	8						
237 HYDN IS-N SHORE												
238 HYDN IS-S SHORE												
239 INDIAN-KEIZER												
240 INDIAN-LABISH	2	14	2	14			2	14				
241 INDIAN-NORTH	2	4	2	4			2	4				
242 INDIAN-STATION												
243 INDIAN-WEST	2	291	2	291			2	291				
244 ISLAND 13KV												
245 ISLAND-13180	1	4,521	1	4,521			1	4,521				
246 ISLAND-13187	4	292	4	292			4	292				
247 ISLAND-13188	3	1,523	3	1,523			3	1,523				
248 JEN LDG 13KV	2	502	2	502			2	502				
249 JEN LDG-MELDRUM	3	1,634	3	1,634			3	1,634				
250 JEN LDG-O GROVE	4	3,636	4	3,636			4	3,636				
251 JEN LDG-WEBSTER	1	7	1	7			1	7				
252 KELLEY POINT-LEDBETTER												
253 KELLEY POINT-SOLAR1												
254 KELLEY POINT-SOLAR2												
255 KELLEY PT 13 KV												
256 KING CTY-BULL MT												
257 KING CTY-FISCHER	2	3,146	2	3,146			2	3,146				
258 KING CTY-HAZEL B												
259 KING CTY-NORTH												
260 KING CTY-SUMERFL												
261 KLY BU-BINNSMED												
262 KLY BU-FAIRLAWN	1	215	1	215			1	215				
263 KLY BU-MALL 205	5	404	5	404			5	404				
264 KLY BU-MC GREW	1	4	1	4			1	4				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 9 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken		Total Preventable (Tree Contact)
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	
265 KLY PT-MARINEDR											
266 KLY PT-SIMMONS											
267 LAKE LABISH 4KV											
268 LELAND-BEAVERC	5	68	5	68			5	68			
269 LELAND-CARUS	14	11,173	14	11,173	1	147	13	11,025			
270 LELAND-KELM	2	46	2	46			2	46			
271 LENTS-13101	4	140	4	140			4	140			
272 LENTS-HAPPY VAL	3	12,735	3	12,735			3	12,735			
273 LENTS-MT SCOTT	3	300	3	300			3	300			
274 LENTS-NORTH	1	27	1	27			1	27			
275 LIB-BROWNING	1	8	1	8			1	8			
276 LIB-LONE OAK											
277 LIB-MORNINGSIDE											
278 LIB-ROSEDALE	6	29	6	29	1	3	5	26			
279 LIB-VISTA	1	54	1	54			1	54			
280 LIBERAL 13KV	1	2	1	2			1	2			
281 LIBERAL-SAWMILL											
282 LIBERTY-SKYLINE	4	252	4	252	1	13	3	239			
283 MAIN-AIRPORT	2	194	2	194			2	194			
284 MAIN-BENTLEY	1	1,066	1	1,066			1	1,066			
285 MAIN-EXPRESS											
286 MAIN-GRIFFIN											
287 MAIN-JFS1											
288 MAIN-JONES FARM											
289 MAIN-RVR RD	2	8	2	8	1	2	1	6			
290 MC CL-COTTAGE											
291 MC CL-FRONT ST											
292 MC CL-HOLLYWOOD											
293 MCGILL-LSIAIR1A											
294 MCMINNVILLE W AND L											
295 MERIDIAN 13KV	6	191	6	191	1	7	4	182	1	2	
296 MERIDIAN-65TH											
297 MERIDIAN-BORLND	4	6,566	4	6,566			4	6,566			

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 10 of 19

	<b>Feeder Name</b>	<b>Total Trees</b>			Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable	
		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	(Tree Contact)
298	MERIDIAN-CHILDS													
299	MERIDIAN-LAKEVIEW													
300	MERIDIAN-NYBERG													
301	MERIDIAN-PLKNGTN	5	860	5	860			5	860					
302	MERIDIAN-SAGERT													
303	MIDGROVE-BROWN													
304	MIDGROVE-CHEMEK													
305	MIDGROVE-CORDON	1	1	1	1			1	1					
306	MIDGROVE-SWEGLE													
307	MIDGROVE-WEST													
308	MIDWAY-DIVISION	2	217	2	217			2	217					
309	MIDWAY-DOUGLAS	2	29	2	29			2	29					
310	MIDWAY-LYNCH													
311	MIDWAY-POWLHST	1	108	1	108			1	108					
312	MILL CREEK 13KV													
313	MILL CREEK-EASTLAND	2	6	2	6			2	6					
314	MILL CREEK-KUEBLER													
315	MOLALLA-BUCKAROO													
316	MOLALLA-FOREST	3	6	3	6			3	6					
317	MOLALLA-MARQUAM	12	3,314	12	3,314	3	2,973	9	341					
318	MOLALLA-YODER	2	123	2	123			2	123					
319	MRKT ST-ENGLEWD	1	8	1	8					1	8			
320	MRKT ST-FAIRGND	2	4	2	4			1	3	1	1			
321	MRKT ST-HAWTHNE	3	2,678	3	2,678			2	207	1	2,471			
322	MRKT ST-PARK													
323	MT ANGEL-EAST													
324	MT ANGEL-WEST	3	25	3	25			3	25					
325	MT PLS-CLAIRMONT	1	3	1	3			1	3					
326	MT PLS-MT VIEW	1	9	1	9			1	9					
327	MT PLS-RIVRCRST	1	4,949	1	4,949			1	4,949					
328	MT PLS-SOUTHEND	1	17	1	17			1	17					
329	MULINO-NORTH	4	18	4	18			3	17	1	2			
330	MULINO-SOUTH	9	3,018	9	3,018	2	164	7	2,854					

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 11 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	
331 MULTNOMAH 13KV	4	1,421	4	1,421			4	1,421			
332 MULTNOMAH-13176	1	66	1	66			1	66			
333 MULTNOMAH-13177	3	79	3	79			3	79			
334 MULTNOMAH-13181	1	1,099	1	1,099			1	1,099			
335 MURRAYHILL 13KV											
336 MURRAYHL-KINTON											
337 MURRAYHL-QUARRY											
338 MURRAYHL-REUSER											
339 MURRAYHL-TEAL											
340 N MARION FRONT											
341 N MARION-CROSBY	1	3	1	3			1	3			
342 N MARION-HUBBRD	1	3	1	3			1	3			
343 N MARION-MCLARN	2	133	2	133			2	133			
344 N PLAINS 13KV	16	6,482	16	6,482	4	820	12	5,662			
345 N PLAINS-M HILL	12	752	12	752			11	718	1	33	
346 NEWBERG-CHEHALM	5	970	5	970			5	970			
347 NEWBERG-COLLEGE											
348 NEWBERG-DUNDEE	5	954	5	954			5	954			
349 NEWBERG-HOOVR PK	3	36	3	36			3	36			
350 NORTHERN-11009											
351 NORTHERN-11016											
352 NORTHERN-11071	2	94	2	94			2	94			
353 OAK HILLS 13KV											
354 OAK HILLS-5 OAK											
355 OAK HILLS-BRIER											
356 OAK HILLS-SMRST	1	504	1	504			1	504			
357 OAK HILLS-WLRD											
358 OCKLEY GRN 4KV											
359 OK GRV-LK HARRT	3	416	3	416			3	416			
360 OK GRV-WT WATER											
361 ORENCO 13KV											
362 ORENCO PRIMATE											
363 ORENCO-231ST											

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 12 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
364 ORENCO-AMBRGLEN												
365 ORENCO-BASELINE												
366 ORENCO-WILKINS												
367 ORIENT 13KV	20	8,906	20	8,906			20	8,906				
368 ORIENT-BARLOW	11	4,492	11	4,492			11	4,492				
369 OSWEGO-IRON MTN	2	86	2	86			2	86				
370 OSWEGO-MARYLHST	2	14	2	14	1	8	1	6				
371 OSWEGO-PALATINE	10	608	10	608			10	608				
372 OSWEGO-STAFFORD	1	28	1	28			1	28				
373 OXFORD 13KV												
374 OXFORD-FAIRVIEW	1	80	1	80			1	80				
375 OXFORD-LEE												
376 OXFORD-MADRONA												
377 OXFORD-RURAL												
378 OXFORD-SHELTON												
379 PELTON-ROUND BUTTE												
380 PENIN PARK 4KV												
381 PLSNT VALY 13KV	12	927	12	927	1	1	11	925				
382 PLSNT VALY-BXTR	1	2,513	1	2,513			1	2,513				
383 PLSNT VALY-MOON	2	7	2	7			2	7				
384 PLSNT VALY-SUN	2	2,250	2	2,250			2	2,250				
385 PORTLAND GRD W PUMPING												
386 PORTSMTH-CARB												
387 PORTSMTH-DISP												
388 PORTSMTH-WILL												
389 PRGRS-GREENBURG												
390 PRGRS-HALL												
391 PRGRS-ROBINSON												
392 PRGRS-SAWYER	1	1	1	1			1	1				
393 PRGRS-WSH SQ #1												
394 PRGRS-WSH SQ #2												
395 RAL H-DOGWOOD	5	849	5	849			5	849				
396 RAL H-MONTCLAIR	2	129	2	129			2	129				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 13 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
397 RAL H-OLESON RD	3	155	3	155			3	155				
398 RAMAPO 13KV	1	101	1	101			1	101				
399 RAMAPO-GILBERT	1	9	1	9			1	9				
400 REDLAND 13KV	13	1,877	13	1,877	1	196	12	1,681				
401 REDLAND-HENRICI	11	1,052	10	680			10	680			1	372
402 REED-BLANTON												
403 REED-HAZELDALE	2	96	2	96			2	96				
404 REED-INTEL #1												
405 REED-INTEL #2												
406 REED-INTEL #3												
407 REED-INTEL #4												
408 REED-TV HWY	2	54	2	54			2	54				
409 REEDVILLE-AUGUSTA	1	56	1	56			1	56				
410 ROCKWD 13KV	4	231	4	231			4	231				
411 ROCKWD-AIRPT WY												
412 ROCKWD-BOEING												
413 ROCKWD-INDUSTR												
414 ROCKWD-REYNOLDS												
415 ROCKWD-WILKES												
416 ROSEMONT-HIDDEN SPRINGS	2	7	2	7	1	5	1	2				
417 ROSEMONT-MOSSY BRAE	3	341	3	341			3	341				
418 ROSEMONT-OVERLOOK	1	26	1	26			1	26				
419 ROSEWAY 13 KV	1	11	1	11			1	11				
420 ROSEWAY-ALEXNDR												
421 ROSEWAY-ESPLANA	1	323	1	323			1	323				
422 ROUND BUTTE SPILLWAY												
423 RUBY-13502												
424 RUBY-13503	1	315	1	315			1	315				
425 RVRGATE-11010												
426 RVRGATE-11011												
427 RVRGATE-PEARCY												
428 RVRGATE-SWIFT												
429 RVRVIW-FULTON	4	504	4	504	1	5	3	498				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 14 of 19

	Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable	
		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	(Tree Contact)	Outs
430	RVRVIW-MACADAM												
431	RVRVIW-TWILLIGR	6	63	6	63	2	8	4	55				
432	SALEM-13260												
433	SALEM-13261												
434	SALEM-13262												
435	SALEM-13263												
436	SALEM-13264												
437	SALEM-UNION												
438	SANDY 13KV	23	1,685	23	1,685	1	1	22	1,684				
439	SANDY-362ND	3	383	3	383			3	383				
440	SANDY-BLUFF												
441	SANDY-WILDCAT	18	7,191	18	7,191			18	7,191				
442	SCHOLLS FERRY-KEMMER RD												
443	SCHOLLS FERRY-RAINBOW	11	2,141	11	2,141			11	2,141				
444	SCHOLLS FERRY-ROY ROGERS												
445	SCOGG-CHERRY G	2	690	2	690			2	690				
446	SCOGG-LAUREL W	7	16	7	16			7	16				
447	SCOTTSMILL 13KV	15	5,388	15	5,388			14	5,320	1	68		
448	SELLWD 13KV	1	1,580	1	1,580			1	1,580				
449	SELLWD-KELOG PK	2	191	2	191			2	191				
450	SELLWD-WAVERLY												
451	SHERIDAN EAST	4	181	4	181			4	181				
452	SHERIDAN-KADELL												
453	SILVERTON-NORTH												
454	SILVERTON-SOUTH	4	2,875	4	2,875			4	2,875				
455	SILVERTON-WEST	11	598	11	598	2	298	9	300				
456	SIX COR-13359	4	163	4	163			4	163				
457	SIX COR-13360												
458	SIX COR-BORCHER	5	1,160	4	471	1	3	3	468		1	689	
459	SIX COR-CHAPMAN												
460	SIX CORNER-13KV												
461	SMURFIT-NEWBERG												
462	SPRINGBK-FERNWD	3	265	3	265			3	265				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 15 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
463 SPRINGBK-STPAUL	3	796	3	796			3	796				
464 SPRINGBK-VILLA												
465 SPRINGBK-ZIMRI	4	238	4	238	2	138	1	4	1	97		
466 ST LOUIS-EAST												
467 ST LOUIS-NORTH	2	4	2	4			2	4				
468 ST LOUIS-WEST	2	9	2	9			2	9				
469 ST MARY 13KV												
470 ST MARY-BETHANY												
471 ST MARY-BUTNER	6	406	6	406			6	406				
472 ST MARY-ELMONIC												
473 ST MARY-JENKINS												
474 ST MARY-MILLIKN												
475 STEPHN-11001												
476 STEPHN-11020												
477 STEPHN-11054												
478 STEPHN-11055												
479 STEPHN-11092												
480 STEPHN-11093												
481 STEPHN-11094												
482 STEPHN-11095												
483 STEPHN-11097												
484 STEPHN-11098												
485 STEPHN-11099												
486 SULL-ROBINWOOD	3	860	3	860			3	860				
487 SULL-SALAMO	2	82	2	82			2	82				
488 SULL-SUSSEX												
489 SULL-WILLAMETTE	2	1,217	2	1,217			2	1,217				
490 SULLIVAN-TANNER												
491 SULZER 115A												
492 SULZER 115B												
493 SULZER BINGHAM												
494 SUMMIT-GOVT CAMP	1	1	1	1			1	1				
495 SUMMIT-MEADOWS												

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 16 of 19

Feeder Name	Total Trees			Total Non-Preventable			Uprooted			Limb			Tree Broken or Felled into			Total Preventable (Tree Contact)		
	Outs	Hrs		Outs	Hrs		Outs	Hrs		Outs	Hrs		Outs	Hrs		Outs	Hrs	
496 SUMMIT-SUMMIT	1	27		1	27					1	27							
497 SUNSET-BLANCHET																		
498 SUNSET-COLFAX																		
499 SUNSET-CORNELL																		
500 SUNSET-D1X1																		
501 SUNSET-DORION																		
502 SUNSET-IDTB																		
503 SUNSET-INTEL D1B1																		
504 SUNSET-KOMATSU #1																		
505 SUNSET-KOMATSU #2																		
506 SUNSET-KOMATSU #3																		
507 SUNSET-LANE																		
508 SUNSET-LINDE PHASE 1																		
509 SUNSET-MCCALL																		
510 SUNSET-MEEK																		
511 SUNSET-PAULING																		
512 SUNSET-SPALDING																		
513 SUNSET-WHITMAN																		
514 SUNSET-YOUNG																		
515 SWAN IS-BASIN																		
516 SWAN IS-DOLPHIN																		
517 SWAN IS-FREIGHTLINER																		
518 SWAN IS-GOING																		
519 SWAN IS-SHIPYRD																		
520 SYLVAN-BARNES	13	4,679		13	4,679					13	4,679							
521 SYLVAN-PATTON	6	1,327		6	1,327					6	1,327							
522 TABOR 13KV																		
523 TABOR-82ND AV																		
524 TABOR-HOSPITAL																		
525 TEK 13KV																		
526 TEK-HOCKEN																		
527 TEK-NORTH																		
528 TEK-SHANNON	5	854		4	506					4	506				1	348		

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 17 of 19

Feeder Name	Total Trees			Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
529 TEK-SOUTH													
530 TEK-WEST													
531 TEMP-NORTH													
532 TEMP-SOUTH													
533 TIGARD - 13 KV	1	462		1	462	1	462						
534 TIGARD-13336													
535 TIGARD-13337													
536 TIGARD-13361													
537 TIGARD-13362													
538 TNCTR-LAWNFIELD													
539 TNCTR-MONTEREY	1	34		1	34			1	34				
540 TNCTR-NORTH 13KV													
541 TNCTR-PRECISION													
542 TNCTR-SOUTH 13KV													
543 TNCTR-SUNNYBROOK													
544 TNCTR-VALLEY VW													
545 TROJAN PLNT E													
546 TUALATIN 13KV													
547 TUALATIN-AVERY													
548 TUALATIN-CIPOLE	2	4		2	4			2	4				
549 TUALATIN-HERMAN													
550 TUALATIN-IBACH	1	1,542		1	1,542			1	1,542				
551 TUALATIN-LEVETON													
552 TURNER 13KV	1	111		1	111			1	111				
553 TURNER-CASCADE	1	2		1	2	1	2						
554 TWILIGHT-BREMER	5	194		5	194			5	194				
555 UNIONVALE 13KV	11	1,806		11	1,806			11	1,806				
556 UNIVRSITY-MILL													
557 UNIVRSITY-TRADE	1	1		1	1			1	1				
558 URBAN-BARBUR													
559 URBAN-CAMPUS													
560 URBAN-CORBETT	2	3		2	3			2	3				
561 URBAN-GAINES	2	14		2	14			2	14				

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 18 of 19

	Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable	
		Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	(Tree Contact)	Outs
562	URBAN-GIBBS												
563	URBAN-KELLY												
564	URBAN-LANDING												
565	URBAN-MEDICAL												
566	URBAN-OHSU												
567	W PTLD 13KV	7	2,403	7	2,403			7	2,403				
568	W PTLD-72ND	1	1,099	1	1,099			1	1,099				
569	W PTLD-NORTH	4	374	4	374			4	374				
570	W PTLD-PACIFIC												
571	W UNION 13KV												
572	W UNION-CORNELS	7	2,420	7	2,420			7	2,420				
573	WACKER												
574	WACONDA 13KV	5	12	5	12			5	12				
575	WACONDA-NORPAC												
576	WACONDA-RIVER RD	3	3	3	3			3	3				
577	WALLACE RD 13KV	3	500	3	500			3	500				
578	WALLACE-WILLOW LAKE	1	1	1	1			1	1				
579	WELCHES 13KV	18	4,986	18	4,986	1	5	17	4,981				
580	WELCHES-ZIG ZAG	31	18,008	30	17,740	3	262	26	17,366	1	112	1	268
581	WILLAMINA-BRIDGE	2	41	2	41			2	41				
582	WILLAMINA-BUELL	2	12	2	12			2	12				
583	WILLAMINA-LUMBER												
584	WILLBRDG #1												
585	WILLBRDG #4												
586	WILSV-BOECKMAN	2	129	2	129			2	129				
587	WILSV-CHARBNEAU	3	3	3	3			3	3				
588	WILSV-CITY												
589	WILSV-MENTORTEK												
590	WILSV-PARKWAY												
591	WILSV-VILLEBOIS												
592	WILSV-WEST												
593	WOODBURN-CANNERY												
594	WOODBURN-EAST	4	189	3	188			3	188			1	1

Hrs - # of customers \* duration hrs

Outs = Outages

## 2014 Outages by Vegetation

Page 19 of 19

Feeder Name	Total Trees		Total Non-Preventable		Uprooted		Limb		Tree Broken or Felled into		Total Preventable (Tree Contact)	
	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs	Outs	Hrs
			1	3			1	3			1	3
595 WOODBURN-TOMLIN	1	3			1	3			1	3		
596 WOODBURN-WEST												
597 YAMHILL 13KV	4	262			4	262			4	262		
598 YAMHILL-CARLTON	9	336			9	336			9	336		
<b>Grand Total:</b>	<b>1,089</b>	<b>281,929</b>			<b>1,076</b>	<b>279,148</b>	<b>65</b>	<b>27,019</b>	<b>992</b>	<b>248,703</b>	<b>19</b>	<b>3,425</b>
											<b>13</b>	<b>2,781</b>

## **SECTION VIII**

### **2014 Feeder Information**

- 2014 Feeder List with Customer Counts and Feeder Classifications
- 2014 Feeder Modifications

Attachment A  
PGE 2014 Annual Reliability Report

Confidential - Provided on CD Only  
Section III, Feeder Performance Summary  
Section VIII, 2014 Feeder Information

## **SECTION IX**

### **Appendix**

- Reliability Measure Definitions
- IEEE 1366 TMED Definition and Classification
- Cause Code Category
- PGE Service Territory Map

## Reliability Measure Definitions

1. Reliability The degree to which electric service is supplied without interruptions.
2. SAIDI The system average interruption duration index. This is the sustained interruption duration time (in minutes) that an average customer experiences during the year. It is determined by dividing the annual sum of all customer sustained interruption durations by the total number of customers served.
$$\text{SAIDI} = \frac{\text{Sum of customer sustained interruption durations}}{\text{Total number of PGE customers served}}$$
3. SAIFI The system average sustained interruption frequency index. This index is the number of times that an average customer experiences a sustained interruption during a year. It is determined by dividing the total annual number of customer sustained interruptions by the total number of customers served.
$$\text{SAIFI} = \frac{\text{Total number of customer sustained interruptions}}{\text{Total number of PGE customers served}}$$
4. MAIFle Momentary average interruption frequency index of events for the system. This index is the number of times that an average customer experiences momentary interruption events during a year. It is determined by dividing the total annual number of customer momentary interruption events by the total number of customers served. Note that this index does not include the events immediately preceding a sustained interruption.
$$\text{MAIFle} = \frac{\text{Total number of customer momentary interruption events}}{\text{Total number of PGE customers served on Feeders with MV90 or SCADA}}$$
5. Major Event Designates a catastrophic event which:
  - exceeds the design limits of the electric power system;
  - Includes at least one Major Event Day (MED)

## **Major Event Day (MED) Definition and Classification<sup>1</sup>**

A MED is a day in which the daily system SAIDI exceeds a threshold value, TMED. The SAIDI index is used as the basis of this definition since it leads to consistent results regardless of utility size, and because SAIDI is a good indicator of operational and design stress. Even though SAIDI is used to determine the MEDs, all indices should be calculated based on removal of the identified days.

In calculating daily system SAIDI, any interruption that spans multiple days is accrued to the day on which the interruption begins. The MED identification TMED value is calculated at the end of each reporting period (typically one year) for use during the next reporting period, as follows:

- a) Collect values of daily SAIDI for five sequential years, ending on the last day of the last complete reporting period. If fewer than five years of historical data are available, use all available historical data until five years of historical data are available.
- b) Only those days that have a SAIDI/Day value will be used to calculate TMED (do not include days that did not have any interruptions).
- c) Take the natural logarithm (ln) of each daily SAIDI value in the data set.
- d) Find  $\alpha$  (Alpha), the average of the logarithms (also known as the log-average) of the data set.
- e) Find  $\beta$  (Beta), the standard deviation of the logarithms (also known as the log-standard deviation) of the data set.
- f) Compute the MED threshold, TMED, using:

$$T_{MED} = e^{(\alpha+2.5\beta)}$$

- g) Any day with daily SAIDI greater than the threshold value TMED that occurs during the subsequent reporting period is classified as a MED.

Activities that occur on days classified as MEDs should be separately analyzed and reported.

---

<sup>1</sup> Per IEEE Standard 1366-2012: IEEE Guide for Electric Power Distribution Reliability Indices

**Outage Management System - Cause Codes - 2014**

OMS Cause Code	Distribution - Equipment
101	OH Conductor Failure
102	UG Conductor Failure
103	Switch/Reclsoer Failure
104	Cutout/Fuse/Arrestor Failure
105	OH Transformer Failure
106	UG Transformer Failure
109	OH Clamp Failure
110	Pole Failure
111	Pole Hardware Failure
112	UG Hardware Failure
113	UG Clamp Failure
114	Meter Problem/Failure
115	AMI Meter Install Failure
116	Regulator
OMS Cause Code	Distribution - Public
2	Customer Equipment Problem/Non-Billing
200	House Fire
201	Customer Equipment Problem/Billing
202	Customer Problem/Dispatched
203	Dispatcher Resolved
5	Equipment Damage/Misc Public Accident
501	Equipment Damage/Vandalism
502	Equipment Damage/Car Hit Pole
503	Equipment Damage/UG Wire Dig In
504	Equipment Damage/Pad Transformer
505	Equipment Damage/OH Transformer
507	Balloons
OMS Cause Code	Loss of Supply - Substation
107	Substation Transformer
108	Other Substation Equipmenet
OMS Cause Code	Loss of Supply - Transmission
117	Loss of Supply Transmission

OMS Cause Code	Distribution - Weather-Other than Lightning
4	Weather-Normal Conditions
401	Weather-Heavy Snow
402	Weather-High Winds
403	Weather-Ice/Freezing Rain
405	Flooding
OMS Cause Code	Distribution -Vegetation
701	Tree Burning
702	Tree-Uprooted
703	Tree-Broken Limb/Top
506	Tree Cut/Felled into Line
704	Hay on Line
OMS Cause Code	Distribution -Wildlife
6	Animal/Squirrel
601	Bird/Reportable Bird
OMS Cause Code	Lightning
404	Lightning
OMS Cause Code	Planned
8	Planned Outage
801	Planned Outage-Load Curtailment
OMS Cause Code	Other
3	Operations-Switching Error
802	Crew Caused/Not Planned
OMS Cause Code	Unknown
9	Unknown/Investigating Cause
90	Unknown/No Cause Found
OMS Cause Code	Codes Removed from Reliability Numbers
10	Non-Outage
1001	Telco Wire
1002	Cable TV
1003	Verizon Equipment
1004	Qwest Equipment
1005	Comcast Equipment

# PGE SERVICE TERRITORY

Including Regional Boundaries

REVISED: 2/24/2012

## Legend

- SERVICE TERRITORY BOUNDARY
  - EASTERN
  - SOUTHERN
  - WESTERN
- © PORTLAND GENERAL ELECTRIC

