

McDowell Rackner & Gibson PC



WENDY MCINDOO
Direct (503) 595-3922
wendy@mcd-law.com

April 24, 2015

VIA ELECTRONIC AND U.S. MAIL

PUC Filing Center
Public Utility Commission of Oregon
PO Box 1088
Salem, OR 97308-1088

Re: UM _____ – In the Matter of IDAHO POWER COMPANY Application for Approval of Solar Integration Charge

Attention Filing Center:

Attached for filing is an electronic copy of Idaho Power Company's Application for Approval of Solar Integration Charge. Concurrent with this filing, we are making the following related filings:

1. Application to Lower Standard Contract Eligibility Cap and to Reduce the Standard Contract Term;
2. Application for Change in Resource Sufficiency Determination; and
3. Motion for Temporary Stay of its Obligation to Enter into New Power Purchase Agreements with Qualifying Facilities.

A copy of this filing has been served on all parties to Docket UM 1610 via electronic mail as indicated on the attached certificate of service.

Please contact this office with any questions.

Very truly yours,

Wendy McIndoo
Office Manager

Enclosures

cc: UM 1610 Service List

CERTIFICATE OF SERVICE

I hereby certify that I served a true and correct copy of the foregoing document on the service list in Docket UM 1610 the following named person(s) on the date indicated below by email addressed to said person(s) at his or her last-known address(es) indicated below.

Annala, Carey, Baker, et al., PC
Will K. Carey
wcarey@hooddriverattorneys.com

Association of Oregon Counties
Mike McArthur
mmcarthur@aocweb.org

Cable Huston Benedict et al.
Chad Stokes
cstokes@cablehuston

Cable Huston Benedict et al.
Richard Lorenz
rlorenz@cablehuston.com

Citizens' Utility Board of Oregon
OPUC Dockets
dockets@oregoncub.org

Citizens' Utility Board of Oregon
Sommer Templet
sommer@oregoncub.org

City of Portland — Planning and
Sustainability
David Tooze
david.tooze@portlandoregon.gov

Citizens' Utility Board of Oregon
Robert Jenks
bob@oregoncub.org

Loyd Fery Farms LLC
Loyd Fery
dlchain@wvi.com

Cleantech Law Partners PC
Diane Henkels
dhenkels@cleantechlawpartners.com

Davison Van Cleve PC
S. Bradley Van Cleve
bvc@dvclaw.com

Davison Van Cleve PC
Tyler C. Pepple
tcp@dvclaw.com

Irion A. Sanger
Sanger Law PC
irion@sanger-law.com

PUC Staff -- Department of Justice
Stephanie S. Andrus
stephanie.andrus@state.or.us

Energy Trust of Oregon
Thad Roth
thad.roth@energytrust.org

Energy Trust of Oregon
John M. Volkman
john.volkman@energytrust.org

Exelon Wind LLC
John Harvey
John.harvey@exeloncorp.com

Exelon Business Services Company, LLC
Paul Ackerman
paul.ackerman@constellation.com

Richardson Adams, PLLC
Peter J. Richardson
peter@richardsonadams.com

Small Business Utility Advocates
James Birkelund
james@utiliyadvocates.org

Thomas H. Nelson
Attorney at Law
nelson@thnelson.com

Obsidian Renewables, LLC
Todd Gregory
tgregory@obsidianrenewables.com

Richardson Adams, PLLC
Gregory M. Adams
greg@richardsonadams.com

Stoll Berne
David A. Lokting
dlokting@stollberne.com

Obsidian Renewables, LLC
David Brown
dbrown@obsidianfinance.com

Portland General Electric
V. Denise Saunders
Denise.saunders@pgn.com

DATED: April 24 2015


Wendy McIndoo
Office Manager

1 **BEFORE THE PUBLIC UTILITY COMMISSION**
2 **OF OREGON**

3 **UM** _____

4
5 In the Matter of
6 IDAHO POWER COMPANY
7 Application for Approval of Solar
8 Integration Charge.

**APPLICATION FOR APPROVAL OF
SOLAR INTEGRATION CHARGE**

9 **I. INTRODUCTION**

10 Pursuant to OAR 860-001-0400(2) and ORS 758.535(2) Idaho Power Company
11 ("Idaho Power") respectfully requests that the Public Utility Commission of Oregon
12 ("Commission") issue an order modifying the terms and conditions under which Idaho
13 Power enters into power purchase agreements with Qualifying Facilities ("QFs") pursuant
14 to the Public Utility Regulatory Policies Act of 1978 ("PURPA"). Idaho Power requests that
15 the Commission authorize Idaho Power to account for the costs of solar integration in both
16 standard and negotiated QF contracts in accordance with Idaho Power's completed 2014
17 Solar Integration Study ("2014 Study") and pending 2015 Solar Integration Study ("2015
18 Study"). The Commission has already ordered utilities to account for the costs to integrate
19 wind generation in their QF contracts. Idaho Power is asking for the same treatment for
20 QF solar generation.

21 Over the past year, Idaho Power has experienced significant interest in solar QF
22 development in both Idaho and Oregon, and the Company expects its QF solar
23 penetration to soon exceed its wind QF penetration. The Company has signed contracts
24 for 461 megawatts ("MW") of new QF solar generation¹, 60 MW of which are in Oregon;

25 _____
26 ¹ On April 6, 2015, 4 of these QF solar contracts (141 MW total) were terminated for the projects'
failure to post required Delay Security, which is a material breach of the agreements. This leaves

1 projects totaling another 1,326 MW have requested contracts, 245 MW of which are in
2 Oregon.² For all solar projects located in Idaho, the Company was able to negotiate the
3 inclusion of appropriate solar integration charges consistent with the costs identified in its
4 2014 Study. The 60 MW of signed contracts for QF solar generation in Oregon contain no
5 integration charges. Given the rapid and substantial growth in solar development, the
6 integration costs resulting from solar QF development are significant and must be
7 accounted for if customers are to be held indifferent to solar QF generation.

8 The Company's 2014 Study was developed consistent with well-established
9 principles for the integration of variable generation resources and with the advice and
10 involvement of a Technical Review Committee ("TRC"), which, like the TRC for the
11 Company's wind studies, provided input, review, and guidance for the Study. The Idaho
12 Public Utilities Commission ("IPUC") recently approved an all-party stipulation agreeing to
13 implement solar integration costs based upon the 2014 Study.³ In that Stipulation, whose
14 signatories included the Idaho Conservation League, Sierra Club, and Snake River
15 Alliance, the parties agreed to implement the solar integration charges "as proposed and
16 filed by Idaho Power."⁴

17 Given the sheer volume of solar development that the Company expects both in
18 Oregon and Idaho, it is critical that the prices solar QFs pay reflect the true costs avoided
19 by the utility. For this reason the Commission should take all steps to ensure appropriate
20 prices, including the adoption of solar integration charges. Moreover, without a
21 comparable solar integration charge in Oregon, and given the current disparity in the
22

23 Idaho Power with 320 MW of QF solar projects currently under contract to come online in 2016, 60
of which is in Oregon.

24 ² Idaho Power/106, Allphin/1-2 In the Matter of Idaho Power Company Application to Lower
Standard contract Eligibility Cap and to Reduce the Standard Contract Term.

25 ³ Idaho Power Co., Case No. IPC-E-14-18, Order No. 33227 (Feb. 11, 2015).

26 ⁴ *Id.* at 3.

1 avoided cost prices, the Company is concerned that the rapid QF development that has
2 occurred recently in Idaho will move to Oregon to take advantage of the higher prices. In
3 fact, 60 MW of QF solar projects in Oregon have all ready executed fixed price, standard
4 contracts without accounting for the costs of integrating intermittent solar generation onto
5 the system. Adopting a consistent solar integration charge across Idaho Power's
6 integrated system will result in more comparable prices between the states and reduce the
7 incentive for QFs to game the system to take advantage of more advantageous
8 contracting and pricing in Oregon.

9 Contemporaneously with this filing, the Company is requesting an order placing a
10 temporary stay on Idaho Power's obligation under PURPA to enter into fixed-price,
11 standard PURPA contracts with QFs. The Company's motion seeks a temporary stay until
12 the Commission has fully addressed the Company's substantive filings requesting
13 modifications to QF pricing and contracting. In the alternative, the Company's motion
14 requests interim relief, in the form of lowering the eligibility cap, shortening the contract
15 term, implementing a solar integration charge, and changing the Company's
16 sufficiency/deficiency demarcation, pending the outcome of the Commission's
17 investigation of these issues.

18 The Company notified Staff and the parties to docket UM 1610 of its intention to
19 make this PURPA filing. As reflected in the *Stipulation re: Issues List* filed on February 20,
20 2015, in docket UM 1610, Staff and the parties supports the Company's decision to raise
21 this issue in an Idaho Power-specific proceeding, rather than in Phase II of the generic
22 PURPA investigation.

23 In support of this Application requesting the Commission to implement solar
24 integration charges, Idaho Power presents its 2014 Solar Integration Study Report as
25 Idaho Power/101, DeVol/1-36, filed contemporaneously with this Application. Also filed
26 with this Application is the Direct Testimony of Michael J. Youngblood which sets forth the

1 Company's request and proposal to implement solar integration rates and charges based
2 upon the costs identified in the 2014 Study. Idaho Power/201, Youngblood/1-16 sets forth
3 the Company's requested solar integration charges in Schedule 86, which is consistent
4 with the approve Idaho PUC Schedule 87 setting forth intermittent generation integration
5 charges for the Company's Idaho jurisdiction.

6 Communications regarding this Application should be addressed to:

7 Lisa Rackner
8 McDowell Rackner & Gibson PC
9 419 SW 11th Avenue, Suite 400
10 Portland, OR 97205-2605
11 dockets@mcd-law.com

Donovan Walker
Idaho Power Company
P.O. Box 70
Boise, Idaho 83707
dwalker@idahopower.com

11 Christa Bearry
12 Idaho Power Company
13 P.O. Box 70
14 Boise, Idaho 83707
15 dockets@idahopower.com

14 II. BACKGROUND

15 A. Status of Solar QF Development on Idaho Power's System.

16 Until recently, Idaho Power's tremendous amount of QF activity was due primarily to
17 wind development. Between approximately 2006 and 2012, the Company added more
18 than more 575 MW of QF wind to its portfolio, and today has 678 MW of wind operating on
19 its system,⁵ with an additional 50 MW of wind under contract in its Oregon jurisdiction.
20 The tide has changed. Over the last year the Company has signed contracts with 461
21 MW of solar QF generation, and additional QF solar projects totaling 1,326 MW are
22 actively seeking contracts and/or interconnection. If all of this solar generation is built, the
23
24
25

26 ⁵ This is comprised of approximately 577 MW of QF wind, and 101 MW of non-PURPA wind.

1 Company will have over 1,600 MW of QF solar projects on its system, and a grand total of
2 over 2,400 MW of PURPA generation from all sources.⁶

3
4 **III. ARGUMENT**

5 **A. Idaho Power's Solar Penetration is Sufficient to Approve an Integration Charge.**

6 In Phase I of docket UM 1610 no party requested that the Commission approve an
7 integration cost for solar resources, in light of the limited solar development at the time
8 and the lack of any completed solar integration studies in the record.⁷ Idaho Power had
9 not yet completed its 2014 Solar Integration Study, and sought implementation only of
10 wind integration charges at the time testimony was submitted for Phase 1. Additionally,
11 Idaho Power had no QF solar projects under contract at that time. The Commission
12 noted, however, that "we will revisit this issue in the future after more solar development
13 occurs."⁸ Given the rapid growth in solar QF capacity on Idaho Power's system, it is now
14 necessary for the Commission to revisit this issue for Idaho Power and implement a solar
15 integration charge.

16 Today Idaho Power has significant levels of solar penetration, a completed 2014
17 Solar Integration Study, and has initiated its second solar integration study in January of
18 2015. Idaho Power's solar QF development now exceeds the level of wind development
19 that the Commission concluded was sufficient to account for integration costs.⁹ When the
20 Commission approved the wind integration costs in Order No. 14-058, Idaho Power had a
21 total of 678 MW of wind on its system (577 MW of PURPA wind and an additional 101 MW

22

23 ⁶ Idaho Power/101, Allphin/1, Idaho Power/105, Allphin/1-9, Idaho Power/106, Allphin/1-2, In the
24 Matter of Idaho Power Company Application to Lower Standard contract Eligibility Cap and to
Reduce the Standard Contract Term.

25 ⁷ Order No. 14-058 at 15.

26 ⁸ Order No. 14-058 at 15.

⁹ Order No. 14-058 at 13.

1 from the Elkhorn Valley Wind Farm). The Company's solar penetration, based on projects
2 that are either under contract or proposed, is expected to exceed 1,300 MW in 2016, or
3 nearly double the level of wind penetration.

4 The rapid and unforeseen increase in solar QF development on Idaho Power's
5 system makes timely approval of the integration charge essential. If Idaho Power is
6 required to enter into long-term contracts with Oregon solar QFs that do not account for
7 integration costs, customers will bear those costs for the life of the contract. For the
8 currently proposed 245 MW of Oregon QF solar projects this could represent an
9 overpayment of approximately \$49 to \$188 million over the life of all of the proposed QF
10 solar contracts.¹⁰

11 **B. The Company has Completed its 2014 Solar Integration Study and Commenced**
12 **its 2015 Solar Integration Study this Year.**

13 The 2014 Study was designed to determine the economic impact on the Company's
14 system resulting from the integration of intermittent solar generation. Due to the variable
15 and intermittent nature of solar generation, Idaho Power must modify its system
16 operations to successfully integrate solar power without impacting system reliability,
17 similar to wind generation. Specifically, Idaho Power, or any electrical system operator,
18 must provide operating reserves from resources that are capable of increasing or
19 decreasing dispatchable generation on short notice to offset changes in non-dispatchable
20 solar generation. As a result, these resources cannot be economically dispatched to their
21 fullest capability, resulting in higher power supply costs. The Study quantifies these higher
22 power supply costs and determines an appropriate integration charge on a dollar per MWh
23 basis.

24 _____
25 ¹⁰ Idaho Power current has 320 MW of QF solar that remains under contract. The associated solar
26 integration charge for penetration levels of 400 MW through 1,500 MW starts at approximately
\$3.12/MWh for penetration levels of 401 MW through 500 MW, and escalates to \$18.29 for
penetration levels of 1,401 MW through 1500 MW. Idaho Power/200, Youngblood/1-10.

1 The 2014 Study was conducted in a manner comparable to the Company's wind
2 integration study and is consistent with industry standards. The conduct of the study was
3 guided by two key industry documents: *Principles for Technical Review (TRC)*
4 *Involvement in Studies of Variable Generation Integration into Electrical Power Systems*,
5 produced by the National Renewable Energy Laboratory ("NREL") and the Utility Variable-
6 generation Integration Group; and *The Evolution of Wind Power Integration Studies: Past,*
7 *Present, and Future*, which was authored by five NREL researchers considered to be at
8 the forefront of the study of renewable integration and was published by the Institute of
9 Electrical and Electronics Engineers.

10 In general terms, the cost of integrating solar generation increases as the amount of
11 solar generation on the electrical system increases. The 2014 Study determined solar
12 integration costs for four solar build-out scenarios at installed capacities of 100 MW, 300
13 MW, 500 MW, and 700 MW. The Company is currently conducting a second study, (the
14 2015 Study), which will include penetration levels beyond 700 MW. The 2014 Study
15 utilized geographically dispersed build-out scenarios with solar generation located across
16 the Company's service territory at Parma, Boise, Grand View, Twin Falls, Picabo, and
17 Aberdeen. For each penetration level the Company conducted two simulations: a test
18 case that required dispatchable generators to carry extra capacity in reserve to allow them
19 to respond to unplanned solar variations, and a base case with no extra capacity
20 requirement. The cost difference between these two cases forms the basis of the
21 integration charge.

22 Given that the Company's expected solar penetration already exceeds these initial
23 build-out scenarios, the Company has extrapolated the Study's results to determine solar
24 integration costs for build-out scenarios consistent with the Company's current expected
25 penetration. The 2015 Study will account for the level of solar penetration the Company is
26 currently anticipating.

1 Consistent with the Commission's requirements for wind integration studies, the
2 Company's solar integration studies utilize a TRC, with the purpose of providing input,
3 review, and guidance for the studies. The TRC for the 2014 Study included Staff from
4 both the Commission and the IPUC, as well as representatives from the University of
5 Idaho, the Renewable Northwest, the Idaho National Laboratory, and the City of Boise.

6 While the study of solar integration is relatively young, especially when compared to
7 the study of wind integration, the Company was able to verify the reasonableness of its
8 results through comparisons to studies that have been conducted for other utility systems.

9 **C. The IPUC Recently Approved the Company's Proposed Solar Integration**
10 **Costs.**

11 On July 1, 2014, Idaho Power filed with the IPUC an application to implement solar
12 integration charges for Idaho QFs. The application was based on the 2014 Study, the
13 same Study presented here. The parties to the Idaho proceeding entered into a
14 settlement stipulation that requested approval of the Company's proposed solar
15 integration charges as filed. The agreement also included several terms related to the
16 Company's 2015 Study, which was commenced in January 2015. The IPUC approved the
17 settlement stipulation on February 11, 2015. The IPUC "commend[ed] the parties for
18 agreeing to put a [solar integration charge] in place while a second study is conducted."¹¹
19 In the event that solar penetration exceeded the Study's 700 MW level, the IPUC directed
20 Idaho Power "utilize the same process/methodology that it applied in its first study to
21 extrapolate integration charges as solar penetration increases."¹² The stipulation was
22 signed by representatives of several environmental groups, including the Sierra Club.

23

24

25

¹¹ *Idaho Power Co.*, Case No. IPC-E-14-18, Order No. 33227 at 5 (Feb. 11, 2015).

26

¹² *Idaho Power Co.*, Case No. IPC-E-14-18, Order No. 33227 at 5-6 (Feb. 11, 2015).

1 Here, the Company requests approval of the same solar integration costs agreed to
2 by the parties and approved by the IPUC. Consistency across jurisdictions will lessen the
3 opportunity for regulatory arbitrage based on disparate avoided cost prices.

4 **IV. CONCLUSION**

5 For all of the reasons stated above, Idaho Power requests that the Commission
6 approve the Company's proposed solar integration costs for QF contracts.

7 Respectfully submitted this 24th day of April, 2015.

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

MCDOWELL RACKNER & GIBSON PC



Lisa F. Rackner
Adam Lowney

IDAHO POWER COMPANY

Donovan Walker
Lead Counsel
1221 West Idaho Street
P.O. Box 70
Boise, Idaho 83707

Attorneys for Idaho Power Company

BEFORE THE PUBLIC UTILITY COMMISSION
OF OREGON

UM _____

In the Matter of)
)
IDAHO POWER COMPANY)
)
Application for Approval of Solar Integration)
Charge.)
_____)

IDAHO POWER COMPANY
DIRECT TESTIMONY
OF
PHILIP B. DeVOL

April 24, 2015

1 **Q. Please state your name and business address.**

2 A. My name is Philip B. DeVol and my business address is 1221 West Idaho Street,
3 Boise, Idaho 83702.

4 **Q. By whom are you employed and in what capacity?**

5 A. I am employed by Idaho Power Company ("Idaho Power" or "Company") as a Senior
6 Planning Analyst.

7 **Q. Please describe your educational background and work experience with Idaho
8 Power.**

9 A. In May of 1989, I received a Bachelor of Science Degree in Mathematics from Miami
10 University in Oxford, Ohio. I then received a Master of Science Degree in Biostatistics
11 from the University of Michigan in May of 1991.

12 **Q. Please describe your work history at Idaho Power.**

13 A. I began my employment with Idaho Power in 2001 in the Company's Water
14 Management Department, where my responsibilities included modeling of the Idaho
15 Power hydroelectric system for the Integrated Resource Plan ("IRP") and relicensing
16 studies.

17 I transferred in 2005 to the Power Supply Planning Department at Idaho Power,
18 where I remain employed as a Senior Planning Analyst. My responsibilities in Power
19 Supply Planning have been varied, and have included several studies of renewable
20 integration. My duties have included project management for the most recent (2013)
21 Idaho Power wind integration study, and Idaho Power's first solar integration study
22 completed in 2014.

23 I have been involved in regional and national proceedings related to the study
24 of wind integration. I participated in methodology discussions for the 2007 Wind
25 Integration Action Plan produced by the Northwest Wind Integration Forum. I have
26 attended numerous Utility Wind Integration Group ("UWIG") workshops, and

1 presented at UWIG workshops in Oklahoma City in 2006, Portland, Oregon, in 2007,
2 and San Antonio, Texas in 2014. I also presented to the Idaho Wind Working Group
3 at its September 2011 meeting. In November of 2013, I presented at a Centre for
4 Energy Advancement through Technological Innovation workshop focused on
5 forecasting uncertainties for renewable energy supply.

6 **Q. What is the purpose of your testimony in this matter?**

7 A. The purpose of my testimony is to describe Idaho Power's solar integration study
8 ("Study" or "2014 Study" or "Solar Study") and to provide the results. The 2014 Solar
9 Integration Study Report ("Study Report") is attached hereto as Idaho Power/101,
10 DeVol/1-36. The Study Report was completed on June 16, 2014.

11 **Q. Can you provide a high level description or summary of the Company's 2014**
12 **Study?**

13 A. Yes. Electric power from solar generation resources exhibits greater variability and
14 uncertainty than energy from conventional generation sources. The greater variability
15 and uncertainty exhibited by solar resources requires an electric utility integrating solar
16 to modify its operating practices by holding extra operating reserves on dispatchable
17 generation resources. The effect of having to hold operating reserves on dispatchable
18 resources is that the use of those resources is restricted and they cannot be
19 economically dispatched to their fullest capability. The objective of the Study is to
20 determine the costs of the operational modifications necessary to integrate solar
21 generation.

22 The Company's Solar Study determined solar integration costs for four solar
23 build-out scenarios at installed capacities of 100 megawatts ("MW"), 300 MW, 500
24 MW, and 700 MW. The Study utilized geographically dispersed build-out scenarios
25 with solar generation located across the Company's service territory at Parma, Boise,
26

1 Grand View, Twin Falls, Picabo, and Aberdeen. Pages 6 and 7 of the Study Report
2 provide additional information regarding the build-out scenarios.

3 The Company initiated the Study with the formation of a Technical Review
4 Committee ("TRC"), with the purpose of providing input, review, and guidance for the
5 Study. In collaboration with the TRC, Idaho Power organized the Study into four
6 primary steps: (1) data gathering and scenario development; (2) statistical-based
7 analysis of solar characteristics; (3) production cost simulation analysis; and (4) study
8 conclusions and results. The Study determined solar integration costs through paired
9 simulation of Idaho Power's system at each solar build-out scenario. Each pair of
10 simulations consists of a test case in which extra capacity in reserve is required of
11 dispatchable generators to allow them to respond to unplanned solar variations and a
12 base case in which no extra capacity in reserve is required. The solar integration costs
13 indicated by the simulations are provided below. These costs are also found in Table
14 2, page 3 of the Study Report, as well as Table 8 and Table 9 on page 15 of the Study
15 Report.

16 **Average Integration Cost Per MWh**

17 (2014 cost and dollars)

18 Build-out Scenarios	0-100 MW	0-300 MW	0-500 MW	0-700 MW
19 Integration Cost	\$0.40	\$1.20	\$1.80	\$2.50

20 **Incremental Integration Cost Per MWh**

21 (2014 cost and dollars)

22 Penetration Level	0-100 MW	100-300 MW	300-500 MW	500-700 MW
23 Integration Cost	\$0.40	\$1.50	\$2.80	\$4.40

24 **Q. What is the difference between Average Integration Cost and Incremental**
25 **Integration Cost?**
26

1 A. As explained in the Study Report, the cost to integrate solar generation onto the
2 Company's system increases with increasing penetration levels. The Average
3 Integration Cost as shown above, reports an average cost per megawatt hour ("MWh")
4 that applies to all of the four solar build-out scenarios modelled in the Study.
5 Conversely, the Incremental Integration Costs indicates the cost of integrating solar
6 generation as it would be assigned separately for the individual build-out scenarios.

7 **Q. When did Idaho Power initiate the 2014 solar integration study?**

8 A. The official Study kick-off was on August 15, 2013, with the first meeting of the TRC.

9 **Q. What is the TRC?**

10 A. The TRC was formed during the summer of 2013 with the purpose of providing input,
11 review, and guidance for the Study. It is made up of participants from outside of Idaho
12 Power that have an interest and/or expertise in the integration of intermittent resources
13 onto utility systems. The TRC consisted of: Brian Johnson from the University of
14 Idaho; Jimmy Lindsay from the Renewable Northwest Project ("RNP") (now with
15 Portland General Electric); Kurt Myers from the Idaho National Laboratory; and Paul
16 Woods with the City of Boise (now self-employed as a consultant). In addition, Staff
17 from both the Idaho and Oregon commissions participated in the Study. Rick Sterling
18 from the Idaho Public Utilities Commission Staff and Brittany Andrus and John Crider
19 from the Public Utility Commission of Oregon Staff participated throughout the Study.
20 Although Mr. Lindsay left RNP, he continued to participate as a TRC member.
21 Cameron Yourkowski was designated by RNP as Mr. Lindsay's replacement for the
22 TRC. Similarly, Mr. Woods continued to serve as a board member after he left
23 employment with the City of Boise.

24 **Q. How was the 2014 Study conducted?**

25 A. The conduct of the Study was guided by two documents that were shared with and
26 discussed with the TRC. *Principles for Technical Review (TRC) Involvement in*

1 *Studies of Variable Generation Integration into Electrical Power Systems* was
2 produced by the National Renewable Energy Laboratory ("NREL") and Utility Variable-
3 generation Integration Group ("UVIG"). The NREL/UVIG principles document
4 provides guidance in defining the important role of the TRC in the Study. The second
5 report, *The Evolution of Wind Power Integration Studies: Past, Present, and Future*,
6 was authored by five NREL researchers considered to be at the forefront of the study
7 of renewable integration and was published by the Institute of Electrical and
8 Electronics Engineers ("IEEE"). This report is used as the roadmap for Idaho Power's
9 solar integration study. Even though the report was written from the perspective of
10 wind integration, the principles remain the same for solar integration. Solar, like wind,
11 is variable and uncertain and, consequently, the system of dispatchable resources has
12 to be operated differently in order to successfully integrate the generation without
13 compromising reliability.

14 **Q. What process did the 2014 Study following?**

15 A. The Study generally followed the process outlined in the IEEE report, which includes
16 the following steps:

17 Step 1: Data gathering and scenario development;

18 Step 2: Study analysis

19 Step 2(a): Statistical-based analysis of solar characteristics;

20 Step 2(b): Production cost simulation analysis;

21 Step 2(c): Reliability assessment;

22 Step 3: Study conclusions and results.

23 **Q. Did the TRC agree with and participate in this process?**

24 A. Yes. Idaho Power comprehensively walked through both guiding documents, as well
25 as the steps outlined above, with the TRC. Additionally, the importance of the guiding
26 documents was emphasized to participants at a May 1, 2014, public workshop. The

1 TRC was extensively involved in Step 1-- data gathering and scenario development.
2 The TRC was integrally involved with the identification of suitable sources of solar
3 production data, as well as discussions leading to the development of scenarios to be
4 studied. The TRC had a leading role in advising on the use of wavelet variability
5 modelling to transform point-source solar data to meaningful production data for a
6 solar farm. This technique is described on page 8 of the Study Report. The TRC's
7 counsel with respect to Idaho Power's use of the wavelet technique was important and
8 needed.

9 **Q. Can you further describe how the 2014 Study progressed to completion?**

10 A. Yes. As noted in the IEEE report, one of the primary tasks of Step 1 is to develop the
11 solar resource data that is needed to model future power output. This task proved
12 particularly challenging for the Study. The solar build-out scenarios consider solar
13 plants at six locations in southern Idaho: Parma, Boise, Grand View, Twin Falls,
14 Picabo, and Aberdeen. The Study was able to obtain solar data from the U.S. Bureau
15 of Reclamation AgriMet network at the desired five-minute time step for all locations
16 except Grand View. NREL maps indicate the area surrounding Grand View and
17 Glens Ferry has the highest annual solar intensity in the state. For this reason, Idaho
18 Power and the TRC have felt it is important to model a solar plant at Grand View.
19 Obtaining five-minute solar data for Grand View has required the acquisition of data
20 from SolarAnywhere, which is a web-based service from Clean Power Research
21 providing satellite-derived solar irradiance data. The Study did not receive data for
22 Grand View from SolarAnywhere until April 2014, causing delay in the Study schedule.

23 With the acquisition of data for the Grand View area, the Study progressed into
24 the statistically-based analysis of solar characteristics. The intent of this analysis is to
25 translate the variability and uncertainty present in the solar data to an incremental
26 reserve requirement. The NREL authors of the IEEE report describe this task as an

1 analysis to determine the increase in ancillary services required by a given solar
2 scenario, where NREL defines ancillary services as services that help grid operators
3 maintain balance on electric power systems. The next step in the Study was to take
4 the increase in reserve requirement, or ancillary services, from step 2.a for any given
5 solar scenario and to input it into the Study's production cost simulations to determine
6 the cost of carrying increased ancillary services, step 2.b.

7 It was also at this point that the decision was made to modify the build-out
8 scenarios to include higher levels of solar penetration. This decision was based
9 primarily upon the increase in proposed solar projects for Idaho Power's system that
10 outpaced the highest penetration level initially contemplated by the Study. Initially, the
11 Study planned to analyze four build-out scenarios: dispersed 50 MW; dispersed 100
12 MW; dispersed 300 MW; and clustered 300 MW. I should note that the build-out
13 scenarios are described as dispersed in the sense that their solar capacity consists of
14 utility-scale power plants spread out over several (or all) of the six data locations in
15 southern Idaho; the use of dispersed as a descriptor does not represent build-out
16 scenarios of small-sized distributed generation. However, with the emergence of over
17 500 MW of solar generation seeking contracts with the Company, the need to study
18 beyond the 300 MW level became apparent. Consequently, in a May 16, 2014,
19 meeting, the Company communicated to the TRC the following four revised build-out
20 scenarios: dispersed 100 MW; dispersed 300 MW; dispersed 500 MW; and dispersed
21 700 MW. The proposal to study these revised build-out scenarios was not
22 controversial with the TRC, and they recognized the need to study expanded build-
23 outs given the potential development described in the Company's May 13, 2014, filing
24 in Case No. IPC-E-14-09 seeking a suspension of its obligation to purchase Public
25 Utility Regulatory Policies Act of 1978 solar generation until the Study could be
26 completed.

1 **Q. How was the statistically-based analysis of solar characteristics conducted?**

2 A. Based on Idaho Power's review of the solar data from its build-out scenarios, the
3 Company focused its analysis of variability and uncertainty in the context of hour-
4 ahead system scheduling. In this context, the hour-ahead system scheduler requires
5 for a given operating hour a forecast for hourly average solar production, as well as
6 forecasts for lower and upper bounds on instantaneous solar production. The Study
7 assumes these forecasts for solar production need to be delivered to the system
8 scheduler 45 minutes prior to the start of the operating hour being scheduled. With
9 this information, the system can be scheduled according to the forecast for hourly
10 average solar production and, importantly, also be scheduled in a manner allowing
11 dispatchable generators to respond during the operating hour if solar production varies
12 from the forecasted level toward either bound. Discussion of the regional electric
13 power market and the Company's hour-ahead scheduling activities is included in
14 pages 8 through 11 in the Study Report.

15 The hour-ahead hourly average solar production forecast developed for the
16 Study is based on persistence, with an adjustment to account for the known changes
17 in the sun's position. The lower and upper bounds on solar production are established
18 as percentages of the hourly average solar production forecast, with adjustments
19 made to narrow the bounds in response to periods of stable production. The logic
20 developed to make these adjustments to the bounds was well received by the TRC,
21 and has been described in TRC meetings as an example of a "learning" or "adaptive"
22 model. The techniques followed to develop the hour-ahead solar production forecast
23 and the accompanying bounds on instantaneous solar production were described to
24 the TRC in a May 16, 2014, meeting.

25 **Q. What was the next step in the Study process?**

26

1 A. Step 2(b) was the production cost simulations. As described earlier in my testimony,
2 the Study followed the conventional design of simulating two scenarios: a test
3 scenario having incremental amounts of solar-caused reserve and a base scenario
4 without the incremental reserve.

5 **Q. Could you describe the TRC involvement in the later stages of the Study?**

6 A. Yes. The TRC schedule, including the meeting dates and agenda items, is set forth
7 on page 23 of the Study Report. The final formal TRC meeting was held on May 29,
8 2014. The intent of this meeting was to provide a relatively high-level description of
9 the production cost simulations. In response to TRC expressions of interest in
10 understanding how reserves influence system operations, Idaho Power also provided
11 an overview of operating reserves. The discussion during the May 29 meeting focused
12 on an explanation of the production cost model, a demonstration of the input of solar-
13 caused reserve requirements to the production cost model, and an illustration of the
14 effect of the solar-caused reserves on simulated operations. The Company
15 acknowledged the complexity of the production cost simulations to the TRC. There
16 were expressions from some in the TRC to explore in further detail, specifically to
17 explore additional water year types (e.g., low and high water year types). However,
18 the Company expressed that for this phase of the Study further exploration of
19 additional water years was not necessary, emphasizing the need for a timely
20 completion of the Study. Finally, the May 29 meeting ended with a presentation of the
21 integration costs found by the production cost simulations, which at the time were
22 considered preliminary.

23 A draft study report was circulated to the TRC on June 2, 2014. The Company
24 indicated in its correspondence with the TRC on June 2 the continued objective to
25 complete the Study by mid-June. The TRC members submitted comments on the
26

1 process and the Study. Several TRC members identified items for further study, which
2 are listed in the Study Report on page 18.

3 **Q. Can you describe the results of the Study?**

4 A. Yes. The objective of the Study was to determine the costs of the operational
5 modifications necessary to integrate solar generation. The integration costs are driven
6 by the need to carry extra capacity in reserve to allow bidirectional response from
7 dispatchable generators to unplanned variations in solar production. The simulations
8 performed for the Study indicate the following costs associated with holding the extra
9 capacity in reserve. The provided costs are the costs to integrate solar production for
10 the calendar year 2014, and are not costs averaged or levelized over the life of the
11 solar power plant.

12 **Average Integration Cost Per MWh**

13 (2014 cost and dollars)

14 Build-out Scenarios	0-100 MW	0-300 MW	0-500 MW	0-700 MW
15 Integration Cost	\$0.40	\$1.20	\$1.80	\$2.50

16
17 **Incremental Integration Cost Per MWh**

18 (2014 cost and dollars)

19 Penetration Level	0-100 MW	100-300 MW	300-500 MW	500-700 MW
20 Integration Cost	\$0.40	\$1.50	\$2.80	\$4.40

21 **Q. Are the results of Idaho Power's Solar Study consistent with those conducted**
22 **for other utility systems?**

23 A. Yes. Idaho Power's Study results fall within the range reported by other utilities for the
24 cost of integrating solar generation. While the study of solar integration is relatively
25 young, especially when compared to the study of wind integration, I am aware of solar
26 integration studies that have been conducted for other utility systems. Notable among

1 these studies are a 2011 solar integration study for the NV Energy system, a 2012
2 solar integration study for Arizona Public Service ("APS"), and a 2014 solar integration
3 study for Tucson Electric Power ("TEP"). The NV Energy study reports integration
4 costs ranging from \$3.00 to \$8.00 per megawatt-hour ("MWh") of integrated solar
5 generation. The APS study reports integration costs ranging from about \$1.50 to \$3.00
6 per MWh of integrated solar generation. The TEP study reports an integration cost of
7 \$5.20 per MWh.

8 **Q. Has Idaho Power initiated a second solar integration study?**

9 A. Yes, and in fact the Company is currently in the process of developing a new solar
10 integration study. Idaho Power, as referenced and anticipated in the stipulation
11 approved by the Idaho PUC in Case No. IPC-E-14-18, the Company initiated a second
12 solar integration study in January 2015. That study is being led by Ron Schellberg,
13 Engineering Leader, Customer Operations and Planning, for Idaho Power. The 2015
14 solar integration study will utilize a Technical Review Committee ("TRC") which
15 includes members with expertise in solar generation, variable energy integration and
16 electrical grid operations. In addition, the TRC includes participation from both the
17 Idaho and Oregon Commission Staff. My understanding is that a TRC was formed
18 and this second solar integration study is proceeding with the intent of having final
19 results within one year of its initiation. The second study will include penetration levels
20 beyond 700 MW, which was the highest penetration level included in the 2014 Study.

21 **Q. Does this conclude your testimony?**

22 A. Yes, it does.
23
24
25
26

Idaho Power/101
Witness: Philip B. DeVol

BEFORE THE PUBLIC UTILITY COMMISSION
OF OREGON

IDAHO POWER COMPANY

Exhibit Accompanying Direct Testimony of Philip B. DeVol

2014 Solar Integration Study Report

April 24, 2015



Solar Integration Study Report

June 2014

© 2014 Idaho Power

TABLE OF CONTENTS

Table of Contents	1
List of Tables	2
List of Figures	2
List of Appendices	2
Executive Summary	3
Acknowledgments.....	5
Introduction.....	5
Data Gathering and Scenario Development.....	6
Wavelet-Based Variability Model	8
Solar Plant Characteristics	8
Statistical-Based Analysis of Solar Characteristics	8
Hour-Ahead Solar Production Forecast.....	9
Production Cost Simulation Analysis	11
Design of Simulations.....	11
Simulation Inputs	12
Simulation Model.....	13
Wind and Load Reserves	14
Contingency Reserve Obligation	14
Flexible Capacity Resources.....	14
Results.....	15
Study Findings	16
Hour-Ahead Solar Production Forecasting.....	16
Comparison to Wind Integration	16
Geographic Dispersion.....	17
Transmission and Distribution.....	17
Spring-Season Integration.....	17
Conclusions.....	18

Further Study18
Literature Cited19

LIST OF TABLES

Table 1
Solar build-out scenarios studied3

Table 2
Average integration cost per MWh for solar build-out scenarios3

Table 3
Solar build-out scenarios studied6

Table 4
AgriMet site latitude, longitude, and elevation used in IPC’s solar integration study7

Table 5
Forecast error for the hour-ahead solar production forecast10

Table 6
Forecasted incremental and decremental capacity held in reserve, water year 201211

Table 7
Inputs for the solar integration study production cost simulations12

Table 8
Average integration cost per MWh for solar build-out scenarios15

Table 9
Incremental integration cost results for solar build-out scenarios15

LIST OF FIGURES

Figure 1
AgriMet sites used in IPC’s solar integration study7

LIST OF APPENDICES

Appendix 1
Solar integration study appendix.....21

EXECUTIVE SUMMARY

Electric power from solar photovoltaic resources exhibits greater variability and uncertainty than energy from conventional generators. The greater variability and uncertainty exhibited by solar photovoltaic resources require an electric utility integrating solar to modify the operation of dispatchable generating resources. The modified operation involves the sub-optimal dispatch of generators to carry extra capacity in reserve for responding to unplanned solar excursions.

The objective of the Idaho Power solar integration study is to determine the costs of the operational modifications necessary to integrate solar photovoltaic plant generation. This study determines these costs for four solar build-out scenarios provided in Table 1.

Table 1
Solar build-out scenarios studied

Site	Installed Capacity of Solar Build-Out Scenarios			
	100 megawatts (MW)	300 MW	500 MW	700 MW
Parma, ID	10	30	50	100
Boise, ID	20	60	100	100
Grand View, ID	20	60	100	150
Twin Falls, ID	20	60	100	100
Picabo, ID	10	30	50	100
Aberdeen, ID	20	60	100	150
Total MW	100	300	500	700

The study determines solar integration costs through paired simulations of the Idaho Power system for each solar build-out scenario. Each pair of simulations consists of a test case in which extra capacity in reserve is required of dispatchable generators to allow them to respond to unplanned solar excursions and a base case in which no extra capacity in reserve is required. The solar integration costs indicated by the simulations are provided in Table 2.

Table 2
Average integration cost per MWh for solar build-out scenarios

	0-100 MW	0-300 MW	0-500 MW	0-700 MW
Integration cost	\$0.40/MWh	\$1.20/MWh	\$1.80/MWh	\$2.50/MWh

Note: Costs are in 2014 dollars and rounded from simulation results to the nearest \$0.10.

This page left blank intentionally.

ACKNOWLEDGMENTS

Idaho Power acknowledges the important contribution of the Technical Review Committee (TRC) in this solar integration study. The TRC has been involved from the study outset in August 2013 and has provided substantial guidance. Idaho Power especially thanks the TRC for the collegial discussions of solar integration during TRC meetings. These discussions helped shape the study methods followed and are consistent with the TRC guidelines as provided by the Utility Variable-Generation Integration Group (UVIG) and the National Renewable Energy Laboratory (NREL) (UVIG and NREL n.d.). The following are members of the Idaho Power solar integration study TRC:

- Brian Johnson, University of Idaho
- Jimmy Lindsay, Portland General Electric (formerly of Renewable Northwest Project)
- Kurt Myers, Idaho National Laboratory
- Paul Woods, (formerly of City of Boise)
- Cameron Yourkowski, Renewable Northwest Project (replacing Jimmy Lindsay)

Staff from the Idaho and Oregon regulatory commissions have participated as observers throughout the process. The following staff have been observers of the process:

- Brittany Andrus, Public Utility Commission of Oregon (OPUC) staff
- John Crider, OPUC staff
- Rick Sterling, Idaho Public Utilities Commission (IPUC) staff

TRC members and regulatory observers serve either voluntarily or are paid by their own employers and receive no compensation from Idaho Power. The company is grateful for the TRC's time spent supporting the study and recognizes this support has led to a better study.

INTRODUCTION

Electric power from solar photovoltaic resources exhibits greater variability and uncertainty than energy from conventional generators. Because of the greater variability and uncertainty, electric utilities incur increased costs when their other generators are called on to integrate photovoltaic solar plant generation. These costs occur because power systems are operated less optimally in order to successfully integrate solar plant generation without compromising the reliable delivery of electrical power to customers. Idaho Power has studied the modifications it must make to power system operations to integrate solar photovoltaic power plant generation connecting to its system. The objective of this solar integration study is to determine the costs of the operational modifications necessary to integrate solar plant generation. This report is intended to describe the operational modifications and the resulting costs.

In collaboration with the TRC, Idaho Power organized the study into four primary steps:

1. Data gathering and scenario development
2. Statistical-based analysis of solar characteristics
3. Production cost simulation analysis
4. Study conclusions and results

These steps were formulated based on an article published by the Institute of Electrical and Electronics Engineers (IEEE) describing methods for studying wind integration (Ela et al. 2009). While the IEEE article, which was authored by leading researchers at the NREL, was written from the perspective of studying grid integration of wind generation, the principles underlying the study of wind integration are readily transferrable to the study of solar integration. Both wind and solar bring increased variability and uncertainty to power system operation, and a key objective of an integration study for each is to understand how variability and uncertainty lead to impacts and costs.

DATA GATHERING AND SCENARIO DEVELOPMENT

A critical element of the solar integration study is the solar generation data developed for the studied solar build-out scenarios. For Idaho Power's solar integration study, the solar build-out scenarios in Table 3 were studied.

Table 3
Solar build-out scenarios studied

Site	Installed Capacity of Solar Build-Out Scenarios			
	100 megawatts (MW)	300 MW	500 MW	700 MW
Parma, ID	10	30	50	100
Boise, ID	20	60	100	100
Grand View, ID	20	60	100	150
Twin Falls, ID	20	60	100	100
Picabo, ID	10	30	50	100
Aberdeen, ID	20	60	100	150
Total MW	100	300	500	700

The above build-out scenarios were developed in consultation with the TRC to represent geographically dispersed build-outs of solar power plant capacity. The importance of geographic dispersion in reducing integration impacts and costs is discussed in greater detail later in this report. The sites from the solar build-out scenarios are part of the established United States (U.S.) Bureau of Reclamation (USBR) AgriMet Network (AgriMet). AgriMet is a satellite-based network of automated agricultural weather stations operated and maintained by the USBR. The stations are located in irrigated agricultural areas throughout the Pacific Northwest and are

dedicated to regional crop water-use modeling, agricultural research, frost monitoring, and integrated pest and fertility management. The six sites are spread across southern Idaho and cover over 220 miles from east to west (Figure 1). Sites represent elevations ranging from 2,300 feet to 4,900 feet (Table 4).




Figure 1
AgriMet sites used in IPC's solar integration study

Table 4
AgriMet site latitude, longitude, and elevation used in IPC's solar integration study

Station	Latitude (N)	Longitude (west)	Elevation (feet)	Elevation (meter)
Parma	43.18	116.93	2,305	702
Boise	43.60	116.18	2,720	829
Grand View	42.91	116.06	2,580	786
Twin Falls	42.55	114.35	3,920	1,195
Picabo	43.31	114.17	4,900	1,494
Aberdeen	42.95	112.83	4,400	1,341

All data used in the integration study are 5-minute interval global horizontal irradiance data from each site. Idaho Power worked directly with the USBR Pacific Northwest Region AgriMet manager to obtain data for the sites. AgriMet data was augmented with data from the University of Oregon Solar Radiation Monitoring Laboratory when AgriMet data was incomplete. The use of high-resolution (5-minute interval) data is critical to characterizing the variability of solar.

An alternative data-gathering approach was necessary for the Grand View site, for which only 15-minute data was available. To acquire 5-minute data for Grand View, Idaho Power contracted

with SolarAnywhere to provide high-resolution modeled solar data. SolarAnywhere uses hourly satellite images processed using the most current algorithms developed and maintained by Dr. Richard Perez at the University at Albany (SUNY). The algorithm extracts cloud indices from the satellite's visible channel using a self-calibrating feedback process capable of adjusting for arbitrary ground surfaces. The cloud indices are used to modulate physically-based radiative transfer models describing localized clear-sky climatology.

Wavelet-Based Variability Model

AgriMet solar data represents conditions at a single point. To better reflect conditions at a solar plant size, the TRC recommended the use of the wavelet-based variability model (WVM) developed by Dr. Matt Lave of Sandia National Labs (Lave et al. 2013a,b). WVM is designed for simulating solar photovoltaic power plant output given a single irradiance point-sensor time series. The application of the WVM to the point-sensor time series produces a variability reduction reflecting an upscaling of the point-source data to a solar plant-sized area. Research and use into the WVM showed it is not useable at time steps (intervals) greater than 10 minutes and that time steps greater than 5 minutes may under-represent variability in dispersed systems.

Solar Plant Characteristics

This study assumes solar plants comprising the build-out scenarios occupy 7 acres per MW of installed capacity. Solar plant sizes in the build-out scenarios, as well as figures presented for solar generation, are in terms of AC (alternating current) MW. Photovoltaic panels are assumed to be of standard crystalline silicon manufacture. Panels are assumed to be fixed south facing and tilted at latitude. While panel orientation and tracking capability are key factors in the determination of avoided costs, these attributes are of lesser importance with respect to the variability and uncertainty driving integration costs. Illustrations and data summarizing the solar production of the studied build-outs are provided in Appendix 1.

STATISTICAL-BASED ANALYSIS OF SOLAR CHARACTERISTICS

The intent of the statistical-based analysis of solar characteristics is to translate solar's variability and uncertainty into an increased requirement for ancillary services, where ancillary services in this context relate to the electrical system's capacity to maintain a balance between customer demand and generation. For the study, the variability and uncertainty associated with solar generation were viewed from the perspective of hour-ahead scheduling of the Idaho Power system. There are three critical elements from this perspective:

1. Forecast hourly average solar production for the operating hour being scheduled
2. Lower bound for instantaneous solar production during the operating hour
3. Upper bound for instantaneous solar production during the operating hour

From the perspective of real-time generation scheduling in practice, the lower and upper bounds would be considered an interval or band on solar production, and the occurrence of

solar production outside the interval at any moment during the hour is highly unlikely. Moreover, while under prudent operating practices the occurrence of solar production outside the lower and upper bounds should be infrequent, occasional solar excursions outside these bounds do not necessarily bring about events for which system reliability is jeopardized. Conversely, the occurrence of solar production within the interval between the lower and upper bounds would be considered likely enough to warrant the scheduling of dispatchable generators to have capacity to respond if solar production varies during the hour from the forecasted level of production toward either bound.

An understanding of Idaho Power's participation in the regional electric power market is critical to this approach. Idaho Power primarily participates in the Pacific Northwest's Mid-Columbia (Mid-C) electric power market. The company participates in the Mid-C market at multiple time frames ranging from years or months in advance for long-term operations planning to hour-ahead generation scheduling in real time.

The focus for this study is the real-time market activities occurring as part of hour-ahead system scheduling. The study assumes hour-ahead schedulers require the delivery of forecast hourly average solar production and the above-described lower and upper bounds 45 minutes prior to the start of the operating hour being scheduled. Hour-ahead scheduling is assumed binding, and unexpected conditions occurring during the operating hour being scheduled must be managed by changing production for Idaho Power-owned dispatchable resources.

Idaho Power recognizes efforts to establish intra-hour trading in U.S. electric power markets. However, company experience has shown the intra-hour market to be currently highly illiquid. Therefore, the last opportunity to participate in the electric power market is at the hour-ahead time frame; unexpected conditions occurring during the operating hour (e.g., unexpected levels of solar production) cannot be managed through market activity at this time.

Hour-Ahead Solar Production Forecast

The hour-ahead solar production forecast was developed to predict hourly average solar production for the operating hour being scheduled and lower and upper bounds for instantaneous solar production during the operating hour. This forecast was developed using a persistence-based technique that relies on observations from the previous hours to inform the model about subsequent forecast hours. The results of the forecast are a unique set of values (average production, upper bound, and lower bound) for every hour in the year.

The average production forecast is derived based on two components. The first component accounts for the amount of generation the system observed from the last 20 minutes of the preceding forecast hour. This component is referred to as the persistence component. The persistence component serves as a mechanism to increase the average forecast during times of high solar production and decrease the average forecast during times of low solar production. These increases and decreases are made to the forecast hourly and account for changes in solar production. In general, the shape of the production from a solar photovoltaic system increases before solar noon and decreases after solar noon. Every day of the year has a unique clear-day shape. Generally, summer days are long and have a high potential for solar production while winter days are shorter and have less potential. The forecast accounts for the uniqueness of each

day by applying an hourly shaping factor. This shaping component, or shaping factor, is a unique value for every hour in the year. The shaping component is a ratio of the maximum solar potential of the forecast hour divided by the maximum potential of the previous hour.

By utilizing a shaping component and a persistence component, the average production forecast captures hourly changes due to atmospheric conditions and seasonal effects. Table 5 provides the forecast error for the hour-ahead solar production forecast.

Table 5

Forecast error for the hour-ahead solar production forecast

	100 MW	300 MW	500 MW	700 MW
Absolute Mean Hourly Error (MW)	1.9	5.8	9.6	12.2

Table 5 reports the absolute mean error calculated on an hourly basis for water year 2012. The absolute hourly error is calculated as the absolute difference between the average hourly forecast and the average of 5-minute observed production data for a given hour. It is noted that the 5-minute observed production data is the output of the WVM. The absolute mean hour errors range from 1.9 MW to 12.2 MW for the 100 MW and 700 MW build-out scenarios, respectively.

The lower bound for instantaneous solar production during the operating hour is forecasted as a percentage of the forecast average. In addition to the application of a percentage of average, the forecasting tool adjusts the lower bound forecast upward if the previous lower bound forecast was substantially too low. As a result of this secondary adjustment to the lower bound, the amount of incremental capacity held in reserve for the coming hour is reduced.

Similar to the lower bound, the upper bound for instantaneous solar production during the operating hour is forecasted as a percentage of the forecast average. In addition to the application of a percentage of average, the forecasting tool adjusts the upper bound forecast downward if the previous upper bound forecast was substantially too high. As a result of this secondary adjustment to the upper bound, the amount of decremental capacity held in reserve for the coming hour is reduced.

The upper and lower bounds are expected to capture the overwhelming majority of the variability observed in solar production. The upper bound is forecasted in such a way that only 2.5 percent of all observations exceed the upper bound for the entire year. Similarly, the lower bound is defined in such a way that only 2.5 percent of all observations are below the lower bound for the entire year.

The hour-ahead forecast for the average production, lower bound for instantaneous solar, and upper bound for instantaneous solar are calculated for every hour of the year. The amount of incremental capacity held in reserve for a given hour is calculated as the difference between the average production forecast and the lower bound. The amount of decremental capacity held in reserve for a given hour is calculated as the difference between the average production forecast and the upper bound. The total amount of capacity held in reserve for a given hour is used by the production cost model to calculate an integration cost. These reserve amounts, as well as the hour-ahead forecast for solar production, are input to the production cost model on an hour-by-hour basis, simulating the practice of real-time generation scheduling. Table 6 reports the

forecasted amount of capacity held in reserve for water year 2012. Further explanation of the derivation of the hour-ahead solar production forecast and the lower and upper bounds is provided in Appendix 1.

Table 6

Forecasted incremental and decremental capacity held in reserve, water year 2012

	Solar Build-Out Scenarios			
	100 MW	300 MW	500 MW	700 MW
Average hourly production (MW)	17.0	52.5	89.0	118.2
Average hourly capacity held in reserve—incremental (MW)	4.9	13.2	21.2	27.6
Average hourly capacity held in reserve—decremental (MW)	4.9	15.2	26.9	34.8

PRODUCTION COST SIMULATION ANALYSIS

The production cost simulations are designed to isolate the effects on the system associated with integrating solar. Under this design, production cost simulations are paired into a base case and test case, with all inputs to the paired simulations equivalent except an amount of capacity held in reserve in the test case simulation for integrating solar. The capacity held in reserve for the test case varies hourly depending on the hour-ahead forecast of solar production for a given operating hour and the lower and upper bounds on instantaneous solar production for the operating hour. The derivation of the hour-ahead solar production forecast and the lower and upper bounds is described in the previous section of this report.

Design of Simulations

The production cost simulations are set up on a water-year calendar, where by convention a water year is from October 1 to September 30 and is designated by the calendar year in which the 12-month period ends. For example, water year 2013 is the 12-month period from October 1, 2012, through September 30, 2013.

The Idaho Power generating system as it exists at the time of issue of this report is assumed for the production cost simulations. Critical elements of the simulated system of generating resources include 17 hydroelectric facilities totaling 1,709 MW of nameplate capacity, 3 coal-fired facilities totaling 1,118 MW of nameplate capacity, and 3 natural gas-fired facilities totaling 762 MW of nameplate capacity. An illustration of the generating resources is provided in Appendix 1.

Idaho Power's critical interconnections to the regional market are over the Idaho–Northwest, Idaho–Utah (Path C), and Idaho–Montana paths. For the solar integration study modeling, the separate paths were combined to an aggregate path for off-system access. Purchases from the regional market are treated separately from sales to the regional market. Net firm purchases from the market are limited on a monthly basis to only the capacity and energy required to serve

Idaho Power's retail load. Sales to the market are limited to 500 MW in every hour. This profile of purchases and sales reflects the current capabilities of Idaho Power's transmission system.

Idaho Power is pursuing the development of the Boardman to Hemingway Transmission Project (B2H), which will increase Idaho Power's access to the Northwest to make additional purchases and sales. However, the transmission line's current in-service date is at least five years into the future. Previous integration studies have shown that unless there is a liquid capacity balancing market, B2H will not significantly impact the solar integration cost. Idaho Power is actively engaged in regional market discussions that could exist when B2H is completed, but the benefits of a market are highly dependent on its design, and it is premature to speculate or incorporate in this integration study.

Simulation Inputs

Table 7 provides key inputs to the solar integration study production cost simulations.

Table 7
Inputs for the solar integration study production cost simulations

Input	Assumed input level
Solar production	Water year 2012
Snake River streamflows	Water year 2012 (median-type streamflows)
Customer demand	Water year 2012
Nymex—Natural gas prices	Water year 2012
Mid-C—Electric power market prices	Water year 2012
Non-wind PURPA ¹	Water year 2012
Wind (PURPA and PPA) ¹	Water year 2013
Geothermal PPAs	Water year 2014

¹ PPA and PURPA represent facilities from which generation is contractually purchased as a power purchase agreement (PPA) or under the federal *Public Utility Regulatory Policies Act of 1978* (PURPA).

The selection of water year 2012 for the majority of the inputs was driven by the selection of Snake River streamflows for water year 2012 (October 1, 2011–September 30, 2012) and the objective to use time-synchronous input data to the greatest possible extent. Snake River Basin streamflow conditions as observed in water year 2012 were selected because the observed water year 2012 Brownlee reservoir inflow volume of 13.6 million acre-feet is representative of median-type streamflow conditions. A graph of Brownlee inflow volumes for water years 1990 to 2013 is provided in Appendix 1.

The solar production data used in the production cost simulations are considered to be the solar production that would have been observed during water year 2012 had the four studied solar build-out scenarios existed. As described previously, the solar production data is developed by applying a wavelet smoothing transformation technique to 5-minute interval AgriMet and SolarAnywhere data. Importantly, the use of observed customer demand from water year 2012 allows time synchronization between solar and customer demand data in the study. While customer demand has grown since 2012, the benefit of using time-synchronous

customer demand and solar production data is considered to justify the use of 2012 customer demand data. Monthly average customer demand used in the modeling is provided in Appendix 1.

Water year 2012 Nymex natural gas prices and Mid-C electric power market prices are inputs to the simulations. These prices, expressed as a monthly average, are provided in Appendix 1.

Wind capacity under contract with Idaho Power grew by more than 60 percent during water year 2012, expanding from 395 MW of installed capacity to 638 MW. Because of the non-constant amount of on-line wind capacity during water year 2012, the simulations used observed hourly wind production data for water year 2013. The amount of on-line wind capacity during water year 2013 changed only by the addition of a single 40 MW project added during December 2013 that brought wind to the current on-line capacity of 678 MW. Monthly energy production used in the modeling is included in Appendix 1.

The remaining energy purchased from non-wind PURPA qualifying facilities is input into the simulations as observed during water year 2012. The monthly energy from the non-wind PURPA facilities is included in Appendix 1.

Baseload generation from geothermal facilities contractually selling to Idaho Power under PPAs is input as currently projected from these facilities. The amount of baseload generation delivered from these facilities varies seasonally. The amount used in the production cost simulations ranges from 22 MW to 32 MW.

Simulation Model

Idaho Power used an internally developed system operations model for the solar integration study. The model determines optimal hourly scheduling of dispatchable hydro and thermal generators with the objective of minimizing production costs while honoring constraints imposed on the system. System constraints used in the model capture numerous restrictions governing the operation of the power system, including the following:

- Reservoir headwater constraints
- Minimum reservoir outflow constraints
- Reservoir outflow ramping rate constraints
- Generator minimum/maximum output levels
- Market purchase/sale constraints
- Generator ramping rates

The model also stipulated that demand and resources were exactly in balance and importantly that hourly reserve requirements were satisfied. The extra capacity in reserve held to manage variability and uncertainty in solar production drives the production cost differences between the

study's two cases. The derivation of the extra capacity in reserve held for solar is described previously in this report.

Wind and Load Reserves

Capacity in reserve to manage variability and uncertainty in load and wind is included in the simulations in equivalent amounts for the study's two cases. By carrying equivalent amounts in reserve for load and wind, the production cost differences yielded by the study's simulations can be attributed to the extra capacity held in reserve for solar. Thus, while reserves carried for load and wind are not drivers of production cost differences in the paired simulations, it is nevertheless desirable in simulating the system as accurately as possible to incorporate reserve levels for load and wind representative of levels carried in practice.

To manage variability and uncertainty in load, capacity in reserve equal to 3 percent of load is held on dispatchable generators in the modeling for the solar integration study. The amount of simulated capacity in reserve for balancing wind is based on an analysis performed for the Idaho Power wind integration study as described in the February 2013 *Wind Integration Study Report* (Idaho Power 2013). The simulated reserves for the solar integration study are based on a scaling of the reserves at the wind study's 800 MW wind build-out scenario to the water year 2013 wind build-out of 678 MW.

Contingency Reserve Obligation

The study of integration impacts and costs focuses on the need to carry bidirectional capacity in reserve for maintaining compliance with reliability standards. However, balancing authorities, such as Idaho Power, are also required to carry unloaded capacity in reserve for responding to system contingency events, which have traditionally been viewed as large and relatively infrequent system disturbances affecting the production or transmission of power (e.g., the loss of a major generating unit or major transmission line). System modeling for the solar integration study imposes a contingency reserve intended to reflect this obligation equal to 3 percent of load and 3 percent of generation, setting aside this capacity for both study cases (i.e., base and test).

Flexible Capacity Resources

As described previously, the focus of the production cost simulations for the solar integration study is the real-time market activities occurring as part of hour-ahead system scheduling. The study assumes hour-ahead schedulers require the delivery of forecast hourly average solar production and the lower and upper bounds for solar production 45 minutes prior to the start of the operating hour being scheduled. Hour-ahead scheduling is then assumed binding, and unexpected levels of solar production occurring during the operating hour being scheduled must be managed by Idaho Power's system.

To manage deviations in solar production from the forecast during the operating hour, Idaho Power must schedule incremental and decremental capacity in reserve on dispatchable generators. In the modeling for the study, this capacity in reserve is scheduled on Hells Canyon Complex (HCC) hydroelectric generators (Brownlee, Oxbow, and Hells Canyon), natural gas-fired generators (Langley Gulch, Danskin, and Bennett Mountain), and Jim Bridger

coal-fired generators. The allocation of reserve to these generators matches Idaho Power's practice for balancing variations in wind production and load.

RESULTS

The objective of the Idaho Power solar integration study is to determine the costs of the operational modifications necessary to integrate solar photovoltaic power plant generation. The integration costs are driven by the need to carry extra capacity in reserve to allow bidirectional response from dispatchable generators to unplanned excursions in solar production. The simulations performed for the Idaho Power solar integration study indicate the following costs associated with holding the extra capacity in reserve (Table 8). The provided costs are the costs to integrate solar production for calendar year 2014, and are not costs averaged or leveled over the life of a solar power plant.

Table 8
Average integration cost per MWh for solar build-out scenarios

	0-100 MW	0-300 MW	0-500 MW	0-700 MW
Integration cost	\$0.40/MWh	\$1.20/MWh	\$1.80/MWh	\$2.50/MWh

Note: Costs are in 2014 dollars and rounded from simulation results to the nearest \$0.10.

The integration cost results in Table 8 are the cost per MWh to integrate the full installed solar power plant capacity at the respective scenarios studied. For example, the integration cost results indicate the total solar power plant capacity making up the 500 MW build-out scenario brings about costs of \$1.80 for each megawatt-hour (MWh) integrated.

Integration costs can be expressed alternatively in terms of incremental costs. Integration costs when expressed incrementally assume early projects are assessed lesser integration costs, and later projects need to make up the difference to allow full cost recovery for a given build-out scenario. For example, if solar plants comprising the first 100 MW build-out are assessed integration costs of \$0.40/MWh, then plants comprising the increment between 100 MW and 300 MW need assessed integration costs of \$1.50/MWh to allow full recovery of the \$1.20/MWh costs to integrate 300 MW of solar plant capacity. Incremental solar integration costs are provided in Table 9.

Table 9
Incremental integration cost results for solar build-out scenarios

	0-100 MW	100-300 MW	300-500 MW	500-700 MW
Incremental integration cost	\$0.40/MWh	\$1.50/MWh	\$2.80/MWh	\$4.40/MWh

Note: Costs are in 2014 dollars and rounded from simulation results to the nearest \$0.10.

Study Findings

Hour-Ahead Solar Production Forecasting

Analyses suggest a persistence-based forecast with adjustment to account for known changes in the sun's position provides a reasonable production forecast for hour-ahead operations scheduling. The persistence-based hour-ahead solar production forecast used for the study is based entirely on observed production and consequently could be readily adopted in practice.

While a day-ahead solar production forecast would be necessary in practice for a balancing authority integrating solar, deviations from the day-ahead forecast can be managed through a combination of market transactions and operations modifications, and consequently the study imposes no reserve requirement to cover deviations for day-ahead solar production forecasts.

Compared to wind, system operators managing a balancing authority integrating solar would have the benefit of at least six hours at the start of day with no or little solar production. During this period of no or little solar production, system operators could evaluate the day-ahead solar production forecast using information from updated weather forecast products and begin to plan for necessary actions to manage deviations from the day-ahead solar production forecast.

In contrast, deviations from the hour-ahead solar production forecast can only be covered by Idaho Power's dispatchable generators. The analysis for the solar integration study by design determines the amounts of bidirectional capacity in reserve that system operators would need to schedule to position dispatchable generators to cover possible deviations from the hour-ahead solar production forecast. Integration costs are a result of the sub-optimal scheduling of the dispatchable generators associated with holding the solar-caused capacity in reserve.

Comparison to Wind Integration

This study indicates solar plant integration costs are lower than wind plant integration costs. The lower integration costs associated with solar are fundamentally the result of less variability and uncertainty. As described in the preceding section, the study assumes deviations in solar plant production from day-ahead forecast levels can be managed through a combination of market transactions and operations modifications, allowing day-ahead generation scheduling to avoid extra reserve burden. Therefore, reserves carried for solar generation can be focused on readying dispatchable generators to respond to unplanned solar excursions from hour-ahead production forecasts. Moreover, logic incorporated in the derivation of lower and upper bounds on the hour-ahead production forecast, which can be readily adopted in practice, allows the adjustment of the bounds in response to observed solar production patterns. In effect, the hour-ahead forecast is based on a persistence of level of production (adjusted for the known change in the sun's position), as well as a persistence of variability in production. The consequence of these methods is that bidirectional capacity held in reserve on dispatchable generators to respond to solar variability and uncertainty is less than that required for responding to wind.

Qualitatively, solar is more predictable than wind. Sunrise and sunset times, as well as the time of solar noon, are a certainty. The theoretical maximum level of production can be

readily derived, reflecting patterns on daily, monthly, and seasonal time scales. Finally, land requirements for a solar power plant are likely to promote a relatively high level of dispersion, which is critical to the mitigation of impacts from severe and abrupt ramps in production exhibited by individual panels in response to passing clouds. The effects of geographic dispersion are discussed further in the following section.

Geographic Dispersion

Production for a single solar photovoltaic panel exhibits severe and abrupt intermittency during variably cloudy conditions; a TRC member expressed during a meeting that for a single panel, the drop in production from a cloud is effectively instantaneous. The effect of severe and abrupt intermittency is commonly attributed to the absence of inertia in the photovoltaic process. While the intermittency effect is severe for a single panel, dampening occurs when considering the production from a solar plant-sized aggregation of panels, and even further dampening occurs when considering the production from several solar plants spread over a region such as southern Idaho. Therefore, geographic dispersion has significant influence on solar integration impacts and is perhaps of greater importance for solar than wind.

The four studied solar build-out scenarios each have capacity installed at six southern Idaho locations spread over more than 220 miles from east to west. Because of the substantial geographic dispersion, severe instantaneous ramps in solar production for the study data are relatively infrequent. If solar plant development in southern Idaho occurs in a more clustered fashion than assumed for this study, actual integration impacts and costs will be higher than the results of this study.

Transmission and Distribution

The focus of Idaho Power's solar integration study is a macro-level investigation of the operations modifications necessary to maintain balance between power supply and customer demand for a balancing authority integrating photovoltaic solar plant generation. The objective is to understand the impacts and costs of the sub-optimal operation of dispatchable generating capacity. The study is not an investigation of integration issues related to the delivery of energy from proposed solar photovoltaic power plants to the retail customer; these issues are addressed in individual interconnection studies performed on a plant-by-plant basis.

Spring-Season Integration

The production cost simulations suggest reserve requirements are particularly problematic when hydroelectric resources are highly constrained, such as frequently occurs during spring-season periods characterized by high water, low customer demand, and high generation from variable generating resources, such as wind and solar. Experience has shown wind integration to be particularly challenging during these periods, and the simulations suggest similar challenges integrating solar. This study finding is corroborated by NREL in the Western Wind and Solar Integration Study Phase 2 (Lew et al. 2013), which reports the need for flexibility is notably high during the spring and that during these periods the curtailment of variable generation is one source of flexibility enabling the balancing of generation and customer demand.

CONCLUSIONS

The cost to integrate the variable and uncertain delivery of energy from solar photovoltaic power plants is driven by the need to carry extra capacity in reserve. This extra capacity in reserve is necessary to allow bidirectional response from dispatchable generators to unplanned excursions in solar production. The simulations performed for Idaho Power's solar integration study indicate the costs associated with holding the extra capacity in reserve (Table 8).

Further Study

The integration of variable generation, including the study of methods for determining integration impacts and costs, continues to be the subject of considerable research. The breadth of this research highlights the interest in variable-generation integration, as well as the evolution of study methods. Idaho Power appreciates the level of interest in its study of integration of variable generation and recognizes the likelihood of a second-phase study with expanded scope.

During the course of the solar integration study, in discussions with the TRC and participants of the public workshop, Idaho Power has received suggestions for a second-phase study of solar integration. Suggestions for a second phase include the study of the following:

- Alternative water-year types (e.g., low-type and high-type)
- Intra-hour trading opportunities
- Shortening the hour-ahead forecast lead time from 45 minutes to 30 minutes
- Clustered solar build-out scenarios
- Smaller solar build-out scenarios (e.g., 50 MW of installed capacity)
- Other solar plant technologies (e.g., tracking systems or varied fixed-panel orientation)
- Distributed solar systems (i.e., rooftop systems)
- Correlation between solar, wind, and load variability and uncertainty
- Improved forecasting methods
- Energy imbalance markets
- Voltage/frequency regulation

Idaho Power will consider these suggestions during the development of scope for a second-phase study.

LITERATURE CITED

- Ela E., M. Milligan, B. Parsons, D. Lew, and D. Corbus. 2009. The evolution of wind power integration studies: Past, present, and future. IEEE Power & Energy Society General Meeting, 2009 PES '09.
- Idaho Power. 2013. Wind Integration Study Report. Boise, ID: Idaho Power.
- Lave, M., A. Ellis, and J. Stein. 2013a. Simulating solar power plant variability: A review of current methods. Sandia report—SAND2013-4757. http://energy.sandia.gov/wp/wp-content/gallery/uploads/SAND2013-4757_Simulating_Solar_Power_Plant_Variability_A_Review_of_Current_Methods_FINAL.pdf. Accessed June 2014.
- Lave, M., J. Kleissl, J. S. Stein. 2013b. A wavelet-based variability model (WVM) for solar PV power plants. IEEE Transactions on Sustainable Energy, Vol. 4, No. 2.
- Lew, D., G. Brinkman, A. Ibanez, A. Florita, M. Heaney, B. M. Hodge, M. Hummon, G. Stark, J. King, S. A. Lefton, N. Kumar, D. Agan, G. Jordan, and S. Venkataraman. 2013. Western Wind and Solar Integration Study Phase 2. NREL/TP-5500-55588. Golden, CO: National Renewable Energy Laboratory. <http://www.nrel.gov/docs/fy13osti/55588.pdf>. Accessed June 2014.
- [UVIG and NREL]. Utility Variable-Generation Integration Group and National Renewable Energy Laboratory. No date. Principles for Technical Review Committee (TRC) involvement in studies of variable generation integration into electric power systems. <http://variablegen.org/wp-content/uploads/2009/05/TRCPrinciplesJune2012.pdf>. Accessed June 2014.

This page left blank intentionally.

Appendix 1
Solar integration study appendix

Table of Contents

Introduction

Technical Review Committee

 List of TRC Members

 Regulatory Commission Staff Observers

 TRC Schedule and Agenda

 Public Workshop Schedule and Agenda

Data Inputs and Assumptions

 Natural Gas Price Assumptions

 Market Power Price Assumptions

 IPC Customer Load Data

 Idaho Power Existing Generation

 Hydroelectric Generation Data

 Run-of-River Projects

 Wind Generation Data

 Aggregate PPA and PURPA Projects

 Non-Wind PURPA Generation Data

 Solar Production Data

 Derivation of Hour-Ahead Solar Production Forecast and Upper/Lower Bounds

INTRODUCTION

This appendix contains supporting data and explanatory materials used to develop Idaho Power's *2014 Solar Integration Study*.

The main document, the *2014 Solar Integration Study*, contains a full narrative of Idaho Power's process for studying solar integration costs. For information or questions concerning the study, contact Idaho Power:

Idaho Power—Resource Planning
1221 W. Idaho St.
Boise, Idaho 83702
208-388-2623

TECHNICAL REVIEW COMMITTEE

The Technical Review Committee (TRC) was formed during summer 2013 to provide input, review, and guidance for the study. It is comprised of participants from outside of Idaho Power that have an interest and/or expertise with the integration of intermittent resources onto utility systems.

As part of preparing the *2014 Solar Integration Study*, Idaho Power held one public meeting and four TRC meetings. Idaho Power values these opportunities to convene, and the TRC members have made significant contributions to this plan.

List of TRC Members

Brian Johnson.....University of Idaho
Jimmy LindsayPortland General Electric (formerly of Renewable Northwest Project)
Kurt MyersIdaho National Laboratory
Paul Woods(formerly of City of Boise)
Cameron YourkowskiRenewable Northwest Project (replacing Jimmy Lindsay)

Regulatory Commission Staff Observers

Brittany Andrus.....Public Utility Commission of Oregon (OPUC) staff
John Crider.....OPUC Staff
Rick SterlingIdaho Public Utilities Commission (IPUC) staff

TRC Schedule and Agenda

Meeting Dates

2013 Thursday, August 15

Agenda Items

Introductions and role of TRC
Idaho Power system overview
Formulation of basic study design
Establish solar futures
Techniques for building solar generation data
Closing thoughts and comments

2013 Thursday, September 19

Study design
Key study components
Hydro—WY 2011 vs. WY 2012 vs. WY 2013
Solar—WY 2011 vs. WY 2012 vs. WY 2013
Market power prices
Natural gas prices
Solar penetration levels

2014 Monday, January 6

Review of Study Design
Solar Data Availability
Wavelet-based Variability Model
Analysis Conclusions

2014 Friday, May 16

Review of Integration Study Design
Review of IPUC Filing
Development of Reserve Requirement for solar scenarios

2014 Thursday, May 29

Review of Operating Reserves
Review of Production Cost Model

Public Workshop Schedule and Agenda

Meeting Dates

2014 Thursday, May 1

Agenda Items

Introduction of Technical Review Committee
Idaho Power system overview
Study objective
Study design
System modeling
Next steps

DATA INPUTS AND ASSUMPTIONS

Natural Gas Price Assumptions

Table 1
Actual monthly average Nymex price for water year 2012

Year	Month	Average Monthly Price
2011	October	\$3.76
	November	\$3.52
	December	\$3.36
2012	January	\$3.08
	February	\$2.68
	March	\$2.45
	April	\$2.19
	May	\$2.04
	June	\$2.43
	July	\$2.77
	August	\$3.01
	September	\$2.63

Market Power Price Assumptions

Table 2
Actual average Mid-Columbia dollars/megawatt-hour (MWh) for water year 2012

Year	Month	Average Monthly Price
2011	October	\$26.02
	November	\$30.81
	December	\$30.13
2012	January	\$24.53
	February	\$23.50
	March	\$16.30
	April	\$8.99
	May	\$5.81
	June	\$4.50
	July	\$12.05
	August	\$24.75
	September	\$24.47

IPC Customer Load Data

Table 3
Actual average megawatt (MW) for water year 2012

Year	Month	Average Load
2011	October	1,403
	November	1,563
	December	1,729
2012	January	1,680
	February	1,597
	March	1,457
	April	1,504
	May	1,742
	June	2,108
	July	2,388
	August	2,197
	September	1,679

Idaho Power Existing Generation




Figure 1
Existing Idaho Power generating resources




Figure 2
Brownlee Reservoir inflow by water year

Hydroelectric Generation Data

Run-of-River Projects

Table 4
Actual monthly average MW (aMW) for water year 2012

Year	Month	aMW
2011	October	447
	November	418
	December	415
2012	January	358
	February	365
	March	380
	April	388
	May	252
	June	337
	July	292
	August	251
	September	208

Wind Generation Data

Aggregate PPA and PURPA Projects

Table 5
Actual monthly aMW for water year 2013

Year	Month	aMW
2011	October	95
	November	190
	December	120
2012	January	194
	February	167
	March	191
	April	172
	May	166
	June	163
	July	144
	August	131
	September	116

Non-Wind PURPA Generation Data

Table 6
Actual monthly aMW for water year 2012

Year	Month	aMW
2011	October	96
	November	52
	December	45
2012	January	43
	February	43
	March	54
	April	104
	May	135
	June	131
	July	140
	August	130
	September	111

Solar Production Data





Figure 3
Dispersed 100 MW





Figure 4
Dispersed 300 MW





Figure 5
Dispersed 500 MW





Figure 6
Dispersed 700 MW

Derivation of Hour-Ahead Solar Production Forecast and Upper/Lower Bounds




Figure 8
Hour-ahead forecast example

The average forecast is shown on Figure 8 as the green series. For each hour of the day, the forecast average is calculated by applying the follow equation:

$$Forecast\ Avg(t) = Forecast\ Obs(MW)_{(t-1:00 \rightarrow t-1:15)} * \frac{Avg\ CSIS_{(t:00 \rightarrow t:55)}}{Avg\ CSIS_{(t-2:20 \rightarrow t-1:15)}}$$

Where:

t = forecast hour

CSIS = Clear Sky Index Surrogate

The Clear Sky Index Surrogate (CSIS) is an important measure of the maximum amount of solar generation the system could experience in any given hour. The CSIS is a component of the average solar production forecast and accounts for the seasonal changes that influence solar photovoltaic generation. This value is unique for every hour of the year. The CSIS is calculated using 5-minute, modeled production data from the wavelet-based variability model (WVM). The CSIS is calculated by taking the maximum 5-minute observation for a given hour. This maximum value is the absolute maximum for a given hour over a 10-day period. After identifying the absolute maximum from water year 2011, the forecast also identifies the absolute maxima for water years 2012 and 2013. With the three absolute maxima identified from the three water years analyzed, the forecast applies the maximum CSIS observed in three years

of data for a given hour. It is noted that the ratio of the CSIS values, described in the above equation, result in the least amount of average production forecast error. Multiple variations of this ratio were tested, and the final version of the ratio was the most accurate. The process detailing the calculation of the CSIS is described in the equations below.

$$CSIS_{(t)} = Max ([CSIS_{(Water\ Year\ 2011)}], [CSIS_{(Water\ Year\ 2012)}], [CSIS_{(Water\ Year\ 2013)}])$$

Where:

$$CSIS_{(Water\ Year\ 2011)} = Max ([5\ min\ Obs(MW)_{(t)(d-1)}], [5\ min\ Obs(MW)_{(t)(d-2)}], \dots, [5\ min\ Obs(MW)_{(t)(d-10)}])$$

$$CSIS_{(Water\ Year\ 2012)} = Max ([5\ min\ Obs(MW)_{(t)(d-1)}], [5\ min\ Obs(MW)_{(t)(d-2)}], \dots, [5\ min\ Obs(MW)_{(t)(d-10)}])$$

$$CSIS_{(Water\ Year\ 2013)} = Max ([5\ min\ Obs(MW)_{(t)(d-1)}], [5\ min\ Obs(MW)_{(t)(d-2)}], \dots, [5\ min\ Obs(MW)_{(t)(d-10)}])$$

Where:

t = forecast hour

d = forecast day

Figure 8 is a good example of how the persistence-based forecast does very well under the majority of solar conditions and how a forecasting model struggles with extreme weather events. Despite the limitations of a persistence forecast, within a short period of time the forecast returned to accurate predictions. Figure 8 is a select, extremely variable generation profile. The afternoon observations that fall beneath the lower bound forecast are included in the 2.5 percent of lower forecast error reported in the solar integration study. Generally, the forecast does well capturing the variability in production due to solar. The forecast has the ability to tighten the range between the upper and lower bounds. This ensures the amount of capacity held in reserve is sufficient but not unduly large.

This page left blank intentionally.

BEFORE THE PUBLIC UTILITY COMMISSION
OF OREGON

UM _____

In the Matter of

IDAHO POWER COMPANY

Application for Approval of Solar Integration
Charge.

)
)
)
)
)
)

IDAHO POWER COMPANY

DIRECT TESTIMONY

OF

MICHAEL J. YOUNGBLOOD

April 24, 2015

1 **Q. Please state your name and business address.**

2 A. My name is Michael J. Youngblood and my business address is 1221 West Idaho
3 Street, Boise, Idaho 83702.

4 **Q. By whom are you employed and in what capacity?**

5 A. I am employed by Idaho Power Company ("Idaho Power" or "Company") as the
6 Manager of Regulatory Projects in the Regulatory Affairs Department.

7 **Q. Please describe your educational background.**

8 A. In May of 1977, I received a Bachelor of Science Degree in Mathematics and
9 Computer Science from the University of Idaho. From 1994 through 1996, I was a
10 graduate student in the Executive MBA program of Colorado State University. Over
11 the years, I have attended numerous industry conferences and training sessions,
12 including Edison Electric Institute's "Electric Rates Advanced Course."

13 **Q. Please describe your work experience with Idaho Power.**

14 A. I began my employment with Idaho Power in 1977. During my career, I have worked
15 in several departments of the Company and subsidiaries of IDACORP, including
16 Systems Development, Demand Planning, Strategic Planning, and IDACORP
17 Solutions. From 1981 to 1988, I worked as a Rate Analyst in the Rates and Planning
18 Department where I was responsible for the preparation of electric rate design
19 studies and bill frequency analyses. I was also responsible for the validation and
20 analysis of the load research data used for cost-of-service allocations.

21 From 1988 through 1991, I worked in Demand Planning and was responsible
22 for the load research and load forecasting functions of the Company, including
23 sample design, implementation, data retrieval, analysis, and reporting. I was
24 responsible for the preparation of the five-year and twenty-year load forecasts used
25 in revenue projections and resource plans, as well as the presentation of these
26 forecasts to the public and regulatory commissions.

1 From 1991 through 1998, I worked in Strategic Planning. As a Strategic
2 Planning Associate, I coordinated the complex efforts of acquiring Prairie Power
3 Cooperative, the first acquisition of its kind for the Company in 40 years. From 1996
4 to 1998, as a part of a Strategic Planning initiative, I helped develop and provide two-
5 way communication between customers and energy providers using advanced
6 computer technologies and telecommunications.

7 From 1998 to 2000, I was a General Manager of IDACORP Solutions, a
8 subsidiary of IDACORP, reporting to the Vice President of Marketing. I was directly
9 responsible for the direction and management of the Commercial and Industrial
10 Business Solutions division.

11 In 2001, I returned to the Regulatory Affairs Department and worked on
12 special projects related to deregulation, the Company's Integrated Resource Plan
13 ("IRP"), and filings with both the Idaho Public Utilities Commission ("IPUC") and the
14 Public Utility Commission of Oregon ("OPUC" or "Commission").

15 In 2008, I was promoted to the position of Manager of Rate Design for Idaho
16 Power. In that position I was responsible for the management of the rate design
17 strategies of the Company, as well as the oversight of all tariff administration.

18 In January of 2012, I became the Manager of Regulatory Projects for Idaho
19 Power, which is my current position. In this position, I provide the regulatory support
20 for many of the large individual projects and issues currently facing the Company.
21 Most recently that has included providing regulatory support for the inclusion of the
22 Langley Gulch power plant investment in rate base and supporting the Company's
23 efforts to address numerous issues involving Qualifying Facilities ("QF") as defined
24 under the Public Utility Regulatory Policies Act of 1978 ("PURPA"), including the
25 Company's efforts in Case No. GNR-E-11-03, the review of PURPA QF contract
26 provisions. Most recently, and pertinent to this docket, I provided direct testimony for

1 the Company in its Idaho Application to Implement Solar Integration Rates and
2 Charges, IPUC Docket IPC-E-14-18.

3 **Q. What is the purpose of your testimony in this matter?**

4 A. Idaho Power is requesting that the OPUC authorize the Company to implement solar
5 integration rates and charges consistent with its 2014 solar integration study ("Study"
6 or "2014 Study" or "Solar Study"). The 2014 Solar Study Report is attached as Idaho
7 Power/101, DeVol/1-36. Mr. DeVol's testimony provides a summary of the Solar
8 Study, a description of the Technical Review Committee and process utilized for the
9 Study, and the results of the Study. The purpose of my testimony is to provide the
10 Commission with the Company's request to implement solar integration rates and
11 charges based upon the costs identified by the 2014 Solar Study.

12 **Q. Have solar integration rates and charges based upon the costs identified by
13 the 2014 Solar Study been implemented in the Company's Idaho jurisdiction?**

14 A. Yes they have. On February 11, 2015, the Idaho Public Utilities Commission
15 ("IPUC") issued Order No. 33227 in Case No. IPC-E-14-18, approving a Settlement
16 Stipulation between Idaho Power, the IPUC Commission Staff, the Idaho
17 Conservation League, Sierra Club and Snake River Alliance, implementing the solar
18 integration rates and charges as filed by the Company.

19 **Q. Based on the results of the 2014 Study, what is the cost of integrating solar
20 generation on Idaho Power's electrical system?**

21 A. As presented in Mr. DeVol's testimony, the Solar Study analyzed four solar build-out
22 scenarios at installed capacities of: 100 megawatts ("MW"), 300 MW, 500 MW, and
23 700 MW. The results of the Solar Study show the integration costs indicated in the
24 following tables:
25
26

**Average Integration Cost per MWh
(2014 cost and dollars)**

Build-out Scenarios	0-100 MW	0-300 MW	0-500 MW	0-700 MW
Integration Cost	\$0.40	\$1.20	\$1.80	\$2.50

**Incremental Integration Cost per MWh
(2014 cost and dollars)**

Penetration Level	0-100 MW	100-300 MW	300-500 MW	500-700 MW
Integration Cost	\$0.40	\$1.50	\$2.80	\$4.40

The costs identified by the Solar Study reflect the costs to integrate solar generation for the calendar year 2014. The costs are reported in 2014 dollars and were rounded to the nearest ten (10) cents. They are not averaged or levelized over the life of the solar project or plant.

Q. What is the difference between the Average Integration Cost and the Incremental Integration Cost described in the 2014 Study?

A. The Average Integration Cost, as shown above, reports an average cost per megawatt-hour ("MWh") for each of the four discrete solar build-out scenarios modeled in the Study. In other words, the Average Integration Cost reflects the average cost per MWh to integrate one block of solar generation, independently, for each penetration level of solar generation: 0-100 MW; 0-300 MW; 0-500 MW; and 0-700 MW. Conversely, the Incremental Integration Cost indicates the cost of integrating solar generation as it would be assigned across the four blocks of solar generation penetration levels, in 200 MW increments.

Q. Please provide an example to further explain the distinction between Average Integration Cost and Incremental Integration Cost.

A. Certainly. According to the 2014 Study, the Average Integration Cost for all solar generation from 0-700 MW is \$2.50 per MWh. That means that if the total cost of


1 integrating 700 MW of solar were to be spread equally to all 700 MW of solar
2 generation, the cost of integration would be \$2.50 for each MWh generated.
3 However, if that same cost of integrating 700 MW of solar were to be broken up into
4 100 and 200 MW increments, the Incremental Integration Cost for the first 100 MW
5 of solar generation would be only \$0.40 per MWh. The incremental cost of
6 integration for the next 200 MW of solar generation (from 100 MW to 300 MW),
7 assuming that the first 100 MW of solar generation remains at \$0.40 per MWh, would
8 be \$1.50 per MWh. For the next 200 MW (300 MW to 500 MW), again assuming
9 that the cost per MWh for the each of the first two blocks of integration remained
10 unchanged, would be a cost of \$2.80 per MWh. The last 200 MW (500 MW to 700
11 MW) of solar generation would incur a cost of \$4.40 per MWh.

12 In aggregate, the total cost of integrating solar identified by either method, the
13 Average Integration Cost or the Incremental Integration Cost, is the same.
14 Essentially, the cost of solar integration increases as the penetration levels of solar
15 increase on the system. The Study identified the cost to integrate solar generation at
16 four discrete penetration levels. However, if costs are assigned on an incremental
17 basis, then costs are more closely assigned with the cause of those costs, and thus
18 the initial generation is assigned a lower cost than the later generation that shows up
19 when it is more costly to integrate.

20 **Q. How does the Company propose to implement solar integration cost recovery?**

21 A. Idaho Power proposes that a solar integration charge be established to collect the
22 incremental cost of integration at each 100 MW of solar generation penetration.
23 When Idaho Power first applied for a solar integration charge in Idaho (IPUC Case
24 No. IPC-E-14-18), there were no solar projects paying any integration charges on
25 Idaho Power's system, and therefore, the solar integration charge simply started at
26 zero and increased consistent with the costs of integration identified in the Solar

1 Study, at every 100 MW of solar nameplate capacity penetration level. The
2 proposed solar integration charges are rounded to the nearest penny and are
3 illustrated in the chart below:



16 **Q. How does the Company propose to implement solar integration charges in the**
17 **Company's Oregon jurisdiction?**

18 **A.** Similar to the implementation in the Company's Idaho jurisdiction, Idaho Power
19 recommends that the Commission allocate costs on a per MWh basis for incremental
20 levels of solar penetration. Idaho Power also proposes that solar integration charges
21 be set forth in a schedule, specifically established for intermittent generation
22 integration charges.

23 **Q. Have you provided an example of what an integration schedule might look**
24 **like?**

25 **A.** Yes. Idaho Power/201, Youngblood/1-16 is a draft Schedule 86, Solar Generation
26 Integration Charges. The integration charges from Schedule 86 would be deducted

1 from the avoided cost rates established for and set out in a PURPA contract.

2 **Q. Can you describe the proposed Schedule 86, Solar Generation Integration**
3 **Charges, you provide in Idaho Power/201, Youngblood/1-16?**

4 A. Yes. Schedule 86 is a draft of a new schedule which is intended to provide the
5 incremental integration charges to be assessed to solar QFs whose generation
6 resource is variable and intermittent in nature. Schedule 86 would provide the solar
7 integration charges consistent with the most recent integration study applicable to
8 solar generation. The draft of Schedule 86 submitted as Idaho Power/201,
9 Youngblood/1-16 contains the proposed incremental integration charges for solar
10 generation based upon the 2014 Study, and which are consistent with the solar
11 integration charges implemented by the IPUC in the Company's Idaho jurisdiction.
12 The charges set forth in Schedule 86 are the amounts to be deducted from avoided
13 cost rates each year, beginning in the year the project comes online, based on the
14 nameplate capacity of installed solar generation at the scheduled operation date of
15 the proposed project. Adoption of a schedule would allow integration costs to be
16 updated for new contracts as additional solar generation is added to the system, or
17 whenever a new solar integration study is completed and identifies a change in
18 integration costs. Having the costs set forth in Schedule 86 provides transparency
19 for the developers as to what the appropriate integration charges would be based
20 upon the scheduled operation date of the proposed project.

21 **Q. Can you describe the format in which the integration charges are set out in**
22 **Schedule 86?**

23 A. Yes. For simplicity and clarity, Idaho Power has formatted the integration charges to
24 appear in the same format as the Idaho Tariff Schedule 87. Each penetration level
25 (each 100 MW increment) has its own table clearly identified and set forth in
26 Schedule 86, and discloses both the levelized integration charge, as well as the non-


1 levelized stream of integration charge amounts listed by year. The scheduled
2 operation date for the proposed generation project is used as the starting point in the
3 table, and each yearly amount through the term of the proposed contract is set out
4 accordingly.

5 **Q. Is the Company proposing any solar integration charges in addition to those**
6 **currently implemented in Schedule 87 in Idaho?**

7 A. Yes. As I stated earlier, when Idaho Power first applied for a solar integration charge
8 in Idaho, there were no solar projects paying any integration charges on Idaho
9 Power's system, and therefore, the solar integration charge simply started at zero
10 and increased by 100 MW increments to 700 MW. The last table for solar integration
11 charges in Schedule 87 is for the 601 – 700 MW of solar capacity penetration level.
12 Since the time of the Company's filing in the Idaho case, the Company has received
13 solar project requests for pricing that have exceeded the 700 MW identified in the
14 table. Therefore, the Company is proposing to augment the Oregon Schedule 86 to
15 include incremental solar integration charges through 1,500 MW of solar capacity.

16 **Q. How does the Company propose to augment the incremental solar integration**
17 **charges?**

18 A. In IPUC Order No. 33227, the Idaho Commission stated that in the event that solar
19 penetration exceeded the Study's 700 MW level, the Company was directed to
20 "utilize the same process/methodology that it applied in its first study to extrapolate
21 integration charges as solar penetration increases." Therefore, based upon that
22 directive, in order to determine the additional incremental pricing, I simply developed
23 a mathematical formula to fit the curve of the existing increments which were based
24 upon the 2014 Solar Study, and then used that formula to extrapolate the
25 incremental charges from 700 MW to 1,500 MW in 100 MW increments. The chart
26 below shows the results of that extrapolation:



15 **Q. Is the Company planning on conducting another solar integration study?**

16 A. Yes, the Company is currently in the process of developing a new solar integration
17 study. As part of the Settlement Stipulation in IPUC Docket No. IPC-E-14-18, the
18 parties agreed that Idaho Power would initiate a second solar integration study in
19 January 2015, which we did. The 2015 solar integration study will utilize a Technical
20 Review Committee ("TRC") which includes members with expertise in solar
21 generation, variable energy integration and electrical grid operations. In addition, the
22 TRC includes participation from both the Idaho and Oregon Commission Staff.

23 **Q. Does the proposed Oregon Schedule 86 include the extrapolated integration
24 costs defined above?**

25 A. Yes. The Company's proposed Oregon Schedule 86 includes the same 100 MW
26 incremental levels from 0 to 700 MW as approved in Idaho, and then includes the

1 additional 100 MW increments from 701 MW through 1,500 MW, as defined above.

2 **Q. Does this conclude your testimony?**

3 A. Yes, it does.

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

Idaho Power/201
Witness: Michael J. Youngblood

BEFORE THE PUBLIC UTILITY COMMISSION
OF OREGON

IDAHO POWER COMPANY

Exhibit Accompanying Direct Testimony of Michael J. Youngblood

Schedule 86

April 24, 2015

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES

APPLICABILITY

This schedule is applicable to all qualifying facility ("QF") generators interconnected to the Company that have solar generation of an intermittent nature. The initial charges within this schedule are to be assessed to solar generation based upon the total nameplate capacity of solar generation interconnected to Company's system.

SOLAR INTEGRATION CHARGES

The following tables are applicable to all QF solar generation contracts that come online after May 1, 2015:

Continued on next page

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

0 - 100 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	0.54	2014	0.43
2015	0.56	2015	0.44
2016	0.58	2016	0.46
2017	0.59	2017	0.47
2018	0.61	2018	0.48
2019	0.63	2019	0.50
		2020	0.51
		2021	0.53
		2022	0.54
		2023	0.56
		2024	0.58
		2025	0.60
		2026	0.61
		2027	0.63
		2028	0.65
		2029	0.67
		2030	0.69
		2031	0.71
		2032	0.73
		2033	0.75
		2034	0.78
		2035	0.80
		2036	0.82
		2037	0.85
		2038	0.87
		2039	0.90

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

101 - 200 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	1.49	2014	1.18
2015	1.53	2015	1.22
2016	1.58	2016	1.25
2017	1.63	2017	1.29
2018	1.68	2018	1.33
2019	1.73	2019	1.37
		2020	1.41
		2021	1.45
		2022	1.50
		2023	1.54
		2024	1.59
		2025	1.63
		2026	1.68
		2027	1.73
		2028	1.79
		2029	1.84
		2030	1.89
		2031	1.95
		2032	2.01
		2033	2.07
		2034	2.13
		2035	2.20
		2036	2.26
		2037	2.33
		2038	2.40
		2039	2.47

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

201 - 300 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	2.32	2014	1.84
2015	2.39	2015	1.89
2016	2.46	2016	1.95
2017	2.54	2017	2.01
2018	2.61	2018	2.07
2019	2.69	2019	2.13
		2020	2.20
		2021	2.26
		2022	2.33
		2023	2.40
		2024	2.47
		2025	2.55
		2026	2.62
		2027	2.70
		2028	2.78
		2029	2.87
		2030	2.95
		2031	3.04
		2032	3.13
		2033	3.23
		2034	3.32
		2035	3.42
		2036	3.52
		2037	3.63
		2038	3.74
		2039	3.85

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

301 - 400 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	3.12	2014	2.48
2015	3.22	2015	2.55
2016	3.32	2016	2.63
2017	3.41	2017	2.71
2018	3.52	2018	2.79
2019	3.62	2019	2.87
		2020	2.96
		2021	3.05
		2022	3.14
		2023	3.23
		2024	3.33
		2025	3.43
		2026	3.53
		2027	3.64
		2028	3.75
		2029	3.86
		2030	3.97
		2031	4.09
		2032	4.22
		2033	4.34
		2034	4.47
		2035	4.61
		2036	4.75
		2037	4.89
		2038	5.03
		2039	5.19

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

401 - 500 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	3.94	2014	3.12
2015	4.06	2015	3.22
2016	4.18	2016	3.31
2017	4.31	2017	3.41
2018	4.44	2018	3.52
2019	4.57	2019	3.62
		2020	3.73
		2021	3.84
		2022	3.96
		2023	4.08
		2024	4.20
		2025	4.32
		2026	4.45
		2027	4.59
		2028	4.72
		2029	4.87
		2030	5.01
		2031	5.16
		2032	5.32
		2033	5.48
		2034	5.64
		2035	5.81
		2036	5.98
		2037	6.16
		2038	6.35
		2039	6.54

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

501 - 600 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	4.76	2014	3.78
2015	4.91	2015	3.89
2016	5.05	2016	4.01
2017	5.21	2017	4.13
2018	5.36	2018	4.25
2019	5.52	2019	4.38
		2020	4.51
		2021	4.64
		2022	4.78
		2023	4.93
		2024	5.07
		2025	5.23
		2026	5.38
		2027	5.55
		2028	5.71
		2029	5.88
		2030	6.06
		2031	6.24
		2032	6.43
		2033	6.62
		2034	6.82
		2035	7.02
		2036	7.24
		2037	7.45
		2038	7.68
		2039	7.91

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

601 - 700 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	5.54	2014	4.39
2015	5.71	2015	4.53
2016	5.88	2016	4.66
2017	6.06	2017	4.80
2018	6.24	2018	4.95
2019	6.43	2019	5.09
		2020	5.25
		2021	5.40
		2022	5.57
		2023	5.73
		2024	5.91
		2025	6.08
		2026	6.26
		2027	6.45
		2028	6.65
		2029	6.85
		2030	7.05
		2031	7.26
		2032	7.48
		2033	7.70
		2034	7.94
		2035	8.17
		2036	8.42
		2037	8.67
		2038	8.93
		2039	9.20

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

701 - 800 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	6.70	2014	5.31
2015	6.91	2015	5.47
2016	7.11	2016	5.64
2017	7.33	2017	5.81
2018	7.55	2018	5.98
2019	7.77	2019	6.16
		2020	6.35
		2021	6.54
		2022	6.73
		2023	6.93
		2024	7.14
		2025	7.36
		2026	7.58
		2027	7.80
		2028	8.04
		2029	8.28
		2030	8.53
		2031	8.78
		2032	9.05
		2033	9.32
		2034	9.60
		2035	9.89
		2036	10.18
		2037	10.49
		2038	10.80
		2039	11.13

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

801 - 900 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	7.98	2014	6.32
2015	8.21	2015	6.51
2016	8.46	2016	6.71
2017	8.71	2017	6.91
2018	8.98	2018	7.11
2019	9.25	2019	7.33
		2020	7.55
		2021	7.77
		2022	8.01
		2023	8.25
		2024	8.50
		2025	8.75
		2026	9.01
		2027	9.28
		2028	9.56
		2029	9.85
		2030	10.14
		2031	10.45
		2032	10.76
		2033	11.08
		2034	11.42
		2035	11.76
		2036	12.11
		2037	12.48
		2038	12.85
		2039	13.24

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

901 - 1000 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	9.52	2014	7.54
2015	9.80	2015	7.77
2016	10.10	2016	8.00
2017	10.40	2017	8.24
2018	10.71	2018	8.49
2019	11.03	2019	8.74
		2020	9.01
		2021	9.28
		2022	9.55
		2023	9.84
		2024	10.14
		2025	10.44
		2026	10.75
		2027	11.08
		2028	11.41
		2029	11.75
		2030	12.10
		2031	12.47
		2032	12.84
		2033	13.23
		2034	13.62
		2035	14.03
		2036	14.45
		2037	14.89
		2038	15.33
		2039	15.79

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

1001 - 1100 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	11.38	2014	9.02
2015	11.72	2015	9.29
2016	12.07	2016	9.56
2017	12.43	2017	9.85
2018	12.80	2018	10.15
2019	13.19	2019	10.45
		2020	10.77
		2021	11.09
		2022	11.42
		2023	11.76
		2024	12.12
		2025	12.48
		2026	12.85
		2027	13.24
		2028	13.64
		2029	14.05
		2030	14.47
		2031	14.90
		2032	15.35
		2033	15.81
		2034	16.28
		2035	16.77
		2036	17.28
		2037	17.79
		2038	18.33
		2039	18.88

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

1101 - 1200 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON-LEVELIZED RATES
2014	13.61	2014	10.78
2015	14.01	2015	11.11
2016	14.43	2016	11.44
2017	14.87	2017	11.78
2018	15.31	2018	12.14
2019	15.77	2019	12.50
		2020	12.88
		2021	13.26
		2022	13.66
		2023	14.07
		2024	14.49
		2025	14.93
		2026	15.37
		2027	15.84
		2028	16.31
		2029	16.80
		2030	17.30
		2031	17.82
		2032	18.36
		2033	18.91
		2034	19.48
		2035	20.06
		2036	20.66
		2037	21.28
		2038	21.92
		2039	22.58

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

1201 - 1300 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	16.26	2014	12.89
2015	16.75	2015	13.28
2016	17.25	2016	13.67
2017	17.77	2017	14.08
2018	18.30	2018	14.51
2019	18.85	2019	14.94
		2020	15.39
		2021	15.85
		2022	16.33
		2023	16.82
		2024	17.32
		2025	17.84
		2026	18.38
		2027	18.93
		2028	19.50
		2029	20.08
		2030	20.68
		2031	21.30
		2032	21.94
		2033	22.60
		2034	23.28
		2035	23.98
		2036	24.70
		2037	25.44
		2038	26.20
		2039	26.99

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

1301 - 1400 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON- LEVELIZED RATES
2014	19.40	2014	15.38
2015	19.98	2015	15.84
2016	20.58	2016	16.31
2017	21.20	2017	16.80
2018	21.84	2018	17.31
2019	22.49	2019	17.83
		2020	18.36
		2021	18.91
		2022	19.48
		2023	20.06
		2024	20.66
		2025	21.28
		2026	21.92
		2027	22.58
		2028	23.26
		2029	23.96
		2030	24.67
		2031	25.41
		2032	26.18
		2033	26.96
		2034	27.77
		2035	28.60
		2036	29.46
		2037	30.35
		2038	31.26
		2039	32.19

Issued by IDAHO POWER COMPANY
By Gregory W. Said, General Manager, Regulatory Affairs
1221 West Idaho Street, Boise, Idaho

OREGON
Issued:
Effective with Service
Rendered on and after:

Advice No.

SCHEDULE 86
SOLAR GENERATION INTEGRATION CHARGES
(Continued)

SOLAR INTEGRATION CHARGES (Continued)

1401 - 1500 MW Solar Capacity Penetration Level			
LEVELIZED		NON-LEVELIZED	
ON-LINE YEAR	20 YEAR CONTRACT TERM LEVELIZED RATES	CONTRACT YEAR	NON-LEVELIZED RATES
2014	23.07	2014	18.29
2015	23.77	2015	18.84
2016	24.48	2016	19.40
2017	25.21	2017	19.98
2018	25.97	2018	20.58
2019	26.75	2019	21.20
		2020	21.84
		2021	22.49
		2022	23.17
		2023	23.86
		2024	24.58
		2025	25.31
		2026	26.07
		2027	26.86
		2028	27.66
		2029	28.49
		2030	29.35
		2031	30.23
		2032	31.13
		2033	32.07
		2034	33.03
		2035	34.02
		2036	35.04
		2037	36.09
		2038	37.18
		2039	38.29