



Portland General Electric
121 SW Salmon Street · Portland, Ore. 97204

March 23, 2020

Public Utility Commission of Oregon
Attn: Filing Center
201 High Street S.E., Suite 100
P.O. Box 1088
Salem, OR 97308-1088

RE: Second Supplemental Filing of Advice No. 20-04 Community Solar Program
Interconnection and Power Purchase Schedule

Portland General Electric Company (PGE) submits this filing pursuant to Oregon Revised Statutes (ORS) 757.205 and 757.210 and Oregon Administrative Rule (OAR) 860-022-0025 for filing proposed tariff sheets associated with Tariff P.U.C. No. 18. PGE initially filed Advice No. 20-04 on February 18, 2020 with a requested effective date of March 11, 2020. The initial filing also included an application requesting a waiver of the less than 30-day notice which is still valid. PGE then submitted a Supplemental Filing on March 6, 2020 at the request of Staff to allow more time for review and PGE requested an effective date of April 8, 2020 which remains the same. PGE is now submitting this Second Supplemental Filing in response to comments from Staff and stakeholders.

Enclosed are the following replacement sheets:

Original Sheet No. 204-5
Original Sheet No. 204-7

All other sheets remain as previously filed.

PGE hereby submits updated supporting documents as Exhibits A - E.

Exhibit A: Redline of Schedule 204
Exhibit B: Redline Standard Interconnection Procedures for CSP Projects
Exhibit C: Redline System Impact Study Agreement for CSP Projects
Exhibit D: Redline Facilities Study Agreement for CSP Projects
Exhibit E: Redline CSP Interconnection Agreements

On March 19, 2020 PGE participated in a workshop hosted by Staff to discuss Community Solar Interconnection Documents filed on February 18, 2020 as part of PGE's Advice No. 20-04. In PGE's original Advice filing PGE endeavored to improve and streamline the existing process for interconnecting CSP projects. In preparation for the workshop Staff submitted comments to PGE's Interconnection Documents;¹ that requested PGE match the existing rules from OAR Chapter 860, Division 082 (Division 82 Rules).

To move CSP forward quickly, PGE is reverting the language to the current Division 82 Rules. PGE does this with the understanding with Staff and stakeholders that its interconnection process improvements proposed with the initial Advice No. 20-04 filing will be discussed in a separate docket (UM 2032). The underlying issues addressed by the proposed changes to PGE's interconnection documents are very important and PGE looks forward to having those discussions in a separate docket.

Thus, PGE has generally adopted Staff's edits and recommendations to align with current Division 82 Rules. We have also provided edits to the Schedule to address Staff concerns regarding contract terms that would allow potential settlement of the outstanding issues involving projects that have already sold their power to PGE through QF agreements, while maintaining the Commission's admonition that going forward, this problem should not exist and the sanctity of contracts must be upheld. Finally, PGE has included provisions on cost sharing and an informational NRIS review. The information is included to provide transparency and clarity on how cost responsibilities will be split between projects that have been studied jointly. PGE included the informational NRIS review to help increase the learnings on this important issue.

To satisfy the requirements of Oregon Administrative Rules 860-022-0025(2), PGE provides the following responses:

OAR 860-022-0025 requires that PGE submit a statement of the tariff schedule change, the number of Customers affected, the change in revenue, and the grounds supporting the change. The number of participants for this optional service is unknown as it is not yet available. The revenue change is therefore unknown.

¹ *Topic List and Staff Redlines for the Interconnection Workshop*, Docket UM 1930, Other Filing/Pleading (March 17, 2020)

Second Supplemental Filing of Advice No. 20-04
Community Solar Program Interconnection and Power Purchase Schedule
Page 3

Please direct questions or comments regarding this filing to Santiago Beltran Laborde, (503) 464-7902. Please direct all formal correspondence and requests to the following email address pge.opuc.filings@pgn.com

Sincerely,

\s\ Robert Macfarlane

Robert Macfarlane
Manager, Pricing and Tariffs

Enclosures
cc: Service List – UM 1930

PGE Second Supplemental Advice No. 20-04
Exhibits A - E

SCHEDULE 204 (Continued)

SP Interconnection Process (Continued)

4. Low-side Metering. An applicant may request Low-side Metering for a CSP Project 360 kW and smaller.
5. Joint Study. If an applicant for CSP Interconnection has multiple CSP Projects eligible for interconnection, it can request that the Company study the CSP Projects jointly if the CSP Interconnection Applications are submitted in back to back queue order. Such projects shall equally share in the costs for CSP interconnection study purposes in accordance with the process described in the Interconnection Procedures for CSP Projects, attached as Exhibit A to this Schedule.

C. CSP Interconnection Exhibits

1. The Interconnection Procedures for CSP Projects are set forth in Exhibit A to this Schedule.
2. The System Impact Study Agreement for CSP Projects is set forth in Exhibit B to this Schedule.
3. The Facilities Study Agreement for CSP Projects is set forth in Exhibit C to this Schedule.
4. The CSP Project Completion Form is set forth in Exhibit D to this Schedule.
5. The CSP Project Interconnection Agreement is set forth in Exhibit E to this Schedule.

PART 2: CSP PURCHASE AGREEMENT

A. Applicable

To CSP Projects that:

1. Are located within the Company's Service Territory;
2. Are certified or exempt from certification as a Qualifying Facility;
3. Are pre-certified or Certified as a CSP Project by the Commission under Oregon Administrative Rule (OAR) 860-088-0050; and
4. [Except for CSP Projects that have otherwise received consent from the Company, or as otherwise legally required by the Commission, H](#)have not already sold, leased assigned, contracted for (including pursuant to the execution of a power purchase agreement under PURPA) or otherwise disposed of the Net Output of the CSP Project, except for the sale of subscriptions for Subscribed Energy to Participants consistent with the CSP.

SCHEDULE 204 (Concluded)

C. CSP Administration

1. Energy Delivery: Once a Certified Project has commenced commercial operation, not later than the second day of each month, the Company shall report to the Program Administrator the amount of Net Output received from the Certified Project at the Point of Delivery for the preceding month.
2. Compensation: As provided in the Program Implementation Manual and the CSP Purchase Agreement, the Company shall provide compensation monthly for each kWh of Net Output accepted at the Point of Delivery as follows:
 - a. Subscribed Energy: For all Subscribed Energy delivered by the CSP Project to the Company at the Point of Delivery, the Company will apply a bill credit to each Participant's utility bill in accordance with the process and calculations set forth in ORS 757.386(6), OAR 860-088-0170, the Program Implementation Manual, and the CSP Purchase Agreement.
 - b. Unsubscribed Energy: The Company will pay the Program Administrator on a monthly basis for each kWh of Unsubscribed Energy in the manner described in OAR 860-088-0140, the Program Implementation Manual, and the CSP Purchase Agreement.
3. Program Fees: The Company will apply Program Fees to each Participant's monthly utility bill in the manner described in ORS 757.386, OAR 860-088-0120, the Program Implementation Manual, and PGE's CSP Operational Tariff.
4. Term: The Term of the CSP Purchase Agreement is up to twenty (20) years from the Facility's Commercial Operation Date, in accordance with ORS 757.386(2)(a)(D) and OAR 860-088-0140(1)(a).

D. CSP Purchase Agreement

The form of the CSP Purchase Agreement is provided as Exhibit F of this Schedule.

STANDARDS FOR INTERCONNECTION OF COMMUNITY SOLAR PROGRAM PROJECTS

1. Scope and Applicability

Pursuant to ORS 757.386, the Community Solar Program (CSP) Rules, the Program Implementation Manual, Commission Order No. 19-392, this document (“CSP Interconnection Standards” or “Standards”) describes the process and requirements for CSP interconnection service as set forth in the Schedule.

(1) These Standards govern the interconnection of a CSP Project with a nameplate capacity of 3 megawatts AC or less to PGE’s transmission or distribution system. The Standards do not apply if the interconnection between the CSP Project and PGE is subject to the jurisdiction of the Federal Energy Regulatory Commission (FERC).

(2) These Standards do not apply to the interconnection of a net metering facility, which is governed by OAR chapter 860, division 039 or a small generator facility, which is governed by OAR chapter 860, division 082.

(3) In the event there is a conflict between the terms of the Schedule and these Standards, the terms of the Schedule shall apply and prevail.

2. Waiver

(1) Upon request or its own motion, the Commission may waive any portion of these Standards for good cause shown. A request for waiver must be made in writing, unless otherwise allowed by the Commission.

(2) PGE and an applicant or interconnection customer may agree to reasonable extensions to the required timelines in the Schedule or these Standards without requesting a waiver from the Commission.

(a) If PGE and an applicant or CSP Interconnection Service customer are unable to agree to waive a timeline, then PGE, applicant, or CSP Interconnection Service customer may request that the Commission grant a waiver.

(b) In deciding whether to grant a waiver of a timeline, the Commission will consider the number of pending applications for interconnection review and the type of applications, including review level, facility type, and facility size.

(c) Waiver of a timeline, whether by agreement or Commission order, does not affect an application’s queue position.

3. Definitions

- (1) “Adverse system impact” means a negative effect caused by the interconnection of a CSP Project that may compromise the safety or reliability of a transmission or distribution system.
- (2) “Affected system” means a transmission or distribution system, not owned or operated by the interconnecting public utility, which may experience an adverse system impact from the interconnection of a CSP Project.
- (3) “Aggregated nameplate capacity” means the total combined nameplate capacity of:
 - (a) A proposed CSP Project;
 - (b) Existing CSP Projects, small generator facilities, net metering facilities, FERC jurisdictional generators, and state jurisdictional generators with a nameplate capacity greater than 10 megawatts; and
 - (c) CSP Projects, small generator facilities, net metering facilities, FERC jurisdictional generators, and state jurisdictional generators with a nameplate capacity greater than 10 megawatts that have pending completed applications with higher queue positions than the proposed CSP Project.
- (4) “Applicant” means a person or business who has submitted an application to interconnect a CSP Project to a public utility’s transmission or distribution system.
- (5) “Application” means a written request to interconnect a CSP Project with a public utility’s transmission or distribution system.
- (6) “Area network” means a type of distribution system served by multiple transformers interconnected in an electrical network circuit in order to provide high reliability of service. This term has the same meaning as the term “secondary grid network” as defined in IEEE 1547, section 4.1.4.
- (7) “Certificate of completion” means a certificate signed by an applicant and an interconnecting public utility attesting that a CSP Project is complete, meets the applicable requirements of the Schedule, and has been inspected, tested, and certified as physically ready for operation. A certificate of completion includes the “as built” specifications and initial settings for the CSP Project and its associated interconnection equipment.
- (8) “CSP Project” has the meaning as set forth in the Schedule. A CSP Project does not include interconnection equipment, interconnection facilities, or system upgrades.
- (9) “CSP queue” means the separate queue from the standard small generator queue set forth in 4.1.c below, which a CSP Project may qualify for if it meets certain criteria.
- (10) “Distribution system” means the portion of an electric system that delivers electricity from transformation points on the transmission system to points of connection on a customer’s premises.

(11) “Fault current” means an electrical current that flows through a circuit during a fault condition. A fault condition occurs when one or more electrical conductors contact ground or each other. Types of faults include phase to ground, double-phase to ground, three-phase to ground, phase to phase, and three-phase.

(12) “Field-tested equipment” means interconnection equipment that is identical to equipment that was approved by the interconnecting public utility for a different CSP Project or small generator facility interconnection under Tier 4 review and successfully completed a witness test within three years before the date of the submission of the current application.

(13) “IEEE 1547” means the standards published by the Institute of Electrical and Electronics Engineers (IEEE) Standard 1547, titled “Interconnecting Distributed Resources with Electric Power Systems” and approved by the IEEE SA Standards Board.

(14) “IEEE 1547.1” means the standards published by the IEEE Standard 1547.1, titled “Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems” and approved by the IEEE SA Standards Board.

(15) “Interconnection agreement” means a contract between an applicant or interconnection customer and an interconnecting public utility that governs the interconnection of a CSP Project to the public utility’s transmission or distribution system and the ongoing operation of the CSP Project after it is interconnected.

(16) “Interconnection customer” means a person with one or more CSP Projects interconnected to a public utility’s transmission or distribution system.

(17) “Interconnection equipment” means a group of components or an integrated system provided by an interconnection customer or applicant to connect a CSP Project to a public utility’s transmission or distribution system.

(18) “Interconnection facilities” means the facilities and equipment required by a public utility to accommodate the interconnection of a CSP Project to the public utility’s transmission or distribution system and used exclusively for that interconnection. Interconnection facilities do not include system upgrades.

(19) “CSP interconnection service” means the interconnection service provided by an interconnecting public utility to an interconnection customer hereunder.

(20) “Lab-tested equipment” means interconnection equipment that has been designed to comply with IEEE 1547, tested in accordance with IEEE 1547.1, and certified and labeled as compliant with these IEEE standards at the point of manufacture by a nationally recognized testing lab. For interconnection equipment to be considered lab-tested equipment under these rules, the equipment must be used in a manner consistent with the certification.

(21) “Line section” means that portion of a public utility’s transmission or distribution system that is connected to an interconnection customer and bounded by automatic sectionalizing devices or the end of a distribution line.

(22) “Losses” are the loss of electric energy occurring as a result of the transformation and transmission of electric energy from the CSP Project to the Point of Interconnection.

(23) “Low-side Metering” means loss-compensated revenue metering located on the low voltage side of the CSP Project’s step-up transformer.

(24) “Minor equipment modification” means a change to a CSP Project or its associated interconnection equipment that:

(a) Does not affect the application of the approval requirements in Tiers 2;

(b) Does not, in PGE’s reasonable opinion, have a material impact on the safety or reliability of PGE’s transmission or distribution system or an affected system; and

(c) Does not affect the nameplate capacity of a CSP Project.

(25) “Nameplate capacity” means the full-load electrical quantities assigned by a CSP Project’s designer to the generator and its prime mover or other piece of electrical equipment, such as transformers and circuit breakers, under standardized conditions, as expressed in amperes, kilovoltamperes, kilowatts, volts, megawatts, or other appropriate units. Nameplate capacity is usually indicated on a nameplate attached to the individual device.

(26) “Nationally recognized testing laboratory” or “NRTL” means a qualified private organization that performs independent safety testing and product certification. Each NRTL must meet the requirements set forth by the United States Occupational Safety and Health Administration.

(27) “Net metering facility” has the meaning set forth in ORS 757.300(1)(d).

(28) “Network Resource Interconnection Service” or “NRIS” means an Interconnection Service that allows the interconnecting customer to integrate its generating facility with the Public Utility's Transmission System in a manner comparable to that in which the Public Utility integrates its generating facilities to serve native load customers.

~~(289)~~ “Pending completed application” means an application for interconnection of a CSP Project, a small generator facility, a net metering facility, or a FERC jurisdictional generator that PGE has deemed complete.

~~(2930)~~ “Person” has the meaning set forth in OAR 860-011-0035(8).

(301) “Point of interconnection” means the point on the high side of the CSP Project’s step-up transformer(s) where a CSP Project is electrically connected to PGE’s transmission or distribution system. This term has the same meaning as “point of common coupling” as defined in IEEE 1547, section 3.1.13. This term does not have the same meaning as “point of common coupling” as defined in OAR 860-039-0005(3)(p).

(312) “Pre-certified Project” is a CSP Project that is pre-certified by the Oregon Public Utility Commission under the Community Solar Program and in accordance with OAR 860-088-0040 and the Program Implementation Manual.

(323) “Primary line” means a distribution line with an operating voltage greater than 600 volts.

(334) “Public utility” has the meaning set forth in ORS 757.005 and is limited to a public utility that provides electric service.

(345) “Queue position” means the rank of a pending completed application, relative to all other pending completed applications, that is established based on the date and time that PGE receives the completed applications, including application fees. The CSP queue and standard small generator queue will have separate queue positions.

(356) “Schedule” means PGE’s Community Solar Program Interconnection and Power Purchase Schedule, including these Standards, and including all exhibits attached thereto or incorporated by reference.

(367) “Scoping meeting” means an initial meeting between representatives of an applicant and PGE that is conducted to discuss alternative interconnection options; to exchange information, including any relevant transmission or distribution system data and earlier studies that would reasonably be expected to affect the interconnection options; to analyze such information; and to determine the potentially feasible points of interconnection.

(378) “Secondary line” means a service line with an operating voltage of 600 volts or less.

(389) “Spot network” means a type of transmission or distribution system that uses two or more intertied transformers protected by network protectors to supply an electrical network circuit. A spot network may be used to supply power to a single customer or a small group of customers.

(3940) “System upgrade” means an addition or modification to a public utility’s transmission or distribution system or to an affected system that is required to accommodate the interconnection of a CSP Project.

(401) “Transmission line” means any electric line operating at or above 50,000 volts.

(412) “Transmission system” means a public utility’s high voltage facilities and equipment used to transport bulk power or to provide transmission service under the public utility’s open access transmission tariff.

(423) “Witness test” means the on-site visual verification of the interconnection installation and commissioning as required in IEEE 1547, sections 5.3 and 5.4. For interconnection equipment that does not meet the definition of lab-tested equipment, the witness test may, at the discretion of the public utility, also include a system design and production evaluation according to IEEE 1547, sections 5.1 and 5.2, as applicable to the specific interconnection equipment used.

(434) “Written notice” means a notice required by these Standards sent via First Class United States mail. The duty to provide written notice is deemed fulfilled on the day that the notice is deposited in the mail. A public utility and an applicant or interconnection customer may agree in writing to accept written notice via electronic mail. If using electronic mail by agreement, then the duty to provide written notice is deemed fulfilled on the day the notice is sent. A public utility and an applicant or interconnection customer are responsible for informing one another of changes to the physical or electronic address used to receive notifications.

4. Pre-Application Process

(1) PGE will post on its website relevant information about the CSP interconnection service process. Potential CSP Projects may obtain pre-application information regarding PGE’s transmission or distribution system, and affected systems through informal requests concerning a proposed CSP Project at a specific site. The information provided by PGE in response to a potential applicant’s request may include relevant existing studies and other materials that may be used to understand the feasibility of interconnecting a CSP Project at a particular point on the public utility’s transmission or distribution system. CSP Projects that have been certified by the Third-Party Program Administrator (PA) as non-profit or governmental-based projects may make up to five pre-application information requests at no cost. Program Managers must provide written evidence from the PA of their non-profit or governmental based status prior to making such information requests. PGE will comply with reasonable requests for access to or copies of such information, except to the extent that providing such materials would violate security requirements, confidentiality obligations to third parties, or be contrary to federal or state regulations. PGE may require a person to sign a confidentiality agreement if required to protect confidential or proprietary information. For potential CSP Projects requiring Tier 4 interconnection review, and at the potential applicant’s request, PGE will meet with the potential applicant to exchange information. A PGE employee with relevant technical expertise will attend any such meeting.

(2) Except as otherwise provided in 3(1), Eeach pre-application information request requires payment of a \$300 fee.

5. Applications to Interconnect a CSP Project

(1) A person may not interconnect a CSP Project to PGE’s transmission or distribution system without authorization from PGE.

(a) A person proposing to interconnect a new CSP Project to PGE’s transmission or distribution system must submit an application to PGE.

(b) A person with an existing interconnected CSP Project who proposes to make any change to the facility, other than a minor equipment modification, must submit an application to the public utility. This includes changes affecting the nameplate capacity of the existing interconnected CSP Project or the output capacity authorized in the agreement governing the terms of the interconnection.

(bc) A person proposing more than one community solar facility to be interconnected to the same distribution feeder may request that PGE jointly study the requests if the interconnection applications are submitted in back to back queue order.

(ed) An applicant with a pending completed application to interconnect a CSP Project must submit a new application if the applicant proposes to make any change to the CSP Project other than a minor equipment modification. This includes changes affecting the nameplate capacity of the proposed CSP Project.

(de) In order to qualify for the CSP queue an applicant with a pending completed application to interconnect a CSP Project together with all other interconnected generators and higher queued generators requesting interconnection on the same feeder and substation transformer must be less than 100 percent of the daytime minimum load (DML). If a measure of DML is not available for the feeder and substation transformer associated with the point of interconnection, PGE will use 30 percent of the summer peak load on the feeder and or substation transformer. The following also apply:

(A) The applicant relinquishes the standard small generator queue position assigned to the pending completed application, and PGE assigns a new CSP queue position based on the date and time PGE receives the new application.

(B) If the new interconnection application is submitted within 30 business days of the date of submission of the original application, then PGE must apply the original application fee to the application fee required for the new CSP queue application.

(e) A person with a pending completed application to interconnect a net metering facility or a FERC jurisdictional generator who proposes to change the facility to a CSP Project must submit a new application under the Schedule and these Standards, and the following apply:

(A) The applicant relinquishes the queue position assigned to the pending completed application, and PGE assigns a new queue position based on the date and time that PGE receives the community solar interconnection application.

(B) If the interconnection application is received within 30 business days of the date of submission of the original net metering or FERC jurisdictional generator interconnection application, then PGE must apply the original application fee to the application fee required for the new application.

(2) All applications must be made using the appropriate application form and must follow the standard form applications developed by PGE and approved by the Commission. PGE will

provide separate application forms for review under Tier 2 and Tier 4. PGE will provide a copy of an application form to any person upon request and must post copies of the application forms on PGE's website.

(b) Applicants must use the form for review under Tiers 2, or 4 for interconnection of all CSP Projects.

(3) PGE may require payment of a nonrefundable application processing fee. The amount of the fee depends upon the review tier requested in the application and is intended to cover the reasonable costs of processing and evaluating the application.

(a) The application fee may not exceed \$500 for Tier 2 review, and \$1000 for review under Tier 4.

(b) An applicant must pay the reasonable costs incurred by PGE to perform any studies and engineering evaluations permitted by the Schedule and these Standards, and necessary to evaluate the proposed application to interconnect. Before PGE may assess any costs in excess of the application fee, PGE must receive written authorization from the applicant. If the applicant does not authorize the additional costs, then the application is deemed withdrawn and the original application fee is forfeited.

(c) If an application is denied at Tier 2, and the applicant resubmits the application at a Tier 4 within 15 business days after the date the applicant received notification of the denial, then the applicant maintains the queue position assigned to the original application and PGE must apply the original application fee and any other fees paid in conjunction with the original application to the fees applicable to the resubmitted application.

(4) If an applicant proposes to interconnect multiple CSP Projects to PGE's transmission or distribution system at a single point of interconnection, then PGE must evaluate the applications based on the combined total nameplate capacity for all of the CSP Projects. If the combined total nameplate capacity exceeds 3 megawatts, then the Schedule and these Standards do not apply.

(5) An applicant must provide documentation of site control with an interconnection application. Site control may be demonstrated through ownership of the site, a leasehold interest in the site, or an option or other right to develop the site for the purpose of constructing the CSP Project. Site control may be documented by a property tax bill, deed, lease agreement, or other legally binding contract.

(6) PGE may propose to interconnect multiple CSP Projects at a single point of interconnection to minimize costs, and an affected applicant or interconnection customer may not unreasonably refuse such a proposal. An applicant or interconnection customer will, however, maintain a separate point of interconnection.

(7) Application review process.

(a) Within 10 business days of receipt of an application to interconnect a CSP Project, PGE must provide written notice to the applicant stating whether the application is complete.

(A) If the application is incomplete, then PGE must provide the applicant with a detailed list of the information needed to complete the application. An application is deemed complete when PGE receives the listed information. The applicant must provide the listed information within 10 business days of receipt of the list or the application is deemed withdrawn.

(B) If PGE does not have a record of receipt of an application or cannot locate an application, then the applicant must provide an additional copy of the application to PGE. If the applicant can demonstrate that a complete application was originally delivered to PGE at a particular time on a particular date, then PGE must assign a queue position to the application based on the original time and date of delivery.

(b) Once PGE deems an application to be complete, PGE must assign the application a queue position. If the application meets the eligibility requirements for the CSP queue, it will be assigned to the CSP queue, otherwise, it will be assigned to the standard small generator queue. An applicant must meet all applicable deadlines in the Schedule and these Standards to maintain its queue position unless the deadlines have been waived by agreement with PGE or by Commission order.

(c) If PGE determines during the evaluation process that supplemental or clarifying information is required, then PGE must request the information from the applicant. The time necessary to complete the evaluation of the application may be extended by the time required for the receipt of the additional information. Requests for information do not affect the applicant's queue position.

(d) PGE must use IEEE 1547 and IEEE 1547.1 to evaluate interconnection applications unless otherwise specified in these Standards or unless the Commission grants a waiver to use different or additional standards.

(e) PGE must provide an executable interconnection agreement no later than five business days after the date of approval of an interconnection application. The interconnection agreement must follow the standard form agreement developed by PGE and approved by the Commission. The applicant must return an executed interconnection agreement to PGE within 15 business days of receipt or the application is deemed withdrawn.

(A) An applicant and PGE ~~is~~are entitled to the terms in the standard form agreement, but may choose to mutually negotiate and agree to different terms.

(B) If negotiated changes to a standard interconnection agreement are materially inconsistent with the Schedule and these Standards, then the applicant and PGE must seek Commission approval of the negotiated interconnection agreement.

(f) The applicant must provide PGE written notice at least 20 business days before the planned commissioning for the CSP Project.

(A) PGE has the option of conducting a witness test at a mutually agreeable time within 10 business days of the scheduled commissioning.

(B) PGE must provide written notice to the applicant indicating whether the public utility plans to conduct a witness test or will waive the witness test.

(C) If PGE notifies the applicant that it plans to conduct a witness test, but fails to conduct the witness test within 10 business days of the scheduled commissioning date or within a time otherwise agreed upon by the applicant and PGE, then the witness test is deemed waived.

(D) If the witness test is conducted and is not acceptable to PGE, then PGE must provide written notice to the applicant describing the deficiencies within five business days of conducting the witness test. PGE must give the applicant 20 business days from the date of the applicant's receipt of the notice to resolve the deficiencies. If the applicant fails to resolve the deficiencies to the reasonable satisfaction of PGE within 20 business days, then the application is deemed withdrawn.

(g) PGE must meet all applicable deadlines in the Schedule and these Standards unless the deadlines have been waived by agreement with an applicant or interconnection customer or by Commission order. If PGE cannot meet an applicable deadline, then PGE must provide written notice to the applicant or interconnection customer explaining the reasons for the failure to meet the deadline and an estimated alternative deadline. PGE's failure to meet an applicable deadline does not affect an applicant's queue position.

6. Construction, Operation, Maintenance, and Testing of CSP Projects

(1) An interconnection customer or applicant must construct, operate, and maintain a CSP Project and its associated interconnection equipment in compliance with IEEE 1547 and 1547.1.

(2) The applicant must provide written notice to PGE 10 business days before beginning operation of an approved CSP Project.

(3) Before beginning operation of a CSP Project, an interconnection customer or applicant must receive approval of the facility under the Schedule and these Standards, must have received certification under the Community Solar Program and must execute an interconnection agreement with PGE. Applicants or interconnection customers are entitled to a maximum 20-year term for an interconnection agreement.

(4) A CSP Project must be capable of being isolated from PGE's transmission or distribution system. An interconnection customer may not disable an isolation device without the prior written consent PGE.

(a) For CSP Projects interconnecting to a primary line, the interconnection customer or applicant must use a lockable, visible-break isolation device readily accessible to PGE.

(b) For CSP Projects interconnecting to a secondary line, the interconnection customer or applicant must use a lockable, visible-break isolation device that is readily accessible to PGE.

(A) The interconnection customer or applicant may elect to provide PGE access to an isolation device that is contained in a building or area that may be unoccupied and locked or not otherwise readily accessible to PGE. The interconnection customer or applicant must provide a lockbox capable of accepting a lock provided by PGE that provides ready access to the isolation device. The interconnection customer or customer must install the lockbox in a location that is readily accessible by PGE and must affix a placard in a location acceptable to PGE that provides clear instructions to utility personnel on how to access the isolation device.

(c) All isolation devices must be installed, owned, and maintained by the interconnection customer or applicant; must be capable of interrupting the full load of the CSP Project; and must be located between the CSP Project and the point of interconnection.

(5) PGE must have access to an interconnection customer's or an applicant's premises for any reasonable purpose related to an interconnection application or an interconnected CSP Project. PGE must request access at reasonable hours and upon reasonable notice. In the event of an emergency or hazardous condition, PGE may access the interconnection customer's or applicant's premises at any time without prior notice, but PGE must provide written notice within five business days after entering the interconnection customer's or applicant's premises that describes the date of entry, the purpose of entry, and any actions performed on the premises.

(6) When a CSP Project undergoes maintenance or testing in compliance with these Standards, IEEE 1547, or IEEE 1547.1, the interconnection customer must retain written records for at least seven years documenting the maintenance and the results of testing. The interconnection customer must provide copies of these records to PGE upon request.

7. Cost Responsibility

(1) Study costs. Whenever a study is required under these Standards, the applicant must pay PGE for the reasonable costs incurred in performing the study. PGE must base study costs on the scope of work determined and documented in the system impact study agreement, or the facilities study agreement, as applicable. The estimated engineering costs used in calculating study costs must not exceed \$100 per hour. PGE may adjust the \$100 hourly rate once in January of each year to account for inflation and deflation as measured by the Consumer Price Index. Before beginning a study, PGE may require an applicant to pay a deposit of up to 50 percent of the estimated costs to perform the study or \$1000, whichever is less.

(a) CSP Projects requesting to be studied jointly will have the study costs allocated equally amongst the participants.

(2) Interconnection facilities. For interconnection review under Tier 4, PGE must identify the interconnection facilities necessary to safely interconnect the CSP Project with PGE's transmission or distribution system. The applicant must pay the reasonable costs of the

interconnection facilities. PGE constructs, owns, operates, and maintains the interconnection facilities.

(a) If joint studying of CSP Projects are undertaken, each CSP Project will have Interconnection Facilities directly assigned.

(3) Interconnection equipment. An applicant or interconnection customer must pay all expenses associated with constructing, owning, operating, maintaining, repairing, and replacing its interconnection equipment. Interconnection equipment is constructed, owned, operated, and maintained by the applicant or interconnection customer.

(4) System upgrades. PGE must design, procure, construct, install, and own any system upgrades to PGE's transmission or distribution system necessitated by the interconnection of a CSP Project. PGE must identify any adverse system impacts on an affected system caused by the interconnection of a CSP Project to PGE's transmission or distribution system. PGE must determine what actions or upgrades are required to mitigate these impacts. Such mitigation measures are considered system upgrades as defined in these rules. The applicant must pay the reasonable costs of any system upgrades.

(a) If joint studying of CSP Projects are undertaken, the CSP Projects will be allocated the costs for System Upgrades based the proportional capacity of each project. The final cost sharing will be detailed in the Attachments to the Community Solar Project interconnection agreement.

(b) If a CSP Project that has been jointly studied and allocated a share of system upgrade costs withdraws, PGE will reassess the System Upgrades needed to complete the interconnection(s) and reallocate the System Upgrade costs to the remaining Community Solar Project(s) using the same methodology in Section 6(4)(a).

(5) PGE may not begin work on interconnection facilities or system upgrades before an applicant receives PGE's good-faith, non-binding cost estimate and provides written notice to PGE that the applicant accepts the estimate and agrees to pay the costs. PGE may require an applicant to pay a deposit before beginning work on the interconnection facilities or system upgrades.

(a) If an applicant agrees to make progress payments on a schedule established by the applicant and PGE, then PGE may require the applicant to pay a deposit of up to 25 percent of the estimated costs or \$10,000, whichever is less. PGE and the applicant must agree on progress billing, final billing, and payment schedules before PGE begins work.

(b) If an applicant does not agree to make progress payments, then PGE may require the applicant to pay a deposit of up to 100 percent of the estimated costs. If the actual costs are lower than the estimated costs, then PGE must refund the unused portion of the deposit to the applicant within 20 business days after the actual costs are determined.

8. Insurance

(1) PGE may not require an applicant or an interconnection customer with a CSP Project with a nameplate capacity of 200 kilowatts or less to obtain prudent amounts of general liability insurance in order to interconnect to PGE's transmission or distribution system.

(1) PGE may require an applicant or an interconnection customer with a CSP Project with a nameplate capacity greater than 200 kilowatts to obtain prudent amounts of general liability insurance in order to interconnect to PGE's transmission or distribution system.

9. Tier 2 Interconnection Review

(1) PGE must use the Tier 2 interconnection review procedures for an application to interconnect a CSP Project that meets the following requirements:

(a) The CSP Project must have a nameplate capacity of two megawatts or less;

(b) The CSP Project must be interconnected to either a radial distribution circuit or a spot network distribution circuit limited to serving one customer;

(c) The CSP Project must not be interconnected to a transmission line; and

(d) The CSP Project must use interconnection equipment that is either lab-tested equipment or field-tested equipment. For equipment to gain status as field-tested equipment, the applicant must provide all the documentation from the prior Tier 4 study, review, and approval, including any interconnection studies and the certificate of completion.

(2) Tier 2 Approval Criteria. PGE must approve an application to interconnect a CSP Project under the Tier 2 interconnection review procedures if the facility meets the approval criteria in subsections (a) through (l). A public utility may not impose different or additional approval criteria.

(a) For interconnection of a CSP Project to a radial distribution circuit, the aggregated nameplate capacity on the circuit must not exceed 15 percent of the line section annual peak load as most recently measured at the substation or calculated for the line section.

(b) For interconnection of a CSP Project to the load side of spot network protectors, the aggregated nameplate capacity on the load side of the spot network protectors must not exceed the lesser of five percent of a spot network's maximum load or 50 kilowatts.

(c) The aggregated nameplate capacity must not contribute more than 10 percent to the distribution circuit's maximum fault current at the point on the primary voltage distribution line nearest the point of interconnection.

(d) The aggregated nameplate capacity on the distribution circuit must not cause any distribution protective devices and equipment (including substation breakers, fuse cutouts, and line reclosers) or other PGE equipment on the transmission or distribution system to be exposed to fault currents exceeding 90 percent of the short circuit interrupting capability. The CSP Project's point

of interconnection must not be located on a circuit that already exceeds 90 percent of the short circuit interrupting capability.

(e) The aggregated nameplate capacity on the distribution side of a substation transformer feeding the circuit where the CSP Project proposes to interconnect must not exceed 10 megawatts in an area where there are known or posted transient stability limitations to generating units located in the general electrical vicinity (for example, three or four distribution busses from the point of interconnection).

(f) If the CSP Project interconnection is to a primary line on the distribution system, then the interconnection must meet the following criteria:

(A) If the CSP Project is three-phase or single-phase and will be connected to a three-phase, three-wire primary line, then the CSP Project must be connected phase-to-phase.

(B) If the CSP Project is three-phase or single-phase and will be connected to a three-phase, four-wire primary line, then the CSP Project must be connected line-to-neutral and effectively grounded.

(g) For interconnection of a CSP Project to a single-phase shared service line on the transmission or distribution system, the aggregated nameplate capacity on the shared secondary line must not exceed 20 kilowatts.

(h) For interconnection of a single-phase CSP Project to the center tap neutral of a 240-volt service line, the addition of the CSP Project must not create a current imbalance between the two sides of the 240-volt service line of more than 20 percent of the nameplate rating of the service transformer.

(i) Except as provided in subsection (2)(l), the interconnection of the CSP Project must not require system upgrades or interconnection facilities different from or in addition to the applicant's proposed interconnection equipment.

(j) The aggregated nameplate capacity, in combination with exiting transmission loads, must not cause the transmission system circuit directly connected to the distribution circuit where the CSP Project interconnection is proposed to exceed its design capacity.

(k) If the public utility's distribution circuit uses high speed reclosing with less than two seconds of interruption, then the small generator facility must not be a synchronous machine. If the small generator facility is a synchronous machine, then the applicant must submit a Tier 4 application.

~~(kl)~~ If the CSP Project fails to meet one or more of the criteria in subsections (2)(a) through (k), but PGE determines that the CSP Project could be interconnected safely if minor modifications to the transmission or distribution system were made (for example, changing meters, fuses, or relay settings), then PGE must offer the applicant a good-faith, non-binding estimate of the costs of such proposed minor modifications. Modifications are not considered minor under this subsection if the total cost of the modifications exceeds \$10,000. If the applicant authorizes PGE

to proceed with the minor modifications and agrees to pay the entire cost of the modifications, then PGE must approve the application under Tier 2.

(3) In addition to the timelines and requirements in OAR 860-082-0025, the following timelines and requirements apply to Tier 2 interconnection reviews:

(a) PGE must schedule a scoping meeting within 10 business days after notifying an applicant that its application is complete. PGE and the applicant may agree to waive the scoping meeting requirement.

(b) Within 20 business days after PGE notifies an applicant that its application is complete or a scoping meeting is held, whichever is later, PGE must:

(A) Evaluate the application using the Tier 2 approval criteria in section (2);

(B) Review any independent analysis of the proposed interconnection provided by the applicant that was performed using the Tier 2 approval criteria; and

(C) Provide written notice to the applicant stating whether PGE approved the application. If applicable, PGE must include a comparison of its evaluation to the applicant's independent analysis.

(4) The interconnection process is not complete until:

(a) PGE approves the application;

(b) Any minor modifications to the transmission or distribution system required under subsection (2)(1) are complete;

(c) The witness test, if conducted by PGE, is successful; and

(d) The applicant and PGE execute a certificate of completion. The certificate of completion must follow the standard form certificate developed by PGE.

(5) If a CSP Project is not approved under the Tier 2 interconnection review procedure, then the applicant may submit a new application under the Tier 4 review procedures. At the applicant's request, PGE must provide a written explanation of the reasons for denial within five business days of the request.

10. Tier 4 Interconnection Review

(1) PGE must use the Tier 4 interconnection review procedures for an application to interconnect a CSP Project that meets the following requirements:

(a) The CSP Project does not qualify for or failed to meet the Tier 2 interconnection review requirements; and

- (b) The CSP Project must have a nameplate capacity of 3 megawatts or less.
- (2) PGE must approve an application to interconnect a CSP Project under the Tier 4 interconnection review procedures if PGE determines that the safety and reliability of PGE's transmission or distribution system will not be compromised by interconnecting the CSP Project. The applicant must pay the reasonable costs of any interconnection facilities or system upgrades necessitated by the interconnection.
- (3) In addition to the timelines and requirements in OAR 860-082-0025, the timelines and requirements in sections (5) through (12) of this rule apply to Tier 4 interconnection reviews.
- (4) PGE and an applicant may agree to waive the requirement for a scoping meeting.
- (5) PGE must schedule a scoping meeting within 10 business days after notifying an applicant that its application is complete.
 - (a) PGE and the applicant must bring to the scoping meeting all personnel, including system engineers, as may be reasonably required to accomplish the purpose of the meeting.
 - (b) PGE and applicant must discuss whether PGE should perform a system impact study, a facilities study, or an interconnection agreement.
 - (c) If PGE determines that no studies are necessary, then PGE must approve the application within 15 business days of the scoping meeting if:
 - (A) The application meets the criteria in section (2); and
 - (B) The interconnection of the CSP Project does not require system upgrades or interconnection facilities different from or in addition to the applicant's proposed interconnection equipment.
 - (d) If PGE determines that no studies are necessary and that the CSP Project could be interconnected safely if minor modifications to the transmission or distribution system were made (for example, changing meters, fuses, or relay settings), then PGE must offer the applicant a good-faith, non-binding estimate of the costs of such proposed minor modifications. Modifications are not considered minor under this subsection if the total cost of the modifications exceeds \$10,000. If the applicant authorizes PGE to proceed with the minor modifications and agrees to pay the entire cost of the modifications, then PGE must approve the application within 15 business days of receipt of the applicant's agreement to pay for the minor modifications.
- (6) If PGE reasonably concludes that an adequate evaluation of an application requires a system impact study, then PGE must provide the applicant with an executable system impact study agreement within five business days of the date of the scoping meeting.

(a) The system impact study agreement must include a detailed scope for the system impact study, a reasonable schedule for completion of the study, and a good-faith, non-binding estimate of the costs to perform the study.

(b) The system impact study agreement must follow the standard form agreement developed by PGE and approved by the Commission.

(c) The applicant must execute the system impact study agreement within 15 business days of receipt of the agreement or the application is deemed withdrawn.

(d) PGE must make reasonable, good-faith efforts to follow the schedule set forth in the system impact study agreement for completion of the study.

(e) The system impact study must identify and detail the impacts on PGE's transmission or distribution system or on an affected system that would result from the interconnection of the CSP Project if no modifications to the CSP Project or system upgrades were made. The system impact study must include evaluation of the adverse system impacts identified in the scoping meeting.

(f) In determining possible adverse system impacts, PGE must consider the aggregated nameplate capacity of all generating facilities that, on the date the system impact study begins, are directly interconnected to PGE's transmission or distribution system, have a pending completed application to interconnect with a higher queue position, or have an executed interconnection agreement with PGE.

(g) The system impact study must include:

(A) A short circuit analysis;

(B) A stability analysis;

(C) A power flow analysis;

(D) Voltage drop and flicker studies;

(E) Protection and set point coordination studies;

(F) Grounding reviews;

(G) The underlying assumptions of the study;

(H) The results of the analyses; and

(I) Any potential impediments to providing the requested CSP interconnection service, including a non-binding informational NRIS portion that addresses the additions, modifications, and upgrades to PGE's Transmission System that would be required at or beyond the point at

which the interconnection facilities connect to PGE's Transmission System to accommodate the interconnection of the CSP Project.

(h) If an applicant provides an independent system impact study to PGE, then PGE must evaluate and address any alternative findings from that study.

(i) PGE must provide a copy of the system impact study to the applicant within five business days of completing the study.

(j) If PGE determines in a system impact study that interconnection facilities or system upgrades are necessary to safely interconnect a CSP Project, then PGE must perform a facilities study.

(k) If PGE determines that no interconnection facilities or system upgrades are required, and PGE concludes that the application meets the criteria in section (2), then PGE must approve the application within 15 business days of completion of the system impact study.

(l) If PGE determines that no interconnection facilities or system upgrades are required and that the CSP Project could be interconnected safely if minor modifications to the transmission or distribution system were made (for example, changing meters, fuses, or relay settings), then PGE must offer the applicant a good-faith, non-binding estimate of the costs of such proposed minor modifications. Modifications are not considered minor under this subsection if the total cost of the modifications exceeds \$10,000. If the applicant authorizes PGE to proceed with the minor modifications and agrees to pay the entire cost of the modifications, then PGE must approve the application within 15 business days of the applicant's agreement to pay for the minor modifications.

(7) If PGE is required to perform a facilities study under subsection 6(j), or if an applicant and PGE agree in the scoping meeting to waive the system impact study and proceed directly to the facilities study, then PGE must provide the applicant with an executable facilities study agreement within five business days of completing the system impact study or within five business days from the date of the scoping meeting, whichever is applicable.

(a) The facilities study agreement must include a detailed scope for the facilities study, a reasonable schedule for completion of the study, and a good-faith, non-binding estimate of the costs to perform the study.

(b) The facilities study agreement must follow the standard form agreement developed by PGE and approved by the Commission.

(c) The applicant must execute the interconnection facilities study agreement within 15 business days after receipt of the agreement or the application is deemed withdrawn.

(d) PGE must make reasonable, good-faith efforts to follow the schedule set forth in the facilities study agreement for completion of the study.

(e) The facilities study must identify the interconnection facilities and system upgrades required to safely interconnect the CSP Project and must determine the costs for the facilities and upgrades, including equipment, engineering, procurement, and construction costs. PGE must also identify the electrical switching configuration of the equipment, including transformer, switchgear, meters, and other station equipment.

(f) PGE may contract with a third-party consultant to complete the interconnection facilities and system upgrades identified in the facilities study. PGE and an applicant may agree in writing to allow the applicant to hire a third-party consultant to complete the interconnection facilities and system upgrades, subject to PGE oversight and approval.

(g) The interconnection facilities study must include a detailed estimate of the time required to procure, construct, and install the required interconnection facilities and system upgrades.

(h) If the applicant agrees to pay for the interconnection facilities and system upgrades identified in the facilities study, then PGE must approve the application within 15 business days of the applicant's agreement.

~~(i) If, during the course of the study process PGE identifies network upgrades associated with the CSP Project, the network upgrades and the estimated cost for the upgrades must be reviewed and approved for recovery by the Commission prior to PGE approving the application.~~

(8) PGE may contract with a third-party consultant to complete a system impact study, or facilities study. PGE and an applicant may agree in writing to allow the applicant to hire a third-party consultant to complete a system impact study, or facilities study, subject to PGE oversight and approval.

(9) The interconnection process is not complete until:

(a) PGE approves the application;

(b) Any interconnection facilities or system upgrades have been completed;

(c) Any minor modifications to PGE's transmission or distribution system required under subsections (5)(d), 6(i)(B), or (7)(l) have been completed;

(d) The witness test, if conducted by PGE, is successful; and

(e) The applicant and PGE execute a certificate of completion.

(10) If a CSP Project is not approved under the Tier 4 interconnection review procedures, then PGE must provide a written explanation of the denial to the applicant.

11. Joint Study Interconnection Review

(1) CSP Projects that request a joint study must agree in writing to be studied together and must meet the following requirements:

- (a) The nameplate rating of the joint CSP Projects must be less than 100 percent of the feeder/substation daytime minimum load.
- (b) The joint CSP Projects must enter the CSP Queue in back to back queue order.
- (c) The joint CSP Projects must have their point of interconnections on the same feeder.
- (d) The joint CSP Projects must be within .5 miles of one another.
- (e) The study requirements and process will follow the Tier 4 Interconnection Review criteria.

12. Recordkeeping and Reporting Requirements

(1) PGE must maintain a record of the following information for at least two years:

- (a) The number of complete interconnection applications received;
- (b) The time required to complete the review process for each application; and
- (c) The reasons for the approval or denial of each application.

(2) For as long as an interconnection customer's CSP Project is interconnected to PGE's transmission or distribution system, PGE must maintain copies of the interconnection application, interconnection agreement, and certificate of completion for the CSP Project. PGE must provide a copy of the interconnection customer's records to the interconnection customer within 15 business days after receipt of a written request.

(3) PGE must submit an annual report to the Commission summarizing PGE's interconnection activities for the previous calendar year. The annual report must be filed by May 30 and must include the following information:

- (a) The number of complete community solar interconnection applications received;
- (b) The number of CSP Project interconnections completed;
- (c) The CSP Project's nameplate capacity;
- (d) The location of completed and proposed community solar facilities by zip code;
- (e) For each Tier 4 interconnection approval, the basic telemetry configuration, if applicable; and
- (f) For each Tier 4 interconnection approval:

(A) The interconnection facilities required to accommodate the interconnection of a CSP Project and the estimated costs of those facilities; and

(B) The system upgrades required to accommodate the interconnection of a CSP Project and the estimated costs of those upgrades.

13. Metering and Monitoring

(1) PGE must install, maintain, test, repair, operate, and replace any metering and data acquisition equipment necessary under the terms of PGE's interconnection agreement, power purchase agreement, or power service agreement with an applicant or interconnection customer. The applicant or interconnection customer is responsible for all reasonable costs associated with the metering and data acquisition equipment. PGE and the applicant or interconnection customer must have unrestricted access to such equipment as necessary to conduct routine business or respond to an emergency.

(2) CSP Projects with a nameplate rating of 360 kW or less will need to connect directly to PGE's distribution system and must not be associated with a load. The project can request to be metered on the secondary side (low side) of the distribution transformer. Projects receiving service at secondary voltage will be billed based on meter registration less 1-1/2% to account for transformation losses.

(3) CSP Projects with a nameplate rating larger than 360 kW will be required to connected directly to PGE's distribution system at primary voltage.

(4) Except as provided in subsection 3(b), PGE may not require an applicant or interconnection customer with a CSP Project with a nameplate capacity of less than three megawatts to provide or pay for the data acquisition or telemetry equipment necessary to allow PGE to remotely monitor the CSP Project's electric output.

~~(5) At its discretion, PGE may require an applicant or interconnection customer to pay for the purchase, installation, operation, and maintenance of the data acquisition or telemetry equipment necessary to allow PGE to remotely monitor the CSP Project's electric output if:~~

~~(a) The CSP Project has a nameplate capacity equal to 2 megawatts or greater; or~~

~~(65) PGE and an applicant or interconnection customer may mutually agree to waive or modify the telemetry requirements in this rule.~~

~~(76) Telemetry Requirements.~~

(a) The communication must take place via a private network link using a frame relay, fractional T-1 line, or other suitable device. Dedicated remote terminal units from the interconnected CSP Project to PGE's substation and energy management system are not required.

(b) A single communication circuit from the CSP Project to PGE is sufficient.

- (c) Communications protocol must be DNP 3.0 or another reasonable standard used by PGE.
- (d) The CSP Project must be capable of sending telemetric monitoring data to PGE at a minimum rate of every two seconds from the output of the CSP Project's telemetry equipment to PGE's energy management system.
- (e) A CSP Project must provide the following minimum data to PGE:
 - (A) Net real power flowing out or into the CSP Project (analog);
 - (B) Net reactive power flowing out or into the CSP Project (analog);
 - (C) Bus bar voltage at the point of common coupling (analog);
 - (D) Data processing gateway heartbeat (used to certify the telemetric signal quality); and
 - (E) On-line or off-line status (digital).
- (f) If an applicant or interconnection customer operates the equipment associated with the high voltage switchyard interconnecting the CSP Project to the transmission or distribution system and is required to provide monitoring and telemetry, then the interconnection customer must provide the following data to PGE in addition to the data in subsection (e):
 - (A) Switchyard line and transformer megawatt and mega volt ampere reactive values;
 - (B) Switchyard bus voltage; and
 - (C) Switching device status.

14. Temporary Disconnection

- (1) Under emergency conditions, PGE or an interconnection customer may suspend CSP interconnection service and temporarily disconnect a CSP Project from PGE's transmission or distribution system at any time and for as long as reasonably necessary.
 - (a) PGE must notify an interconnection customer immediately after becoming aware of an emergency condition that may reasonably be expected to affect a CSP Project's operation. To the extent possible, the notice must describe the emergency condition, the extent of the damage or deficiency, the expected effect on the CSP Project, the anticipated duration of the condition, and the necessary corrective action.
 - (b) An interconnection customer must notify PGE immediately after becoming aware of an emergency condition that may reasonably be expected to affect PGE's transmission or distribution system. To the extent possible, the notice must describe the emergency condition, the extent of the damage or deficiency, the expected effect on the public utility's transmission or distribution system, the anticipated duration of the condition, and the necessary corrective action.

(2) PGE or an interconnection customer may suspend CSP interconnection service and temporarily disconnect a CSP Project to perform routine maintenance, construction, or repairs. PGE or an interconnection customer must provide written notice five business days before suspending CSP interconnection service or temporarily disconnecting the CSP Project. PGE and an interconnection customer must use reasonable efforts to coordinate interruptions caused by routine maintenance, construction, or repairs.

(3) PGE must use reasonable efforts to provide written notice to an interconnection customer affected by a forced outage of PGE's transmission or distribution system at least five business days before the forced outage. If prior written notice is not given, then PGE must provide the interconnection customer written documentation explaining the circumstances of the disconnection within five business days after the forced outage.

(4) PGE may disconnect a CSP Project if PGE determines that operation of the CSP Project will likely cause disruption or deterioration of service to other customers served by PGE's transmission or distribution system, or if PGE determines that operation of the CSP Project could cause damage to PGE's transmission or distribution system.

(a) PGE must provide written notice to the interconnection customer of the disconnection at least five business days before the disconnection. If the condition requiring disconnection can be remedied, then PGE must describe the remedial action necessary.

(b) If requested by the interconnection customer, PGE must provide documentation supporting PGE's decision to disconnect.

(c) PGE may disconnect the CSP Project if the interconnection customer fails to perform the remedial action identified in the notice of disconnection within a reasonable time, but no less than five business days after the interconnection customer received the notice of disconnection.

(5) PGE may temporarily disconnect a CSP Project if an interconnection customer makes any change to the facility, other than a minor equipment modification, without PGE's prior written authorization. PGE may disconnect the CSP Project for the time necessary for PGE to evaluate the affect of the change to the CSP Project on PGE's transmission or distribution system.

(6) PGE has the right to inspect an interconnection customer's CSP Project at reasonable hours and with reasonable prior written notice to the interconnection customer. If PGE discovers that the CSP Project is not in compliance with the requirements of the Schedule and these Standards, then PGE may require the interconnection customer to disconnect the CSP Project until compliance is achieved.

15. Arbitration of Disputes

(1) PGE or an interconnection applicant may petition the Commission for arbitration of disputes arising during review of an application to interconnect a CSP Project or during negotiation of an interconnection agreement. If PGE or the applicant petitions the Commission to arbitrate their

dispute, then the Commission will use an administrative law judge (ALJ) as arbitrator unless workload constraints necessitate the use of an outside arbitrator.

(2) A petition for arbitration of an interconnection agreement must contain:

(a) A statement of all unresolved issues;

(b) A description of each party's position on the unresolved issues; and

(c) A proposed agreement addressing all issues, including those on which the parties have reached agreement and those that are in dispute.

(3) A petition for arbitration of a dispute arising during review of an application to interconnect a CSP Project must contain:

(a) A statement of all unresolved issues;

(b) A description of each party's position on the unresolved issues; and

(c) A proposed resolution for each unresolved issue.

(4) Respondent may file a response within 25 calendar days of the petition for arbitration. In the response, the respondent must address each issue listed in the petition, describe the respondent's position on those issues, and present any additional issues for which the respondent seeks resolution.

(5) The filing of a petition for arbitration of a dispute arising during review of an application to interconnect a CSP Project does not affect the application's queue position.

(6) The arbitration is conducted in a manner similar to a contested case proceeding, and the arbitrator has the same authority to conduct the arbitration process as an ALJ has in conducting hearings under the Commission's rules, but the arbitration process is streamlined. The arbitrator holds an early conference to discuss processing of the case. The arbitrator establishes the schedule and decides whether an oral hearing is necessary. After the oral hearing or other procedures (for example, rounds of comments), each party submits its final proposed interconnection agreement or resolution of disputed issues. The arbitrator chooses between the two final offers. If neither offer is consistent with applicable statutes, Commission rules, and Commission policies, then the arbitrator will make a decision that meets those requirements.

(7) The arbitrator may allow formal discovery only to the extent deemed necessary. Parties are required to make good faith attempts to exchange information relevant to any disputed issue in an informal, voluntary, and prompt manner. Unresolved discovery disputes are resolved by the arbitrator upon request of a party. The arbitrator will order a party to provide information if the arbitrator determines the requesting party has a reasonable need for the requested information and that the request is not overly burdensome.

(8) Only the two negotiating parties have full party status. The arbitrator may confer with Commission staff for assistance throughout the arbitration process.

(9) To keep the process moving forward, appeals to the Commission are not allowed during the arbitration process. An arbitrator may certify a question to the Commission if the arbitrator believes it is necessary.

(10) To accommodate the need for flexibility, the arbitrator may use different procedures so long as the procedures are fair, treat the parties equitably, and substantially comply with the procedures listed here.

(11) The arbitrator must serve the arbitration decision on the interconnecting public utility and the interconnection applicant. The parties may file comments on the arbitration decision with the Commission within 10 calendar days after service.

(12) The Commission must accept, reject, or modify an arbitration decision within 30 calendar days after service of the decision.

(13) Within 14 calendar days after the Commission issues an order on a petition for arbitration of an interconnection agreement, the petitioner must prepare an interconnection agreement complying with the terms of the decision and serve it on respondent. Respondent must either sign and file the interconnection agreement or file objections to it within 10 calendar days of service of the agreement. If objections are filed, respondent must state how the interconnection agreement fails to comply with the Commission order and offer substitute language complying with the decision. The Commission must approve or reject a filed interconnection agreement within 20 calendar days of its filing or the agreement is deemed approved.

(14) If petitioner, without respondent's consent, fails to timely prepare and serve an interconnection agreement on respondent, respondent may file a motion requesting the Commission dismiss the petition for arbitration with prejudice. The Commission may grant such motion if the petitioner's failure to timely prepare and serve the interconnection agreement was the result of inexcusable neglect on the part of petitioner.

(15) The public utility and the applicant may agree to hire an outside arbitrator rather than file a petition with the Commission. The public utility and the applicant must share equally the costs of an outside arbitrator unless they mutually agree to a different payment arrangement.

16. Complaints for Enforcement

(1) This rule specifies the procedure PGE, an interconnection customer, or an applicant to file a complaint for the enforcement of an interconnection agreement. Filing dates for enforcement complaint proceedings are calculated and enforced per OAR 860-001-0150.

(2) At least 10 days prior to filing a complaint for enforcement, complainant must give written notice to defendant and the Commission that complainant intends to file a complaint for enforcement. The notice must identify the provisions in the agreement that complainant alleges

were or are being violated and the specific acts or failure to act that caused or are causing the violation, and whether complainant anticipates requesting temporary or injunctive relief. On the same day the notice is filed with the Commission, complainant must serve a copy of the notice on defendant's authorized representative, attorney of record, or designated agent for service of process. Complainant must also serve the notice on all persons designated in the interconnection agreement to receive notices;

(3) A complaint for enforcement must:

(a) Contain a statement of specific facts demonstrating that the complainant conferred with defendant in good faith to resolve the dispute, and that despite those efforts the parties failed to resolve the dispute;

(b) Include a copy of the written notice, required by section (2), indicating that the complainant intends to file a complaint for enforcement;

(c) Include a copy of the interconnection agreement or the portion of the agreement that the complainant contends that defendant violated or is violating. If a copy of the entire agreement is provided, complainant must specify the provisions at issue;

(d) Contain a statement of the facts or law demonstrating defendant's failure to comply with the interconnection agreement and complainant's entitlement to relief. The statement must indicate that the remedy sought is consistent with the dispute resolution provisions in the agreement, if any. Statements of facts must be supported by written testimony with affidavits made by persons competent to testify and having personal knowledge of the relevant facts. Statements of law must be supported by appropriate citations. If exhibits are attached to the affidavits, the affidavits must contain the foundation for the exhibits;

(e) Designate up to three persons to receive copies of pleadings and documents;

(f) Include an executive summary, filed as a separate document not to exceed 8 pages, outlining the issues and relief requested; and

(g) Include any motions for affirmative relief, filed as a separate document and clearly marked. Nothing in this subsection precludes complainant from filing a motion subsequent to the filing of the complaint if the motion is based upon facts or circumstances unknown or unavailable to complainant at the time the complaint was filed.

(4) On the same day the complaint is filed with the Commission, complainant must serve a copy of the complaint on defendant's authorized representative, attorney of record, or designated agent for service of process. Service may be by telephonic facsimile, electronic mail, or overnight mail, but the complaint must arrive at defendant's location on the same day the complaint is filed with the Commission. Service by facsimile or electronic mail must be followed by a physical copy of the complaint the next day by overnight delivery.

(5) Within 10 business days after service of the complaint, defendant may file an answer with the Commission. Any allegations raised in the complaint and not addressed in the answer are deemed admitted. The answer must:

(a) Contain a statement of specific facts demonstrating that the defendant conferred with complainant in good faith to resolve the dispute and that despite those efforts the parties failed to resolve the dispute;

(b) Respond to each allegation in the complaint and set forth all affirmative defenses;

(c) Contain a statement of the facts or law supporting defendant's position. Statements of facts must be supported by written testimony with affidavits made by persons competent to testify and having personal knowledge of the relevant facts. Statements of law must be supported by appropriate citations. If exhibits are attached to the affidavits, then the affidavits must contain the foundation for the exhibits; and

(d) Designate up to three persons to receive copies of other pleadings and documents.

(6) On the same day as the answer is filed, the defendant must also file its response to any motion filed by complainant and its motions for affirmative relief. Each response and each motion must be filed as a separate filing. Nothing in this section precludes defendant from filing a motion subsequent to the filing of the answer if the motion is based upon facts or circumstances unknown or unavailable to defendant at the time the answer was filed.

(7) On the same day the answer is filed with the Commission, the defendant must serve a copy of the answer to the complainant's authorized representative, attorney of record, or designated agent for service of process.

(8) Complainant must file a reply to an answer that contains affirmative defenses within 5 business days after the answer is filed. On the same day the reply is filed with the Commission, complainant must serve a copy of the reply to defendant's authorized representative, attorney of record, or designated agent for service of process.

(9) A cross-complaint or counterclaim must be answered within the 10-business day time frame allowed for answers to complaints.

(10) The Commission will conduct a conference regarding each complaint for enforcement of an interconnection agreement.

(a) The administrative law judge (ALJ) schedules a conference within 5 business days after the answer is filed, to be held as soon as practicable. At the discretion of the ALJ, the conference may be conducted by telephone.

(b) Based on the complaint and the answer, all supporting documents filed by the parties, and the parties' oral statements at the conference, the ALJ determines whether the issues raised in the complaint can be determined on the pleadings and submissions without further proceedings or

whether further proceedings are necessary. If further proceedings are necessary, the ALJ establishes a procedural schedule. Nothing in this subsection is intended to prohibit the bifurcation of issues where appropriate.

(c) In determining whether further proceedings are necessary, the ALJ must consider, at a minimum, the positions of the parties, the need to clarify evidence through the examination of witnesses, the complexity of the issues, the need for prompt resolution, and the completeness of the information presented.

(d) The ALJ may make oral rulings on the record during the conference on all matters relevant to the conduct of the proceeding.

(11) A party may file with the complaint or answer a request for discovery, stating the matters to be inquired into and their relationship to matters directly at issue.

(12) When warranted by the facts, the complainant or defendant may file a motion requesting that an expedited procedure be used. The moving party must file a proposed expedited procedural schedule along with its motion. The ALJ must schedule a conference to be held as soon as practicable to determine whether an expedited schedule is warranted.

(a) The ALJ will consider whether the issues raised in the complaint or answer involve a risk of imminent, irrevocable harm to a party or to the public interest.

(b) If a determination is made that an expedited procedure is warranted, the ALJ will establish a procedure that ensures a prompt resolution of the merits of the dispute, consistent with due process and other relevant considerations. The ALJ will consider, but is not bound by, the moving party's proposed expedited procedural schedule.

(c) In general, the ALJ will not entertain a motion for expedited procedure where the dispute solely involves the payment of money.

Form 4
8-21-09 rev.*

Formatted: Right



Small Generator Facility/Community Solar Facility
System Impact Study Agreement

This Agreement is made and entered into this _____ by and between _____, an individual a company, (“Applicant”) and Portland General Electric Company, a corporation existing under the laws of the State of Oregon, (“PGE”). Applicant and PGE each may be referred to as a “Party,” or collectively as the “Parties.”

Recitals:

Whereas, Applicant is proposing to develop a Small Generator Facility/Community Solar Facility or adding generating capacity to an existing Small Generator Facility/Community Solar Facility consistent with the Application completed on _____; and

Whereas, Applicant desires to interconnect the Small Generator Facility/Community Solar Facility with PGE’s Transmission & Distribution (T&D) System; and

Whereas, PGE has completed a Feasibility Study and provided the results of said study to Applicant (This recital to be omitted if the Parties have agreed to forego the Feasibility Study.); and

Whereas, Applicant has requested PGE perform a System Impact Study to assess the impact of interconnecting the Small Generator Facility/Community Solar Facility to PGE’s T&D System.

Now, therefore, in consideration of and subject to the mutual covenants contained herein the Parties agree as follows:

1. When used in this Agreement, with initial capitalization, the terms specified shall have the meanings set forth in this Agreement or as given in OAR 860-082-0005 through 860-082-0085 PGE’s Tariff Schedule 204 (Tariff) and to the extent that this Agreement conflicts with the Rules Tariff, the Rules Tariff shall take precedence.
2. Applicant elects and PGE shall cause to be performed a System Impact Study consistent with OAR 860-082-0060(7)the Tariff.
3. The Parties shall set out the assumptions to be used in conducting the System Impact Study in Attachment A which is incorporated as part of this Agreement.
4. The System Impact Study will be based upon the results of the Feasibility Study, if applicable, technical information provided in the Application, and by Attachment A to this Agreement. PGE reserves the right to request additional technical information

SYSTEM IMPACT STUDY AGREEMENT FOR SMALL-GENERATOR-FACILITY/COMMUNITY SOLAR FACILITY, PAGE 1 OF 4

Form 4
8-21-09 rev. 4

Formatted: Right

from Applicant as may reasonably become necessary consistent with Good Utility Practice during the course of the System Impact Study. If Applicant modifies its designated Point of Interconnection, Application, or the technical information provided therein is modified, the time to complete the System Impact Study may be extended.

5. The System Impact Study report shall provide the following information:

- 5.1 Identification of any circuit breaker short circuit capability limits exceeded as a result of the interconnection,
- 5.2 Identification of any thermal overload or voltage limit violations resulting from the interconnection,
- 5.3 Identification of any instability or inadequately damped response to system disturbances resulting from the interconnection, and
- 5.4 Description and good faith non-binding cost estimate of facilities required to interconnect the ~~Small Generator Facility~~ Community Solar Facility to PGE's T&D System and to address the identified short circuit, instability, and power flow issues.

6. As required by ~~OAR 860-082-0060(7)(a)~~ the Tariff, Attachment A to this Agreement provides a detail of the scope for the System Impact Study, a reasonable schedule for completion of the study, and a good-faith, non-binding estimate of the cost to perform the System Impact Study. The System Impact Study shall be completed and the results transmitted to the Applicant within sixty (60) business days after this Agreement is signed by the Parties unless otherwise agreed to as part of this Agreement. Attachment A shall be incorporated as part of this Agreement.

7. PGE may require a study deposit as described ~~OAR 860-082-0035~~ of in the Rule Tariff.

8. Study fees and cost responsibility are described in ~~OAR 860-082-0035~~ of the Rule Tariff and will be based on actual costs and as follows:

- 8.1 The non-binding good faith estimate of the cost to complete the System Impact Study is \$_____. Applicant is required to pay a deposit of fifty (50) percent of estimate or \$1,000, whichever is less, prior to start date of study.
- 8.2 Any study fees shall be based on PGE's actual costs and will be invoiced to Applicant after the study is completed and delivered and will include a summary of professional time.
- 8.3 Applicant must pay any study costs that exceed the deposit without interest within thirty (30) calendar days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, PGE shall refund such excess

Form 4
8-21-09 rev. 4

Formatted: Right

within thirty (30) calendar days of the invoice without interest.

9. Cost responsibility is detailed in ~~OAR 860-082-0035~~ of the Rule Tariff.

Signatures:

In witness whereof, the Parties have caused this Agreement to be executed by their respective duly authorized representatives.

For APPLICANT:

Signature: _____

Printed Name: _____

Title (*if any*): _____

Date: _____

For PORTLAND GENERAL ELECTRIC COMPANY:

Signature: _____

Printed Name: _____

Title (*if any*): _____

Date: _____

Form 4
8-21-09 rev.*

Formatted: Right

Attachment A
System Impact Study Agreement
PGE Provided Scope, Schedule, and Budget for System Impact Study



**Small Generator Facility Community Solar Facility
Facilities Study Agreement**

This Agreement is made and entered into this date, _____ by and between _____, an individual a company, (“Applicant”) and Portland General Electric Company, a corporation existing under the laws of the State of Oregon, (“PGE”). Applicant and PGE each may be referred to as a “Party,” or collectively as the “Parties.”

Recitals:

Whereas, Applicant is proposing to develop a Small Generator Facility Community Solar Facility or adding generating capacity to an existing Small Generator Facility Community Solar Facility consistent with the Application completed on _____; and

Whereas, Applicant desires to interconnect the Small Generator Facility Community Solar Facility with PGE’s Transmission & Distribution (T&D) System; and

Whereas, PGE has completed a System Impact Study and provided the results of said study to Applicant (This recital to be omitted if the Parties have agreed to forego the System Impact Study.); and

Whereas, Applicant has requested PGE to perform a Facilities Study to specify and estimate the cost of the equipment, engineering, procurement and construction work in accordance with Good Utility Practice needed to physically and electrically connect the Small Generator Facility Community Solar Facility to PGE’s T&D System.

Now, therefore, in consideration of and subject to the mutual covenants contained herein the Parties agree as follows:

1. When used in this Agreement, with initial capitalization, the terms specified shall have the meanings set forth in this Agreement or as given in OAR 860-082-0005 through 860-082-0085 PGE’s Tariff Schedule 204 (Tariff) and to the extent that this Agreement conflicts with the Rules Tariff, the Rules Tariff shall take precedence.
2. Applicant and PGE shall cause to be performed a Facilities Study consistent with OAR 860-082-0060(8) the Tariff.
3. The scope of the Facilities Study shall be subject to data provided by Applicant in its Application as well as the data provided by the Applicant in Attachment A of this Agreement.

4. A Facilities Study report (1) shall provide a description, estimated cost, and schedule for required Interconnection Facilities and System Upgrade(s) to interconnect the ~~Small Generator Facility~~ Community Solar Facility to PGE’s T&D System including a description of any facilities or upgrades necessary to address impacts to Affected Systems and (2) shall address the short circuit, instability, and power flow issues identified in any prior System Impact Studies.

5. PGE may require a study deposit as described in ~~ÖAR 860-082-0035(1)~~ the Tariff.

6. As required by ~~ÖAR 860-082-0060(8)(a)~~ the Tariff, the public utility will provide scope for the Facilities Study, a reasonable schedule for completion of the study, and a good-faith, non-binding cost estimate to perform the study (Attachment B). In cases where no System Upgrade or Interconnection Facilities is required, the Facilities Study shall be completed and the results will be transmitted to Applicant within (60) business days after this Agreement is signed by the Parties.

7. Study fees will be based on actual costs in accordance with the provisions of ~~860-082-0035~~ the Tariff and as follows:

7.1 The non-binding good faith estimate of the cost to complete the Facilities Study is \$_____. Applicant is required to pay a deposit of fifty (50) percent this estimate or \$1,000, whichever is less, prior to start date of study.

7.2 Any study fees shall be based on PGE’s actual costs and will be invoiced to Applicant after the study is completed and delivered and will include a summary of professional time.

7.3 Applicant must pay any study costs that exceed the deposit without interest within thirty (30) calendar days on receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced fees, PGE shall refund such excess within thirty (30) calendar days of the invoice without interest.

8. Cost Responsibility is detailed in ~~ÖAR 860-082-0035~~ of the Rule Tariff.

Signatures:

In witness whereof, the Parties have caused this Agreement to be executed by their respective duly authorized representatives.

For APPLICANT:

Signature: _____

Printed Name: _____

Title (*if any*):

Date:

For PORTLAND GENERAL ELECTRIC COMPANY:

Signature:

Printed Name:

Title (*if any*):

Date:

Attachment A

Facilities Study Agreement

Data to be Provided by Applicant with the Facilities Study Agreement

Provide location plan and simplified one-line diagram of the plant and station facilities. For staged projects, please indicate future generation, distribution circuits, etc.

Please provide a 7.5-minute quadrangle map of the site. Indicate the plant, station, distribution line, and property lines.

Estimated line length from interconnection station to the PGE's T&D System: ____feet.

On the one-line diagram, indicate the generation capacity attached at each utility metering location (maximum load on CT/PT).

One set of metering is required for each generation connection to the new ring bus or existing PGE station. Number of generation connections: _____

On the one-line diagram, indicate the location of any auxiliary power and minimum load on CT/PT (Amps).

Will an alternate source of auxiliary power be available during CT/PT maintenance?

Will a transfer bus on the generation side of the metering require that each meter set be designed for the total plant generation? _____ (Please indicate on the one-line diagram.)

What type of control system or PLC will be located at the Generating Facility?

What protocol does the control system or PLC use? _____

Attachment B
Facilities Study Agreement
PGE Provided Scope, Schedule, and Budget for Facilities Study

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right



**Interconnection Agreement for ~~Small Generator Facility~~Community Solar Facility
Tier 1, Tier 2, ~~Tier 3~~ or Tier 4 Interconnection**

(~~Small Generator~~Community Solar Facilities with Electric Nameplate Capacities of 403 MW or Less)

This Interconnection Agreement (sometimes also referred to as "Agreement") is made and entered into this _____ by and between _____, an individual a company, ("Applicant") and Portland General Electric Company, a corporation existing under the laws of the State of Oregon, ("PGE"). Applicant and PGE each may be referred to as a "Party," or collectively as the "Parties."

Recitals:

Whereas, the Applicant is proposing to develop a _____ MW ~~Small Generator Facility~~Community Solar Facility, or to add generating capacity to an existing ~~Small Generator Facility~~Community Solar Facility, consistent with the Application completed on _____ ;

Whereas, the Applicant desires to interconnect the ~~Small Generator Facility~~Community Solar Facility with PGE's Transmission and Distribution System (T&D System); and

Whereas, the Agreement shall be used for all approved ~~Tier 1, Tier 2, Tier 3~~ and Tier 4 Interconnection Applications according to the procedures set forth in ~~OPUC Rule Tariff OAR 860, Division 082 (Rule Tariff)~~PGE's tariff in effect on the Effective Date of the Agreement (the "~~Tariff~~"). Terms with initial capitalization, when used in this Agreement, shall have the meanings given in the ~~Rule Tariff~~ and, to the extent this Agreement conflicts with the ~~Rule Tariff~~, the ~~Rule Tariff~~ shall take precedence.

Now, therefore, in consideration of and subject to the mutual covenants contained herein, the Parties agree as follows:

Article 1. Scope and Limitations of Agreement

1.1 Scope

The Agreement establishes standard terms and conditions approved by the Commission under which the ~~Small Generator Facility~~Community Solar Facility with a Nameplate Capacity of 403 MW or less will interconnect to, and operate in parallel with PGE's T&D System. Additions, deletions or changes to the standard terms and conditions of an Interconnection Agreement will not be permitted unless they are mutually agreed to by the Parties or approved by the Commission if required by the ~~Rule Tariff~~.

1.2 Power Purchase

The Agreement does not constitute an agreement to purchase, transmit, or deliver the

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Applicant's power nor does it constitute an electric service agreement.

1.3 Other Agreements

Nothing in the Interconnection Agreement is intended to affect any other agreement between PGE and the Applicant or another Interconnection Customer. However, in the event that the provisions of the Agreement are in conflict with the provisions of other PGE tariffs, PGE tariff shall control.

1.4 Responsibilities of the Parties

- 1.4.1 The Parties shall perform all obligations of this Agreement in accordance with all applicable laws.
- 1.4.2 The Applicant will construct, own, operate, and maintain its ~~Small Generator Facility~~Community Solar Facility in accordance with the Agreement, IEEE Standard 1547, the National Electrical Code and applicable standards required by the Commission.
- 1.4.3 Each Party shall be responsible for the safe installation, maintenance, repair and condition of their respective lines and appurtenances on their respective sides of the Point of Interconnection. Each Party shall provide Interconnection Facilities that adequately protect the other Parties' facilities, personnel, and other persons from damage and injury. The allocation of responsibility for the design, installation, operation, maintenance and ownership of Interconnection Facilities is prescribed in the ~~Rule~~Tariff.

1.5 Parallel Operation and Maintenance Obligations

Once the ~~Small Generator Facility~~Community Solar Facility has been authorized to commence Parallel Operation by execution of the Interconnection Agreement, the Applicant will abide by all written provisions for operating and maintenance as required by the ~~Rule~~Tariff and detailed by PGE in Form 7, title "**Interconnection Equipment As Built Specifications, Initial Settings and Operating Requirements**" a copy of which is provided on PGE's website.

1.6 Metering and Monitoring

The Applicant will be responsible for metering and monitoring as required by ~~GAR 860-082-0070~~the Tariff.

1.7 Power Quality

The Applicant will design its ~~Small Generator Facility~~Community Solar Facility to maintain a composite power delivery at continuous rated power output at the Point of Interconnection that meets the requirements set forth in IEEE 1547. PGE may, in some circumstances, also require the Applicant to follow voltage or VAR schedules used by similarly situated, comparable generators in the control area. Any special operating requirements will be detailed in ~~Form 7~~Form 7 provided on the Commission website and completed by PGE as required by the ~~Rule~~Tariff. Under no circumstances shall these additional requirements for voltage or reactive power support exceed the normal operating capabilities of the ~~Small~~

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

~~Generator Facility~~Community Solar Facility. For purposes of this Agreement, “control area” shall mean an electrical system or systems bounded by interconnection metering and telemetry, capable of controlling generation to maintain its interchange schedule with other control areas and contributing to frequency regulation of the interconnection.

Article 2. Inspection, Testing, Authorization, and Right of Access

2.1 Equipment Testing and Inspection

The Applicant will test and inspect its ~~Small Generator Facility~~Community Solar Facility Facilities prior to interconnection in accordance with IEEE 1547 Standards as provided for in the ~~Rule~~Tariff. The Interconnection will not be final until the Witness Test and Certificate of Completion provisions in the ~~Rule~~Tariff have been satisfied. Operation of the ~~Small Generator Facility~~Community Solar Facility requires an-Interconnection Agreement; electricity sales require a Power Purchase Agreement.—To the extent that the Applicant decides to conduct interim testing of the ~~Small Generator Facility~~Community Solar Facility prior to the Witness Test, it may request that PGE observe these tests and that these tests be deleted from the final Witness Test. If PGE agrees to send qualified personnel to the ~~Small Generator Facility~~Community Solar Facility to observe such interim testing, it will be doing so at its own expense unless the Parties agree otherwise

2.2 Right of Access

As provided in ~~OAR 860-082-0020~~the Tariff, PGE will have access to the Applicant’s premises for any reasonable purpose in connection with the Interconnection Application and any Interconnection Agreement that is entered in to pursuant to this ~~Rule~~Tariff or if necessary to meet the legal obligation to provide service to its customers. Access will be requested at reasonable hours and upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition.

Article 3. Effective Date, Term, Termination, and Disconnection

3.1 Effective Date

The Agreement shall become effective upon execution by the Parties.

3.2 Term of Agreement

The Agreement will be effective on the Effective Date and will remain in effect for a period of twenty (20) years or the life of the Power Purchase Agreement, whichever is shorter or a period mutually agreed to by Parties, unless terminated earlier by the default or voluntary termination by the Applicant or by action of the Commission.

3.3 Termination

No termination will become effective until the Parties have complied with all applicable laws and any clauses of the ~~Rule~~Tariff or this Agreement applicable to such termination.

3.3.1 The Applicant may terminate this Agreement at any time by giving PGE twenty (20) business days written notice.

3.3.2 Either Party may terminate this Agreement after default pursuant to Article 5.6 of

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

this Agreement.

3.3.3 The Commission may order termination of this Agreement.

3.3.4 Upon termination of this Agreement, the ~~Small Generator Facility~~ Community Solar Facility will be disconnected from PGE's T&D System at the Applicant's expense. The termination of this Agreement will not relieve either Party of its liabilities and obligations, owed or continuing at the time of the termination.

3.3.4 The provisions of this Article shall survive termination or expiration of this Agreement.

3.4 Temporary Disconnection

PGE or the Applicant may temporarily disconnect the ~~Small Generator Facility~~ Community Solar Facility from its T&D System for so long as reasonably necessary, as provided in ~~OAR 860-082-0075~~ of the Rule Tariff, in the event one or more of the following conditions or events occurs:

3.4.1 Under emergency conditions, PGE or the Applicant may immediately suspend interconnection service and temporarily disconnect the ~~Small Generator Facility~~ Community Solar Facility. PGE shall notify the Applicant promptly when it becomes aware of an emergency condition that may reasonably be expected to affect the ~~Small Generator Facility~~ Community Solar Facility operation. The Applicant will notify PGE promptly when it becomes aware of an emergency condition that may reasonably be expected to affect PGE's T&D System. To the extent information is known, the notification shall describe the emergency condition, the extent of the damage or deficiency, the expected effect on the operation of both Parties' facilities and operations, its anticipated duration, and the necessary corrective action.

3.4.2 For routine Maintenance, Parties will make reasonable efforts to provide five (5) business days notice prior to interruption caused by routine maintenance or construction and repair to the ~~Small Generator Facility~~ Community Solar Facility or PGE's T&D system and shall use reasonable efforts to coordinate such interruption.

3.4.3 For Forced outages of the T&D System, PGE shall use reasonable efforts to provide the Applicant with prior notice of forced outages to effect immediate repairs to the T&D System. If prior notice is not given, PGE shall, upon request, provide the Applicant written documentation after the fact explaining the circumstances of the disconnection.

3.4.4 For disruption or deterioration of service, where PGE determines that operation of the ~~Small Generator Facility~~ Community Solar Facility will likely cause disruption or deterioration of service to other customers served from the same electric system, or if operating the ~~Small Generator Facility~~ Community Solar Facility could cause damage to PGE's T&D System, PGE may disconnect the ~~Small Generator~~

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

~~Small Generator Facility~~Community Solar Facility. PGE will provide the Applicant upon request all supporting documentation used to reach the decision to disconnect. PGE may disconnect the ~~Small Generator Facility~~Community Solar Facility if, after receipt of the notice, the Applicant fails to remedy the adverse operating effect within a reasonable time which shall be at least five (5) business days from the date the Applicant receives PGE's written notice supporting the decision to disconnect, unless emergency conditions exist, in which case the provisions of 3.4.1 of the Agreement apply.

3.4.5 If the Applicant makes any change other than Minor Equipment Modifications without prior written authorization of PGE, PGE will have the right to temporarily disconnect the ~~Small Generator Facility~~Community Solar Facility.

3.5 Restoration of Interconnection

The Parties shall cooperate with each other to restore the ~~Small Generator Facility~~Community Solar Facility, Interconnection Facilities, and PGE's T&D System to their normal operating state as soon as reasonably practicable following any disconnection pursuant to section 3.4.

Article 4. Cost Responsibility and Billing

The Applicant is responsible for the application fee and for such facilities, equipment, modifications and upgrades as required in ~~860-082-0035~~the Tariff.

4.1 Minor T&D System Modifications

Modifications to the existing T&D System identified by PGE and set forth in Attachment A, such as changing meters, fuses or relay settings, are deemed Minor Modifications. It is PGE's sole discretion to decide what constitutes a Minor Modification. The Applicant will bear the costs of making such Minor Modifications as may be necessary to gain approval of an Application.

4.2 Interconnection Facilities

PGE will identify, under the study procedures of an Application review, the Interconnection Facilities necessary to safely interconnect the ~~Small Generator Facility~~Community Solar Facility with PGE. Attachment A itemizes the Interconnection Facilities for the Applicant, including the cost of the facilities and the time required to build and install those facilities. The Applicant is responsible for the cost of the Interconnection Facilities.

4.3 Interconnection Equipment

The Applicant is responsible for all reasonable expenses, including overheads, associated with owning, operating, maintaining, repairing, and replacing its Interconnection Equipment.

4.4 System Upgrades

PGE will design, procure, construct, install, and own any System Upgrades. The actual cost of the System Upgrades, including overheads, is set forth in Attachment A and will be directly assigned to the Applicant. An Applicant may be entitled to financial

Form 8
1-19-10 rev.

compensation from other PGE Interconnection Customers who, in the future, benefit from the System Upgrades paid for by the Applicant. Such compensation will be governed by separate ~~rules~~ promulgated by the Commission or by terms of a tariff filed and approved by the Commission. Such compensation will only be available to the extent provided for in the separate ~~rules~~ or tariff. In such cases when there are multiple Community Solar Facilities on a single circuit of the Distribution System that are jointly studied, the PGE shall allocate the System Upgrade costs based on the proportional capacity of each Community Solar Project. The cost sharing will be detailed in the Attachments to this Agreement. If a Community Solar Project that has been jointly studied and allocated a share of system upgrade costs withdraws, the Company will reassess the System Upgrades needed to complete the interconnection(s) and reallocate the System Upgrade costs to the remaining Community Solar Project(s) using the same methodology.

Formatted: Tab stops: 7.1", Right

Formatted: Font: 12 pt, Font color: Auto

Formatted: Font: 12 pt, Font color: Auto

4.5 Adverse System Impact

PGE is responsible for identifying Adverse System Impacts on any Affected Systems and for determining what mitigation activities or upgrades may be required to accommodate a ~~Small Generator Facility~~ Community Solar Facility. The actual cost of any actions taken to address the Adverse System Impacts, including overheads, shall be directly assigned to the Applicant. The Applicant may be entitled to financial compensation from other public utilities or other Interconnection Customers who, in the future, utilize the upgrades paid for by the Applicant, to the extent as allowed by the Commission. Adverse System Impacts are set forth in Attachment A.

4.6 Billings

PGE may require a deposit of not more than 50% of the cost estimate, not to exceed \$1,000, to be paid up front by the Applicant for studies necessary to complete an Application and to interconnect the ~~Small Generator Facility~~ Community Solar Facility to the T&D System. PGE may require a deposit of no more than 25% of the estimated costs, not to exceed \$10,000, for Interconnection Facilities necessary to complete an Application and to interconnect the ~~Small Generator Facility~~ Community Solar Facility to the T&D System. Progress billing, final billing and payment schedules must be agreed to by Parties prior to commencing work.

Article 5. Assignment, Liability, Indemnity, Force Majeure, Consequential Damages, and Default

5.1 Assignment

The Interconnection Agreement may be assigned by either Party upon fifteen (15) business days prior written notice. Except as provided in Articles 5.1.1 and 5.1.2, said assignment shall only be valid upon the prior written consent of the non-assigning Party, which consent shall not be unreasonably withheld.

5.1.1 Either Party may assign the Agreement without the consent of the other Party to any affiliate (which shall include a merger of the Party with another entity), of the assigning Party with an equal or greater credit rating and with the legal authority and operational ability to satisfy the obligations of the assigning Party under this Agreement;

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

5.1.2 The Applicant shall have the right to assign the Agreement, without the consent of PGE, for collateral security purposes to aid in providing financing for the ~~Small Generator Facility~~ Community Solar Facility. For Small Generator systems that are integrated into a building facility, the sale of the building or property will result in an automatic transfer of the Agreement to the new owner who shall be responsible for complying with the terms and conditions of this Agreement.

5.1.3 Any attempted assignment that violates this Article is void and ineffective. Assignment shall not relieve a Party of its obligations, nor shall a Party's obligations be enlarged, in whole or in part, by reason thereof. An assignee is responsible for meeting the same obligations as the Applicant.

5.2 Limitation of Liability and Consequential Damages

A Party is liable for any loss, cost claim, injury, or expense including reasonable attorney's fees related to or arising from any act or omission in its performance of the provisions of an Interconnection Agreement entered into pursuant to the ~~Rule Tariff~~ except as provided for in ORS 757.300(4)(c). Neither Party will seek redress from the other Party in an amount greater than the amount of direct damage actually incurred.

5.3 Indemnity

5.3.1 This provision protects each Party from liability incurred to third parties as a result of carrying out the provisions of the Agreement. Liability under this provision is exempt from the general limitations on liability found in Article 5.2.

5.3.2 Each Party shall, to the extent allowed by law, and subject to the limitations imposed by ORS 30.260 to ORS 30.300, if applicable, at all times indemnify, defend, and hold the other Party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demands, suits, recoveries, costs and expenses, court costs, attorney fees at trial and on appeal, and all other obligations by or to third parties (hereinafter "Harm"), arising out of or resulting from its negligent action or failure to meet its obligations under this Agreement. Such indemnity obligation shall be limited to the proportional extent the Harm is caused by the negligence of the indemnified Party.

5.3.3 If an indemnified person is entitled to indemnification under this Article as a result of a claim by a third party, and the indemnifying Party fails, after notice and reasonable opportunity to proceed under this Article, to assume the defense of such a claim, such indemnified person may at the expense of the indemnifying Party contest, settle or consent to the entry of any judgment with respect to, or pay in full, such claim.

5.3.4 If an indemnifying party is obligated to indemnify and hold any indemnified person harmless under this Article, the amount owing to the indemnified person shall be the amount of such indemnified person's actual loss, net of any insurance or other

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

recovery.

- 5.3.5 Promptly after receipt by an indemnified person of any claim or notice of the commencement of any action or administrative or legal proceeding or investigation as to which the indemnity provided for in this Article may apply, the indemnified person shall notify the indemnifying party of such fact. Any failure of or delay in such notification shall not affect a Party's indemnification obligation unless such failure or delay is materially prejudicial to the indemnifying party.
- 5.3.6 The indemnifying Party shall have the right to assume the defense thereof with counsel designated by such indemnifying Party and reasonably satisfactory to the indemnified person. If the defendants in any such action include one or more indemnified persons and the indemnifying Party and if the indemnified person reasonably concludes that there may be legal defenses available to it and/or other indemnified persons which are different from or additional to those available to the indemnifying Party, the indemnified person shall have the right to select separate counsel to assert such legal defenses and to otherwise participate in the defense of such action on its own behalf. In such instances, the indemnifying Party shall only be required to pay the fees and expenses of one additional attorney to represent an indemnified person or indemnified persons having such differing or additional legal defenses.
- 5.3.7 The indemnified person shall be entitled, at its expense, to participate in any such action, suit or proceeding, the defense of which has been assumed by the indemnifying Party. Notwithstanding the foregoing, the indemnifying Party (i) shall not be entitled to assume and control the defense of any such action, suit or proceedings if and to the extent that, in the opinion of the indemnified person and its counsel, such action, suit or proceeding involves the potential imposition of criminal liability on the indemnified person, or there exists a conflict or adversity of interest between the indemnified person and the indemnifying Party, in such event the indemnifying Party shall pay the reasonable expenses of the indemnified person, and (ii) shall not settle or consent to the entry of any judgment in any action, suit or proceeding without the consent of the indemnified person, which shall not be reasonably withheld, conditioned or delayed.

5.4 Consequential Damages

Neither Party shall be liable to the other Party, under any provision of the Agreement, for any losses, damages, costs or expenses for any special, indirect, incidental, consequential, or punitive damages, including but not limited to loss of profit or revenue, loss of the use of equipment, cost of capital, cost of temporary equipment or services, whether based in whole or in part in contract, in tort, including negligence, strict liability, or any other theory of liability; provided, however, that damages for which a Party may be liable to the other Party under another agreement will not be considered to be special, indirect, incidental, or consequential damages hereunder.

5.5 Force Majeure

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

- 5.5.1 As used in this Agreement, a Force Majeure Event shall mean “any act of God, labor disturbance, act of the public enemy, war, acts of terrorism, insurrection, riot, fire, storm or flood, explosion, breakage or accident to machinery or equipment through no direct, indirect, or contributory act of a Party, any order, regulation or restriction imposed by governmental, military or lawfully established civilian authorities, or any other cause beyond a Party’s control. A Force Majeure Event does not include an act of negligence or intentional wrongdoing.”
- 5.5.2 If a Force Majeure Event prevents a Party from fulfilling any obligations under this Agreement, the Party affected by the Force Majeure Event (Affected Party) shall promptly notify the other Party of the existence of the Force Majeure Event. The notification must specify in reasonable detail the circumstances of the Force Majeure Event, its expected duration, and the steps that the Affected Party is taking to mitigate the effects of the event on its performance, and if the initial notification was verbal, it should be promptly followed up with a written notification. The Affected Party shall keep the other Party informed on a continuing basis of developments relating to the Force Majeure Event until the event ends the Affected Party will be entitled to suspend or modify its performance of obligations under this Agreement (other than the obligation to make payments) only to the extent that the effect of the Force Majeure Event cannot be reasonably mitigated. The Affected Party will use reasonable efforts to resume its performance as soon as possible. The Parties shall immediately report to the Commission should a Force Majeure Event prevent performance of an action required by [Rule Tariff](#) that the [Rule Tariff](#) does not permit the Parties to mutually waive.

5.6 Default

- 5.6.1 No default shall exist where such failure to discharge an obligation (other than the payment of money) is the result of a Force Majeure Event as defined in this Agreement, or the result of an act or omission of the other Party. Upon a default, the non-defaulting Party shall give written notice of such default to the defaulting Party. Except as provided in Article 5.6.2, the defaulting Party shall have sixty (60) calendar days from receipt of the default notice within which to cure such default; provided however, if such default is not capable of cure within sixty (60) calendar days, the defaulting Party shall commence such cure within twenty (20) calendar days after notice and continuously and diligently complete such cure within six (6) months from receipt of the default notice; and, if cured within such time, the default specified in such notice shall cease to exist.
- 5.6.2 If a default is not cured as provided for in this Article, or if a default is not capable of being cured within the period provided for herein, the non-defaulting Party shall have the right to terminate the Agreement by written notice at any time until cure occurs, and be relieved of any further obligation hereunder and, whether or not that Party terminates the Agreement, to recover from the defaulting Party all amounts due hereunder, plus all other damages and remedies to which it is entitled at law or in equity. Alternately, the non-defaulting Party shall have the right to seek dispute

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

resolution pursuant to Article 7 with the Commission in lieu of default. The provisions of this Article will survive termination of the Agreement.

Article 6. Insurance

A Party is liable for any loss, cost claim, injury, or expense including reasonable attorney's fees related to or arising from any act or omission in its performance of the provisions of this [Rule Tariff](#) or the Interconnection Agreement entered into pursuant to this [Rule Tariff](#).

- 6.1 Pursuant to the [Rule Tariff](#) adopted by the Commission, PGE may not require the Applicant to maintain general liability insurance in relation to the interconnection of a [Small Generator Facility Community Solar Facility](#) with an Electric Nameplate Capacity of 200 kW or less. With regard to the interconnection of a [Small Generator Facility Community Solar Facility](#) with an Electric Nameplate Capacity equal to or less than ~~103~~ MW but in excess of 200 kW, the Applicant shall, at its own expense, maintain in force throughout the period of this Agreement general liability insurance sufficient to protect any person (including PGE) who may be affected by the Applicant's [Small Generator Facility Community Solar Facility](#) and its operation and such insurance shall be sufficient to satisfy the Applicant's indemnification responsibilities under Article 5.3 of this Agreement.
- 6.2 Within ten (10) business days following execution of this Agreement, and as soon as practicable after the end of each fiscal year or at the renewal of the insurance policy and in any event within ninety (90) calendar days there after, the Applicant shall provide PGE with certification of all insurance required in this Agreement, executed by each insurer or by an authorized representative of each insurer.
- 6.3 All insurance required by this Article 6 shall name PGE, its parent, associated and Affiliate companies and their respective directors, officers, agents, servants and employees ("Other Party Group") as additional insured. All policies shall contain provisions whereby the insurers waive all rights of subrogation against the Other Party Group and provide thirty (30) calendar days advance written notice to the Other Party Group prior to anniversary date of cancellation or any material change in coverage or condition. The Applicant's insurance shall contain provisions that specify that the policies are primary and shall apply to such extent without consideration for other policies separately carried and shall state that each insured is provided coverage as though a separate policy had been issued to each, except the insurer's liability shall not be increased beyond the amount for which the insurer would have been liable had only one insured been covered. The insurance policies, if written on a Claims First Made Basis, shall be maintained in full force and effect for two (2) years after termination of this Agreement, which coverage may be in the form of tail coverage or extended reporting period coverage if agreed by the Parties.
- 6.4 The Parties agree to report to each other in writing as soon as practical all accidents or occurrences resulting in injuries to any person, including death, and any property damage arising out of this Agreement.

- 6.5 The requirements contained herein as to insurance are not intended to and shall not in any

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

manner limit or qualify the liabilities and obligations assumed by the Parties under this Agreement.

Article 7. Dispute Resolution

Parties will adhere to the dispute resolution provisions in ~~OAR 860-082-0080~~ [the Tariff](#).

Article 8. Miscellaneous

8.1 Governing Law, Regulatory Authority, and ~~Rule~~Tariffs

The validity, interpretation and enforcement of the Agreement and each of its provisions shall be governed by the laws of the State of Oregon, without regard to its conflicts of law principles. The Agreement is subject to all applicable laws. Each Party expressly reserves the right to seek changes in, appeal, or otherwise contest any laws, orders, or regulations of a governmental authority.

8.2 Amendment

The Parties may mutually agree to amend the Agreement by a written instrument duly executed by both Parties in accordance with provisions of the ~~Rule~~Tariff and applicable Commission Orders and provisions of the laws if the State of Oregon.

8.3 No Third-Party Beneficiaries

The Agreement is not intended to and does not create rights, remedies, or benefits of any character whatsoever in favor of any persons, corporations, associations, or entities other than the Parties, and the obligations herein assumed are solely for the use and benefit of the Parties, their successors in interest and where permitted, their assigns.

8.4 Waiver

8.4.1 The failure of a Party to the Agreement to insist, on any occasion, upon strict performance of any provision of the Agreement will not be considered a waiver of any obligation, right, or duty of, or imposed upon, such Party.

8.4.2 The Parties may agree to mutually waive a section of this Agreement so long as prior Commission approval of the waiver is not required by the ~~Rule~~Tariff.

8.4.3 Any waiver at any time by either Party of its rights with respect to the Agreement shall not be deemed a continuing waiver or a waiver with respect to any other failure to comply with any other obligation, right, or duty of the Agreement. Any waiver of the Agreement shall, if requested, be provided in writing.

8.5 Entire Agreement

The Interconnection Agreement, including any supplementary Form attachments that may be necessary, constitutes the entire Agreement between the Parties with reference to the subject matter hereof and supersedes all prior and contemporaneous understandings or agreements, oral or written, between the Parties with respect to the subject matter of the Agreement. There are no other agreements, representations, warranties, or covenants that constitute any part of the consideration for, or any condition to, either Party's compliance

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

with its obligations under the Agreement.

8.6 Multiple Counterparts

The Agreement may be executed in two or more counterparts, each of which is deemed an original but all constitute one and the same instrument.

8.7 No Partnership

The Agreement will not be interpreted or construed to create an association, joint venture, agency relationship, or partnership between the Parties or to impose any partnership obligation or partnership liability upon either Party. Neither Party shall have any right, power or authority to enter into any agreement or undertaking for, or act on behalf of, or to act as or be an agent or representative of, or to otherwise bind, the other Party.

8.8 Severability

If any provision or portion of the Agreement shall for any reason be held or adjudged to be invalid or illegal or unenforceable by any court of competent jurisdiction or other governmental authority; (1) such portion or provision shall be deemed separate and independent; (2) the Parties shall negotiate in good faith to restore insofar as practicable the benefits to each Party that were affected by such ruling; and (3) the remainder of the Agreement shall remain in full force and effect.

8.9 Subcontractors

Nothing in the Agreement shall prevent a Party from utilizing the services of any subcontractor, or designating a third party agent as one responsible for a specific obligation or act required in the Agreement (collectively subcontractors), as it deems appropriate to perform its obligations under the Agreement; provided, however, that each Party will require its subcontractors to comply with all applicable terms and conditions of the Agreement in providing such services and each Party will remain primarily liable to the other Party for the performance of such subcontractor.

8.9.1 The creation of any subcontract relationship shall not relieve the hiring Party of any of its obligations under the Agreement. The hiring Party shall be fully responsible to the other Party for the acts or omissions of any subcontractor the hiring Party hires as if no subcontract had been made. Any applicable obligation imposed by the Agreement upon the hiring Party shall be equally binding upon, and will be construed as having application to, any subcontractor of such Party.

8.9.2 The obligations under this Article will not be limited in any way by any limitation of subcontractor's insurance.

8.10 Reservation of Rights

Either Party will have the right to make a unilateral filing with the Commission to modify the Interconnection Agreement. This reservation of rights provision will include but is not limited to modifications with respect to any rates terms and conditions, charges, classification of service, rule or regulation under tariff rates or any applicable State or Federal law or regulation. Each Party shall have the right to protest any such filing and to participate fully in any proceeding before the Commission in which such modifications

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

may be considered.

Article 9. Notices and Records

9.1 General

Unless otherwise provided in the Agreement, any written notice, demand, or request required or authorized in connection with the Agreement shall be deemed properly given if delivered in person, delivered by recognized national courier service, or sent by first class mail, postage prepaid, to the person specified below:

If to the Applicant:

Applicant: _____
Attention: _____
Address: _____
City: _____ State: _____ Zip: _____
Phone: _____
Fax: _____
E-mail: _____

If to PGE:

Attention: _____
Address: _____
City: _____
Phone: _____
Fax: _____
E-mail: _____

9.2 Records

PGE will maintain a record of all Interconnection Agreements and related Form attachments for as long as the interconnection is in place as required by ~~OAR 860-082-065~~ [the Tariff](#). PGE will provide a copy of these records to the Applicant within fifteen (15) business days if a request is made in writing.

9.3 Billing and Payment

Billings and payments shall be sent to the addresses set out below:

If to the Applicant (complete if different than Article 9.1):

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Applicant: _____
Attention: _____
Address: _____
City: _____ State: _____ Zip: _____
Phone: _____
Fax: _____
E-mail: _____

If to PGE (complete if different than Article 9.1):

Attention: _____
Address: _____
City: _____ State: _____ Zip: _____

9.4 Designated Operating Representative

The Parties will designate operating representatives to conduct the communications which may be necessary or convenient for the administration of the operations provisions of the Agreement. This person will also serve as the point of contact with respect to operations and maintenance of the Party's facilities:

Applicant's Operating Representative (complete if different than Article 9.1):

Applicant: _____
Attention: _____
Address: _____
City: _____ State: _____ Zip: _____
Phone: _____
Fax: _____
E-mail: _____

PGE's Operating Representative (complete if different than Article 9.1):

Attention: _____
Address: _____
City: _____

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Phone: _____
Fax: _____
E-mail: _____

9.5 Changes to the Notice Information

Either Party may change this notice information by giving five (5) business days written notice prior to the effective date of the change.

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Article 10. Signatures

IN WITNESS WHEREOF, the Parties have caused the Agreement to be executed by their respective duly authorized representatives.

For the Applicant:

Signature: _____

Printed Name: _____

Title (*if applicable*): _____

Date: _____

For PGE:

Signature: _____

Printed Name: _____

Title: _____

Date: _____

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Attachment A

**Description and Costs of Minor Modifications, Interconnection Facilities,
System Upgrades, and Adverse System Impacts**

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Attachment B
Description of Interconnection Facilities
and Metering Equipment Operated or Maintained by PGE

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Attachment C
One-Line Diagram

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Attachment D

Scope of Work/Milestones

In-Service Date: _____

Critical milestones and responsibility as agreed to by the Parties:

	Milestone/Date	Responsible Party
(1)	_____	_____
(2)	_____	_____
(3)	_____	_____
(4)	_____	_____
(5)	_____	_____
(6)	_____	_____
(7)	_____	_____
(8)	_____	_____
(9)	_____	_____
(10)	_____	_____

Form 8
1-19-10 rev.

Formatted: Tab stops: 7.1", Right

Attachment E
Additional Operating Requirements

SCHEDULE 204 (Continued)

SP Interconnection Process (Continued)

4. Low-side Metering. An applicant may request Low-side Metering for a CSP Project 360 kW and smaller.
5. Joint Study. If an applicant for CSP Interconnection has multiple CSP Projects eligible for interconnection, it can request that the Company study the CSP Projects jointly if the CSP Interconnection Applications are submitted in back to back queue order. Such projects shall equally share in the costs for CSP interconnection study purposes in accordance with the process described in the Interconnection Procedures for CSP Projects, attached as Exhibit A to this Schedule.

C. CSP Interconnection Exhibits

1. The Interconnection Procedures for CSP Projects are set forth in Exhibit A to this Schedule.
2. The System Impact Study Agreement for CSP Projects is set forth in Exhibit B to this Schedule.
3. The Facilities Study Agreement for CSP Projects is set forth in Exhibit C to this Schedule.
4. The CSP Project Completion Form is set forth in Exhibit D to this Schedule.
5. The CSP Project Interconnection Agreement is set forth in Exhibit E to this Schedule.

PART 2: CSP PURCHASE AGREEMENT

A. Applicable

To CSP Projects that:

1. Are located within the Company's Service Territory;
2. Are certified or exempt from certification as a Qualifying Facility;
3. Are pre-certified or Certified as a CSP Project by the Commission under Oregon Administrative Rule (OAR) 860-088-0050; and
4. Except for CSP Projects that have otherwise received consent from the Company, or as otherwise legally required by the Commission, have not already sold, leased assigned, contracted for (including pursuant to the execution of a power purchase agreement under PURPA) or otherwise disposed of the Net Output of the CSP Project, except for the sale of subscriptions for Subscribed Energy to Participants consistent with the CSP.

SCHEDULE 204 (Concluded)

C. CSP Administration

1. Energy Delivery: Once a Certified Project has commenced commercial operation, not later than the second day of each month, the Company shall report to the Program Administrator the amount of Net Output received from the Certified Project at the Point of Delivery for the preceding month.
2. Compensation: As provided in the Program Implementation Manual and the CSP Purchase Agreement, the Company shall provide compensation monthly for each kWh of Net Output accepted at the Point of Delivery as follows:
 - a. Subscribed Energy: For all Subscribed Energy delivered by the CSP Project to the Company at the Point of Delivery, the Company will apply a bill credit to each Participant's utility bill in accordance with the process and calculations set forth in ORS 757.386(6), OAR 860-088-0170, the Program Implementation Manual, and the CSP Purchase Agreement.
 - b. Unsubscribed Energy: The Company will pay the Program Administrator on a monthly basis for each kWh of Unsubscribed Energy in the manner described in OAR 860-088-0140, the Program Implementation Manual, and the CSP Purchase Agreement.
3. Program Fees: The Company will apply Program Fees to each Participant's monthly utility bill in the manner described in ORS 757.386, OAR 860-088-0120, the Program Implementation Manual, and PGE's CSP Operational Tariff.
4. Term: The Term of the CSP Purchase Agreement is up to twenty (20) years from the Facility's Commercial Operation Date, in accordance with ORS 757.386(2)(a)(D) and OAR 860-088-0140(1)(a).

D. CSP Purchase Agreement

The form of the CSP Purchase Agreement is provided as Exhibit F of this Schedule.