BEFORE THE PUBLIC UTILITY COMMISSION OF OREGON

UM 1860

Served electronically at Salem, Oregon, 8/7/17, to:

Respondent's Attorney
V. Denise Saunders
Portland General Electric Company
121 SW Salmon Street
Portland, Oregon 97204
denise.saunders@pgn.com

Complainant's Attorneys & Representative
Irion A. Sanger
Sidney Villanueva
Sanger Law, PC
1117 SE 53rd Avenue
Portland, Oregon 97215
irion@sanger-law.com
sidney@sanger-law.com

Troy Snyder Red Prairie Solar, LLC TLS Capital 3519 NE 15th Avenue, Suite 325 Portland, Oregon 97212

Re: UM 1860, Complainant RED PRAIRIE SOLAR, LLC vs. PORTLAND GENERAL ELECTIRC COMPANY, Respondent

Red Prairie Solar, LLC has filed a complaint against Portland General Electric. A copy of the complaint is attached and served on Respondent, under ORS 756.512(1). The Commission has assigned Docket No. UM 1860 to this complaint. Please use this number whenever you refer to this case.

The Public Utility Commission must receive an Answer from the Respondent or their attorney by August 28, 2017, under OAR 860-001-0400(4)(a). A copy must be served on the complainant.

After the filing of the answer, the matter will be set for hearing and you will be notified of the time and place.

PUBLIC UTILITY COMMISSION OF OREGON

Cheryl Walker

Administrative Specialist 2

Administrative Hearings Division

(503) 378-2849

c: Barbara Parr, barbara.parr@pgn.com

Attachments: Complaint

Notice of Contested Case Rights and Procedures

NOTICE OF CONTESTED CASE RIGHTS AND PROCEDURES

Oregon law requires state agencies to provide parties written notice of contested case rights and procedures. Under ORS 183.413, you are entitled to be informed of the following:

Hearing: The time and place of any hearing held in these proceedings will be noticed separately. The Commission will hold the hearing under its general authority set forth in ORS 756.040 and use procedures set forth in ORS 756.518 through 756.610 and OAR Chapter 860, Division 001. Copies of these statutes and rules may be accessed via the Commission's website at www.puc.state.or.us. The Commission will hear issues as identified by the parties.

Right to Attorney: As a party to these proceedings, you may be represented by counsel. Should you desire counsel but cannot afford one, legal aid may be able to assist you; parties are ordinarily represented by counsel. The Commission Staff, if participating as a party in the case, will be represented by the Department of Justice. Generally, once a hearing has begun, you will not be allowed to postpone the hearing to obtain counsel.

Administrative Law Judge: The Commission has delegated the authority to preside over hearings to Administrative Law Judges (ALJs). The scope of an ALJ's authority is defined in OAR 860-001-0090. The ALJs make evidentiary and other procedural rulings, analyze the contested issues, and present legal and policy recommendations to the Commission.

Hearing Rights: You have the right to respond to all issues identified and present evidence and witnesses on those issues. *See* OAR 860-001-0450 through OAR 860-001-0490. You may obtain discovery from other parties through depositions, subpoenas, and data requests. *See* ORS 756.538 and 756.543; OAR 860-001-0500 through 860-001-0540.

Evidence: Evidence is generally admissible if it is of a type relied upon by reasonable persons in the conduct of their serious affairs. *See* OAR 860-001-0450. Objections to the admissibility of evidence must be made at the time the evidence is offered. Objections are generally made on grounds that the evidence is unreliable, irrelevant, repetitious, or because its probative value is outweighed by the danger of unfair prejudice, confusion of the issues, or undue delay. The order of presenting evidence is determined by the ALJ. The burden of presenting evidence to support an allegation rests with the person raising the allegation. Generally, once a hearing is completed, the ALJ will not allow the introduction of additional evidence without good cause.

Record: The hearing will be recorded, either by a court reporter or by audio digital recording, to preserve the testimony and other evidence presented. Parties may contact the court reporter about ordering a transcript or request, if available, a copy of the audio recording from the Commission for a fee set forth in OAR 860-001-0060. The hearing record will be made part of the evidentiary record that serves as the basis for the Commission's decision and, if necessary, the record on any judicial appeal.

Final Order and Appeal: After the hearing, the ALJ will prepare a draft order resolving all issues and present it to the Commission. The draft order is not open to party comment. The Commission will make the final decision in the case and may adopt, modify, or reject the ALJ's recommendation. If you disagree with the Commission's decision, you may request reconsideration of the final order within 60 days from the date of service of the order. *See* ORS 756.561 and OAR 860-001-0720. You may also file a petition for review with the Court of Appeals within 60 days from the date of service of the order. *See* ORS 756.610.

Irion A. Sanger OSB No. 003750 Sanger Law, PC 1117 SE 53rd Ave. Portland, Oregon 97215 503-756-7533 (tel.) 503-334-2235 (fax) irion@sanger-law.com

BEFORE THE PUBLIC UTILITY COMMISSION OF OREGON

Red Prairie Solar, LLC, Complainant,)	DOCKET NO
v.)	COMPLAINT
Portland General Electric Company, Defendant.)	
))	

I. INTRODUCTION

- This is a complaint ("Complaint") filed by Red Prairie Solar, LLC ("Red Prairie
- 3 Solar" or "Complainant") with the Oregon Public Utility Commission (the "Commission"
- 4 or "OPUC") under Oregon Revised Statute ("ORS") 756.500 and Oregon Administrative
- 5 Rule ("OAR") 860-001-0170. Portland General Electric Company ("PGE" or the
- 6 "Company") has not agreed to purchase the net output from Red Prairie Solar's solar
- 7 qualifying facility ("QF") ("Red Prairie Solar Project") as a mandatory purchase under
- 8 the Public Utility Regulatory Policies Act of 1978 ("PURPA"). PGE has failed to
- 9 comply with its own rate Schedule 201, the Commission's rules and policies, the Federal
- 10 Energy Regulatory Commission's ("FERC") rules and policies, and the Oregon and

1 federal PURPA statutes. PGE has refused to finalize or execute a power purchase

2 agreement ("PPA") with Red Prairie Solar.

Red Prairie Solar has formed a legally enforceable obligation because it has been ready, willing, and able to sign a PPA with PGE since at least July 27, 2017, and has repeatedly and unequivocally committed itself to sell the net output to PGE at the Schedule 201 avoided cost rates and standard PPA terms and conditions that are currently in effect. This includes Red Prairie Solar obligating itself to provide power or be subject to penalty pursuant to the standard PPA terms and conditions for failing to deliver energy on the scheduled commercial on-line date. PGE should be required to execute a PPA with Red Prairie Solar because the establishment of a legally enforceable obligation turns on Red Prairie Solar's commitment, and not PGE's actions.

Red Prairie Solar has formed a legally enforceable obligation despite PGE's failure to execute a PPA because PGE has violated PURPA, the Commission's and FERC's rules and policies, and its own Schedule 201. PGE's actions that have sought to prevent Red Prairie Solar from forming a legally enforceable obligation include, but are not limited to: 1) delaying the PPA negotiation process; 2) seeking interim relief to prevent Red Prairie Solar from being able to execute a PPA; 3) refusing to inform Red Prairie Solar that it was going to make or had made its Solar Limitation Filing; 4)

Specifically, PGE has proposed to lower the size threshold for standard contract prices to 2 to 3 megawatts ("MW") and impose a permanent lifetime cap on any owner that prevents them from even requesting more than 10 MW of standard contract QF projects ("Solar Limitation Filing"). PGE has sought interim relief to make the Solar Limitation Filing retroactive to June 30, 2017. If granted, then these restrictions could apply to Red Prairie Solar because it is more than 2 MW and its owner has requested more than 10 MW of QF projects.

PGE's purpose in not informing Red Prairie Solar was to ensure that Red Prairie Solar would not complete and execute a PPA prior to June 30, 2017. PGE

- seeking an early rate effective date for its post Integrated Resource Plan avoided cost rate
- 2 update;³ 5) failing to inform Red Prairie Solar seeking an early rate effective date for its
- 3 post Integrated Resource Plan avoided cost rate update; 6) stating that it was not willing
- 4 to provide Red Prairie Solar with an executable PPA or otherwise execute a PPA; 7)
- 5 refusing to provide an executable PPA or otherwise execute a PPA that should have been
- 6 provided; 4 and 8) claiming that it no longer needs to comply with the law since it has
- 7 sought interim relief seeking to change the Commission's PURPA policies. PGE is
- 8 required to comply with Commission orders and policies, and cannot unilaterally refuse
- 9 to comply with the law or prevent Red Prairie Solar from forming a legally enforceable
- obligation simply because it has sought, but not yet obtained, equitable relief seeking to
- retroactively lower the solar size threshold and imposing a permanent lifetime cap on any
- one owner requesting standard contract and rate PPAs.

decided sometime in early 2017 that it would attempt to delay the PPA negotiation process past June 30, 2017, and that it would refuse to provide an executable PPA, if it was able to delay negotiations past June 30, 2017. But for PGE keeping its plans a secret, Red Prairie Solar's PPA would have been more expeditiously processed and it could have been fully executed.

- On August 4, 2017, PGE announced in its 2016 IRP that PGE will ask the Commission to change its current avoided cost rate process (which re-sets avoided cost rates only after approval of a new rate filing that is made 30 days after the IRP acknowledgment) to instead ensure that the avoided cost prices paid to QFs that enter into contracts or achieve a legally enforceable obligation after the Commission's acknowledgement will no longer to be eligible for the current rates ("August Early Rate Effective Date Request").
- Red Prairie Solar has been working on obtaining a PPA for over three months, and has requested a final and executable PPA. Under FERC's policies and rules, a legally enforceable obligation can be effectuated in less than one month. Under the Commission's policies and Schedule 201, an executable contract can generally be provided in less than two months from initial request. In addition, Red Prairie Solar would have requested and obtained an executable PPA earlier, if PGE had provided advance notice of the May 1, 2017 avoided cost rate update, or its Solar Limitation Filing.

1	The Commission cannot revise its own rules or policies to lower the size
2	threshold, impose an ownership cap, or make other changes in a manner that effectively
3	prevents Red Prairie Solar from committing itself to sell the net output of its project or
4	otherwise creating a legally enforceable obligation. Red Prairie Solar has relied upon the
5	Commission maintaining a settled and uniform institutional climate for QFs, and
6	upholding its policies regarding eligibility for standard avoided cost rates and contracts,
7	including ensuring that Red Prairie Solar is able to enter contracts or create legally
8	enforceable obligations based on the policies and rules in effect at the time that the QF
9	makes its request for a PPA.
10	Given PGE's refusal to execute a PPA and attempt to change Commission
11	policies to prevent Red Prairie Solar from executing a PPA, Red Prairie Solar respectfully
12	requests that the Commission confirm: 1) that Red Prairie Solar has a legally enforceable
13	obligation with PGE based on its commitment to sell its net output under the partially
14	executed PPA, which is the same as the Commission's approved contract and rates and
15	the last draft PPA provided by PGE; and 2) require PGE to enter into a PPA with Red
16	Prairie Solar with the rates, terms, and conditions under Schedule 201 and the standard
17	renewable PPA currently in effect.
18	II. SERVICE
19	Copies of all pleadings and correspondence should be served on Red Prairie
20	Solar's counsel and representatives at the addresses below:
21 22 23 24 25 26	Irion Sanger Sanger Law, PC Red Prairie Solar, LLC TLS Capital Portland, Oregon 97215 irion@sanger-law.com Troy Snyder Red Prairie Solar, LLC TLS Capital 3519 NE 15 th Ave, Suite 325 Portland, Oregon 97212 troy@tlscapital.com

1 2	Sidney Villanueva Sanger Law, PC
3	1117 SE 53rd Ave.
4	Portland, Oregon 97215
5	sidney@sanger-law.com
6 7	
8	In support of this Complaint, Red Prairie Solar alleges as follows:
9	III. IDENTITY OF THE PARTIES
10	1. PGE is an investor-owned public utility regulated by the Commission
11	under ORS Chapter 757. PGE is headquartered at 121 Southwest Salmon Street,
12	Portland, Oregon 97204.
13	2. Red Prairie Solar, a limited liability company organized under the laws of
14	Oregon, is the owner of the Red Prairie Solar Project and will be the seller of the net
15	output of the Red Prairie Solar Project. Red Prairie Solar's mailing address is Red Prairie
16	Solar, c/o TLS Capital, Inc., 3519 NE 15th Ave., #325, Portland, Oregon 97212.
17	IV. APPLICABLE STATUTES AND RULES
18	3. The Oregon statutes expected to be involved in this case include:
19	ORS 756.040-756.068, 756.500-756.558, 756.990, and 758.505-758.575. The Oregon
20	rules expected to be involved in this case include: OAR 860-001, and 860-029.
21	4. The federal statute expected to be involved in this case is PURPA, 16
22	United States Code ("USC") 824a-3. The federal rules expected to be involved in this
23	case include: 18 Code of Federal Regulations ("CFR") 292.101-292.602.
24	V. JURISDICTION
25	5. FERC has adopted regulations and policies governing utility purchases
26	from QFs under PURPA. 18 CFR 292.101-292.602. State regulatory agencies are
27	required to implement FERC's regulations. See 16 USC 824a-3(f); FERC v. Mississippi,

- 1 456 U.S. 742, 751, 102 S. Ct. 2126 (1982). FERC's rules provide each QF with the right
- 2 to unilaterally create a legally enforceable obligation to sell its energy and capacity at
- 3 projected avoided cost rates in effect on the date that the QF obligates itself to sell energy
- 4 and capacity. 18 CFR 292.304(d)(2)(ii); FLS Energy Inc., 157 FERC ¶ 61,211 at PP 23-
- 5 25 (2016).
- 6. Oregon law also includes a requirement that a QF has the right to legally
- 7 obligate itself to sell its net output prior to the delivery of its net output. Specifically,
- 8 ORS 758.525(2)(b) provides: "At the option of the qualifying facility, exercised before
- 9 beginning delivery of the energy or energy and capacity, such prices may be based on . . .
- 10 [t]he projected avoided costs calculated at the time the legal obligation to purchase the
- energy or energy and capacity is incurred." Thus, the "obligation to purchase power is
- imposed by law on a utility; it is not voluntarily assumed." Snow Mountain Pine Co. v.
- 13 Maudlin, 84 Or. App. 590, 598, 734 P.2d 1366 (1987).
- The Commission is the Oregon state agency that implements the state and
- 15 federal PURPA statutes. ORS 758.505(3); OAR 860-029-0001; Snow Mountain, 84 Or.
- App. at 593. Public utilities are defined in ORS 758.505(7), and include PGE. Oregon
- law provides that the "terms and conditions for the purchase of energy or energy and
- capacity from a qualifying facility shall . . . [b]e established by rule by the commission if
- 19 the purchase is by a public utility." ORS 758.535(2)(a). The Commission has the power
- and jurisdiction to hear complaints by QFs against public utilities, including PGE. ORS
- 21 756.040, 756.500-756.558, and 758.505-758.555; OAR 860-001-0010(3), and 860-029-
- 22 0030.

23

VI. FACTUAL BACKGROUND

- 1 8. The Red Prairie Solar Project will be a 2.2 megawatt ("MW") nameplate
- 2 solar generation facility located in Yamhill County, Oregon.
- 3 9. The Red Prairie Solar Project will interconnect with PGE.
- 4 10. Red Prairie Solar is owned by TLS Capital.
- 5 11. TLS Capital has previously submitted and executed standard PPAs with
- 6 PGE, including the Willamina Mill Solar Project.
- 7 12. The Willamina Mill Solar Project will be 2.2 MW nameplate solar
- 8 generation facility located in Polk County, Oregon.
- 9 13. The Willamina Mill Solar Project will interconnect with PGE.
- 10 14. Red Prairie Solar understood that PGE would make its annual avoided
- 11 cost rate update filing on May 1, 2017, but expected PGE's avoided cost rates to change
- in the end of June 2017.
- 13 15. Red Prairie Solar is aware that PGE's integrated resource plan is
- scheduled for acknowledgement at the end of August 2017, and expects PGE's avoided
- 15 cost rates to be revised about two months later, or the end of October 2017.
- 16 Before May 1, 2017, PGE decided to prepare an application that would
- 17 update and lower its Schedule 201 prices and request Commission approval at the May
- 18 16, 2017 public meeting ("May 1 Update").
- 19 17. On May 1, 2017, PGE filed its May 1 Update.
- 20 18. PGE chose not to inform QFs that it was planning to file its May 1 Update
- and to seek an early effective date and approval at the May 16, 2017 public meeting.
- 22 19. On May 5, 2017, Red Prairie Solar initially contacted PGE and requested a
- 23 standard PPA.

- 1 20. PGE did not respond to Red Prairie Solar's initial contact.
- 2 21. On May 10, 2017, Red Prairie Solar again contacted PGE and requested a
- 3 standard PPA.
- 4 22. On June 2, 2017, Red Prairie Solar provided complete information to
- 5 obtain a standard PPA.
- 6 23. On June 16, 2016, TLS Capital inquired regarding its Willamina Mill
- 7 Solar facility and spoke with PGE regarding the maximum generation numbers. The
- 8 Willamina Mill Solar PPA was executed by PGE. TLS Capital inquired because PGE
- 9 offered no guidance regarding the maximum generation number, and informed PGE that
- it would use 150% of the year 1 generation. PGE accepted this in the Willamina Mill
- 11 Solar facility without an inquiry.
- On June 22, 2017, PGE did not provide Red Prairie Solar with a draft
- standard PPA, instead responded with a letter requesting clarifying information regarding
- 14 the maximum generation.
- 15 25. TLS Capital submitted substantially the same type of information
- regarding previous QFs' maximum generation, and PGE did not raise any other issues or
- ask for any additional clarifying information, with the one exception of inquiring about
- the maximum generation hourly profile.
- 19 26. PGE should have at least provided a draft PPA at this time because that
- 20 TLS Capital had submitted similar information using the exact same methodology and
- 21 obtained an executed PPA.

- 1 27. PGE should have provided a draft PPA because Red Prairie Solar had
- 2 provided all the required information under Schedule 201 and PGE's Initial Information
- 3 Request.
- 4 28. On June 28, 2017, Red Prairie Solar provided clarifying information
- 5 regarding the maximum generation profile.
- 6 29. On June 29, 2017, PGE responded that they received the additional
- 7 information and that by July 20, 2017 PGE will send either a draft standard PPA or a
- 8 request for any additional or clarifying information.
- 9 30. On or after May 1, 2017, PGE decided to prepare its Solar Limitation
- Filing. This filing would propose to lower the eligibility cap for a QF to obtain standard
- avoided cost prices from PGE from 10 MW to 3 MW, and declare that a solar QF project
- with a capacity above 100 kilowatts ("kW") is not eligible for a standard contract or
- standard prices from PGE if any owner of the solar QF project has requested or obtained
- standard prices from PGE for more than 10 MW of solar QF capacity; or in the
- alternative, lower to 2 MW the eligibility cap for a solar QF project to obtain prices from
- 16 PGE effective June 30, 2017.
- 17 31. PGE chose not to inform Red Prairie Solar that PGE intended to make the
- 18 Solar Limitation Filing.
- 19 32. PGE did not inform Red Prairie Solar and other QFs that PGE intended to
- 20 make the Solar Limitation Filing in order to ensure that Red Prairie Solar would not
- 21 execute a PPA before June 30, 2017.
- 22 33. Red Prairie Solar was materially prejudiced by PGE's failure to give
- 23 notice because, among other things, it prevented Red Prairie Solar from having the

- 1 opportunity to expedite its request and Red Prairie Solar would have processed its PPA
- 2 request more quickly if it had been aware that PGE intended to make the Solar Limitation
- 3 Filing.
- 4 34. On July 20, 2017, PGE did not send either a draft standard PPA or a
- 5 request for any additional or clarifying information.
- 6 35. On July 22, 2017, PGE sent a letter once again requesting additional or
- 7 clarifying information. The additional or clarifying information requested on July 22,
- 8 2017 was in relation to the year 1 generation profile, which was not inquired about or
- 9 asked to be clarified in PGE's first request for clarifying information on June 22, 2017.
- 10 36. On July 24, 2017, Red Prairie Solar responded to PGE requesting that
- PGE provide a draft Standard PPA immediately and that PGE reduce the time for PGE to
- provide the final draft PPA for each day of the delay. Red Prairie Solar pointed out that
- there was no need for additional information because "Everything that was provided as
- part of the IIR for Red Prairie Solar was the same material provided in previous IIRs for
- other PPAs which TLS Capital has requested and which PGE deemed complete and
- 16 ultimately executed."
- 17 37. PGE ignored Red Prairie Solar's July 24, 2017 email.
- 18 38. On July 26, 2017, Red Prairie Solar again inquired about the status of its
- draft PPA, and sent a follow up to email to confirm that the previous email was received
- and request that PGE immediately provide a draft Standard PPA.
- 21 39. On July 26, 2017, PGE finally responded stating that they are waiting on
- additional or clarifying information and that within 15 business days of receiving that
- 23 information, they would send either a draft Standard PPA or another request for

- additional or clarifying information. It is not clear if PGE would have ever responded to
- 2 Red Prairie Solar's inquires if Red Prairie Solar had not followed up.
- 3 40. On July 27, 2017, almost two months after submitting all the required
- 4 information, Red Prairie Solar requested that PGE provide a final and executable PPA,
- 5 and was ready, willing, and able to sign a PPA.
- Red Prairie may have committed and been ready, willing and able to
- 7 execute a PPA earlier, if PGE had not raised unreasonable objections and requests for
- 8 additional information.
- 9 42. On July 27, 2017, Red Prairie Solar explained why the year 1 hourly
- 10 generation profile should be acceptable to PGE.
- On July 28, 2017, PGE responded by not providing an executable or draft
- 12 PPA, but again concerns regarding information in the Initial Information Request dated
- June 28, 2017. PGE stated that it was struggling to understand Red Prairie Solar's
- 14 "Maximum Annual Net Output value in comparison to the Average Annual Net Output
- value. This was a new issue that PGE had not previously raised.
- On July 28, 2017, PGE did not clarify whether its separate concern
- 17 regarding the year 1 hourly generation profile is now acceptable to PGE.
- 18 45. On July 31, 2017, Red Prairie Solar noted that TLS Capital noted that it
- 19 previously submitted similar information was deemed acceptable to PGE, and provided
- 20 the example of the maximum generation numbers for the Willamina Mill Solar Facility
- 21 that PGE accepted without an inquiry.
- 22 46. On July 31, 2017, Red Prairie Solar stated that the only difference between
- 23 the Red Prairie Solar Facility and Willamina Mill Solar Facility is that PGE has requested

- to change the Commission's policies regarding standard price and contract provisions on
- 2 June 30, 2017.
- 3 47. On July 31, 2017, Red Prairie Solar stated that PGE is raising
- 4 unreasonable and discriminatory questions and issues in an effort to delay the PPA
- 5 negotiation process so that it does not execute a PPA prior to a Commission order
- 6 potentially changing its policies.
- 7 48. On July 31, 2017, Red Prairie Solar requested an executable PPA from
- 8 PGE prior to the Commission issuing any orders in its Solar Limitation Filing. Red
- 9 Prairie Solar made it clear that it was again obligating itself to provide power or be
- subject to penalty pursuant to the standard PPA terms and conditions for failing to deliver
- energy on the scheduled commercial on-line date.
- 12 49. On August 1, 2017, PGE informed Red Prairie Solar that it did not agree
- with all of Red Prairie Solar's characterizations, that is still seeks information that
- validates the Maximum Annual Net Output value, and that PGE does not expect that both
- parties will be in full agreement as to all terms and conditions until Red Prairie Solar
- provides additional information that allows PGE to understand the value proposed by Red
- 17 Prairie Solar.
- 18 50. On August 1, 2017, PGE provided Red Prairie Solar a draft PPA.
- On August 4, 2017, PGE announced in its 2016 IRP that PGE will ask the
- 20 Commission to change its current avoided cost rate process (which re-sets avoided cost
- 21 rates only after approval of a new rate filing that is made 30 days after the IRP
- acknowledgment) to instead ensure that the avoided cost prices paid to QFs that enter into

- 1 contracts or achieve a legally enforceable obligation after the Commission's
- 2 acknowledgement will no longer to be eligible for the current rates.
- 3 52. On August 4, 2017, PGE confirmed that the usual Commission process is
- 4 PGE must file to update avoided cost prices within 30 days of the Commission's IRP
- 5 acknowledgement, and once PGE files, there is a 90-day review period before prices
- 6 become effective.
- 7 53. On August 4, 2017, PGE explained that only QFs that enter into a contract
- 8 or achieve a legally enforceable obligation prior to acknowledgement of the IRP will be
- 9 eligible for current avoided cost rates.
- 10 54. PGE chose not to inform Red Prairie Solar that PGE intended to make the
- 11 August Early Rate Effective Date Request.
- 12 55. PGE did not inform Red Prairie Solar that PGE intended to make the
- August Early Rate Effective Date Request in order to ensure that Red Prairie Solar would
- 14 not timely execute a PPA.
- 15 S6. Red Prairie Solar was materially prejudiced by PGE's failure to give
- 16 notice because, among other things, it prevented Red Prairie Solar from having the
- opportunity to expedite its request and Red Prairie Solar would have processed its PPA
- request more quickly if it had been aware that PGE intended to make the August Early
- 19 Rate Effective Date Request.
- 20 57. PGE's intent and purpose for requesting that QFs that have not entered
- 21 into a contract or achieve a legally enforceable obligation prior to acknowledgment of the
- 22 IRP not being eligible for current avoided cost rates is to prevent Red Prairie Solar and
- other QFs from being able to complete and execute a PPA at current rates.

1 58 On August 7, 2017, Red Prairie Solar executed the standard draft PPA. 2 59. On August 7, 2017, Red Prairie Solar informed PGE that it was again 3 committing itself to sell power to PGE under the currently effective Schedule 201 rates, 4 and the terms and conditions of the partially executed PPA, and obligating itself to 5 provide power or be subject to penalty for failing to deliver energy on the scheduled 6 commercial on-line date. 7 VII. LEGAL CLAIMS 8 Complainant's First Claim for Relief 9 Red Prairie Solar is entitled to PGE's standard contract with currently effective Schedule 201 rates because Red Prairie Solar legally obligated itself to sell the net 10 output prior to the filing of this Complaint 11 12 13 60. Red Prairie Solar re-alleges all the preceding paragraphs. 14 61 PGE has an obligation to purchase a QF's net output that is directly or indirectly made available to PGE. 18 CFR 292.303(a)&(d), 292.304(d); ORS 15 16 758.525(2)(b), 758.535(2)(a)&3(b); OAR 860-029-0030(1). 17 62. PGE has an obligation to purchase the net output of a QF pursuant to 18 either a contract or a legally enforceable obligation. 18 CFR 292.304(d); Order No. 69, 19 FERC Stats. & Regs. ¶ 30,128, 45 Fed. Reg. 12,214 at 12,219-20, 12,224 (1980). A 20 legally enforceable obligation is broader than a simple contract between an electric utility 21 and a QF, and may exist without a written, executed contract. FLS Energy, 157 FERC ¶ 22 61,211 at PP 24, 26; Grouse Creek, LLC, 142 FERC ¶ 61,187 at P 38 (2013). 23 63. The establishment of a legally enforceable obligation turns on the QF's 24 commitment to sell its net output to the electric utility. FLS Energy, 157 FERC ¶ 61,211 at P 24; JD Wind 1, LLC, 129 FERC ¶ 61,148, at P 25 (2009). A QF can enter into a 25

- legally enforceable obligation by committing itself to sell power to an electric utility.
- 2 <u>FLS Energy</u>, 157 FERC ¶ 61,211 at P 25; <u>Cedar Creek Wind</u>, <u>LLC</u>, 137 FERC ¶ 61,006
- 3 at PP 36, 39 (2011); Snow Mountain, 734 P.2d at 1371.
- 4 64. A QF can require a utility to purchase its net output, even if the utility has
- 5 refused to enter into a contract. <u>Id.</u> at 1370-71; <u>FLS Energy</u>, 157 FERC ¶ 61,211 at P 24;
- 6 Murphy Flat Power, 141 FERC ¶ 61,145 at P 24 (2012); Grouse Creek, 142 FERC ¶
- 7 61,187 at P 38. A utility cannot refuse to sign a contract "so that a later and lower
- 8 avoided cost is applicable." <u>FLS Energy</u>, 157 FERC ¶ 61,211 at P 25; <u>Cedar Creek</u>
- 9 Wind, 137 FERC ¶ 61,006 at P 36. Similarly, a QF cannot be required to tender an
- 10 executed interconnection agreement to form a legally enforceable obligation because that
- requirement would allow "the utility to control whether and when a legally enforceable
- obligation exists." FLS Energy, 157 FERC ¶ 61,211 at PP 23, 26.
- 13 65. The Commission has confirmed the process for obtaining a PPA includes:
- 14 "(1) a QF initiates the process by submitting certain information, the utilities then have
- 15 days to provide a draft standard contract; (2) the QF may agree to the terms of the
- draft contract and ask the utility to provide a final executable contract, or suggest
- changes; (3) the utility provides iterations of the draft standard contract no later than 15
- days after each round of comments by the negotiating QF; and (4) when the QF indicates
- that it agrees to all the terms in the draft contract, the utility has 15 days to forward a final
- 20 executable contract to the QF." Re Investigation Into QF Contracting and Pricing,
- 21 Docket No. UM 1610, Order No. 16-174 at 24 (May 13, 2016). Thus, when the QF
- 22 informs PGE that it has agreed to all terms and conditions in the draft PPA, then PGE is
- required to provide an executable PPA to the QF.

- 1 66. The Commission has determined that a legally enforceable obligation will
- 2 be established "once a QF signs the final draft of an executable contract provided by a
- 3 utility to commit itself to sell power to the utility." Re Investigation Into QF Contracting
- 4 and Pricing, Docket No. UM 1610, Order No. 16-174 at 3, 27-28 (May 13, 2016).
- 5 However, a legally enforceable obligation "may be established earlier if a QF
- 6 demonstrates delay or obstruction of progress towards a final draft of an executable
- 7 contract, such as a failure by a utility to provide a QF with required information or
- 8 documents on a timely basis." Id.
- 9 67. The Commission has determined that a PPA can be executed and a legally
- 10 enforceable obligation can be created in less than two months under normal
- circumstances. <u>Re Investigation Into QF Contracting and Pricing</u>, Docket No. UM 1610,
- 12 Order No. 16-174 at 24, 27-28 (May 13, 2016).
- FERC has found that legally enforceable obligations have been created in
- 14 about one month. <u>Rainbow Ranch Wind</u>, LLC, 139 FERC ¶ 61,077 at PP 2-5, 24 (2012);
- 15 Grouse Creek Wind Park, LLC, 142 FERC ¶ 61,187, at PP 37-43 (2013).
- Red Prairie Solar has repeatedly committed itself to sell power to PGE
- under the currently effective Schedule 201 rates, and the terms and conditions of the draft
- 18 PPA, including to provide power or be subject to penalty for failing to deliver on the
- scheduled commercial on-line date. These commitments include but are not limited to
- 20 Red Prairie Solar's request for an executable PPA on July 27, 2017, Red Prairie Solar's
- demand letter sent on July 31, 2017, and Red Prairie Solar's execution of the draft PPA
- 22 on August 7, 2017.

1 70 Red Prairie Solar has continued to commit, and is still committing, itself to 2 sell the net output of the Red Prairie Solar Project to PGE at the Schedule 201 rates, 3 terms, and conditions in the partially executed final PPA. 4 71. PGE is required to purchase the net output of the Red Prairie Solar Project 5 at the Schedule 201 rates, terms, and conditions in the partially executed final PPA, 6 despite PGE's refusal to execute the partially executed final PPA. 7 72. Red Prairie Solar's execution of the draft PPA, continuing commitment to 8 sell the net output of the Red Prairie Solar Project, and efforts to obtain PGE's execution 9 of the partially executed final PPA establish a legally enforceable obligation at the 10 currently effective Schedule 201 rates, and all the terms and conditions in the partially 11 executed final PPA. 12 **Complainant's Second Claim for Relief** 13 Red Prairie Solar is entitled to PGE's standard contract with currently effective 14 Schedule 201 rates because Red Prairie Solar legally obligated itself to sell the net output prior to the filing of this Complaint, and PGE violated the OPUC's and 15 FERC's policies and rules, and Schedule 201 16 17 18 73. Red Prairie Solar re-alleges all the preceding paragraphs. 19 74. The Commission has established rules, policies, standard contracts, and 20 rate schedules to facilitate and direct the process by which a QF and an Oregon electric 21 utility enter into a contract. Re Investigation Relating to Electric Utility Purchases from 22 QFs, Docket No. UM 1129, Order No. 05-584 at 6-12, 16 (May 13, 2005). The purpose 23 of the Commission approving standard contacts and schedules for each utility is to pre-24 establish "rates, terms and conditions that an eligible QF can elect without any

negotiation with the purchasing utility" and to "eliminate negotiations " Id. at 12, 16.

25

- 1 75. PGE's failure to abide by the terms of PURPA, the Commission's rules
- and policies, FERC's rules and policies, and/or Schedule 201 can result in the creation of
- a legally enforceable obligation. Re Investigation Into QF Contracting and Pricing,
- 4 Docket No. UM 1610, Order No. 16-174 at 3, 27-28 (May 13, 2016); Snow Mountain,
- 5 734 P.2d at 1371; International Paper v. PacifiCorp, Docket No. UM 1449, Order No. 09-
- 6 439 at 6 (Nov 4, 2009).
- 7 76. The Commission's polices include that, "when the QF indicates that it
- 8 agrees to all the terms in the draft contract, the utility has 15 days to forward a final
- 9 executable contract to the QF." Re Investigation Into QF Contracting and Pricing,
- 10 Docket No. UM 1610, Order No. 16-174 at 24 (May 13, 2016).
- 11 77. PGE's Schedule 201 includes timelines and requirements that a utility
- should follow when entering into a PPA with a QF 10 MWs and under. Schedule 201
- provides that: "When both parties are in full agreement as to all terms and conditions of
- 14 the draft Standard PPA, the Company will prepare and forward to the Seller a final
- executable version of the agreement within 15 business days."
- The Commission's rules and policies prevent a utility from delaying or
- obstructing "progress towards a final draft of executable contract". Re Investigation Into
- QF Contracting and Pricing, Docket No. UM 1610, Order No. 16-174 at 27-28 (May 13,
- 19 2016).
- 20 79. PGE must continue to comply with the Commission's rules and policies,
- even though PGE has requested interim relief in the Solar Limitation Filing.

- 1 80. By no later than August 7, 2017, Red Prairie Solar had agreed to all terms
- 2 and conditions, and Red Prairie Solar requested executed a final executable version of the
- 3 PPA.
- 4 81. PGE did not provide and has not provided a final executable version of the
- 5 PPA.
- 6 82. PGE violated the Commission's rules and policies, FERC's rules and
- 7 policies, and Schedule 201 when it refused to notify prior to filing or serve Red Prairie
- 8 Solar and other QFs with its May 1 Update, Solar Limitation Filing and August Early
- 9 Rate Effective Date Request with the intention to prevent Red Prairie Solar from timely
- 10 executing a PPA.
- 11 83. PGE violated the Commission's rules and policies, FERC's rules and
- policies, and Schedule 201 when it stated that no binding PPA will exist between PGE
- and Red Prairie Solar unless and until PGE has provided Red Prairie Solar with an
- 14 executable PPA.
- 15 84. PGE violated the Commission's rules and policies, FERC's rules and
- policies, and Schedule 201 when it stated that no binding PPA will exist between PGE
- and Red Prairie Solar unless Red Prairie Solar and PGE both have executed the PPA.
- 18 85. PGE violated the Commission's rules and policies, FERC's rules and
- policies, and Schedule 201 when it stated that it did not expect to provide and would not
- 20 provide an executable PPA before the Commission has ruled on PGE's motion for
- 21 interim relief in the Solar Limitation Filing.

- 1 86. PGE violated the Commission's rules and policies, FERC's rules and
- 2 policies, and Schedule 201 when it delayed and obstructed progress toward executing a
- 3 PPA.
- 4 87. PGE violated the Commission's rules and policies, FERC's rules and
- 5 policies, and Schedule 201 when it raised concerns regarding year 1 hourly generation
- 6 profile and maximum annual net output.
- 7 88. PGE violated the Commission's rules and policies, FERC's rules and
- 8 policies, and Schedule 201 when it refused to provide an executable PPA or to execute
- 9 the draft PPA.
- 10 89. PGE's violations of the Commission's rules and policies, FERC's rules
- and policies, and Schedule 201, and Red Prairie Solar's execution of the final PPA,
- 12 continuing commitment to sell the net output of the Red Prairie Solar Project, and efforts
- to obtain PGE's signature resulted in a legally enforceable obligation at the currently
- effective Schedule 201 rates, and all the terms and conditions in the partially executed
- final PPA.

16 VIII. PRAYER FOR RELIEF

- WHEREFORE, Red Prairie Solar respectfully requests the Commission issue an
- 18 order:
- 19 1. Finding PGE in violation of: 1) the mandatory purchase obligation of the Oregon
- 20 PURPA; 2) the mandatory purchase obligation of the federal PURPA; 3) FERC's
- 21 PURPA regulations, policies, and orders; 4) the Commission's PURPA
- regulations, policies, and orders; and 5) PGE's Schedule 201;

- 1 2. Requiring PGE to purchase the net output of the Red Prairie Solar Project at the
- 2 currently effective Schedule 201 rates, and all the terms and conditions in the
- 3 partially executed final PPA;
- 4 3. Requiring PGE to enter into a PURPA PPA with Red Prairie Solar at the currently
- 5 effective Schedule 201 rates, and all the terms and conditions in the partially
- 6 executed final PPA;
- 7 4. Instituting penalties up to \$10,000 pursuant to ORS 756.990 against PGE and paid
- by PGE's shareholders for each violation of ORS 758.525(2), 758.535(2)(b),
- 9 18 CFR 292.303(a), 292.304(d), and Commission Order Nos. 05-584 and 16-174.
- 5. Granting any other such relief as the Commission deems necessary.

Dated this 7th day of August, 2017.

Respectfully submitted,

Irion A. Sanger Sanger Law, PC

1117 SE 53rd Avenue

Portland, OR 97215

Telephone: 503-756-7533

Fax: 503-334-2235 irion@sanger-law.com

Of Attorneys for Red Prairie Solar

CERTIFICATE OF FILING

I certify that on August 7, 2017, I filed the foregoing Complaint on behalf of Red Prairie Solar with the Oregon Public Utility Commission by electronic communication as consistent with OAR 860-001-0170.

Sanger Law, PC

1117 SE 53rd Avenue

Portland, OR 97215

Telephone: 503-756-7533

Fax: 503-334-2235 irion@sanger-law.com


Attachment A

Red Prairie

Power Purchase Agreement

STANDARD RENEWABLE IN-SYSTEM VARIABLE POWER PURCHASE

AGREEMENT



Draft. Not For Execution.

Draft. AOT FOR EXECUTION OF SET AOT FOR EXECUTION

Draft. AOT FOR EXECUTION Draft.

Draft. AOT FOR EXECUTION OF SHEET FOR EXECUTI

Draft. Not For Execution

Orafit. NOT FOR EXECUTION OF THE OPERATE OP

Draft. April For Extending to the control of the co

Draft. NOT FOR EXECUTION OF STREET

Draft. Apol Forest Stranger of the Stranger of

Oraft. AOT FOR EXECUTION OF A STREET FOR EXE

Draft. Not For Execution.

Orafit. Not For Fixe Cultilla Property of the Contract of the

Draft. April 10 Property of the Cultillory of th

Drafte. And Forest And France Control of the Contro

To PGE:

Contracts Manager

QF Contracts, 3WTC0306 PGE - 121 SW Salmon St. Portland, Oregon 97204

20.2 The Parties may change the person to whom such notices are addressed, or their addresses, by providing written notices thereof in accordance with this Section 20.


IN WITNESS WHEREOF, the Parties hereto have caused this Agreement to be executed in their respective names as of the Effective Date.

PGE
By: Name: Title: Date:
Red Prairie Solar, LLC (Name Seller)
By: Name: Troy Snych- Title: Manage Date: \$/7/17
Ordin

Red Prairie Solar
Yamhill - 45°05′14.6″N 123°25′02.
Or
6/30/
7/31/
20 Years from Effective
Limited Liability Corpor
Or
214
478
Red Prairie Sola
C/O TLS Capito
7455 SW Bridgeport Road, St.
Tigard, OR 9
TLS Capito
3519 NE 15th Ave,
40. "100000000
Portland, OR 9
Atta
Filed - 3/1
ž A
Does not
TLS Capito
TLS Capital, Inc & List of Entities on Attache
▼ , · · · ,
TLS Capita
Lease - Atta
OF17-807-000 - Atta
Q+17-807-000 - Atta
Hire EPC Contr
Interconnection Application
Sol
6/30,
Atta
Atta
Atta
Atte
Atta

45°05'14.6"N 123°25'02
Red Prairie Rd, Sherida
Red Prairie Rd, Sherida Yamhill County Taxlots R5634 01600, R6604 00200/0

W. Experted Solar Capacity Factor V. Maximum annual output (monthly MWh detail) Iv. Loss Diagram Description of Modeles 3. Module type 0. Max power vortage 1. Max power untered 1. Max power untered 1. Max power untered 2. Max power untered 3. Description of fracting 3. Description of fracting 3. L. Typer (fixed till, single-ask tracking, or dual-ask tracking, etc.) 3. L. Typer (fixed till, single-ask tracking, or dual-ask tracking, etc.) 3. L. Typer (fixed till, single-ask tracking, or dual-ask tracking, etc.) 4. Description of Inverters: 5. Maximum fower (MW) 6. Description of Inverters: 7. Maximum Fower (MW) 8. Maximum fower (MW) 9. Max. Output Current (A) 9. Rated DC Voltage 9. Rated DC Voltage 9. Rated DC voltage 9. Rated DC voltage 9. Facility AC Capacity (Maximum 9. Facility AC Capacity (Maximum 9. Facility AC Capacity (Maximum 9. Pacility AC Capacity (Maximum 9. Transaction Service Request Number, Interconnection Application 1. Interconnection Application	ii. Annual degradation factor iii. Average 24-br profile of generation MWh (AC) for each month during the first calendar year iv. Expected Solar Capacity Factor v. Maximum annual output (monthly MWh detail) iv. Loss Diagram lo	PVSyst (or equivalent) simulation results detail, including but not limited to:	
ii. Annual degradation factor iii. Average 24-br profile of generation MWh (AC) for each month during the first calendar year iv. Espected Solar Capacity Factor v. Maximum annual output (monthly MWh detail) v. Loss Diagram	ii. Annual degradation factor iii. Average 24-br profile of generation MWh (AC) for each month during the first calendar year iv. Espected Solar Capacity Factor v. Maximum annual output (monthly MWh detail) v. Loss Diagram	i. Annual MWh (AC) for the first calendar year of commercial operation	
iii. Average 24-br profile of generation MVN (AC) for each month during the first calendar year iv. No Assimum annual output (monthly MVN detail) iv. Loss Digarm 2. Description of Modules: a. Module type b. ii. of modules c. Max power voltage d. Max power voltage c. Max power voltage (if fixed 40) c. Maximum Power (NV) c. Max	iii. Average 24-br profile of generation MVN (AC) for each month during the first calendar year iv. No Assimum annual output (monthly MVN detail) iv. Loss Digarm 2. Description of Modules: a. Module type b. ii. of modules c. Max power voltage d. Max power voltage c. Max power voltage (if fixed 40) c. Maximum Power (NV) c. Max		
iv. Espected Solar Capacity Factor v. Nasimum annual output (monthly MWh detail) v. Loss Diagram 2. Description of Moudales a. Module type 6. Max power voltage 7. Max system voltage 8. Max power unrent 8. Max system voltage 8. Max power unrent 9. Max system voltage 1. Trial range lef fined-fixed fixed fixe	iv. Espected Solar Capacity Factor v. Nasimum annual output (monthly MWh detail) v. Loss Diagram 2. Description of Moudales a. Module type 6. Max power voltage 7. Max system voltage 8. Max power unrent 8. Max system voltage 8. Max power unrent 9. Max system voltage 1. Trial range lef fined-fixed fixed fixe		
V. Maximum annual output (monthly MWh detail) N. Loss Diagram 2. Description of Modules: 3. Module type 5. It of modules 6. A Max power current 7. A Max power current 8. A Max power current 9. A Max power p	V. Maximum annual output (monthly MWh detail) N. Loss Diagram 2. Description of Modules: 3. Module type 5. It of modules 6. A Max power current 7. A Max power current 8. A Max power current 9. A Max power p		
ix. Loss Diagram 2. Description of Modeles 3. Module type 4. Max power voltage 4. Max power unrent 6. Max system voltage 7. Total DC Systems size 8. Description of Racking 1. Type: (Tixed titl, single-axis tracking or dual-axis tracking, etc.) 11. Titl angle (if fixed-titl) 11. Titl angle (if fixed-titl) 11. Titl angle (if fixed-titl) 11. Authruth (sefault - south-facing) 4. Description of Inverters: 2. Number of Inverters: 3. Number of Inverters: 3. Number of Inverters: 4. Number of Univerters: 5. Model 6. Operating Voltage (VAC) 7. Racked DC Voltage 8. Racked DC current 8. Number of Lord (Valtage) 9. Racked DC current 9. Number of Lord (Valtage) 9. Racked DC current 9. Number of Lord (Valtage) 9. Racked DC Lord (Valtage) 9. Racked	ix. Loss Diagram 2. Description of Modeles 3. Module type 4. Max power voltage 4. Max power unrent 6. Max system voltage 7. Total DC Systems size 8. Description of Racking 1. Type: (Tixed titl, single-axis tracking or dual-axis tracking, etc.) 11. Titl angle (if fixed-titl) 11. Titl angle (if fixed-titl) 11. Titl angle (if fixed-titl) 11. Authruth (sefault - south-facing) 4. Description of Inverters: 2. Number of Inverters: 3. Number of Inverters: 3. Number of Inverters: 4. Number of Univerters: 5. Model 6. Operating Voltage (VAC) 7. Racked DC Voltage 8. Racked DC current 8. Number of Lord (Valtage) 9. Racked DC current 9. Number of Lord (Valtage) 9. Racked DC current 9. Number of Lord (Valtage) 9. Racked DC Lord (Valtage) 9. Racked		
2. Description of Modules a. Module type b. If of modules c. Max power variage d. Max power current e. Max yelser workage f. Total DC system size 3. Racking a. Racking i. Type: (fixed titt, single-axis tracking, or dual-axis tracking, etc.) ii. Titt angle (if fixed-tit) iii. Ariman (iceanit is outh-facing) 4. Description of Inverters: b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Maximum Power (kW) d. Goperating Voltage (VAC) f. Rated DC Voltage g. Rated DC Corrent h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating b. Model c. Facility AC rating h. Inverter Inverter b. Model c. Facility AC rating h. Inverter Inverter c. High Voltage Rating h. Inverter Inverter b. Model c. Hagh Voltage Rating h. Inverter Inverter b. Model c. Facility AC stanting h. Inverter Inverter loading ratio h. Rating Account the Model h. Maximum Output (kW) g. Facility AC communications, and monitoring f. Bescription of transformers h. Model h. Model h. Rating Account the Model h. Model h. Rating Account to the Model h. Maximum Output (kW) g. Facility AC control h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act acting h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Accounter h. Maximum Output (kW	2. Description of Modules a. Module type b. If of modules c. Max power variage d. Max power current e. Max yelser workage f. Total DC system size 3. Racking a. Racking i. Type: (fixed titt, single-axis tracking, or dual-axis tracking, etc.) ii. Titt angle (if fixed-tit) iii. Ariman (iceanit is outh-facing) 4. Description of Inverters: b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Maximum Power (kW) d. Goperating Voltage (VAC) f. Rated DC Voltage g. Rated DC Corrent h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating b. Model c. Facility AC rating h. Inverter Inverter b. Model c. Facility AC rating h. Inverter Inverter c. High Voltage Rating h. Inverter Inverter b. Model c. Hagh Voltage Rating h. Inverter Inverter b. Model c. Facility AC stanting h. Inverter Inverter loading ratio h. Rating Account the Model h. Maximum Output (kW) g. Facility AC communications, and monitoring f. Bescription of transformers h. Model h. Model h. Rating Account the Model h. Model h. Rating Account to the Model h. Maximum Output (kW) g. Facility AC control h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act rating h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Act acting h. Inverter Inverter Inverter h. Maximum Output (kW) h. Facility Accounter h. Maximum Output (kW		
a. Module type b. # of modules c. Max power voltage d. Max power voltage d. Max power voltage e. Max system voltage f. Total De System size 3. Description of Racking a. Racking i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) ii. Tit angle [if fixed-tilt] iii. All immunity (default - south-facing) d. Description of Inverters a. Number of Inverters b. Model d. Description of Inverters a. Number of Inverters b. Model d. Description of Inverters a. Number of Inverters b. Model d. Operating Voltage (VMC) d. Operating Voltage (VMC) g. Rated DC current h. Maximum Output (MV) g. Raciliny AC capacity Rating h. Maximum Output (MV) g. Raciliny AC capacity Rating h. Inverter booling ratio l. Facility AC capacity Rating h. Inverter booling ratio l. Facility AC capacity Rating h. Inverter booling ratio l. Facility AC capacity Rating f. High Voltage Balting d. Low Voltage Balting g. Low Voltage Balting g. Low Voltage Balting g. Low Voltage Rating g. Low Voltage Rating g. Low Voltage Connection and Interconnection applications Interconnection applications Interconnection application Interconnection Application Interconnection Application Interconnection Application	a. Module type b. # of modules c. Max power voltage d. Max power voltage d. Max power voltage e. Max system voltage f. Total De System size 3. Description of Racking a. Racking i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) ii. Tit angle [if fixed-tilt] iii. All immunity (default - south-facing) d. Description of Inverters a. Number of Inverters b. Model d. Description of Inverters a. Number of Inverters b. Model d. Description of Inverters a. Number of Inverters b. Model d. Operating Voltage (VMC) d. Operating Voltage (VMC) g. Rated DC current h. Maximum Output (MV) g. Raciliny AC capacity Rating h. Maximum Output (MV) g. Raciliny AC capacity Rating h. Inverter booling ratio l. Facility AC capacity Rating h. Inverter booling ratio l. Facility AC capacity Rating h. Inverter booling ratio l. Facility AC capacity Rating f. High Voltage Balting d. Low Voltage Balting g. Low Voltage Balting g. Low Voltage Balting g. Low Voltage Rating g. Low Voltage Rating g. Low Voltage Connection and Interconnection applications Interconnection applications Interconnection application Interconnection Application Interconnection Application Interconnection Application		
b. B. of modules c. Max power vurtent d. Max power current e. Max system voltage f. Total DC system size 3. Description of Racking i. Type: (fixed tilt, single-axis tracking, ordual-axis tracking, etc.) ii. Tilt angle (if fixed-tilt) iii. Alimin (default = south-facing) 4. Description of Inverters: b. Model c. Maximum Fower (kW) d. Operating Voltage (VAC) d. Operating Voltage (VAC) f. Rated DC Voltage g. Rated DC Cotage g. Rated DC Cotage g. Rated DC Cotage g. Rated DC Cotage g. Facility AC Capacity Rating h. Inverter loading ratio h. Facility AC rating b. Model c. Facility AC rating d. Low Voltage Connection g. Low voltage connection g. Low voltage connection g. Low voltage connection and transformers and summing a first of the commendations, and monitoring for the communications, and monitoring for the communications and monitoring for the communication and transmission plan Interconnection applications Interconnection applications Interconnection Application Interconnection Application Interconnection Application Interconnection Application Interconnection Application Interconnection Application	b. B. of modules c. Max power vurtent d. Max power current e. Max system voltage f. Total DC system size 3. Description of Racking i. Type: (fixed tilt, single-axis tracking, ordual-axis tracking, etc.) ii. Tilt angle (if fixed-tilt) iii. Alimin (default = south-facing) 4. Description of Inverters: b. Model c. Maximum Fower (kW) d. Operating Voltage (VAC) d. Operating Voltage (VAC) f. Rated DC Voltage g. Rated DC Cotage g. Rated DC Cotage g. Rated DC Cotage g. Rated DC Cotage g. Facility AC Capacity Rating h. Inverter loading ratio h. Facility AC rating b. Model c. Facility AC rating d. Low Voltage Connection g. Low voltage connection g. Low voltage connection g. Low voltage connection and transformers and summing a first of the commendations, and monitoring for the communications, and monitoring for the communications and monitoring for the communication and transmission plan Interconnection applications Interconnection applications Interconnection Application Interconnection Application Interconnection Application Interconnection Application Interconnection Application Interconnection Application		Dalue
c. Max power vortage d. Max power current e. Max system voltage f. Total DC system size 3. Description of Racking a. Racking ii. Type: (fixed tilt, single-ask tracking, or dual-axis tracking, etc.) ii. This angle (if fixed-tilt) iii. Azimuth (default - south-facing) d. Description of Inverters a. Number of Inverters a. Number of Inverters b. Model c. Maximum Power (NV) c. Maximum Power (NV) d. Operating Voltage (VAC) e. Max. Oripat Current (A) f. Rated DC current h. Maximum Oriput (NV) g. Racking Voltage (VAC) g. Rack Oripat Current (A) h. Maximum Oriput (NV) g. Racking Voltage (VAC) h. Maximum Oriput (NV) g. Racking Voltage (VAC) h. Maximum Oriput (NV) g. Racking Voltage Rating h. Inverter loading ratio h. Facility Ac Capachty Rating h. Inverter loading ratio h. Maximum Oriput (NV) g. Racking Voltage Rating h. Inverter loading ratio h. Maximum Oriputing (VV) g. Racking Voltage Rating h. Inverter loading ratio h. Maximum Oriputing Rating h. Inverter loading ratio h. Racking Rating h. Racking Racking h. Racking	c. Max power vortage d. Max power current e. Max system voltage f. Total DC system size 3. Description of Racking a. Racking ii. Type: (fixed tilt, single-ask tracking, or dual-axis tracking, etc.) ii. This angle (if fixed-tilt) iii. Azimuth (default - south-facing) d. Description of Inverters a. Number of Inverters a. Number of Inverters b. Model c. Maximum Power (NV) c. Maximum Power (NV) d. Operating Voltage (VAC) e. Max. Oripat Current (A) f. Rated DC current h. Maximum Oriput (NV) g. Racking Voltage (VAC) g. Rack Oripat Current (A) h. Maximum Oriput (NV) g. Racking Voltage (VAC) h. Maximum Oriput (NV) g. Racking Voltage (VAC) h. Maximum Oriput (NV) g. Racking Voltage Rating h. Inverter loading ratio h. Facility Ac Capachty Rating h. Inverter loading ratio h. Maximum Oriput (NV) g. Racking Voltage Rating h. Inverter loading ratio h. Maximum Oriputing (VV) g. Racking Voltage Rating h. Inverter loading ratio h. Maximum Oriputing Rating h. Inverter loading ratio h. Racking Rating h. Racking Racking h. Racking		Poly-C
d. Max power current e. Max system voltage f. Total DC system size J. Poscription of Rading J. Radding J. Type: (fixed tith, Single-asis tracking, or dual-axis tracking, etc.) J. Tit angle (if fixed-tit) J. Radding J. Type: (fixed tith, Single-asis tracking, or dual-axis tracking, etc.) J. Tit angle (if fixed-tit) J. Maximum Power (kW) J. Maximum Power (kW) J. Maximum Power (kW) J. Radd DC Current J. Radd DC Curr	d. Max power current e. Max system voltage f. Total DC system size J. Poscription of Rading J. Radding J. Type: (fixed tith, Single-asis tracking, or dual-axis tracking, etc.) J. Tit angle (if fixed-tit) J. Radding J. Type: (fixed tith, Single-asis tracking, or dual-axis tracking, etc.) J. Tit angle (if fixed-tit) J. Maximum Power (kW) J. Maximum Power (kW) J. Maximum Power (kW) J. Radd DC Current J. Radd DC Curr		
e. Max system voltage f. Total DC systems size 3. Description of Racking i. Type: (fixed tilt, single-asis tracking, or dual-axis tracking, etc.) ii. Tit angle (if fixed-sit) iii. Alimuth (default = south-facing) 4. Description of Inverters: a. Number of Inverters b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Raeted DC current p. Maximum Dutup (kW) g. Facility AC Capachy Rating g. Raeted DC current h. Maximum Dutup (kW) g. Facility AC Capachy Rating h. Imerater loading ratio i. F. Imerater loading ratio i. F. Serility AC Part of Part	e. Max system voltage f. Total DC systems size 3. Description of Racking i. Type: (fixed tilt, single-asis tracking, or dual-axis tracking, etc.) ii. Tit angle (if fixed-sit) iii. Alimuth (default = south-facing) 4. Description of Inverters: a. Number of Inverters b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Raeted DC current p. Maximum Dutup (kW) g. Facility AC Capachy Rating g. Raeted DC current h. Maximum Dutup (kW) g. Facility AC Capachy Rating h. Imerater loading ratio i. F. Imerater loading ratio i. F. Serility AC Part of Part		•
f. Total CC systems kie J. Racking I. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) II. Tilt angle (if fixed-tilt) III. Azimmih (default - south-facing) J. Description of Inverters. J. Number of Inverters. J. Rated DC Current (A) J. Rated DC Current (A) J. Rated DC Current J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Number of Inverters J. Description of Inverters (A) J. Number of Inverters J.	f. Total CC systems kie J. Racking I. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) II. Tilt angle (if fixed-tilt) III. Azimmih (default - south-facing) J. Description of Inverters. J. Number of Inverters. J. Rated DC Current (A) J. Rated DC Current (A) J. Rated DC Current J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Number of Inverters (A) J. Rated DC Current J. Number of Inverters (A) J. Number of Inverters J. Description of Inverters (A) J. Number of Inverters J.		WA.
3. Description of Racking 1. Type; (fixed this, single-axis tracking, or dual-axis tracking, etc.) 1. Type; (fixed this, single-axis tracking, or dual-axis tracking, etc.) 1. That angle (if fised-til) 1. Exerciption of inverters: 2. Number of inverters: 3. Number of inverters: 4. Nodel 5. Massimum Power (RW) 6. Operating Voltage (VAC) 7. Rated DC Voltage 8. Rated DC Current 8. Raded DC Current 8. Raded DC Current 9. Facility AC Capacity Rating 10. Inverter loading ratio 1. Facility AC rating 5. Description of transformers 2. Before the sign of transformers 2. Before the sign of transformers 3. Before the sign of transformers 4. Model Coop 6. Low Voltage Rating 6. Low Voltage Rating 6. Low Voltage Rating 6. Low Voltage connection 8. Low voltage connection 9. Low voltage connection 9. Description of fixetion service requirements 7. Description of station service requirements 9. Description of station service Request Number, Interconnection Application 1. Transaction Service Request Number, Interconnection Application 1. Transaction Service Request Number, Interconnection Application	3. Description of Racking 1. Type; (fixed this, single-axis tracking, or dual-axis tracking, etc.) 1. Type; (fixed this, single-axis tracking, or dual-axis tracking, etc.) 1. That angle (if fised-til) 1. Exerciption of inverters: 2. Number of inverters: 3. Number of inverters: 4. Nodel 5. Massimum Power (RW) 6. Operating Voltage (VAC) 7. Rated DC Voltage 8. Rated DC Current 8. Raded DC Current 8. Raded DC Current 9. Facility AC Capacity Rating 10. Inverter loading ratio 1. Facility AC rating 5. Description of transformers 2. Before the sign of transformers 2. Before the sign of transformers 3. Before the sign of transformers 4. Model Coop 6. Low Voltage Rating 6. Low Voltage Rating 6. Low Voltage Rating 6. Low Voltage connection 8. Low voltage connection 9. Low voltage connection 9. Description of fixetion service requirements 7. Description of station service requirements 9. Description of station service Request Number, Interconnection Application 1. Transaction Service Request Number, Interconnection Application 1. Transaction Service Request Number, Interconnection Application		
a. Racking i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) ii. Tilt angle (if fixed-tilt) iii. Azimuth (default = south-facing) 4. Description of inverters a. Number of Inverters b. Model C. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Current h. Maximum Output (kW) g. Racilly AC Capacity Rating h. Inverter loading ratio l. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC capacity Rating h. Inverter loading ratio l. Facility AC traing 5. Description of transformers a. 8 of transformers b. Model c. High Voltage Rating d. Low Voltage Rating f. High voltage connection g. Low vol	a. Racking i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) ii. Tilt angle (if fixed-tilt) iii. Azimuth (default = south-facing) 4. Description of inverters a. Number of Inverters b. Model C. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Current h. Maximum Output (kW) g. Racilly AC Capacity Rating h. Inverter loading ratio l. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC capacity Rating h. Inverter loading ratio l. Facility AC traing 5. Description of transformers a. 8 of transformers b. Model c. High Voltage Rating d. Low Voltage Rating f. High voltage connection g. Low vol		3
i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) ii. Titt angle (if fixed-tilt) iii. Azimuth (default = south-facing) 4. Description of Inverters a. Number of Inverters b. Model 5. Max Summ Power (kW) 6. Operating Voltage (VIC) 7. Rated DC Voltage 8. Rated DC Voltage 9. Rated DC Current 1. Maximum Output (kW) 9. Facility AC grapicity Rating 1. Inverter loading ratio 1. Facility AC rating 5. Description of transformers 1. Model 6. We Noutput Green (Inverter) 7. Description of transformers 1. Model 7. Model 8. Description of transformers 1. Model 8. Description of metering communications, and monitoring 9. Description of metering communications, and monitoring 9. Description of metering communications, and monitoring 9. Description of station service requirements 9. Description of station service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentati	i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.) ii. Titt angle (if fixed-tilt) iii. Azimuth (default = south-facing) 4. Description of Inverters a. Number of Inverters b. Model 5. Max Summ Power (kW) 6. Operating Voltage (VIC) 7. Rated DC Voltage 8. Rated DC Voltage 9. Rated DC Current 1. Maximum Output (kW) 9. Facility AC grapicity Rating 1. Inverter loading ratio 1. Facility AC rating 5. Description of transformers 1. Model 6. We Noutput Green (Inverter) 7. Description of transformers 1. Model 7. Model 8. Description of transformers 1. Model 8. Description of metering communications, and monitoring 9. Description of metering communications, and monitoring 9. Description of metering communications, and monitoring 9. Description of station service requirements 9. Description of station service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentation 9. Transaction Service Requires Number, Interconnection Queue number, and System impact/interconnection study documentati	3. Description of Racking	AND 2000
ii. Titt angle (If fixed-tit) iii. Azimuth (default = south-facing) 4. Description of inverters: a. Number of Inverters b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Current h. Maximum Output (kW) g. Ratell DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC Capacity Rating b. Description of transformers a. B of transformers b. Model c. Neigh Voltage Rating d. Low Voltage Rating g. Low voltage connection g. Low of melering, communications, and monitoring PG Description of station service requirements Description of melering, communications, and monitoring Transaction Service Request Number, Interconnection Application Interconnection applications Interconnection application Interconnection Application Interconnection Application Interconnection Application	ii. Titt angle (If fixed-tit) iii. Azimuth (default = south-facing) 4. Description of inverters: a. Number of Inverters b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Current h. Maximum Output (kW) g. Ratell DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC Capacity Rating b. Description of transformers a. B of transformers b. Model c. Neigh Voltage Rating d. Low Voltage Rating g. Low voltage connection g. Low of melering, communications, and monitoring PG Description of station service requirements Description of melering, communications, and monitoring Transaction Service Request Number, Interconnection Application Interconnection applications Interconnection application Interconnection Application Interconnection Application Interconnection Application		
iii. Azimuth (default = south-facing) 4. Description of Inverters 5. Model 5. Maximum Power (kW) 6. Operating Voltage (VAC) 7. Maximum Power (kW) 8. Rated DC Voltage 9. Rated DC Voltage 9. Rated DC Current 1. Maximum Output (kW) 9. Facility AC Capacity Rating 1. I. Facility AC Capacity Rating 1. I. Facility AC frating 9. Excellity AC Capacity Rating 1. I. Facility AC frating 9. Description of transformers 1. I. Facility AC Inverse Seating 1. Interconnection applications 1. Description of metering communications, and monitoring 1. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation 1. Interconnection Applications 1. Interconn	iii. Azimuth (default = south-facing) 4. Description of Inverters 5. Model 5. Maximum Power (kW) 6. Operating Voltage (VAC) 7. Maximum Power (kW) 8. Rated DC Voltage 9. Rated DC Voltage 9. Rated DC Current 1. Maximum Output (kW) 9. Facility AC Capacity Rating 1. I. Facility AC Capacity Rating 1. I. Facility AC frating 9. Excellity AC Capacity Rating 1. I. Facility AC frating 9. Description of transformers 1. I. Facility AC Inverse Seating 1. Interconnection applications 1. Description of metering communications, and monitoring 1. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation 1. Interconnection Applications 1. Interconn	i. Type: (fixed tilt, single-axis tracking, or dual-axis tracking, etc.)	
4. Description of Inwerters: a. Number of Inwerters: b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio h. Inverter loading ratio h. Inverter loading ratio f. Facility AC rating c. Description of transformers a. # Of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MWA rating e. MWA rating e. MWA rating e. Low voltage connection g. Low voltage connection g. Low voltage connection g. Low voltage connection g. Low retering communications, and monitoring f. Description of station service requirements p. Description of station service requirements p. Transaction Service Request Number, Interconnection Queue number, and System Impact/Interconnection study documentation Interconnection Applications Interconnection Applications Interconnection Applications Interconnection Applications Interconnection Applications	4. Description of Inwerters: a. Number of Inwerters: b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio h. Inverter loading ratio h. Inverter loading ratio f. Facility AC rating c. Description of transformers a. # Of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MWA rating e. MWA rating e. MWA rating e. Low voltage connection g. Low voltage connection g. Low voltage connection g. Low voltage connection g. Low retering communications, and monitoring f. Description of station service requirements p. Description of station service requirements p. Transaction Service Request Number, Interconnection Queue number, and System Impact/Interconnection study documentation Interconnection Applications Interconnection Applications Interconnection Applications Interconnection Applications Interconnection Applications	ii. Tilt angle (if fixed-tilt)	
a. Number of Inverters b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) d. Operating Voltage (VAC) f. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating b. Horder of transformers a. If of transformers a. If of transformers d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage Rating g. Low voltage connection g. Low	a. Number of Inverters b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) d. Operating Voltage (VAC) f. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating b. Horder of transformers a. If of transformers a. If of transformers d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage Rating g. Low voltage connection g. Low	iii. Azimuth (default = south-facing)	
b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection of metering, communications, and monitoring g. PGE 7. Description of station service requirements g. Description of station service requir	b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection of metering, communications, and monitoring g. PGE 7. Description of station service requirements g. Description of station service requir	4. Description of Inverters:	
b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection of metering, communications, and monitoring g. PGE 7. Description of station service requirements g. Description of station service requir	b. Model c. Maximum Power (kW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio l. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection of metering, communications, and monitoring g. PGE 7. Description of station service requirements g. Description of station service requir	a. Number of Inverters	4 4
c. Maximum Power (AW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Current h. Maximum Output (KW) g. Facility AC capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop c. High Voltage Rating d. Low Voltage Rating f. High voltage Rating g. E. WA rating f. High voltage connection g. Low voltage connection g. Low voltage connection 6. Description of fastion service requirements PGE Description of station service requirements 9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Applications 9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Application 1. Interconnection Appl	c. Maximum Power (AW) d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Current h. Maximum Output (KW) g. Facility AC capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop c. High Voltage Rating d. Low Voltage Rating f. High voltage Rating g. E. WA rating f. High voltage connection g. Low voltage connection g. Low voltage connection 6. Description of fastion service requirements PGE Description of station service requirements 9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Applications 9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Application 1. Interconnection Appl		SMA S
d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC Capacity Rating c. Description of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection g. Low voltage connection g. Low voltage connection g. Description of metering communications, and monitoring p. Coperation of metering communications, and monitoring p. Coperation of metering communications and timeline of interconnection and transmission plan linterconnection Application Interconnection	d. Operating Voltage (VAC) e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC Current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC Capacity Rating c. Description of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection g. Low voltage connection g. Low voltage connection g. Description of metering communications, and monitoring p. Coperation of metering communications, and monitoring p. Coperation of metering communications and timeline of interconnection and transmission plan linterconnection Application Interconnection		SIVIAS
e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC current h. Maximum Output (EW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating f. High voltage connection g. Low Voltage connection g. Low Voltage connection g. Low Voltage connection g. Low Voltage connection f. Description of station service requirements g. Description and timeline of interconnection and transmission plan Interconnection applications g. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application Interconnection Application	e. Max. Output Current (A) f. Rated DC Voltage g. Rated DC current h. Maximum Output (EW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating d. Low Voltage Rating f. High voltage connection g. Low Voltage connection g. Low Voltage connection g. Low Voltage connection g. Low Voltage connection f. Description of station service requirements g. Description and timeline of interconnection and transmission plan Interconnection applications g. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application Interconnection Application		2
f. Rated DC Voltage g. Rated DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection g. Low voltage connection for Description of station service requirements Description and timeline of interconnection and transmission plan Interconnection applications Interconnection Application Interconnection Application Interconnection Application Interconnection Application	f. Rated DC Voltage g. Rated DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection g. Low voltage connection for Description of station service requirements Description and timeline of interconnection and transmission plan Interconnection applications Interconnection Application Interconnection Application Interconnection Application Interconnection Application		5
g. Rated DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection g. Low voltage connection 6. Description of station service requirements 7. Description of station service requirements 8. Description and timeline of interconnection Queue number, and System impact/interconnection study documentation Interconnection Application Interconnection Application Interconnection Application Interconnection Application	g. Rated DC current h. Maximum Output (kW) g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection g. Low voltage connection 6. Description of station service requirements 7. Description of station service requirements 8. Description and timeline of interconnection Queue number, and System impact/interconnection study documentation Interconnection Application Interconnection Application Interconnection Application Interconnection Application		
h. Inwerter loading ratio i. Facility AC Capacity Rating b. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop. c. High Voltage Rating d. Low Voltage Rating e. MNA rating f. High voltage connection g. Low voltage connection g. Low voltage connection f. Description of metering, communications, and monitoring f. Description of station service requirements f. Description and timeline of interconnection and transmission plan Interconnection application for Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Application Interconnection Application	h. Inwerter loading ratio i. Facility AC Capacity Rating b. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop. c. High Voltage Rating d. Low Voltage Rating e. MNA rating f. High voltage connection g. Low voltage connection g. Low voltage connection f. Description of metering, communications, and monitoring f. Description of station service requirements f. Description and timeline of interconnection and transmission plan Interconnection application for Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Application Interconnection Application		400
g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection G. Description of metering, communications, and monitoring F. Description of station service requirements R. Description and timeline of interconnection and transmission plan Interconnection Application Interconnection Application Interconnection Application Interconnection Application	g. Facility AC Capacity Rating h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection G. Description of metering, communications, and monitoring F. Description of station service requirements R. Description and timeline of interconnection and transmission plan Interconnection Application Interconnection Application Interconnection Application Interconnection Application		In All
h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection G. Description of metering, communications, and monitoring PGE 7. Description of station service requirements PGE 8. Description and timeline of interconnection and transmission plan Interconnection Application Interconnection Application Interconnection Application	h. Inverter loading ratio i. Facility AC rating 5. Description of transformers a. # of transformers b. Model Coop c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection G. Description of metering, communications, and monitoring PGE 7. Description of station service requirements PGE 8. Description and timeline of interconnection and transmission plan Interconnection Application Interconnection Application Interconnection Application		100 P
i. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of metering communications, and monitoring 9. Gescription and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application	i. Facility AC rating 5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of metering communications, and monitoring 9. Gescription and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application		
5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application	5. Description of transformers a. # of transformers b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application		
a. # of transformers b. Model Coope c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/interconnection study documentation Interconnection Application Interconnection Application	a. # of transformers b. Model Coope c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/interconnection study documentation Interconnection Application Interconnection Application		
b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring PGE 7. Description and timeline of interconnection and transmission plan g. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	b. Model c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring PGE 7. Description and timeline of interconnection and transmission plan g. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application		
c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	c. High Voltage Rating d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/interconnection study documentation Interconnection Application Interconnection Application	a. # of transformers	
d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 9. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact/interconnection study documentation Interconnection Application Interconnection Application	d. Low Voltage Rating e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring PGE 7. Description and timeline of interconnection and transmission plan Interconnection application s 9. Transaction Service Request Number, Interconnection Queue number, and System impact/interconnection study documentation Interconnection Application	b. Model	Coop
e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Application Interconnection Application	e. MVA rating f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation Interconnection Application Interconnection Application	c. High Voltage Rating	
f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	f. High voltage connection g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	d. Low Voltage Rating	
f. High voltage connection g. Low voltage connection G. Description of metering, communications, and monitoring PGE 7. Description of station service requirements R. Description and timeline of interconnection and transmission plan Interconnection application service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application	f. High voltage connection g. Low voltage connection G. Description of metering, communications, and monitoring PGE 7. Description of station service requirements R. Description and timeline of interconnection and transmission plan Interconnection application service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application	e. MVA rating	
g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	g. Low voltage connection 6. Description of metering, communications, and monitoring 7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application		
6. Description of station service requirements PGE 8. Description and timeline of interconnection and transmission plan Interconnection application of station Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application	6. Description of station service requirements PGE 8. Description and timeline of interconnection and transmission plan Interconnection application of station Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application Interconnection Application		
7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	7. Description of station service requirements 8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application Interconnection Application	6. Description of metering, communications, and monitoring	PGE
8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application of the properties of the	8. Description and timeline of interconnection and transmission plan 9. Transaction Service Request Number, Interconnection Queue number, and System impact, interconnection study documentation Interconnection Application of the properties of the		
9. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application	9. Transaction Service Request Number, Interconnection Queue number, and System impact/Interconnection study documentation Interconnection Application		
		9. Transaction Service Request Number, Interconnection Queue number, and System impact interconnection study documentation	





OKOKK, YOU

Red Prairie So	lar, LLC				
Monthly Gen	eration Profile				
		Output (kWh)			
Month	Year 1	Avg	Max		
1	118,744	71,246	178,115		4
2	201,517	120,910	302,276		
3	257,854	154,712	386,781		
4	326,604	195,962	489,905		
5	408,263	244,958	612,394		
6	410,432	246,259	615,648		4
7	488,363	293,018	732,544		4
8	468,046	280,827	702,069		•
9	380,570	228,342	570,855	AT THE PARTY OF TH	→
10 11	244,223 137,552	146,534	366,334		•
1.1.1			フ ∩ <i>⊆₄</i> ン フ៲៲ℼ₄		•
		82,531 75,724	206,327		•
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		
12	126,207 3,568,372	75,724 2,141,023	189,310 5,352,558		



PVSYST V5.71				15/05/17 Page 1/
C	Grid-Connected System	n: Simulation	parameters	
Project :	Red Prairie			
Geographical Site	Portland,	OR	Country	USA
Situation Time defined as	Latitude Legal Time Albedo	Time zone UT-8	Longitude Altitude	
Meteo data :	Portland, OR, Synthetic Ho	urly data		
Simulation variant :	Red Prairie			
	Simulation date	15/05/17 19h25		
Simulation parameters				
Collector Plane Orientation	Titt	25°	Azimuth	0*
Horizon	Free Horizon			
Near Shadings	No Shadings			
PV Array Characteristics				
PV module		CS6X - 315P Canadian Solar I		
Number of PV modules		19 modules		515 strings
Total number of PV modules			Unit Nom, Power	
Array global power			At operating cond.	
Array operating characteristic Total area	Module area	618 V 18776 m ²		4476 A 17148 m²
Inverter	Model	Sunny Central 2	200CP-US	
	Manufacturer			
Characteristics	Operating Voltage	545-820 V	Unit Nom. Power	2200 kW AC
PV Array loss factors Thermal Loss factor => Nominal Oper. Coll. Te	Uc (const)	29.0 W/m²K C, Wind=1 m/s.)	Uv (wind) NOCT	0.0 W/m²K / m/s 45 °C
Wiring Ohmic Loss	Global array res.	2.3 mOhm	Loss Fraction	1.5 % at STC
Array Soiling Losses			Loss Fraction	
Module Quality Loss			Loss Fraction	
Module Mismatch Losses Incidence effect, ASHRAE pa	rametrization IAM -	1 - bo (1/cos i - 1		2.0 % at MPP
	nameurzauon IAM =	1 - 00 (110081 - 1) DO Falameter	0.00
System loss factors				
AC wire loss inverter to trans		385 Vac tri 83 m 2x5000 mm	Loss Fraction	1.5.% at STC
External transformer	Iron loss (24H connection)		Loss Fraction	
, And an analysis of the second	Resistive/Inductive losses		Loss Fraction	
User's needs :	Unlimited load (grid)			





Orafit. Not keep to be a second of the secon

		Exhibit C			4
	Re	equired Testing			
Required start-up test a					
features and equipment	systems, and subs	systems have been p	roperly designed,		4
manufactured, installed				AND Y	
simultaneously in such c					4
BPA/EIM/PGE's electrica	l system for delive	ry to PGE, which ma	y include but are not		
limited to (as applicable	the following:				
					7
 Safety plan during sta 	rtup and commission	oning (including the	expected number of ind	lividuals covered)	
Review of all QA/QC t	esting				
3. Confirm testing and e	nergizing inverters	in conformance witl	n manufacturer's recom	nmended	
procedures; note opera	ing voltages; and c	confirm inverter is pe	erforming as expected		
4. Energizing transforme	rs				
5. Under full sun conditi	ons, and after at le	ast 15 minutes of op	peration, taking and 🤌	9	
recording PV Plant opera	nting data—such as	but not limited to N	ЛWDC, MWAC, VDC,		
VAC, IDC, IAC, Solar Rad	ation, etc.				
6. Testing the system co	ntrol and monitori	ng system to verify	hat it is performing cor	rectly	
7. Testing the communic	ation system for o	ffsite monitoring an	d all requirements of th	e Western Energy I	mbalance Market
8. Testing the Plant met	ering and protective	e relaying to verify t	hey meet utility require	ments	
9. Documentation of su	cessful startup and	d commissioning pro	cedure		
10. Written notification	submitted by Conti	ractor to Owner tha	t the completion of Acc	eptance Testing	
and Commissioning has	occurred	4			
11. Testing to meet the	equirements of Se	ction 1.5.3.			
CX					
A U					

Orafit. Not FOR EXECUTION

• • • • •

-												
												-
				,								
								1				

				- · · · · ·		

İ						

 1 1 1	 			 	 	 	
				 			~ ~
1		1	1		1		

-						

1 1	 		 	 	 	1 1 1	
	 	 	 1 1 1	1 1 1	 		
				<u> </u>		<u> </u>	<u> </u>

	 	 , , , , ,		 	 	
 	 	 	1 1 1		 	

-						

		-					
+ + + + + + + + + + + + + + + + + + + +							
		'					
	1			1			
						1	
	1 1	-			<u> </u>		
	1						
		1	-				
+ + +	+						
	1						
