

e-FILING REPORT COVER SHEET

REPORT NAME: Supplement to Electric Service Reliability Annual Report for 2012

COMPANY NAME: Idaho Power Company

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes

If yes, please submit only the cover letter electronically. Submit confidential information as directed OAR 860-001-0070 or the terms of an applicable protective order.

If known, please select designation: RE (Electric) RG (Gas) RW (Water)
 RO (Other)

Report is required by: OAR 860-023-0150
 Statute
 Order
 Other

Is this report associated with a specific docket/case? No Yes
If Yes, enter docket number: RE 90

Key words:

If known, please select the PUC Section to which the report should be directed:

- Corporate Analysis and Water Regulation
- Economic and Policy Analysis
- Electric and Natural Gas Revenue Requirements
- Electric Rates and Planning
- Natural Gas Rates and Planning
- Utility Safety, Reliability & Security
- Administrative Hearings Division
- Consumer Services Section

PLEASE NOTE: Do NOT use this form or e-filing with the PUC Filing Center for:

- **Annual Fee Statement form and payment remittance or**
- **OUS or RSPF Surcharge form or surcharge remittance or**
- **Any other Telecommunications Reporting or**
- **Any daily safety or safety incident reports or**
- **Accident reports required by ORS 654.715.**



LISA D. NORDSTROM
Lead Counsel
lnordstrom@idahopower.com

June 4, 2013

Attention: Filing Center
Public Utility Commission of Oregon
550 Capitol Street NE, Suite 215
P. O. Box 2148
Salem, OR 97308-2148

Re: Supplement to Idaho Power Company's Electric Service Reliability Annual Report for the Year 2012

Dear Sir or Madam:

Idaho Power Company herewith transmits for electronic filing a supplement to the Electric Service Reliability Annual Report for the Year 2012, previously filed on May 1, 2013. After the filing was made, errors were found on pages 9 and 51 of the report. Enclosed are replacement pages with the corrected information.

If you have any substantive questions, please call Perry Van Patten at 208-388-5944.

Very truly yours,

A handwritten signature in black ink that reads "Lisa D. Nordstrom".

Lisa D. Nordstrom

LDN:kkt
Enclosures

Table 2
Five years of circuit SAIFI data with and without MED

Circuit	2008	2009	2010	2011	2012	2012 SAIFI
						MED Excluded
ADRN11	0.00	1.73	0.11	3.37	3.34	3.34
ADRN12	3.37	0.47	4.47	1.38	3.02	3.02
CARO11	1.38	0.24	1.07	4.27	0.29	0.29
CARO12	4.27	0.05	1.07	1.16	0.82	0.82
CARO13	1.16	0.13	0.27	1.20	0.49	0.49
CWVY11	1.20	0.73	3.17	0.47	1.13	1.09
CWVY12	0.47	5.30	4.35	2.37	2.68	2.68
DRKE11	2.37	2.31	0.00	3.48	1.07	1.07
DUKE11	3.48	3.25	1.29	3.37	2.59	1.59
DWSY11	3.37	1.00	7.00	0.00	1.23	1.23
ESTN11	0.00	0.00	0.00	0.00	4.00	4.00
HCSU11	0.00	1.50	5.14	3.51	1.00	1.00
HFVY11	3.51	2.46	0.11	4.33	2.90	0.90
HFVY12	4.33	1.02	3.29	1.69	1.71	0.37
HGTN11	1.69	0.01	1.14	0.99	2.84	2.84
HGTN12	0.99	7.60	2.34	0.55	1.04	1.04
HMDL12	0.55	3.33	3.14	1.29	1.50	1.50
HOLY11	1.29	1.17	3.27	1.28	0.43	0.43
HOLY12	1.28	1.31	2.42	1.06	0.38	0.38
HOLY13	1.06	3.20	2.24	1.87	1.46	1.43
HOPE11	1.87	3.21	8.06	3.87	0.46	0.46
HRPR11	3.87	3.52	4.37	3.25	0.29	0.21
HRPR12	3.25	2.26	3.77	4.06	1.23	1.23
JMSN11	4.06	0.52	1.48	0.24	1.21	1.16
JMSN12	0.24	2.27	3.42	3.38	2.83	2.83
JNTA11	3.38	1.12	4.30	2.06	1.37	1.37
JNTA12	2.06	6.26	8.19	7.00	1.04	1.04
JNVY11	7.00	6.12	7.56	7.43	6.18	3.18
JNVY12	7.43	8.59	8.26	7.62	6.12	3.06
JNVY31	7.62	2.52	1.94	1.32	8.36	4.41
LIME11	1.32	0.04	5.04	3.55	1.94	1.94
LIME12	3.55	0.39	1.22	1.83	0.00	0.00
MRBT41	1.83	0.20	0.10	0.10	1.15	1.15
MRBT42	0.10	1.86	0.77	0.14	1.10	1.10
NYSA11	0.14	1.20	0.95	2.01	0.13	0.13

Table 5

Five years of sustained interruption causes

Cause	Number of Sustained Interruptions					Percent of Total Sustained Interruptions				
	2008	2009	2010	2011	2012	2008	2009	2010	2011	2012
Adverse environment	2	12	99	161	104	0.31	2.09	11.47	22.24	15.23
Adverse weather	48	40	0	0	0	7.37	6.96	0.00	0.00	0.00
Customer's equipment*	15	9	7	8	35	2.30	1.57	0.81	1.10	5.12
Equipment failures	151	110	216	162	173	23.20	19.13	25.03	22.38	25.33
Foreign interference	119	99	63	11	19	18.28	17.22	7.30	1.52	2.78
Human element	36	7	20	12	15	5.53	1.22	2.32	1.66	2.20
Lightning	9	19	16	15	15	1.38	3.30	1.85	2.07	2.20
Loss of supply	38	19	26	31	25	5.84	3.30	3.01	4.28	3.66
Major events**	0	0	0	0	2	0.00	0.00	0.00	0.00	0.29
Scheduled outages	112	64	155	149	136	17.20	11.13	17.96	20.58	19.91
Tree contacts	22	25	49	45	59	3.38	4.35	5.68	6.22	8.64
Unknown	114	180	219	138	137	17.51	31.30	25.38	19.06	20.06
Total	651	575	863	724	683	100.00	100.00	100.00	100.00	100.00

*not included in calculations

**not included in calculations, see MED summary