



VIA ELECTRONIC FILING

August 6, 2021

Public Utility Commission of Oregon
Attn: Filing Center
201 High St. SE, Suite 100
Post Office Box 1088
Salem, Oregon 97308-1088

Re: WA 83 – In the Matter of Sunriver Water LLC, Expanded Service Territory Application – Public Comment Hearing Discussion Follow-Up

Administrative Law Judge Allwein:

Sunriver Water LLC (“Sunriver Water” or the “Company”) very much appreciates the robust questions and comments from, and discussion with, our customers, parties and Your Honor during the Public Comment Hearing on Wednesday, August 4, 2021. The Company asked for permission to follow-up on several items requested during the Public Comment Hearing. At your direction, we are filing this letter in the docket with the requested additional information.

- Sunriver Water’s Master Plan covers capital projects through 2040 and water resources needed for full buildout.
- The North Well location is adjacent to the North Reservoir.
- The North Well Application 16874 (Permit 17882) allows 1,790 acre-feet annual use at 3.9 CFS rate (1,750 gpm rate). This right requires mitigation to use the water. Sunriver Water already has acquired 2.1 acre-feet of permanent mitigation credits, which allows 5.25 acre-feet of use.
- Our hydrologist has confirmed that our wells are the best indicators of potential impact from external environmental factors (e.g., precipitation levels).
- Most of the Deschutes River water systems are tapping a shallow aquifer, whereas Sunriver Water’s wells are in a deeper aquifer.

Sincerely,

Sunriver Water LLC

/s/ Tim Smith

Tim Smith
General Manager
tsmith@sunriverutilities.com
(971) 285-4025