Oregon Public Utility Commission

e-FILING REPORT COVER SHEET

| COMPANY NAME: PacifiCorp d/b/a Pacific Power |
|---|
| DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes If yes, submit a redacted public version (or a cover letter) by email. Submit the confidential information as directed in OAR 860-001-0070 or the terms of an applicable protective order. |
| Select report type: RE (Electric) RG (Gas) RW (Water) RT (Telecommunications) RO (Other, for example, industry safety information) |
| Did you previously file a similar report? No See, report docket number: RE 107 |
| Report is required by: Statute Order Note: A one-time submission required by an order is a compliance filing and not a report (file compliance in the applicable docket) Other (For example, federal regulations, or requested by Staff) |
| Is this report associated with a specific docket/case? No Yes, docket number: RE 107 |
| List Key Words for this report. We use these to improve search results. |
| Major Event Report |
| Send the completed Cover Sheet and the Report in an email addressed to PUC.FilingCenter@state.or.us |
| Send confidential information, voluminous reports, or energy utility Results of Operations Reports to PUC Filing Center, PO Box 1088, Salem, OR 97308-1088 or by delivery service to 201 High Street SE Suite 100, Salem, OR 97301. |



April 6, 2023

VIA ELECTRONIC FILING

Public Utility Commission of Oregon Attn: Filing Center 201 High Street SE, Suite 100 Salem, OR 97301-3398

Re: RE 107—PacifiCorp Major Event Report

In compliance with OAR 860-023-0161, PacifiCorp d/b/a Pacific Power (PacifiCorp) submits the enclosed report describing a major event that occurred February 22-24, 2023, due to a winter storm that impacted PacifiCorp's service across the coast.

PacifiCorp requests to exclude the outage information for this event from both its network performance reporting and customer guarantee failure payments.

If you require further information regarding this report, please contact Kevin Benson, Director, Asset Risk, at (541) 213-1990.

Sincerely,

Matthew McVee

Vice President, Regulatory Policy and Operations

ph Ml/n

Enclosures

Cc: Heide Caswell/Administrator, Utility Safety, Reliability, and Security Division

Report to the Oregon Public Utility Commission

Electric Service Reliability - Major Event Report

Event Date: February 22-24, 2023

Date Submitted: April 6, 2023

Primary Affected Locations: Oregon

Primary Cause: Winter Storm

Exclude from Reporting Status: Yes

Report Prepared by: Tia Solis

Report Approved by: Kevin Benson

Event Customer Impact and Outage Summary


| Event Outage Summary | | | | | | | | | | |
|--|-----------------|--|--|--|--|--|--|--|--|--|
| # Interruptions (sustained) | 98 | | | | | | | | | |
| Total Customer Interrupted (sustained) | 8,360 | | | | | | | | | |
| Total Customer Minutes Lost | 3,747,507 | | | | | | | | | |
| State Event SAIDI | 5.90 Minutes | | | | | | | | | |
| CAIDI | 448 | | | | | | | | | |
| Major Event Start | 2/22/23 8:18 PM | | | | | | | | | |
| Major Event End | 2/24/23 2:00 PM | | | | | | | | | |

From February 22-24, 2023, Oregon experienced a major event as the result of a winter storm impacting service across the coast. During the event, 98 outages occurred affecting over 8,000 customers. Service reliability was most impacted in the Lincoln City and Coos Bay/ Coquille areas.


Weather

An area of low pressure that was originally forecasted to move across the Oregon coast and Willamette Valley, stalled just off the Oregon Coast late on the 22nd. The lead to an anomalous snowfall event that targeted the Portland Metro area as well as locations along the Oregon coast. The cold nature of the low combined with a persistent moisture fetch off the Pacific Ocean allowed for heavy bands of snow to occur for 24-36 hours over the same area. Snowfall totals ranged between 2-8 inches across the Portland Metro locations, 5-7 inches near Coos Bay and 4-6 inches around the Lincoln City area.


Below are total observed snowfall maps during a 48-hour period covering the major event period for both the Portland Metro area and coastal Oregon locations.



Portland, Oregon Metro Area 48 hour observed snowfall ending February 24, 2023



Coos Bay, Oregon 48 hour observed Snowfall end February 24, 2023




Lincoln City, Oregon 48 hour observed Snowfall end February 24, 2023

Area Outages and Restoration Details

On February 22, 2023, the coast of Oregon began seeing snowfall in the area. At the time the snow had minimal impact on reliability, however after continued snowfall the situation changed. The effects of the snow began damaging vegetation and impacting electric infrastructure. The snow accumulated on trees and caused branches and trees to give way, downing lines across the area. As the weather continued, further and continual impacts to electric infrastructure was experienced. During the event, tree crews cleared interfering vegetation while line crews followed, making repairs, and restoring customers. Approximately, 45% of customer minutes lost (CML) was related to tree damage and 41% related to weather with Lincoln City having the greatest impact at 90% of CML. The below figure shows the CML along the coast over the course of the major event.

Coast Plus CML February 22nd at 20:18 to February 24th at 14:00




Restoration Intervals


| Total Customer Sustained Outage Events | < 3 Hrs. | 3 – 24 Hrs. | 24+ Hrs. |
|--|----------|-------------|----------|
| 8,360 | 2,148 | 5,891 | 321 |

Major Event Declaration

PacifiCorp designates these events and the consequences thereof a major event in accordance with OAR 860-023-0161. This is a major event because it exceeded the design or operating limits of the system, and the Major Event Threshold for Oregon as calculated annually by the company according to IEEE 1366-2022 methodology (commonly referred to as the 2.5 beta method). The company's 2022 Oregon reliability threshold is 4,723,224 customer minutes lost (7.50 Oregon SAIDI minutes) in a 24-hour period.


Event Details





SAIDI, SAIFI, CAIDI by Reliability Reporting Region

Please see the attached system-generated reports.



PacifiCorp Major Event Report

Customer Analysis

| | CoastPlus Oregon | Customer Analysis 2/22/2023 through 2/24/2023 | | | | | | Customers Restored by Intervals | | | | | | | | Major Event Only - metric by operating area customer counts | | |
|----|---|--|------------------------------|-----------|---|-------------------|---------|---------------------------------|-------------------|--------------------|--------------------|--------------------|----------|--|--------|---|-------|--|
| | PacifiCorp Major Events Report Customer Analysis* | Sustained Customers Off | % Sustained Customers Off | CML | Number of Sustained Interruptions | Customer Count | < 5 min | 5 min - 3 hrs | 3 hrs - 24 hrs | 24 hrs - 48 hrs | 48 hrs - 72 hrs | 72 hrs - 96 hrs | 96 + hrs | % Sustained Customers Restored in 3 Hours PS4 | SAIDI | SAIFI | CAIDI | |
| PC | PACIFICORP | 8,321 | 0% | 3,712,425 | 97 | 2,054,233 | _ | 2,143 | 5,857 | 321 | _ | l <u>-</u> | | 26% | 1.81 | 0.004 | 446 | |
| PC | PACIFICORP | 0,321 | 0% | 3,/12,423 | 97 | 2,054,255 | - | 2,143 | 5,657 | 321 | - | - | - | 20% | 1.01 | 0.004 | 440 | |
| PP | Pacific Power | 8,321 | 1% | 3,712,425 | 97 | 812,454 | - | 2,143 | 5,857 | 321 | - | - | - | 26% | 4.57 | 0.010 | 446 | |
| OR | Oregon | 8,321 | 1% | 3,712,425 | 97 | 629,398 | - | 2,143 | 5,857 | 321 | - | - | - | 26% | 5.90 | 0.013 | 446 | |
| OR | CLATSOP (ASTORIA) | | | | | | | | | | | | | | | | | |
| OR | COOS BAY/COQUILLE | 2,043 | 8% | 334,368 | 21 | 26,193 | - | 1,478 | 565 | - | - | - | - | 72% | 12.77 | 0.078 | 164 | |
| OR | HOOD RIVER | , | | , | | , | | | | | | | | | | | | |
| OR | LINCOLN CITY | 5,837 | 47% | 3,319,661 | 60 | 12,424 | - | 313 | 5,203 | 321 | - | - | - | 5% | 267.20 | 0.470 | 569 | |
| OR | PORTLAND | 441 | 1% | 58,396 | 16 | 86,563 | - | 352 | 89 | - | - | - | - | 80% | 0.67 | 0.005 | 132 | |
| | | | | | | | | | | | | | | | | | 1 | |

^{*}Only current event specific metric impact shown. Does not include values from other events which may have occurred in other regions during the same time period.

| Data as of | |
|------------|--|
| 3/7/2023 | |

PacifiCorp Major Event Report SSC by State Analysis

| | C+Dl C | Event | | 02/22/23 | through | 02/24/23 | | Month | | 02/01/23 | through | 02/28/23 | | YTD | FY2024 | 01/01/23 | through | 02/28/23 | |
|----|--|-------|-------|-----------------------|---------|----------|------------------------|-------|-------|-----------------------|---------|----------|------------------------|-------|--------|----------|---------|----------|-------|
| | CoastPlus Oregon Major Events Included Major Event Excluded | | | Major Events Included | | | Major Events Excluded* | | | Major Events Included | | | Major Events Excluded* | | | | | | |
| | PacifiCorp | | | | | | | | | | | | | | | | | | |
| | Major Events Report | | | | | | | | | | | | | | | | | | |
| | SSC by State | SAIDI | SAIFI | CAIDI | SAIDI | SAIFI | CAIDI | SAIDI | SAIFI | CAIDI | SAIDI | SAIFI | CAIDI | SAIDI | SAIFI | CAIDI | SAIDI | SAIFI | CAIDI |
| | | | | | | | | | | | | | | | | | | | |
| PC | PACIFICORP | 5.73 | 0.027 | 214 | 1.36 | 0.009 | 153 | 11.27 | 0.073 | 155 | 6.91 | 0.055 | 126 | 28.84 | 0.165 | 174 | 15.84 | 0.124 | 127 |
| | | | | | | | | | | | | | | | | | | | |
| PP | Pacific Power | 11.59 | 0.050 | 233 | 0.54 | 0.005 | 120 | 20.54 | 0.114 | 181 | 9.49 | 0.068 | 139 | 34.34 | 0.238 | 144 | 20.13 | 0.174 | 116 |
| | | | | | | | | | | | | | | | | | | | |
| OR | Oregon | 6.45 | 0.018 | 367 | 0.56 | 0.004 | 127 | 13.99 | 0.079 | 177 | 8.09 | 0.066 | 123 | 25.41 | 0.189 | 135 | 19.51 | 0.176 | 111 |
| | | | | | | | | | | | | | | | | | | | |
| OR | CLATSOP (ASTORIA) | 0.00 | 0.000 | 280 | 0.00 | 0.000 | 280 | 0.21 | 0.002 | 93 | 0.21 | 0.002 | 93 | 1.87 | 0.040 | 47 | 1.87 | 0.040 | 47 |
| OR | COOS BAY/COQUILLE | 0.53 | 0.003 | 163 | 0.00 | 0.000 | 86 | 0.73 | 0.005 | 154 | 0.20 | 0.002 | 134 | 1.65 | 0.010 | 170 | 1.11 | 0.006 | 173 |
| OR | HOOD RIVER | | | | | | | 0.04 | 0.000 | 196 | 0.04 | 0.000 | 196 | 0.15 | 0.001 | 165 | 0.15 | 0.001 | 165 |
| OR | LINCOLN CITY | 5.28 | 0.009 | 567 | 0.00 | 0.000 | 80 | 5.54 | 0.020 | 273 | 0.26 | 0.011 | 24 | 5.62 | 0.021 | 268 | 0.35 | 0.012 | 30 |
| OR | PORTLAND | 0.11 | 0.001 | 142 | 0.02 | 0.000 | 214 | 0.13 | 0.001 | 153 | 0.04 | 0.000 | 250 | 0.90 | 0.007 | 134 | 0.80 | 0.006 | 134 |
| | | | | | | | | | | | | | | | | | | | |

^{*}may include other regional major event exclusions during the same period. Operating areas are calculated by the state frozen customer count metrics.

| Data as of | |
|------------|--|
| 3/7/2023 | |

4/6/2023