e-FILING REPORT COVER SHEET



COMPANY NAME: PORTLAND GENERAL ELECTRIC COMPANY

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes If yes, submit a redacted public version (or a cover letter) by email. Submit the confidential information as directed in OAR 860-001-0070 or the terms of an applicable protective order.
Select report type: RE (Electric) RG (Gas) RW (Water) RT (Telecommunications) RO (Other, for example, industry safety information)
Did you previously file a similar report? Yes, report docket number: RE 112
Report is required by: Statute Order Note: A one-time submission required by an order is a compliance filing and not a report (file compliance in the applicable docket) Other (For example, federal regulations, or requested by Staff)
Is this report associated with a specific docket/case? No Yes, docket number:
List Key Words for this report. We use these to improve search results.
MAJOR EVENT EXCLUSION
Send the completed Cover Sheet and the Report in an email addressed to PUC.FilingCenter@state.or.us
Send confidential information, voluminous reports, or energy utility Results of Operations Reports to PUC Filing Center, PO Box 1088, Salem, OR 97308-1088 or by delivery service to 201 High Street SE Suite 100, Salem, OR 97301.



February 8, 2019

Oregon Public Utility Commission Attn: Filing Center 201 High Street, S.E. Salem, OR 97308-1088

Re:

Major Event Exclusion

Period:

January 5, 2019

Portland General Electric (PGE) hereby submits this report in compliance with OAR 860-023-0161 which requires the electric company to file a report with the Commission within 30 business days after the conclusion of an event. This report provides a summary of the major storm event that occurred on January 5, 2019.

OAR 860-023-0161: Major Event Filing by Electric Companies

1. Description of the major event, the interruption causes, and factors that impacted restoration of service.

On January 5, 2019 PGE's entire service territory experienced a wind storm causing widespread outages. The Portland area experienced wind gusts of 54 MPH, Salem experienced wind gusts of 54 MPH, and Hillsboro experienced wind gusts of 44 MPH.

The severe wind caused many tree-related outages. Uprooted trees and broken limbs caused damage to PGE's overhead equipment and poles which made restoration difficult.

2. The reliability reporting area and geographic area impacted.

PGE's entire service territory was impacted by the January 5th wind storm. Most outages were in PGE's eastern service territory.

3. The total number of customers affected and the number of customers without service at periodic intervals.

At the peak of the storm, PGE had approximately 56,801 customers without power. During the storm, a total of 57,187 customers were affected.

4. The calculated SAIDI, SAIFI, and CAIDI impacts (i.e., "Event SAIDI¹, SAIFI², CAIDI³ and Tmed⁴") associated with the Major Event on a reliability reporting area and a system-wide basis.

The following table represents the calculated impacts for SAIDI, SAIFI, CAIDI, Tmed, and system-wide basis totals:

	RELL	ABILITY REPORTING	AREAS	SYSTEM-WIDE BASIS
	EASTERN ¹	SOUTHERN	WESTERN	PGE SERVICE TERRITORY
SAIDI ²	10.64	4.16	5.89	20.69
SAIFI³	0.04	0.01	0.02	0.07
CAIDI⁴	298	550	275	320
Customers out at peak	31,202	6,679	18,920	56,801
T med				5.31

¹ Eastern and Central regions are now combined and represented as the Eastern region.

² SAIDI - System Average Interruption Duration Index

³ SAIFI - System Average Interruption Frequency Index

⁴ CAIDI - Customer Average Interruption Duration Index

Major Event Exclusion Occurred: January 5, 2019 Page 3 of 3

Additional Reporting Related to the January 5, 2019 Storm Event:

Attachment A provides a summary of outages within PGE's service territory lasting 5 hours or longer.

For questions regarding this filing, please contact Kalia Savage at (503) 464-7432. Please direct all formal correspondence and requests to the following email address pge.opuc.filings@pgn.com.

Sincerely,

James Landstrom,

Manager, Transmission and Distribution Asset Management

Enclosures

Major Event Exclusion Period: January 5, 2019 Attachment A

Summary of Outages 5 Hours and Longer for the Entire PGE Service Territory

ā		2,542	2.218	2,208	1,634	1,494	1,485	1,484	1,433	1,405	1,403	1,401	1,392	1,391	1,379	1,371	1,354	1,328	1,328	1,328	1,32/	1,321	1,319	1,311	1,296	1,288	1,2/9	1,273	1,255	1,254	4 t	1,24/	1,239	1,230	1.231	1,226	1,223	1,223	1,221	1,207	1,197	1,197	1,197	1,196	1,196	1,193	1,191	1,188	1,187	1,18/	1,183 1,182
CAID	5 6	0, C	2,2	2.2	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,3	1,3	1,3	1,3		L, L	τ, τ.	£,1	τ.	E, I	אל י	ח, י	1,7	1,2	1,7	1,2	1,2	7,1	7,4	1, L	1,7	1,1	1.2	1,2	1,2	1,2	1,2	1,2	1,1	1,1	1,1	1,1	1,1	1,1	1,1	1,1	ב, ,		7 7
SAIE	1 17 1	5.13E-00 6.33E-05	2.26E-06	3.39E-06	6.78E-06	2.26E-06	4.41E-05	1.13E-06	1.13E-06	1.13E-06	1.47E-05	1.13E-06	3.39E-06	2.94E-05	1.13E-06	1.13E-06	2.09E-04	1.135-06	2.26E-06	2.26E-Ub	6.10E-05	6.78E-06	1.135-06	2.26E-06	Z.U3E-U5	1.13E-06	1.135-06	1.13E-06	2,26E-06	4.25E-Ub	1.135-00	1.13t-0b	3.65E-U6	3.28E-05	1.13E-06	1.13E-06	3.39E-06	1.13E-06	1.13E-06	7.23E-05	1.13E-06	7.91E-06	1.13E-06	1.13E-06	3.28E-05	1.13E-06	4.86E-05	5.31E-05	1.13E-06	1.13E-06	1.13E-06 1.13E-06
SAID	ממסט מ	0.002647	0.005014	0.007489	0.011078	0.003377	0.065459	0.001678	0.001619	0.001588	0.020617	0.001584	0.00472	0.04089	0.001559	0.00155	0.283034	0.001501	0.003001	U.UUSUUI	0.081015	0.008959	0.001491	0.002964	0.025358	0.001456	0.001446	0.001439	0.002838	0.002835	0.00141/	0.00141	0.00/001	0.001339	0.001391	0.001386	0.004147	0.001382	0.00138	0.08733	0.001353	0.009471	0.001353	0.001352	0.039204	0.001348	0.057895	0.063089	0.001342	0.001342	0.001337 0.001336
Internit Location	וווופון חמר במבמומוו	FUSE_UH:D4430C-604 / B / B A	COL	FUSE OH:D3331C-473 / AB / 10 A	FUSE_OH:D1134D-3346 / C / 50 A	FUSE_OH:D3231D-2932 / B / 6 A	FUSE_OH:D3228D-492 / ABC / 65 A	SP:23525 S SPANGLER RD	SP:5635 SE JENNE RD	SP:28380 SE BROADLEAF RD	FUSE_OH:D5321B-864 / B / 6 A	SP:Null_23	SP:15243 NE COUNTRYSIDE DR	FUSE_OH:D4201C-2241 / B / 40 A	SP:15428 S HOLCOMB BLVD	SP:7882 JORDAN ST SE_2	FUSE_OH:D1228B-2661 / BC / 100 A	SP:1/200 S OLD RIVER RD_1	XFM_UG:C 50 33623	SP:4/11 SE 1/41H AVE	RECL:3115	FUSE_OH:C4133B-1481 / ABC / 40 A	SP:6255 SW TOWER WAY	SP:2310 SE CONCORD RD	FUSE_UH:C3225A-1/29 / A / 25 A	SP:247 MILL ST	SP:9920 SE CARUTHERS ST	SP:4721 NE 148TH AVE	SP:9920 SE CARUTHERS ST	SP:16565 SW 1131H AVE	SP:16550 SW 1131H AVE	SP:6598 N PORTSMOUTH AVE_10	FUSE_OH:D2335A-1534 / A / 25 A	SP:351 NE 41H AVE SP:10343 BBICK BD SE	SP-1301 MARSHAIL DR SF	XFM UG:A 15 35178	XFM OH:A 15 21987	SP:6821 SW TERWILLIGER BLVD	SP:5301 EDMOND LN NE	FUSE_OH:D6115D-2059 / B / 65 A	SP:3225 SE 58TH AVE	FUSE_OH:D2305C-169 / C / 40 A	SP:18000 SE SUNNYSIDE RD	SP:4809 SW VERMONT ST	FUSE_OH:C3121D-1444 / AB / 25 A	SP:6835 SW 46TH AVE	FUSE_OH:D1121A-60 / ABC / 100 A	FUSE_OH:D4227B-3017 / B / 65 A	SP:1701 PINE ST NE	SP:11025 SW 3/TH AVE	SP:16300 SE HWY 224_1 FUSE_OH:D1121A-60 / B / 100 A
																																,																			
Return		7:04 PIN	10-45 AM	11:20 AM	1:50 AM	11:31 PM	11:16 PM	11:52 PM	10:39 PM	10:25 PM	9:39 PM	9:17 PM	9:17 PM	9:40 PM	10:30 PM	8:23 PM	9:17 PM	8:52 PM	9:05 PM	9:05 PM	8:27 PM	7:38 PM	8:00 PM	8:20 PM	/:25 PM	8:43 PM	7:56 PM	8:07 PM	8:04 PM	7:11 PM	MAII!	8:05 PM	7:09 PM	6.55 PIN	5.51 PM	6:10 PM	5:45 PM	7:35 PM	5:42 PM	6:37 PM	7:33 PM	6:28 PM	6:28 PM	7:32 PM	5:44 PM	7:30 PM	6:54 PM	6:24 PM	5:25 PM	5:44 PM	6:06 PM 6:53 PM
Return	חמוב	1/7/19	1/7/19	1/7/19	1/7/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/13	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/10	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19
Customer	Millates	2342 1207E3	4436	6625.4	9801	2988	57911.1	1484.116667	1432.6	1405.2	18240.08333	1401	4176	36174.66667	1378.8	1371.2	250397.5	1328	2655.266667	2655.2	71673.3	7926	1319.066667	2622.5	23319	1287,966667	1279.333333	1273	2510,5	2508.566667	1254	1247	6193.666667	1238 25944	1231 016667	1226	3669.25	1223.05	1220.6	77259.73333	1197	8379	1197	1196	34683.03333	1193	51218.73333	55814.06667	1187.483333	1187	1182.516667 1181.6
400	Julation	2342	7218	2208	1634	1494	1485	1484	1433	1405	1403	1401	1392	1391	1379	1371	1354	1378	1328	1328	1327	1321	1319	1311	1296	1288	1279	1273	1255	1254	1254	1247	1239	1238	1230	1226	1223	1223	1221	1207	1197	1197	1197	1196	1196	1193	1191	1188	1187	1187	1183 1182
Customers	١	T 2		l rr	9 49	2	39	Н	П	н	13	П	ю	26	Н	Н	185	Н	5	7	54	φ .	ч .	5	18	1		Н	7	7	r-t i	Н :	rv 4	- F	7 -	٠.	ım	1	н	64	Н	7	₽	₩	29	н	43	47	H	Н.	ਜ ਜ
		11:52 PM COLLON-GRAYS HILL	C	10:32 PM IFLAND-CARIIS	0	10:37 PM LELAND-CARUS	10:32 PM LELAND-CARUS	11:08 PM LELAND-CARUS	10:47 PM EASANT VALLEY-PLEASANT 13	11:00 PM :STACADA-ESTACADA 13	10:16 PM COLTON-DHOOGHE	9:56 PM CANBY-BUTTEVILLE	10:05 PM CANBY-BUTTEVILLE	10:29 PM LELAND-CARUS	11:32 PM (BERNETHY-OREGON CITY	Σ	10:44 PM BELL-BATTIN	10:44 PM JSWEGO-MARYLHURST	10:58 PM RAMAPO-GILBERT	10:58 PM RAMAPO-GILBERT	10:20 PM YAMHILL-CARLTON	9:37 PM ORTH MARION-HUBBARD	10:01 PM GLENCULLEN-SUNSET	10:28 PM NNINGS LODGE-OAK GROVE	9:50 PM WILSONVILLE-WEST	11:15 PM MOBILE 5-QUEBEC	10:37 PM KELLY BUTTE-MALL 205	10:54 PM HEMLOCK-MASON	11:09 PM KELLY BUTTE-MALL 205	10:17 PM (ING CITY-SUMMERFIELD	(ING CIT)	11:18 PM DELAWARE-LOMBARD	10:31 PM EAGLE CREEK-RIVER MILL	IU:I8 PM HILLSBURU-JACKSUN			9:22 PM /ACONDA-WACONDA 13	11:12 PM RIVERVIEW-FULTON	9:22 PM /ACONDA-WACONDA 13	10:30 PM 20TTS MILLS-SCOTTS MILLS 13	11:36 PM ARLETA-POWELL	10:31 PM CARVER-CARVER 13	10:31 PM CARVER-CARVER 13	11:36 PM GLENCULLEN-SUNSET	9:49 PM WILSONVILLE-WEST	11:37 PM GLENCULLEN-SUNSET	11:03 PM RIVERVIEW-FULTON	_	9:38 PM MOBILE 5-QUEBEC		10:24 PM CARVER-WOODS 11:12 PM RIVERVIEW-FULTON
				•																	٠.																	` '													
_	1	4 1/5/19						4 1/5/19	0 1/5/19	2 1/5/19	9 1/5/19	8 1/5/19	2 1/5/19	4 1/5/19																				2/5/19								3 1/5/19	8 1/5/19		9 1/5/19	8 1/5/19	7 1/5/19				6 1/5/19 5 1/5/19
1	Onrage #	461654	455505	462475	460120	461631	459842	461094	460760	460742	458829	458558	458622	459684	461423	457863	459965	460332	460832	460835	462460	457794	458594	459387	458286	461114	460093	460823	460934	459117	459118	461494	460017	459198	450221	457053	457643	461240	457642	463935	461529	459473	459768	461573	458229	461578	461677	459821	457893	458562	462376 464895

	CAIDI	1,181	1,180	1,176	1,174	1,174	1,167	1,152	1,148	1,146	1,139	1,137	1,131	1,128	1,124	1,115	1,112	1,111	1,111	1,111	1,108	1,108	1,108	1,106	1,098	1,097	1,095	1,093	1,091	1,075	1,074	1,074	1,065	1,056	1,052	1,038	1,038	1,033	1,030	220,	1,022	120,	1,006	1,006	995	500	993	992	288	982	979	9/4	975 969
	SAIFI C	1.13E-06 1	1.13E-06 1	,,	2.26E-06 1	5.65E-06 1	1.13E-06 1		4.52E-06 1	4.52E-06 1	L.13E-06 1			2.26E-06 1	L.13E-06 1		L.13E-06 1					L.13E-06 1						2.37E-05 1											1.13E-06 1														1.58E-05 1.13E-06
	SAIDI SA	0.001335 1.13	0.001334 1.13		0.002654 2.26	0.006633 5.65	0.001319 1.13	0.001302 1.13	0.005191 4.52	0.00518 4.52	0.001287 1.13	٠,		• •	0.001271 1.13	0.00126 1.13	0.001257 1.13			- 1		٠.				٠.		0.025955 2.37						- -1					0.001165 1.13		0.00231 2.20								_				0.001095 1.58 0.001095 1.13
		0	Ó	Ö	Ö	O	o o	o	o	0	Ö	0	ď	0	Ö	0	Ö	Ö	o	0	o	o'	Ö	0	o o	0	o	o	Ö	ö	Ö	Ö	o	o.	o	Ö	o i	o o	o o	5 5	5	o o	o (o o	o o	o o	o (o' '	0	o i	o (o o
	Interrupt Location	SP:6829 SW 7TH AVE	SP:1870 HEMLOCK ST	FUSE_OH:C8217D-443 / BC / 40 A	SP:19065 PEASE RD	FUSE_OH:D4212C-733 / C / 25 A	SP:6730 SE 67TH AVE	SP:23200 SW GRAHAM'S FERRY RD	FUSE_OH:D4323C-674 / B / 25 A	SP:13092 ARNDT RD NE_3	SP:23737 SW ELDERBERRY LN	SP:22306 BENTS RD NE_1	FUSE_OH:D4405D-11 / ABC / 40 A	XFM_OH:B 15 13746	SP:25230 S WALLENS RD	SP:9580 SW OMARA ST	SP:39400 PIONEER BLVD	XFM_OH:B 37.5 3144	SP:21180 S SWEETBRIAR RD	FUSE_OH:C2102C-2441 / B / 40 A	SP:18830 S HWY 99E_Z	SP:10471 SE 55TH AVE	SP:39893 SW BLOOMING-FERN HILL RD_1	SP:39893 SW BLOOMING-FERN HILL RD	SP:01520 SW CORBETT HILL CIR	SP:6730 SE 67TH AVE	SP:240 21ST ST SE	SP:5422 PORTLAND RD NE_16	SP:23201 SE BORNSTEDT RD	SP:25588 S RHOTEN RD_3	RECL:7678	FUSE_OH:C1112A-2379 / AC / 65 A	FUSE_OH:C5124C-2510 / AC / 25 A	SP:185 EAST ST	FUSE_OH:C8414A-212 / AC / 40 A	FUSE_OH:C2119C-1795 / B / 40 A	FUSE_OH:D1135B-1865 / C / 40 A	SP:7113 CROOKED FINGER RD NE	SP:18/98 S HWY 99E	2F.337/U 3E JACKSON 31	SP.18/30 SW PACIFIC HW1	SPITEOUS SVV PACIFIC HVV I_I	SW_UHLB:6363	SPITSETU SW PACIFIC HWY_1	FUSE_UH:C411/U-523 / ABC / 55 A	FUSE_UH:C1218C-429 / ABC / 4U A	FUSE_UH:D4430A-184 / B / 25 A	SP:1730 SW COLLINS CT	SP:2/83 KIUGEWAY DR SE	SP:1730 SW COLLINS CT	SP:1424 SW FREEMAN ST	SP:43261 SE KEISELKER KU	FUSE_OH:DZZI5D-/Z05 / AC / 40 A FUSE_OH:DS305D-630 / B / 6 A
Return	Time	6:53 PM	5:46 PM	4:39 PM	6:03 PM	7:06 PM	5:52 PM	5:26 PM	6:16 PM	4:33 PM	5:29 PM	4:33 PM	5:48 PM	5:48 PM	5:48 PM	4:57 PM	5:01 PM	4:35 PM	4:41 PM	4:37 PM	4:39 PM	4:32 PM	4:41 PM	4:39 PM	4:15 PM	5:52 PM	5:19 PM	3:39 PM	4:56 PM	4:20 PM	4:51 PM	4:59 PM	3:23 PM	4:38 PM	2:37 PM	2:44 PM	4:02 PM	3:02 PM	4:39 PM	1413 00.4	3:20 PIVI	3:20 PIV	3:39 PIVI	4:20 PIVI	NIA GT:Z	2:35 PIVI	2:56 PIVI	2:48 PM	1:55 PIVI	2:52 PM	2:41 PM	3:US PIVI	3:11 PM 3:17 PM
Return	Date	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	CT/0/T	1/0/13	1/0/13	1/6/19	1/6/19	1/0/13	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	67/9/7	1/6/19 1/6/19
Customer	Minutes	1181	1180.466667	79980.46667	2348.266667	5868.25	1167	1152.15	4592.666667	4583.066667	1139	2273.633333	19227	2256.266667	1124	1114.866667	1112	17781.33333	1111.016667	. 69987.75	1108.133333	1108	1107.683333	1105.833333	1097.933333	1097.233333	1095	22962.45	1091	1075	196477.95	135262	6391.8	1056.05	13682.28333	23866.71667	43581	1033.183333	1030.333333	5055	2043.833333	1021	3691/1.416/	1005.5	69683.83333	33819.8	10918.4166/	992	19/6.666666/	982.1	979	1948.133333	13508 968.9333333
	Duration	1181	1180	1176	1174	1174	1167	1152	1148	1146	1139	1137	1131	1128	1124	1115	1112	1111	1111	1111	1108	1108	1108	1106	1098	1097	1095	1093	1091	1075	1074	1120	1065	1056	1052	1038	1084	1033	1030	1020	1071	1707	1006	1005	ς Σ τ	995	993	992	288	982	979	4/6	976 969
Customers	Affected	1	↔	89	2	r.	1	Н	4	4	н	2	17	2	н	н	H	16	Н	63	н	Н	1	н	₩	Н	н	21	ᆏ	н	183	126	9	Н	13	23	42	ᠳ,	٦ ٢	3 6	7 7	, t	36/	F	2 2	4 4	Ι,	Η (7	ਜ '	근 (7;	14 F
Outage	Time Feeder Name	11:12 PM RIVERVIEW-FULTON	10:06 PM SULLIVAN-SUSSEX	2	10:29 PM 1T PLEASANT-CLAIRMONT	11:33 PM LELAND-CARUS	10:25 PM BELL-SOUTHGATE	10:14 PM TUALATIN-IBACH	11:08 PM COLTON-GRAYS HILL	9:28 PM FARGO-FARGO 13	10:30 PM SULLIVAN-WILLAMETTE	9:37 PM FARGO-FARGO 13	10:57 PM :STACADA-NORTH FORK	11:00 PM :STACADA-NORTH FORK	11:04 PM :STACADA-NORTH FORK	10:22 PM TIGARD-13337	10:29 PM SANDY-WILDCAT	10:04 PM BELL-KING	Š	10:07 PM TIGARD-13337	Į	10:04 PM BELL-KING		10:14 PM DILLEY-DILLEY 13	9:58 PM !VERVIEW-TERWILLIGER		_	9:26 PM INDIAN-LABISH	10:45 PM SANDY-WILDCAT				9:38 PM MOLALLA-YODER	11:02 PM /T PLEASANT-RIVERCREST	9:05 PM FAIRMOUNT-MISSION	9:27 PM 3IX CORNERS-BORCHERS	9:58 PM OSWEGO-PALATINE	9:48 PM COTTS MILLS-SCOTTS MILLS 13	11:29 PM 41 PLEASAN -SOUTH END	ũ	10:25 PIVI SIX CORNERS-13500			_			TO:24 PIM COLI ON-GRAYS HILL	10:16 PM MULTNOMAH-13176	9:2/ PM BARNES-COMMERCIAL	10:30 PM MULTNOMAH-13176	10:22 PM MULTNOMAH-13176	10:54 PIN SANDY-SANDY 13	10:59 PM (BERNETHY-OREGON CLIY 11:09 PM COLTON-DHOOGHE
Outage	Date	1/5/19	1/5/19	1/5/19	1/5/19	1/5/19	1/5/19	1/5/19	1/5/19	1/5/19	1/5/19			1/5/19	1/5/19													1/5/19							1/5/19	1/5/19	1/5/19		1/5/19														1/5/19
	Outage #	461238	458626	457410	459676	461512	464280	461416	460941	457843	463698	457887	461019	460963	461003	463815	459744	463587	460901	458864	458683	462743	459039	459037	458572	461435	461037	457710	460752	463899	463639	460670	457895	460857	457478	457624	458422	458226	461408	450554	453564	409000	46081/	461438	458239	461594	459381	459086	45//53	459400	459554	460815	460/50 461101

	⋖ . ∢	. ◀	. 4
SP:14381 S CLGCKAMAS RIVER DR FUSE_OH:D2209B-3231 / ABC / 100 A	SP:1438.15 CLACKAMAS RIVER DR FUSE_OH:D2209B-3231 / ABC / 100 A FUSE_OH:C1135D-55 / ABC / 40 A SP:1651.37TH AV NW FUSE_OH:B213B-407 / AC / 6 A SP:14140 NW MCDANIEL RD FUSE_OH:C2128C-37Z8 / A / 65 A FUSE_OH:C3128.74 / 65 A FUSE_OH:C3134 WIPPER RD SE SP:SW 61.500 FT N/O CANYON CT SP:15802 NW SHEITERED NOOK RD FUSE_OH:C3201D-181 / C / 65 A SP:355 SW JOSHUA PL_1 REC1:3468 FUSE_OH:D3217D-2573 / B / 65 A FUSE_OH:D3217D-2573 / B / 65 A FUSE_OH:D3210B-1790 / AC / 40 A SP:16805 NW COREY RD_1 FUSE_OH:D1107D-3231 / BC / 65 A	CLACKAMAS RIVER DR 2209B-3231 / ABC / 100 A 31135D-55 / ABC / 100 A 311435D-55 / ABC / 100 A 31714 AV NW 82213B-407 / AC / 6 A NW MCDANIEL RD 22128C-3728 / A / 65 A 94334D-462 / AB / 65 A WIPPER RD 5E 00 FT N/O CANYON CT A SHELTERED NOOK RD C3217D-231 / C / 65 A 3W 105HUA PL_1 3468 22217D-2573 / B / 65 A 33210B-1780 / AC / 40 A 33210B-1780 / AC / 40 A 33210B-1625 / ABC / 100 A 1107D-1625 / ABC / 100 A 1107D-1625 / ABC / 65 A C3114A-4834 / C / 25 A D88105A-370 / C / 15 A B8226C-1020 / C / 40 A 52126C-4187 / AC / 40 A 32505C-813 / ABC / 6 A CLACKAMAS BLVD C4111B-310 / BC / 60 A CALCKEK RD C4111B-310 / BC / 40 A	SP:1438.15 CLACKAMAS RIVER DR FUSE_OH:C1135D-55 / ABC / 100 A FUSE_OH:C1135D-55 / ABC / 100 A FUSE_OH:C2135D-55 / ABC / 40 A SP:1651 37TH AV NW FUSE_OH:B213B-407 / AC / 6 A SP:14140 NW MCDANIEL RD FUSE_OH:C2128C-3728 / A / 65 A FUSE_OH:C3201D-181 / C / 65 A SP:8513 WIPPER RD SE SP:8W 61 500 FT N/O CANYON CT SP:2802 NW SHELTERED NOOK RD FUSE_OH:C3201D-181 / C / 65 A SP:385 SW JOSHUA PL_1 RECL:3468 FUSE_OH:D217D-2573 / B / 65 A FUSE_OH:D217D-3231 / BC / 65 A FUSE_OH:D3107D-3231 / BC / 65 A FUSE_OH:D1107D-3231 / BC / 65 A FUSE_OH:C3114A-4834 / C / 25 A FUSE_OH:C3114A-4834 / C / 25 A FUSE_OH:C3126C-4187 / AC / 40 A FUSE_OH:C3126C-4187 / AC / 40 A FUSE_OH:C3126C-4187 / AC / 40 A FUSE_OH:C1110B-310 / BC / 60 A SP:250 OH:D1118B-4531 / AC / 5 A FUSE_OH:C11118B-4531 / AC / 25 A FUSE_OH:C11118B-4531 / A / 25 A FUSE_OH:C11118B-4531 / A / 25 A FUSE_OH:C1110B-4039 / AB / 100 A SP:5900 S HWY 211 FUSE_OH:C1110B-4039 / AB / 100 A SP:5900 S HWY 211 FUSE_OH:C1110B-4039 / AB / 100 A SP:5900 S HWY 211
7115E OU.C112ED.EE / AI	FUSE_OH:C1135D-55 / ABC / 40 A SP:1651.37TH AV NW FUSE_OH:B2213B-407 / AC / 6 A SP:11410 NW MCDANIEL RD FUSE_OH:C3232B-3728 / A / 65 A FUSE_OH:D4334D-462 / AB / 65 A SP:851.3 WIPPER RD SE SP:3W 61.500 FT N/O CANYON CT SP:15802 NW SHEFTERED NOOK RD FUSE_OH:C3201D-181 / C / 65 A SP:7355 SW JOSHU A PL_1 RECL:3468 FUSE_OH:D217D-2573 / B / 65 A FUSE_OH:D217D-2573 / B / 65 A FUSE_OH:D210D-1790 / AC / 40 A SP:16805 NW COREY RD_1 FUSE_OH:D210D-3231 / BC / 65 A FUSE_OH:D210D-3231 / BC / 65 A FUSE_OH:D210D-3231 / BC / 65 A FUSE_OH:D1107D-3231 / BC / 65 A	FUSE_OH:C1135D-55 / ABC / 40 A SP:1651.37TH AV NW FUSE_OH:B2213B-407 / AC / 6 A SP:11410 NW MCDANIEL RD FUSE_OH:C1128C-3728 / A / 65 A SP:28C_OH:D4334D-462 / AB / 65 A SP:38C_OH:D4334D-462 / AB / 65 A SP:38W 61.500 FT N/O CANYON CT SP:3W 61.500 FT N/O CANYON CT SP:3W 61.500 FT N/O CANYON CT SP:3W 61.500 FT N/O CANYON CT SP:3SS SW JOSHUA PL_1 RECL:3468 FUSE_OH:D2117D-2573 / B / 65 A FUSE_OH:D31107D-3231 / BC / 65 A FUSE_OH:C3114A-4834 / C / 25 A FUSE_OH:C3114A-4834 / C / 25 A FUSE_OH:C31120B-256 / AB / 25 A FUSE_OH:C3120B-256 / AB / 25 A FUSE_OH:D310B-256 / AB / 25 A FUSE_OH:C31120B-256 / AB / 25 A FUSE_OH:C31120B-256 / AB / 25 A FUSE_OH:C3120B-256 / AB / 25 A FUSE_OH:C3120B-2	FUSE_OH:C1135D-55 / ABC / 40 A SP:1651 37TH AV NW FUSE_OH:B2213B-AV / AC / 6 A SP:11410 NW MCDANIEL RD FUSE_OH:C2128C-3728 / A / 65 A FUSE_OH:C4334D-462 / AB / 65 A FUSE_OH:C4334D-462 / AB / 65 A SP:3533 WIPPER RD SE SP:SW 61 500 FT N/O CANYON CT SP:15802 NW SHEITERED NOOK RD FUSE_OH:C3201D-131 / C / 65 A SP:355 SW 105HUA PL_1 REC1:3468 FUSE_OH:C3210B-1790 / AC / 40 A SP:16805 NW COREY RD_1 FUSE_OH:D1107D-2573 / B / 65 A FUSE_OH:D1107D-3231 / BC / 65 A FUSE_OH:D1107D-3231 / BC / 65 A FUSE_OH:D1107D-3231 / BC / 64 A FUSE_OH:D1107D-3231 / BC / 65 A FUSE_OH:D1107D-3231 / BC / 64 A FUSE_OH:D1118B-4331 / AC / 40 A FUSE_OH:D1118B-4331 / A / 25 A FUSE_OH:C11108-4039 / AB / 100 A SP:2900 S HWW 211 FUSE_OH:C11108-4039 / AB / 100 A SP:3900 S HWW 211 FUSE_OH:C3100A-25 A FUSE_OH:C3100A-25 A FUSE_OH:C7307B-2 / AC / 25 A FUSE_OH:C1100B-35861 / ABC / 100 A
10:28 AW P	5,		-
1/6/19 10			
30080 I			
752	750 745 741 741 741 733 733 733 734 737 737	7.50 7.41 7.41 7.41 7.41 7.33 7.33 7.33 7.33 7.33 7.33 7.32 7.32	7.50 7.44 7.41 7.41 7.41 7.33 7.33 7.33 7.33 7.33 7.33 7.33 7.3
1 1	4 11 11 11 1 1 1 1 1 1 1 1 7 6 8 7 8 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	4 11 11 11 11 11 11 11 11 11 12 12 13 14 11 14 17 16 17 18 17 18 17 18 17 18 17 18 17 18 18 18 18 18 18 18 18 18 18 18 18 18	4 11 11 11 11 11 11 11 11 11 11 11 11 11
			E1 &
36 LACE 13	IFES CCORNERS 13 (S HILL ADE ON HAPMAN RELINGTON HAPMAN RELWOOD US S-LENNINGS 13 RCREEK ORTH PLAINS 13 ADSTONE ADSTONE	FIFES (CORNERS 13 (CORNERS 13 S HILL ADE O'ON HAPMAN HAPMAN HAPMAN OSTH PLAINS 13 COLESON OLESON OLESON ALLEBOIS MEO CAT CAT CAT CAT CAT CAT CAT CA	FIFES (CORNERS 13 (CORNERS 13 S HILL ADE ON HAPMAN HAPMAN HELWOOD US JENNINGS 13 RCREEK ADSTONE -OLESON O13 RRMAN CAT RANA CAT RANA CAT SPINING CENTER DER COLESON O13 RCREEK ADSTONE -OLESON O13 RCAT LENNINGS 13 O13 RCAT LENNING CENTER DER 62 LACE 13 ROBER 63 LACE 13
9:56 PM IIGARD-13336 9:42 PM WALLACE-WALLACE 13 10:34 PM ARBORTON-BURLINGTON	10:09 PM CORNELL-BLUFFS 11:07 PM IX CORNERS-SIX CORNERS 13 9:38 PM COLTON-GRAYS HILL 9:39 PM TURNER-CASCADE 10:29 PM SYLVAN-PATTON 10:29 PM SYLVAN-PATTON 10:29 PM STORNER-CHAPMAN 10:32 PM COGGINS-CHAPMAN 10:32 PM COGGINS-LAURELWOOD 10:02 PM LELAND-CARUS 10:41 PM NNINGS LODGE-JENNINGS 13 10:28 PM LELAND-BEAVERCREEK 10:38 PM JRTH PLAINS-NORTH PLAINS 13 10:12 PM LACKAMAS-GLADSTONE 11:14 PM RALEIGH HILLS-OLESON	10:09 PM CORNELL-BLUFFS 11:07 PM IX CORNERS-SIX CORNERS 13 9:58 PM COLTON-GRAYS HILL 9:39 PM TURNER-CASCADE 10:29 PM SYLVAN-PATTON 10:32 PM SYLVAN-PATTON 10:32 PM SIX CORNERS-CHAPMAN 10:32 PM COGGINS-LAURELWOOD 10:02 PM IELAND-CARUS 10:32 PM IELAND-CARUS 10:32 PM IELAND-BEAVERCREEK 10:32 PM IELAND-BEAVERCREEK 10:32 PM ININGS LODGE-LENNINGS 13 10:32 PM IELAND-BEAVERCREEK 10:32 PM STH PLAINS-NORTH PLAINS 1 10:32 PM SALEIGH HILLS-OLESON 11:14 PM RALEIGH HILLS-OLESON 9:54 PM WILSONVILLE-VILLEBOIS 10:35 PM WILSONVILLE-VILLEBOIS 10:35 PM WOOBBURN-EAST 9:45 PM CANBY-ZIMMERMAN 10:57 PM SANDY-WILDCAT 10:09 PM NNINGS LODGE-JENNINGS 13 9:39 PM FARGO-FARGO 13	10:09 PM CORNELL-BLUFFS 11:07 PM IX CORNERS-SIX CORNERS 13 9:58 PM COLTON-GRAYS HILL 9:39 PM TURNER-CASCADE 10:29 PM SYLVAN-PATTON 10:29 PM SYLVAN-PATTON 10:22 PM SYLVAN-BURLINGTON 9:42 PM SYLVAN-BURLINGTON 10:32 PM COGGINS-LAURELWOOD 10:32 PM COGGINS-LAURELWOOD 10:32 PM COGGINS-LAURELWOOD 10:32 PM SYLVAN-BURLINGS 13 10:28 PM STH PLAINS-NORTH PLAINS 11 10:28 PM STH PLAINS-NORTH PLAINS 11 10:29 PM SALEIGH HILLS-OLESON 9:54 PM WILSONVILLE-VILLEBOIS 10:15 PM MOBBILE 5-ROMEO 10:05 PM SALEIGH HILLS-OLESON 9:55 PM SANDY-WILDCAT 10:09 PM NNINGS LODGE-JENNINGS 13 9:39 PM FARGO-FARGO 13 11:23 PM IRLAND-BEAYERCREEK 10:17 PM RALEIGH HILLS-OLESON 10:27 PM SANDY-WILDCAT 10:09 PM NNINGS LODGE-JENNINGS 13 9:39 PM FARGO-FARGO 13 11:23 PM IRLAND-BEAYERCREEK 10:17 PM RALEIGH HILLS-OLESON 10:17
9:56 PM TIG 9:42 PM WAL 10:34 PM ARBC 10:09 PM CO	11:10 PMIX CO. 9:58 PM CO. 9:59 PM TCO. 10:29 PM SYI. 10:29 PM ARBG. 10:32 PM COG. 10:32 PM COG. 10:32 PM LIS. 10:38 PM LIS. 10:38 PM LIS. 10:38 PM LIS.	111.07 PM IX COL 9:35 PM COL 9:39 PM SYI 10:29 PM SYI 10:32 PM COG 10:32 PM COG 10:32 PM LEI 10:34 PM NUIN 10:35 PM SAL 11:14 PM RALE 11:14 PM RALE 11:14 PM RALE 10:35 PM MO 9:35 PM MO 9:37 PM SAL 10:37 PM SAL 10:39 PM CANNIN 10:39 PM CANNIN	111.07 PM IX CO 9:35 PM COL 9:35 PM COL 10:29 PM ARB 10:29 PM ARB 10:20 PM LIA 10:28 PM ILIA 10:28 PM ILIA 10:27 PM ILIA 10:27 PM RALE 10:15 PM MO 9:31 PM MO 10:37 PM SAL 10:37 PM SAL 10:37 PM SAL 10:37 PM SAL 10:37 PM SAL 10:37 PM RALE 10:37 PM SAL 10:37 PM RALE 10:37 P
1/5/19 (1/5/19 (1/5/19 1/5/19 1/5/19 1/5/19 1/5/19 1/5/19 1/5/19 1			1/5/19 1/
	、てににににににてこれ		

Outdage Outdage Customer Affected Costomer Return Feature Time Struct 1/5/19 11.17 PM TIGARD-13336 16/19 9.00 AM 11/6/19 9.00 AM 11/	ā	CAIDI	610	209	607	909	605	594	288	586	579	578	576	573	570	569	797	260	546	545	541	540	539	538	537	532	532	530	516 515	506	490	487	487	480	475	4/0	464	463	463	462	454	444	444	442	437	416	416	414	406	406	401
Color Colo	Ĭ					-																	0									1.13E-06	••																		A RAFLOS
Ontage Outage Affected Duration Customers Affected Duration Return Return Influence Page 11 Page 12 Page 12 Page 13 Page 13 Page 13 Page 14	i di	SAIDI	0.000689	0.024023	0.013036	0.503941	0.000683	0.000672	0.047216	0.018541	0.004578	0.048959	0.090473	0.040804	0.000645	0.274092	0.0884/3	0.001919	0.079675	0.032037	0.006724	0.026851	0.086506	0.015806	0.000607	0.000602	0.132888	0.000599	0.01693	0.188277	0.018838	0.00055	0.0407	0.000543	0.042974	0.001593	0.037762	0.443307	0.001046	0.014085	0.044677	0.000502	0.019087	0.004496	0.296578	1.159315	0.000471	0.049158	0.000459	0.056836	201000
Outsige Iffected Duration Mill Date Iffected		interrupt Location	SP:11280 SW 90TH AVE	FUSE_OH:D2305A-1366 / AC / 65 A	FUSE_OH:D3122B-1863 / B / 25 A	RECL:2576	SP:Null_15	SP:52762 E CHERRYVILLE DR	FUSE_OH:C2201D-106 / ABC / 40 A	FUSE_OH:B3234C-39 / ABC / 25 A	FUSE_OH:D5202A-732 / ABC / 40 A	FUSE_OH:C6116A-959 / ABC / 65 A	FUSE_OH:C6801D-216 / ABC / 65 A	FUSE_OH:A1121A-313 / ABC / 100 A	SP:1625 N SUMNER ST	RECL:7812	FUSE_UH:CIIUSC-/IBI/ ABC/ IUU A	SP:2320 SW STAINLET CI RFCI-3680	FUSE OH:C2114A-2405 / ABC / 65 A	FUSE_OH:B3126A-38 / ABC / 40 A	SP:17190 S HOLCOMB RD	FUSE_OH:C2114A-2407 / B / 40 A	FUSE_OH:A1107D-67 / B / 65 A	FUSE_OH:D2410C-667 / B / 40 A	SP:15000 SE EDELWEISS DR_1	SP:2556 NW ARNOTT LN	FUSE_OH:D21128-2297 / ABC / 65 A	SP:11694 NW BENBURB LN	FUSE_UH:BZIU9C-IU83 / ABC / 40 A	SF.ZOZSO SE BATTIND RECL:6445	FUSE_OH:B1201A-135 / C / 40 A	SP:6225 SW MULTNOMAH BLVD	RECL:3882	SP:15253 NW OLD PUMPKIN RIDGE RD	SP:Null_17	SP:8513 WIPPER RD SE_4 PECL:4608	FUSE OH: D2529D-2797 / C / 40 A	SW OHLB:2824	SP:4509 SW VERMONT ST_1	FUSE_OH:B1127D-306 / C / 40 A	FUSE_OH:D2220C-2141 / ABC / 65 A	SP:6920 SW 182ND AVE	FUSE_OH:C5711B-323 / A / 25 A	FUSE_OH:B1307C-797 / ABC / 65 A	SW_OHLB:3827	BKR:NEWBERG R120	SP:4361 HARVEY WAY	FUSE_OH:C1110B-3385 / ABC / 100 A	SP:3954 CARMAN DR	RECL:2553	A ON / 200 / 200 day / 200 day
Outage Customers Outage Customers 1/5/19 10.25 PM Time Freeder Name Affected Duration Minutes 1/5/19 10.35 PM CARRE-1338-6 3 6.0 20.93.16667 1/5/19 10.35 PM CARRE-1338-4 3 6.0 20.93.16667 1/5/19 10.35 PM CARRE-1338-4 1 6.0 20.93.16667 1/5/19 10.35 PM CARRE-1364-4 1 6.0 20.93.16667 1/5/19 10.35 PM CARRE-1364-4 1 6.0 20.93.16667 1/5/19 10.35 PM CARRE-1364-4 1 5.0 20.93.16667 1/5/19 10.35 PM CARRE-1400-140EA 7 4.838.23 4.838.23 1/5/19 10.45 PM CARRELLANGE 7 5.0 4.838.23 1/5/19 10.45 PM CARRELLANGE 3 5.6 5.0 2.94.466.33 1/5/19 10.45 PM CARRELLANGE 3 5 5.6 4.838.23 3.2 <td>Return</td> <td>ıme</td> <td>9:26 AM</td> <td>9:00 AM</td> <td>9:27 AM</td> <td>7:59 AM</td> <td>9:02 AM</td> <td>9:17 AM</td> <td>7:36 AM</td> <td>8:53 AM</td> <td>8:43 AM</td> <td>8:20 AM</td> <td>7:52 AM</td> <td>8:59 AM</td> <td>9:07 AM</td> <td>7:27 AM</td> <td>7.55 AIVI</td> <td>7:20 AIVI 6:44 AM</td> <td>8:14 AM</td> <td>7:40 AM</td> <td>8:36 AM</td> <td>8:14 AM</td> <td>8:26 AM</td> <td>7:44 AM</td> <td>7:44 AM</td> <td>7:01 AM</td> <td>8:29 AM</td> <td>6:59 AM</td> <td>8:12 AM</td> <td>5:41 AM</td> <td>9:58 AM</td> <td>7:43 AM</td> <td>6:06 AM</td> <td>6:35 AM</td> <td>6:33 AM</td> <td>5:28 AM</td> <td>6:22 AM</td> <td>7:19 AM</td> <td>7:19 AM</td> <td>5:50 AM</td> <td>5:51 AM</td> <td>6:38 AM</td> <td>4:57 AM</td> <td>5:42 AM</td> <td>6:53 AM</td> <td>5:43 AM</td> <td>5:02 AM</td> <td>11:14 AM</td> <td>5:01 AM</td> <td>3:49 AM</td> <td></td>	Return	ıme	9:26 AM	9:00 AM	9:27 AM	7:59 AM	9:02 AM	9:17 AM	7:36 AM	8:53 AM	8:43 AM	8:20 AM	7:52 AM	8:59 AM	9:07 AM	7:27 AM	7.55 AIVI	7:20 AIVI 6:44 AM	8:14 AM	7:40 AM	8:36 AM	8:14 AM	8:26 AM	7:44 AM	7:44 AM	7:01 AM	8:29 AM	6:59 AM	8:12 AM	5:41 AM	9:58 AM	7:43 AM	6:06 AM	6:35 AM	6:33 AM	5:28 AM	6:22 AM	7:19 AM	7:19 AM	5:50 AM	5:51 AM	6:38 AM	4:57 AM	5:42 AM	6:53 AM	5:43 AM	5:02 AM	11:14 AM	5:01 AM	3:49 AM	
Outage Customers Date Time Feeder Name Affected Duration 1/5/19 11.27 PM TGARD-13336 1 610 1/5/19 11.27 PM TGARD-13336 1 610 1/5/19 11.27 PM CANBY-13644 19 607 1/5/19 11.20 PM MULLO-CARLS 19 607 1/5/19 11.20 PM MULLO-CARLS 19 607 1/5/19 11.20 PM MULLO-CARLS 17 588 1/5/19 11.20 PM MULLO-CARLS 17 578 1/5/	Return	Лате	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	1/6/19	
Date Time Feeder Name Affected 1/5/19 11:17 PM TIGARD-13336 1 1/5/19 10:53 PM AND CANER-CANVER 13 35 1/5/19 10:54 PM CANBR-13644 13 1/5/19 10:57 PM MULINO-NORTH 1 1/5/19 11:29 PM CANBR-13644 13 1/5/19 10:57 PM MULINO-NORTH 1 1/5/19 11:20 PM CHOUNDO-BRIGHTWOOD 13 71 1/5/19 11:20 PM CHOUNDO-BRIGHTWOOD 13 71 1/5/19 11:20 PM MULINO-NORTH 1 1/5/19 11:30 PM MUNDEL-BRIGHTWOOD 13 71 1/5/19 11:30 PM MUNDEL-BRIGHTWOOD 13 1 1/5/19 11:30 PM MUNDEL-BRIGHTWEAT 1 1/5/19 11:30 PM DELAWARE-DENANE 1 1/5/19 10:30 PM ANDHAMA-SATILER 1 1/5/19 10:30 PM ANDHAMA-SATILER 1 1/5/19 10:30 PM ANDHAMA-SATILER	Customer	Minutes	609.9166667	21253.16667	11533	445832	604.5833333	594.3166667	41771.66667	16403.33333	4049.966667	43313.75	80040.83333	36099	570.2333333	242486.3	/82/1.3	138789 0667	70487.75	28342.6	5948.616667	23754.86667	76530.9	13983.66667	537	532.2	117564.6333	530.05	149/8.0166/	166567.2167	16666	486.8	36007.16667	480.15	38018.66667	1409.2	33408	392189.2333	925.1666667	12460.5	39525.55	444.433333	16885.9333	3977.7	262380	1025634.25	416.4	43490	406.3	50282	
Outage Feeder Name 1/5/19 11:17 PM TIGARD-13336 1/5/19 11:17 PM TIGARD-13336 1/5/19 10:53 PM CANPK-13644 1/5/19 10:53 PM CANBY-13644 1/5/19 10:57 PM ILLADPARTH 1/5/19 10:57 PM MULINO-NORTH 1/5/19 10:57 PM MULINO-NORTH 1/5/19 10:57 PM MULINO-NORTH 1/5/19 10:58 PM MULINO-NORTH 1/5/19 10:08 PM CANBY-15-2DEWKE 1/5/19 10:07 PM MODALA-FOREST 1/5/19 10:17 PM MATANGEL-WEST 1/5/19 10:17 PM MATANGEL-WEST 1/5/19 10:17 PM MATANGEL-WEST 1/5/19 10:28 PM MODBURNE-SATTLER 1/5/19 10:28 PM MODBURNE-SATTLER 1/5/19 10:28 PM MODBURNE-SATTLER 1/5/19 10:28 PM MODBURNE-SATTLER 1/5/19 10:39 PM MODBURNE-SATTLER 1/5/19 10:30 PM <	i	Duration	610	607	209	909	902	294	588	286	579	278	576	573	570	569	26/	260	546	545	541	540	539	538	537	532	532	530	516	506	715	487	487	480	475	470	464	463	463	462	454	444	444	442	437	416	416	756	406	406	
0utage	Customers	Affected	П	35	19	736	н	ᆏ	71	28	7	75	139	63	ਜ }	426	138	248	129	52	11	44	142	26	Н	Н	221	ᠳ ;	29	379	34	Н	74	н	80	w f	7 22	847	2	27	87	П	38	6	009	2463	н	105	н ;	124	
Outage Date 1/5/19				PM CARVER-CARVER 13			PM MULINO-NORTH	PM GHTWOOD-BRIGHTWOOD 13	PM CHOLLS FERRY-RAINBOW	PM ORTH PLAINS-MASON HILL		PM MT ANGEL-WEST	' PM 3RAND RONDE-AGENCY			PM LTNOMAH-MULTNOMAH 13	PM DAR HILLS-SHOPPING CENTER	PIN LINOMAH-MULINOMAH 13	PM DURHAM-SATTLER	PM ARBORTON-BURLINGTON	PM REDLAND-REDLAND 13	PM DURHAM-SATTLER		' PM SANDY-362ND	PM DUNNS CORNER-KELSO			PM CORNELL-BLUFFS	PM ARBORTON-BURLINGTON	PM MOBILE 5-ROMEO	PM EST UNION-CORNELIUS PASS	PM SARDEN HOME-MCKAY		PM ORTH PLAINS-MASON HILL	PM EAGLE CREEK-BARTON	PMI TURNER-CASCADE	PM SANDY-SANDY 13	PM ARDEN HOME-METZGER	PM GLENCULLEN-SUNSET	PM CORNELL-BLUFFS	PM NNINGS LODGE-JENNINGS 13	PM HUBER-FARMINGTON	PM WILLAMINA-BRIDGE		PM ARDEN HOME-METZGER	. PM NEWBERG-DUNDEE	PM BOONES FERRY-KRUSE	PM TEKTRONIX-SHANNON	PM BOONES FERRY-KRUSE		100 LOCAL DE CONTRACTOR DE CON
		- 1													• •																																				
wip n p t n a n b t n b d d d n b t n b t n b n b t b b b b b d n b d d d d d d d d d d d d		- 1																																																	

	Outage	Outage		Customers		Customer	Return	Return			
Outage #	Date	Time	Feeder Name	Affected	Duration	Minutes	Date	Time	Interrupt Location	SAIDI SAIFI	CAIDI
459844	1/5/19	10:34 PM MULINO-SOUTH	Ю-SOUTH	226	397	89812.4	1/6/19	5:11 AM	FUSE_OH:D4217D-1281 / ABC / 100 A	0.101518 2.55E-04	397
458674	1/5/19	10:05 PM VILSONVILLE-BOECKMAN	ILLE-BOECKMAN	86	393	38553.2	1/6/19	4:38 AM	FUSE_OH:C3112A-4546 / AB / 65 A	0.043578 0.000111	393
459838	1/5/19	10:38 PM MURRAYHILL-REUSSER	YHILL-REUSSER	116	384	44547.86667	1/6/19	5:02 AM	FUSE_OH:C1129C-371 / ABC / 40 A	0.050354 1.31E-04	384
459779	1/5/19	٠.	10:32 PM OONES FERRY-LAKE GROVE	27	379	10227.15	1/6/19	4:50 AM	FUSE_OH:D2117B-861 / AC / 65 A	0.01156 3.05E-05	379
460016	1/2/19	10:31 PM SYLVAN-BARNES	N-BARNES	13	372	4837.95	1/6/19	4:43 AM	FUSE_OH:B1136D-636 / BC / 40 A	0.005469 1.47E-05	372
457363	1/5/19	10:25 AM :STACADA-ESTACADA 13	A-ESTACADA 13	2	364	727.9666667	1/5/19	4:28 PM	ELBOW:D3324A-1974-3	0.000823 2.26E-06	364
457500	1/5/19	9:06 PM INDIAN-LABISH	N-LABISH	41	353	14460.7	1/6/19	2:58 AM	FUSE_OH:C6229A-1286 / ABC / 25 A	0.016345 4.63E-05	353
458735	1/5/19	10:14 PM ISLAND-13188	D-13188	277	353	97688.66667	1/6/19	4:06 AM	FUSE_OH:D2112A-3646 / ABC / 100 A	0.110421 3.13E-04	353
461447	1/5/19	11:29 PM CENTENNIAL-BARKER	NIAL-BARKER	239	344	82124.38333	1/6/19	5:12 AM	FUSE_OH:D1212A-7622 / ABC / 100 A	0.092828 2.70E-04	344
458349	1/5/19	9:55 PM VIOLALLA-MARQUAM	4-MARQUAM	160	342	54682.66667	1/6/19	3:36 AM	RECL:9515	0.06181 1.81E-04	342
458813	1/5/19	10:18 PM REDLAND-REDLAND 13	D-REDLAND 13	120	326	39108	1/6/19	3:43 AM	FUSE_OH:D2224B-3340 / ABC / 65 A	0.044205 1.36E-04	326
458824	1/2/19	10:18 PM REDLAND-REDLAND 13	D-REDLAND 13	715	326	233018.5	1/6/19	3:43 AM	RECL:1232	0.26339 8.08E-04	326
458876	1/2/19	10:18 PM REDLAND-REDLAND 13	D-REDLAND 13	96	326	31284.8	1/6/19	3:43 AM	FUSE_OH:D2223D-1063 / ABC / 100 A	0.035362 1.09E-04	326
458882	1/5/19	10:18 PM REDLAND-REDLAND 13	D-REDLAND 13	9	326	1955.3	1/6/19	3:43 AM	FUSE_OH:D2223D-8968 / C / 6 A	0.00221 6.78E-06	326
458857	1/5/19	10:18 PM REDLAND-REDLAND 13	D-REDLAND 13	Н	326	325.8333333	1/6/19	3:43 AM	XFM_OH:A 25 91622	0.000368 1.13E-06	326
458056	1/5/19	9:43 PM VEWBERG-CHEHALEM	G-CHEHALEM	77	316	24348.68333	1/6/19	2:59 AM	FUSE_OH:C3304C-582 / ABC / 65 A	0.027522 8.70E-05	316
461167	1/5/19	10:35 PM ORTH PLAINS-MASON HILL	AINS-MASON HILL	224	304	68118.4	1/6/19	3:39 AM	RECL:4528	0.076997 2.53E-04	304