e-FILING REPORT COVER SHEET



COMPANY NAME: PORTLAND GENERAL ELECTRIC

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes If yes, submit a redacted public version (or a cover letter) by email. Submit the confidential information as directed in OAR 860-001-0070 or the terms of an applicable protective order.
Select report type: RE (Electric) RG (Gas) RW (Water) RT (Telecommunications) RO (Other, for example, industry safety information)
Did you previously file a similar report? Yes, report docket number: RE 112
Report is required by: Statute Order Note: A one-time submission required by an order is a compliance filing and not a report (file compliance in the applicable docket) Other (For example, federal regulations, or requested by Staff)
Is this report associated with a specific docket/case? No Yes, docket number:
List Key Words for this report. We use these to improve search results.
MAJOR EVENT EXCLUSION
Send the completed Cover Sheet and the Report in an email addressed to PUC.FilingCenter@state.or.us
Send confidential information, voluminous reports, or energy utility Results of Operations Reports to PUC Filing Center, PO Box 1088, Salem, OR 97308-1088 or by delivery service to 201 High Street SE Suite 100, Salem, OR 97301.



November 20, 2017

Oregon Public Utility Commission Attn: Filing Center 201 High Street, S.E. Salem, OR 97308-1088

Re:

Major Event Exclusion

Period:

October 21, 2017

Portland General Electric (PGE) hereby submits this report in compliance with OAR 860-023-0161 which requires the electric company to file a report with the Commission within 30 business days after the conclusion of an event. This report provides a summary of the major storm event that occurred on October 21, 2017.

OAR 860-023-0161: Major Event Filing by Electric Companies

1. Description of the major event, the interruption causes, and factors that impacted restoration of service.

On October 21, 2017, PGE's entire service territory experienced a wind storm causing widespread outages. The Portland area experienced wind gusts of 37 mph, Salem experienced wind gusts of 41 mph, and Hillsboro experienced wind gusts of 38 mph.

The severe wind caused many tree-related outages. Uprooted trees and broken limbs caused damage to PGE overhead equipment and poles which made restoration difficult.

2. The Reliability reporting area and geographic area impacted.

PGE's entire service territory was impacted by October 21, 2017. Most outages were in the eastern part of PGE's service territory.

3. The total number of customers affected and the number of customers without service at periodic intervals.

At the peak of the storm, PGE had approximately 8,877 customers without power. During the storm, a total of 14,856 customers were affected.

4. The calculated SAIDI, SAIFI, and CAIDI impacts (i.e., "Event SAIDI¹, SAIFI², CAIDI³ and Tmed⁴") associated with the Major Event on a reliability reporting area and a system-wide basis.

The following table represents the calculated impacts for SAIDI, SAIFI, CAIDI, Tmed, and system-wide basis totals:

	REI	LIABILITY REPORTING	AREAS	SYSTEM-WIDE BASIS
	EASTERN ¹	SOUTHERN	WESTERN	PGE SERVICE TERRITORY
SAIDI ²	4.18	0.97	0.29	5.44
SAIFI³	0.013	0.004	0.001	0.017
CAIDI ⁴	323	259	522	315
Customers out at peak	6,534	1,990	353	8,877
T med				4.84

¹ Eastern and Central regions are now combined and represented as the Eastern region. ² SAIDI - System Average Interruption Duration Index

³ SAIFI - System Average Interruption Frequency Index

⁴ CAIDI - Customer Average Interruption Duration Index

Major Event Exclusion Occurred: October 21, 2017 Page 3 of 3

Additional Reporting Related to the October 21, 2017 Storm Event:

Attachment A provides a summary of outages within PGE's service territory lasting five hours or longer.

For questions regarding this filing, please contact Kalia Savage at (503) 464-7432. Please direct all formal correspondence and requests to the following email address pge.opuc.filings@pgn.com.

Sincerely,

James Landstrom,

Manager, Transmission and Distribution Asset Management

Enclosures

Major Event Exclusion Period: October 21, 2017 Attachment A Summary of Outages Five Hours and Longer for the Entire PGE Service Territory

Attachment A Summary of Outages 5 hours and longer PGE Service Territory October 21st, 2017

CAIDI	2,098	1,703	1,505	1,480	1,479	1,447	1,410	1,328	1,323	1,316	1,265	1,256	1,218	1,205	1,182	1,158	1,129	1,128	1,124	1,121	1,102	1,098	1,090	1,086	1,066	1,047	1,031	1,021	991	926	958	948	944	933	929	928	914	50.0	100	873	864	845	836	825	819	818	815	804	800	778	767 754	
SAIFI	2.32193E-06	1.81E-04	3.48E-06	9.29E-06	3.48E-06	2.67E-05	4.64E-06	1.28E-05	1.86E-05	6.85E-05	3.48E-06	1.16E-06	1.16E-06	1.16E-06	1.16E-06	2.20583E-05	1.16096E-06	8.825-05	3.48E-06	2.21E-05	1.164-06	1.16E-06	3.48E-06	9.29E-05	3.72E-05	1.16E-05	1.16E-06	2.32E-06	6.50E-05	1.16E-06	1.51E-05	3.48289E-06	1.16E-06	1.16E-06	5.80E-06	1.16E-06	5.80E-06	7.15E-U5	2 225.06	1.34E-05	4.01F-04	1.97E-05	1.97E-05	3.37E-05	6.04E-05	0.000212456	4.43E-04	9.87E-05	1.16E-05	1.16E-06	1.16E-06 2.32E-06	
SAIDI	0.004871251 2	0.308470279	0.005242044	0.013741946	0.005150908	0.03863805	0.006548225	0.016959365	0.02457529	0.090112223	0.004404698	0.001458248	0.001413919	0.001399059				0.09952/139	0.003914771	0.024/2112/	0.001278976	0.00127439	0.003796353	0.100839803	0.039602811	0.012158198	0.001196625	0.00236976	0.064438622	0.001133217			0.001096415	0.001083354	0.005393259	0.001077607	0.005308025	0.001055065	0.002032032	0.00203393	0 346066885	0.016674619	0.016496005	0.027785608	0.049438113	0.173789376 0	0.361546466	0.079315623	0.009292164	0.000902863	0.000890208 0.00174965	
Interrupt Location	SP:6920 SE HOGAN RD	FUSE_OH:D2120A-3 / C / 100 A	XFM_OH:C 25 93694	FUSE_OH:D3411B-2861 / B / 25 A_1	FUSE_OH:A1527A-305 / B / 6 A	FUSE_OH:D2534C-1812 / C / 15 A	FUSE_OH:D1330D-1467 / A / 6 A	FUSE_OH:D2315D-1266 / C / 65 A	FUSE_OH:D1301A-2565 / C / 65 A	FUSE_OH:D1313A-3121 / ABC / 65 A	SP:47675 SE COALMAN RD	SP:SE TRUBEL RD & SE 367TH AVE	SP:8552 SE RODLUN RD	SP:31440 S DRYLAND RD	SP:31985 NW PUMPKIN RIDGE DR	FUSE_OH:C4327B-1347 / ABC / 40 A	SP:721 STEWART ST NE	FUSE_OH:D1222A-4365 / BC / 100 A	XFM_OH:A 50 37375	FUSE_OH:D2426C-2929 / B / 25 A	SP:Nuil_58	SP:194 SW TUALATIN LOOP	FUSE_OH:D1430A-1425 / B / 40 A	SP:15400 NW MCNAMEE RD	FUSE_OH:D1306B-42 / A / 40 A	XFM_UG:B 50 28568	SP:22450 S PARROT CREEK RD	SP:12111 S CASTO RD	FUSE_OH:D2206D-3234 / B / 65 A	SP:12868 MASCHER RD NE	FUSE_OH:D3422D-666 / C / 40 A	SP:35674 SE TUMALA MOUNTAIN RD	SP:14015 SE UPPER ALDERCREST DR	SP:4100 EAGLE CREST RD NW	XFM_OH:C 25 94201	SP:17558 PAINTER LOOP RD NE	SP:14500 S BRUNNER RD	SP:22345 S DAY HILL RU	SP-40EE SE INCKSON ST	5F.4033 3E.3ACN3ON 31 FIISE OH:D3115A-2436 / A / 10 A	FISE OH-D2734C-109 / ABC / 100 A	FUSE OH:D6122A-60 / C / 40 A	FUSE OH:D1117D-2225 / B / 100 A	FUSE_OH:A1130C-435 / A / 40 A	FUSE_OH:A1109C-59 / B / 100 A	FUSE_OH:D1121C-77 / ABC / 100 A	SW_OHLB:2325	FUSE_OH:D3122B-1877 / AC / 40 A	SP:24775 NW PEDERSON RD	SP:18560 NIXON AVE	SP:2804 SW NAITO PKWY SP:18280 S OLD CLARKE RD	
Return Time	9:12 AM	11:56 PM	12:24 AM	7:20 PM	9:45 PM	5:40 PM	7:36 PM	6:40 PM	6:16 PM	9:36 PM	6:01 PM	7:43 PM	8:00 PM	4:01 PM	4:04 PM	9:54 AM	3:48 PM	5:03 PM	5:08 AM	5:01 PM	5:13 PM	1:32 PM	2:36 PM	3:05 PM	5:15 PM	5:06 PM	2:57 PM	3:13 PM	1:06 PM	3:29 PM	12:45 PM	12:48 PM	1:43 PM	1:57 PM	11:31 AM	2:58 PM	11:42 AM	2:34 PIVI	2:11 004	2.11 PINI 2.22 PINI	2.11 PM	12:22 PM	11:13 AM	1:35 PM	11:51 AM	8:29 AM	12:48 PM	1:16 PM	12:20 PM	11:06 AM	12:27 PM 10:45 AM	
Return Date	10/23/17	10/22/17	10/23/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/1/	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/1/	10/22/11/	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17 10/22/17	: 'm /a-
Customer Minutes	4195.866666	265701.7999	4515.249999	11836.66666	4436.749998	33281	5640.333332	14608	21168	77618.43329	3793.99998	1256.066666	1217.883333	1205.083333	1182.016666	21992.81665	1128.516666	85/58	3372	21293.61665	1101.65	1097.7	3270	86858.66664	34112	10472.5	1030.716666	2041.2	55504.4	976.1	12450.31666	2845.399998	944.4	933.15	4645.5	928.2	4572.08333	908./83333	1901.033332	13101 99999	298085 7498	14362.73332	14208.88332	23933.21666	42583.66663	149694	311419.1332	68318.75	8003.83333	777.683333	766.783333 1507.066666	
Duration	2098			1480	1479	1447		1328	1323	1316	1265	1256		1205			1129	1128			1102	1098			1066			1021	991			948	944	933	929	928	914	909			864	845	836	825	·	818		804	800	778	767	
Customers Affected	2	156	m	∞	e	23	4	11	16	29	ю	ч	₩	7	Н	19	⊶ ;	/6	m :	g ,	~	ল	m	80	32	10	ч	2	26	н	13	ю	н	П	15	н	ı,	r	۷ ر	۲ ر <u>ا</u>	345	17	17	53	52	183	382	85	10	Н	7	ı
Feeder Name	HOGAN NORTH-HOGAN NORTH 13	ROSEMONT-MOSSY BRAE	SANDY-WILDCAT	EAGLE CREEK-BARTON	ORIENT-ORIENT 13	SANDY-SANDY 13	PLEASANT VALLEY-PLEASANT 13	BORING-TELFORD	RUBY-JUNCTION	BORING-282ND	SANDY-SANDY 13	SANDY-WILDCAT	HOGAN SOUTH-LAWRENCE	MOLALLA-YODER	NORTH PLAINS-NORTH PLAINS 13	DAYTON-EAST	MCCLAIN-COTTAGE	RAMAPO-RAMAPO 13	CANYON-23RD	SANDY-WILDCAT	TWILIGHT-BREMER	SULLIVAN-SALAMO	BORING-282ND	WEST UNION-CORNELIUS PASS	CENTENNIAL-BARKER	LENTS-HAPPY VALLEY	LELAND-BEAVERCREEK	TWILIGHT-BREMER	HARMONY-MILWAUKIE	SILVERTON-WEST	ESTACADA-FARADAY	ESTACADA-FARADAY	HARMONY-MILWAUKIE	WALLACE-WALLACE 13	GARDEN HOME-METZGER	NORTH MARION-MCLAREN	ABERNETHY-OREGON CITY	ESTACADA-NORTH FORK	HADRACHIC HADRACHY 13	HANNON T-HARINON IS	WFI CHES-718 7AG	SCOTTS MILLS-SCOTTS MILLS 13	GLENCULLEN-SUNSET	SYLVAN-BARNES	CURTIS-CURTIS 13	MULTNOMAH-13176	NORTH MARION-MCLAREN	CANBY-13644	NORTH PLAINS-MASON HILL	SULLIVAN-ROBINWOOD	URBAN-GIBBS LELAND-CARUS	
Outage Time	10:15 PM	7:33 PM	11:19 PM	6:41 PM	9:07 PM	5:33 PM	8:06 PM	8:32 PM	8:13 PM	11:41 PM	8:56 PM	10:47 PM	11:42 PM	7:56 PM	8:22 PM	2:37 PM	9:00 PM	10:15 PM	10:24 AM	10:21 PM	10:52 PM	7:14 PM	8:26 PM	9:00 PM	11:29 PM	11:39 PM	9:46 PM	10:13 PM	8:35 PM	11:13 PM	8:48 PM	9:00 PM	9:59 PM	10:24 PM	8:02 PM	11:29 PM	8:27 PM	11:26 PIVI	11.25 004	11:48 PM	11.47 PM	10:18 PM	9:18 PM	11:50 PM	10:13 PM	6:51 PM	11:13 PM	11:53 PM	11:00 PM	10:09 PM	11:40 PM 10:12 PM	
Outage Date	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/1/	10/21/1/	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17 10/21/17	:= /++ />+
Outage #	1	304417	304991	304360	304552	304262	304476	304490	304514	305090	304536	304872	305063	304467	304589	304004	304530	304730	303883	304797	306706	304403	304513	304603	305012	305108	304588	304736	304501	304982	304517	304529	304714	304802	304471	305006	304487	302008	206510	9TC906	305114	304756	304561	305072	304726	304392	304950	305243	304974	304740	305059 304746	:

Attachment A Summary of Outages 5 hours and longer PGE Service Territory October 21st, 2017

G	CHIC	746	/31	174	407	969	685	299	643	632	673	279	909	574	268	556	553	544	495	486	478	465	461	457	433	424	408	407	382	375	363	351	335	333	330	2, 2	, ,
CAIEI	11125	2.67E-05	1.16E-06	9.75E-U5	1.59E-04	6.855-05	4.33E-04	1.16E-06	7.43017E-05	9.29E-06	6.9/E-06	1.164-06	1.765-04	2.15E-04	3.48E-06	1.16E-06	4.64E-06	8.59E-05	1.16E-06	1.16E-06	6.39E-05	1.16E-06	1.16E-06	1.48F-03	9.29E-05	5.22E-05	6.15311E-05	9.87E-05	4.41E-05	1.16E-06	1.16F-06	2.79E-05	1 07F-04	2.08F-04	4 88F-05	7.55E-05	2.335.03
SAIDI	10100	0.019919824	0.00084911	0.07027933	0.1119/26/6	0.04/6/49/6	0.296812592		~!	0.005868751	0.004339684	0.000/21655	U.106929911	0.123383019	0.001977877	0.000645496	0.002568904	0.046710002	0.000574464	0.000564383	0.0304994	0.000539268	0.000535243	0.67858706	0.0402158	0.02213117	m		0.016873879	0.000435033	0.000421856	0.009779962	0.035747094	0.069163494	0.016100716	790803000	(000000000
Interrupt Location	A 7 704 7 004 000440-110 13111	rose_on:Dilo46-198 / Abc / 6 A	FISE OHANDSEC 1104 / P. / AD A	1 03r_01:A1233C-1104 / B / 40 A	FISE OH-D25254 480 / AB / AD A	103L_011.D2323A-400 / AB / 40 A	COSE_ON:ALISSAZ-33 / ABC / 100 A	SPLEDGED BRADLET RU	FUSE_UH:D/2066-86 / BC / 25 A	FUSE_OH:D5306A-Z / AC / 65 A	CONCLUSION CONTRACTOR AND AND CONTRACTOR CON	SF.ZG443 SE COCHRAIN RD	rose_On.bz4130-820 / bc / b3 A	FUSE_URIDIZZAB-ZBOI / BC / 100 A	FUSE_OH:CS601A-107 / B / 15 A	SP:1725 SW 89TH AVE	XFM_OH:C 25 38507	FUSE_OH:D3124A-3782 / ABC / 40 A	SP:3309 SW FAIRMOUNT BLVD	SP:7525 SE ALDER ST	FUSE_OH:D2130B-4182 / A / 65 A	SP:5950 SW PROSPERITY PARK RD	SP:26440 SE SUNSHINE VALLEY RD	SW_UGLB:6913	FUSE_OH:D1336A-1004 / ABC / 100 A	FUSE_OH:D1336A-950 / ABC / 65 A	RECL:7213	FUSE_OH:D5209B-702 / ABC / 100 A	FUSE_OH:D6214C-650 / B / 25 A	SP:3423 ROYCE WAY	SP:1040 OAK TER	FUSE_OH:C1121D-11052 / C / 40 A	FUSE_OH:C5106A-150 / ABC / 65 A	FUSE_OH:B1136C-47 / ABC / Solid	FUSE OH:C2108A-2809 / B / 40 A	FUSE OH:C41058-291 / ABC / 25 A	VEM OH: A DE ADORE
Return Time	MG 36.0	0.30 FW	MV 75-0	11.20 000	9-22 AM	30-25 ANA	7.47 084	7.44 AIVI	3.45 AIVI	10:09 AIM	2.42 00.4	1117 24.7	7:52 AN	7.33 AIVI	1:34 PM	9:04 AM	9:04 AM	7:28 AM	8:25 PM	5:51 AM	3:44 AM	4:11 AM	6:52 PM	12:06 AM	7:00 AM	7:00 AM	6:37 AM	4:56 AM	2:06 PM	1:47 AM	1:48 AM	12:04 AM	1:19 AM	11:25 PM	4:54 AM	10:56 PM	7.53 08.4
Return Date	10/21/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	70/27/11	10/22/11/	10/22/11/	10/22/11	10/27/11	10/22/1/	10/22/1/	10/27/17	10/22/17	10/22/17	10/22/17	10/21/17	10/22/17	10/22/17	10/22/17	10/21/17	10/22/17	10/22/17	10/22/17	10/22/17	10/22/17	10/21/17	10/22/17	10/22/17	10/22/17	10/22/17	10/21/17	10/22/17	10/21/17	71/17/01
Customer Minutes	17158	731 383333	60793 59997	96448	41064 98329	25560 4164	667.35	41127 05557	41137.00002	3738	5716	02104 4	106276 2227	1702 640000	1/03.649999	922	2212.733332	40233.8	494.816666	486.133333	26270.75	464.5	461.033333	584503	34640	19062,74997	21602.8	34603.5	14534.36665	374.716666	363.366666	8424	30790.86664	59574.18321	13868.4	6924.5	627 26666
Duration	746	72,	724	704	969	685	667	673	2 6	200	523	1 70	277	1 0 3 3	00 1	200	553	544	495	486	478	465	461	457	433	454	408	407	382	375	363	685	335	333	330	315	314
Customers Affected	23	} -	84	137	29	373	; -	+ 7d	ţ °	o co	, ,-	į	187	2	n +	-	4	74	н	Н	55	Н	н	1279	80	45	23	85	38	н	н	24	92	179	42	22	2
Feeder Name	CANYON-CANYON 13	LEIAND-CARUS	GLENDOVEER-13597	ORIENT-ORIENT 13	BRIGHTWOOD-BRIGHTWOOD 13	E-13139	REDI AND-REDI AND 13	SCOTTS MILLS-SCOTTS MILLS 13	COLTON-DHOOGHE	SCHOLLS FERRY-ROY ROGERS	HOGAN NORTH-LINKS	SANDY-WILDCAT	BEII-BATTIN	CHERIDAN-FACT	CEDAP ULLS LEALIN	הבילה הונה היה היה היה היה היה היה היה היה היה ה	BOONES FERRY-MOUNTAIN PARK	TWILIGHT-BREMER	GLENCULLEN-BRIDLEMILE	KELLY BUTTE-BINNSMEAD	MERIDIAN-MERIDIAN 13	MERIDIAN-MERIDIAN 13	BORING-TELFORD	ROSEMONT-OVERLOOK	BORING-282ND	BORING-282ND	COLTON-DHOOGHE	MOLALLA-BUCKAROO	MOLALLA-MARQUAM	MERIDIAN-PILKINGTON	ROSEMONT-OVERLOOK	DENNY-WEST	NORTH MARION-CROSBY	SYLVAN-BARNES	SCHOLLS FERRY-ROY ROGERS	FARGO-FARGO 13	REDLAND-REDLAND 13
Outage Time	8:10 AM	7:38 PM	9:51 PM	11:36 PM	9:46 PM	11:00 PM	8:35 PM	11:04 PM	11:38 PM	10:01 PM	9:21 AM	MG 51:01	10:19 PM	4:07 AM	11-48 DM	11:10 - 10:	MA TC:TT	10:25 PM	12:11 PM	9:45 PM	7:47 PM	8:27 PM	11:11 AM	4:29 PM	11:47 PM	11:57 PM	11:50 PM	10:09 PM	7:44 AM	7:33 PM	7:44 PM	12:39 PM	7:45 PM	5:53 PM	11:24 PM	5:42 PM	2:39 PM
Outage Date Outage Time	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/1/	10/21/1/	10/21/1/	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17	10/21/17
Outage #	303858	304426	304649	305045	304590	304890	304515	304888	305066	304718	303802	304735	304764	303791	305103	205222	505255	304803	303308	304586	304433	304482	303892	304175	305161	305255	305105	304731	303812	304421	304427	303912	304444	304329	305018	304287	304002