



e-FILING REPORT COVER SHEET

Send completed Cover Sheet and the Report in an email addressed to: [PUC.FilingCenter@state.or.us](mailto:PUC.FilingCenter@state.or.us)

REPORT NAME: AMENDED Major Event Report for May 6, 2019

COMPANY NAME: Idaho Power Company

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes

If yes, please submit only the cover letter electronically. Submit confidential information as directed in OAR 860-001-0070 or the terms of an applicable protective order.

If known, please select designation: RE (Electric) RG (Gas) RW (Water) RO (Other)

Report is required by: OAR 860-023-0161

Statute

Order


Other

Is this report associated with a specific docket/case? No Yes

If yes, enter docket number: RE 114

List applicable Key Words for this report to facilitate electronic search:

**DO NOT electronically file with the PUC Filing Center:**



- Annual Fee Statement form and payment remittance or
- OUS or RSPF Surcharge form or surcharge remittance or
- Any other Telecommunications Reporting or
- Any daily safety or safety incident reports or
- Accident reports required by ORS 654.715

**Please file the above reports according to their individual instructions.**

LISA D. NORDSTROM  
Lead Counsel  
[lnordstrom@idahopower.com](mailto:lnordstrom@idahopower.com)

July 2, 2019

Public Utility Commission of Oregon  
Filing Center  
201 High Street SE, Suite 100  
P.O. Box 1088  
Salem, Oregon 97301


Re: AMENDED Filing for Major Event: May 6, 2019  
Docket No. RE 114

Attention Filing Center:

Per conversations between Idaho Power Company and Public Utility Commission of Oregon Staff Member Yassir Rashid, Idaho Power is submitting an amended filing for this major event report because it has been determined that a major event day was not experienced.

If you have any questions, please do not hesitate to contact Perry Van Patten, Manager, Delivery Reliability and Maintenance, at 208-388-5944.

Very truly yours,



Lisa D. Nordstrom

LDN/kkt

Enclosure

cc: Adam Richins  
Angelique Rood  
Perry Van Patten  
Bryan Hobson  
Clint Mills  
Heath Schab



**Oregon Administrative Rule 860-023-0161  
Major Event Filing  
May 6, 2019 / AMENDED July 2, 2019**

**Description:** The outage began on February 14, 2019, at 11:15 AM near Bonita Road and Clover Creek south of the town of Ironside, Oregon. Since the access to the trouble was bad (snow and difficult terrain) and the three service points affected were irrigation pumps, it was determined that the trouble would be fixed later in the spring when access was safer and when the irrigation pumps would be utilizing power from the grid. The customer was contacted at 3:22 PM on February 14, 2019, and agreed to the restoration plan at which time a troubleman lifted a jumper to isolate the issue with the distribution line. The service to the irrigation pumps was subsequently restored on May 6, 2019, at 2:02 PM.

The total outage duration, using February 14, 2019, 3:22 PM as the outage completion time, was 247 minutes. This duration multiplied by three service points resulted in 741 customer minutes of interruption). Idaho Power’s calculated threshold for a major event day ( $T_{MED}$ ) for 2019 in Oregon is 14.11 minutes per customer, and 741 customer minutes of interruption per 19,020 customers is a daily SAIDI of 0.04 minutes per customer.

**Transmission Events:**

Line	Begin Time	End Time	Event Type	Duration (min)	Comments

**Customers Affected:**

Outage Begin – End Date/Time	Feeder - Device	(Oregon) Customers Out	Duration (Minutes)	(Oregon) Customer Minutes Out
2019-02-14 11:15AM –	CWVY 012 -	3	247	741
2019-02-14 03:22PM	JU BEYOND R102 AK			
		<b>3</b>		<b>741</b>

**Circuit Reliability:**

Impacted Circuit	Oregon Customers	SAIDI (Minutes)	SAIFI	CAIDI (Minutes)
CWVY 012	109	7.00	0.03	247.00
<b>Oregon Service Territory</b>	<b>19,020</b>	<b>0.04</b>	<b>0.00</b>	<b>247.00</b>

**Outage Timeline:**

