

e-FILING REPORT COVER SHEET

REPORT NAME: Electric Service Reliability Annual Report for 2013

COMPANY NAME: Idaho Power Company

DOES REPORT CONTAIN CONFIDENTIAL INFORMATION? No Yes

If yes, please submit only the cover letter electronically. Submit confidential information as directed OAR 860-001-0070 or the terms of an applicable protective order.

If known, please select designation: RE (Electric) RG (Gas) RW (Water)
 RO (Other)

Report is required by: OAR 860-023-0151
 Statute
 Order
 Other

Is this report associated with a specific docket/case? No Yes
If Yes, enter docket number:


Key words:

If known, please select the PUC Section to which the report should be directed:

- Corporate Analysis and Water Regulation
- Economic and Policy Analysis
- Electric and Natural Gas Revenue Requirements
- Electric Rates and Planning
- Natural Gas Rates and Planning
- Utility Safety, Reliability & Security
- Administrative Hearings Division
- Consumer Services Section

PLEASE NOTE: Do NOT use this form or e-filing with the PUC Filing Center for:

- Annual Fee Statement form and payment remittance or
- OUS or RSPF Surcharge form or surcharge remittance or
- Any other Telecommunications Reporting or
- Any daily safety or safety incident reports or
- Accident reports required by ORS 654.715.



A faint, light-gray graphic of several parallel power transmission lines is visible across the middle portion of the page. The lines are thin and wavy, creating a sense of depth and movement against the white background.

Idaho Power Company 2013 Electric Service Reliability Annual Report

May 2014
© 2014 Idaho Power

TABLE OF CONTENTS

Table of Contents	i
List of Tables	i
List of Figures	ii
Executive Summary	1
Definitions	2
System Performance	3
System SAIDI, SAIFI, and MAIFI _E Data	5
System SAIDI	5
System SAIFI	5
System MAIFI _E	6
Circuit SAIDI Values	18
Circuit SAIFI Values	29
Circuit MAIFI _E Values	40
Sustained Interruptions Causes	53
Maps	61

LIST OF TABLES

Table 1

Five years of circuit SAIDI data with and without MED	7
---	---

Table 2

Five years of circuit SAIFI data with and without MED	9
---	---

Table 3

Five years of circuit MAIFI _E data with and without MED	11
--	----

Table 4

2013 descending order sort of reliability indices by circuit	13
--	----

Table 5

Five years of sustained interruption causes	51
---	----

Table 6

2013 sustained interruption cause ranking.....52

Table 7

2013 momentary events causes.....56

Table 8

Customer count voltage station.....57

Table 9

Five years of line/trench miles data60

Table 10

MED system summary.....60

LIST OF FIGURES

Figure 1

Five years of system reliability data with and without MED—system SAIDI values5

Figure 2

Five years of system reliability data with and without MED—system SAIFI values5

Figure 3Five years of system reliability data with and without MED—system MAIFI_E values6**Figure 4**

2013 circuit SAIDI descending values.....15

Figure 5

2013 circuit SAIFI descending values16

Figure 62013 circuit MAIFI_E descending values17**Figure 7**

2013 causes for sustained interruptions55

EXECUTIVE SUMMARY

This document is Idaho Power's 2013 Electric Service Reliability Annual Report. The report discusses the performance of Idaho Power's electric service in the state of Oregon.

At year end 2013, Idaho Power served 18,349 customers from 63 distribution circuits and 39 substations in the far central-eastern portion of Oregon. The composite performance of the 63 circuits in 2013 included the following:

- 875 sustained (greater than five minutes) interruptions
- 647 momentary (less than or equal to five minutes) interruptions
- 128,314.5 customer hours out
- System Average Interruption Duration Index (SAIDI) of 6.99
- System Average Interruption Frequency Index (SAIFI) of 2.41
- Momentary Average Interruption Event Frequency Index (MAIFI_E) of 3.80

All the indices, graphs, and figures in this report are calculated by including and excluding identified major event day (MED) occurrences.

The daily threshold MED (TMED)—also referred to as Day SAIDI for 2013 was calculated to be 11.25 minutes (0.19 hours). The identification of a MED also includes a calculation of the Customer Average Interruption Duration Index (CAIDI) of 300 minutes (5 hours) as defined by the Public Utility Commission of Oregon (OPUC) Rule 860-023-0161. Following this criteria, Idaho Power experienced five MEDs, which are summarized in Table 10.

For 2014, Idaho Power's TMED (DaySAIDI) is 13.86 minutes, based on the IEEE 1366 standard methodology. The 300 minutes calculation for CAIDI remains the same.

SAIFI (including MED) was at 2.41, which was an increase of 0.98 over 2012. Excluding MED, SAIFI was 2.01, representing an increase of 0.81 over 2012.

SAIDI (including MED) was at 6.99, an increase from 2012 of 3.42. Excluding MED, SAIDI was at 4.62, representing an increase of 2.35 over 2012.

MAIFI_E (including MED) was at 3.8, which was a decrease over 2012 of 0.9. Excluding MED, MAIFI_E was 3.54, representing a decrease of 1.00 over 2012.

DEFINITIONS

CAIDI—Customer Average Interruption Duration Index

Institute of Electrical Electronic Engineers Standard 1366 (IEEE1366)—The *IEEE Guide for Electric Power Distribution Reliability Indices* (2003 edition), approved on December 10, 2003, by the IEEE Standards Association (IEEE-SA) Standards Board and on April 26, 2004, by the American National Standards Institute (ANSI).

MAIFI_E—Momentary Average Interruption Event Frequency Index

Major Event—An event that exceeds the reasonable design and or operational limits of the electric power system. A major event includes at least one major event day (MED).

Major Event Day (MED)—A day when the daily System Average Interruption Duration Index (SAIDI) exceeds a threshold value (TMED). For the purposes of calculating daily system SAIDI, any interruption that spans multiple calendar days is accrued to the day the interruption began. Statistically, days having a daily system SAIDI greater than TMED are days the energy delivery system experiences stresses beyond normally expected, such as severe weather. Activities occurring on MEDs should be analyzed and reported separately.

Operating Area(s)—Idaho Power's circuits in 1) the Jordan Valley region of the reporting area served by Idaho Power's Canyon Operations Center and 2) in the reporting area serviced by Idaho Power's Western Operations Center.

Reporting Area—Idaho Power's entire service area in Oregon.

SAIDI—System Average Interruption Duration Index

SAIFI—System Average Interruption Frequency Index

TMED—A major event day (MED) identification threshold value.

SYSTEM PERFORMANCE

The attached system charts and tables show Idaho Power's Oregon system performance (63 Oregon circuits) over five years for the reliability indices of SAIDI, SAIFI, and MAIFI_E, including and excluding MED calculations in years 2012 and 2013.

Figures 1 through 3 provide a graphic representation of the overall system reliability for each index. These figures also show the increase in SAIDI and SAIFI and the decrease in MAIFI_E between the 2012 and 2013 reporting years. This represents the affects the five MEDs had on Idaho Power's system. Prior to 2012, MEDs were not indentified and recorded, so the indices excluding MED are represented as zero. Tables 1 through 3 display the calculated SAIDI, SAIFI and MAIFI_E indices for each circuit. Although the last five reporting years are displayed and 2012 data included calculations based on MED information, only the current reporting year (2013) has a calculation showing for each of the indices with MED excluded.

Table 4 lists each of the 63 circuits' data for the three reliability indices, including and excluding MEDs. Each column is sorted in descending order based on the calculation including MEDs. This data reflects the top five active circuits were affected by one or more of the MEDs experienced by Idaho Power in 2013.

Figures 4 through 6 provide a graphic representation of the circuits, in descending order based on Table 4, for the three reliability indices. Also attached are charts for each Oregon circuit by reliability index, graphed to represent the indices including and excluding MEDs.

Tables 5 and 6 show the number of sustained outages experienced by cause code as defined in OPUC Rule 860-023-0161. Table 5 represents the outage causes in alphabetical order for the five consecutive reporting years, and Table 6 represents the current reporting year sorted in descending order based on occurrences. In both tables, the activity attributed to customer equipment and MEDs are shown; however, these causes are excluded from the overall calculation and totals as allowed for in the code. These tables are followed by graphs that show outage activity by cause over the five consecutive reporting years.

The top five causes of Idaho Power's sustained interruptions in 2013 were due to the following (in descending order):

- Equipment Failure
- Scheduled Outages
- Adverse Environment
- Lightning
- Unknown

Figure 7 is a bar chart representing the 12 types of sustained outage causes based on the percent of the total occurrences. This is based on the data in Table 5 for current year activity only.

Table 7 ranks the 2013 momentary event causes by number of interruptions. Except for those few events that were processed through Idaho Power's Outage Management System (OMS), the bulk of these events are not assigned an outage cause code.

Table 8 lists all of Idaho Power's substations and feeders located in Oregon along with the feeder voltage and the number of customers served.

Table 9 provides five years of line/trench miles and customer count data. A slight increase in underground service has been realized in the last five years.


Table 10 provides a summary of the five MEDs Idaho Power experienced in 2013 (full reports for each day are on file with the OPUC). In all five situations, the company experienced equipment failures causing a loss of supply to the distribution system.

The increase in SAIFI and SAIDI experienced in 2013 is largely attributed to the increase in MEDs. Idaho Power experienced equipment failures that caused a loss of supply to the distribution system. Three of the five MEDs experienced were located on lines that are not easily accessed, causing a longer duration than would be Idaho Power's normal response time.

Idaho Power continues to implement programs and projects to help improve customer service and electric service reliability. Some of the programs include the annual Oregon safety inspection/reliability patrols, line clearing program, and annual maintenance projects.

SYSTEM SAIDI, SAIFI, AND MAIFI_E DATA

System SAIDI




System SAIDI Values

2009	2010	2011	2012	2013	2013 MED excluded
3.61	4.98	3.47	3.57	6.99	4.62

Figure 1

Five years of system reliability data with and without MED—system SAIDI values

System SAIFI




System SAIFI Values

2009	2010	2011	2012	2013	2013 MED excluded
1.14	1.62	1.41	1.43	2.41	2.01

Figure 2

Five years of system reliability data with and without MED—system SAIFI values

System MAIFI_E



System MAIFI_E Values

2009	2010	2011	2012	2013	2013 MED excluded
4.78	3.78	3.50	4.70	3.80	3.54

Figure 3

Five years of system reliability data with and without MED—system MAIFI_E values

Table 1
Five years of circuit SAIDI data with and without MED

Circuit	2009	2010	2011	2012	2013	2013 SAIDI MED Excluded
ADRN11	2.31	0.15	1.26	3.52	3.52	3.52
ADRN12	3.45	0.50	2.63	5.69	7.31	6.23
CARO11	0.73	5.48	1.26	0.39	1.54	1.54
CARO12	0.13	0.94	3.35	3.27	1.48	1.37
CARO13	0.08	1.75	0.91	1.40	0.85	0.85
CWVY11	0.33	2.98	2.86	1.88	17.05	8.50
CWVY12	2.61	50.35	7.80	11.19	22.04	13.49
DRKE11	9.42	11.67	7.41	1.95	6.25	6.25
DUKE11	2.96	0.00	9.94	9.08	9.82	5.01
DWSY11	5.19	2.37	9.50	1.63	19.03	18.92
ESTN11	1.57	9.72	0.00	6.53	4.99	4.99
HCSU11	0.00	0.00	0.00	1.17	0.00	0.00
HFWY11	4.16	21.65	9.59	10.66	41.28	18.08
HFWY12	7.10	0.18	13.12	9.72	40.71	15.18
HGTN11	2.30	15.86	2.15	7.67	1.33	1.26
HGTN12	0.03	3.86	0.13	1.82	0.03	0.03
HMDL12	10.87	2.48	0.79	3.38	9.62	9.62
HOLY11	3.65	4.48	0.84	1.56	4.02	4.02
HOLY12	1.63	2.62	0.89	1.23	3.25	3.25
HOLY13	2.01	2.24	0.50	4.56	1.64	1.64
HOPE11	3.09	5.67	3.25	1.62	8.34	8.34
HRPR11	15.35	26.48	8.45	1.41	3.53	3.53
HRPR12	13.83	11.13	7.12	5.81	11.67	11.67
JMSN11	4.59	8.24	4.78	1.79	21.53	15.15
JMSN12	1.01	4.90	0.44	13.04	17.00	10.84
JNTA11	5.91	7.81	7.19	1.57	13.45	13.45
JNTA12	1.76	9.38	5.23	5.44	13.97	13.97
JNVY11	19.28	36.95	36.21	31.27	13.73	8.52
JNVY12	20.93	44.29	38.47	31.19	15.21	10.18
JNVY31	31.32	38.77	42.42	34.08	19.33	9.77
LIME11	7.05	15.90	2.41	3.18	0.38	0.38
LIME12	0.03	25.53	8.11	0.00	0.00	0.00
MRBT41	1.86	1.09	56.83	0.65	0.34	0.34
MRBT42	0.28	0.15	0.10	5.44	0.00	0.00
NYSA11	2.71	0.46	0.39	0.22	2.82	2.82

Table 1 (continued)

Circuit	2009	2010	2011	2012	2013	2013 SAIDI MED Excluded
NYSA12	1.16	1.49	2.65	2.48	8.13	8.13
NYSA13	1.85	0.22	1.08	3.94	1.41	1.41
NYSA14	0.70	0.05	0.48	0.94	3.77	3.77
OBPR11	0.00	0.00	0.00	0.00	0.00	0.00
OBPR12	0.00	0.00	0.00	0.00	0.00	0.00
OIDA11	0.06	0.41	0.72	1.67	1.35	1.35
OIDA12	1.55	4.90	4.92	0.00	3.07	3.07
ONTO14	0.50	1.23	1.37	0.18	8.26	8.26
ONTO18	0.03	0.21	0.27	1.68	0.19	0.19
ONTO19	0.11	1.67	0.33	0.64	0.42	0.42
ONTO20	1.46	0.33	1.66	0.31	1.63	1.63
ONTO23	0.83	0.58	0.29	2.40	0.68	0.68
ONTO24	1.03	2.18	0.14	0.25	1.25	1.23
ONTO25	0.12	0.14	0.32	1.35	0.15	0.15
OYDM11	0.00	0.67	0.00	0.00	0.00	0.00
PNCK11	1.29	17.36	14.37	10.47	9.06	4.25
PNCK12	0.00	0.00	14.20	2.52	4.97	2.40
PRMA12	0.00	0.83	4.42	14.92	7.59	7.59
PRMA42	6.24	6.64	0.27	0.34	8.16	8.14
RKVL11	21.75	54.96	29.68	21.49	15.12	13.04
UNTY11	0.65	0.47	1.89	1.76	28.17	21.78
UNTY12	0.87	0.31	1.66	3.82	21.64	15.25
VALE11	0.29	0.75	1.08	0.99	3.23	3.23
VALE13	34.59	19.98	2.14	9.85	5.21	5.21
VALE14	0.92	2.67	5.43	0.62	0.94	0.94
VALE15	0.53	0.54	0.63	3.01	0.33	0.33
WESR13	7.79	1.52	0.35	0.40	3.57	3.57
WESR14	0.91	0.52	0.42	2.60	0.57	0.57

Table 2

Five years of circuit SAIFI data with and without MED

Circuit	2009	2010	2011	2012	2013	2013 SAIFI MED Excluded
ADRN11	1.73	0.11	3.37	3.34	2.29	2.29
ADRN12	0.47	4.47	1.38	3.02	4.10	3.42
CARO11	0.24	1.07	4.27	0.29	0.58	0.58
CARO12	0.05	1.07	1.16	0.82	0.77	0.74
CARO13	0.13	0.27	1.20	0.49	1.05	1.05
CWVY11	0.73	3.17	0.47	1.13	4.07	3.07
CWVY12	5.30	4.35	2.37	2.68	4.40	3.40
DRKE11	2.31	0.00	3.48	1.07	2.34	2.34
DUKE11	3.25	1.29	3.37	2.59	8.00	3.00
DWSY11	1.00	7.00	0.00	1.23	5.76	5.72
ESTN11	0.00	0.00	0.00	4.00	5.33	5.33
HCSU11	1.50	5.14	3.51	1.00	0.00	0.00
HFWY11	2.46	0.11	4.33	2.90	11.46	7.46
HFWY12	1.02	3.29	1.69	1.71	10.44	7.20
HGTN11	0.01	1.14	0.99	2.84	0.30	0.28
HGTN12	7.60	2.34	0.55	1.04	0.02	0.02
HMDL12	3.33	3.14	1.29	1.50	2.27	2.27
HOLY11	1.17	3.27	1.28	0.43	1.28	1.28
HOLY12	1.31	2.42	1.06	0.38	2.08	2.08
HOLY13	3.20	2.24	1.87	1.46	2.05	2.05
HOPE11	3.21	8.06	3.87	0.46	3.40	3.40
HRPR11	3.52	4.37	3.25	0.29	1.77	1.77
HRPR12	2.26	3.77	4.06	1.23	3.00	3.00
JMSN11	0.52	1.48	0.24	1.21	6.92	5.92
JMSN12	2.27	3.42	3.38	2.83	5.08	4.11
JNTA11	1.12	4.30	2.06	1.37	5.05	5.05
JNTA12	6.26	8.19	7.00	1.04	5.00	5.00
JNVY11	6.12	7.56	7.43	6.18	4.14	3.14
JNVY12	8.59	8.26	7.62	6.12	4.89	3.93
JNVY31	2.52	1.94	1.32	8.36	4.51	3.52
LIME11	0.04	5.04	3.55	1.94	0.29	0.29
LIME12	0.39	1.22	1.83	0.00	0.00	0.00
MRBT41	0.20	0.10	0.10	1.15	0.11	0.11
MRBT42	1.86	0.77	0.14	1.10	0.00	0.00
NYSA11	1.20	0.95	2.01	0.13	1.12	1.12

Table 2 (continued)

Circuit	2009	2010	2011	2012	2013	2013 SAIFI MED Excluded
NYSA12	1.95	0.16	0.40	2.49	3.27	3.27
NYSA13	1.17	0.03	0.30	1.51	1.36	1.36
NYSA14	0.00	0.00	0.00	0.60	2.02	2.02
OBPR11	0.00	0.00	0.00	0.00	0.00	0.00
OBPR12	0.03	0.66	1.14	0.00	0.00	0.00
OIDA11	1.00	4.00	3.00	1.09	2.10	2.10
OIDA12	1.00	1.00	3.10	0.00	3.00	3.00
ONTO14	0.04	0.10	0.20	0.14	0.97	0.97
ONTO18	0.05	0.53	0.16	1.02	0.07	0.07
ONTO19	0.12	0.21	0.46	1.10	0.14	0.14
ONTO20	1.98	1.02	0.22	0.18	1.06	1.06
ONTO23	0.50	1.90	0.07	2.00	1.04	1.04
ONTO24	0.04	0.09	0.19	0.16	0.61	0.59
ONTO25	0.00	0.27	0.00	1.07	0.09	0.09
OYDM11	0.61	3.95	4.31	0.00	0.00	0.00
PNCK11	0.00	0.00	5.00	2.27	7.07	2.10
PNCK12	0.00	0.50	3.00	1.00	4.00	2.00
PRMA12	3.94	3.16	0.18	3.00	5.50	5.50
PRMA42	5.96	6.28	6.11	0.22	3.30	3.28
RKVL11	0.19	0.16	0.44	5.22	4.81	3.89
UNTY11	0.22	0.82	0.55	1.08	6.99	5.99
UNTY12	0.24	0.31	0.66	1.68	5.32	4.32
VALE11	0.49	3.58	0.81	1.07	2.52	2.52
VALE13	0.49	1.55	3.08	4.37	1.34	1.34
VALE14	0.24	0.23	0.56	0.59	0.68	0.68
VALE15	2.25	0.47	0.02	1.76	0.17	0.17
WESR13	0.22	0.35	0.24	0.30	0.23	0.23
WESR14	0.00	0.00	0.00	1.21	0.38	0.38

Table 3
Five years of circuit MAIFI_E data with and without MED

Circuit	2009	2010	2011	2012	2013	2013 MAIFI _E MED Excluded
ADRN11	3.04	2.81	3.52	2.73	11.73	11.73
ADRN12	2.00	4.27	3.44	6.44	28.94	28.00
CARO11	4.00	3.00	1.00	7.69	3.04	3.04
CARO12	10.00	7.00	0.00	3.90	4.77	3.77
CARO13	9.98	11.62	5.71	3.00	4.00	3.00
CWVY11	19.13	6.04	1.09	6.00	10.00	10.00
CWVY12	6.00	2.00	7.00	6.13	8.31	8.31
DRKE11	5.87	19.53	18.26	11.59	3.00	2.00
DUKE11	0.00	0.00	0.00	0.00	5.00	4.00
DWSY11	0.00	0.00	0.00	12.00	22.00	22.00
ESTN11	9.50	15.60	12.75	0.00	0.00	0.00
HCSU11	8.79	9.20	14.32	0.00	0.00	0.00
HFWY11	4.10	1.20	3.00	14.15	14.00	13.00
HFWY12	2.00	0.00	2.00	3.81	13.00	8.00
HGTN11	40.98	20.03	4.52	5.00	5.00	3.00
HGTN12	3.00	1.00	0.00	0.00	5.00	3.00
HMDL12	2.00	1.00	2.00	3.50	5.00	5.00
HOLY11	5.28	1.49	1.29	2.00	4.00	4.00
HOLY12	6.00	22.17	3.22	1.00	3.00	3.00
HOLY13	7.00	17.00	0.00	3.34	3.00	3.00
HOPE11	7.65	23.07	8.27	1.44	0.00	0.00
HRPR11	14.00	13.00	0.00	0.00	0.00	0.00
HRPR12	9.93	6.00	6.38	4.99	15.38	15.38
JMSN11	4.00	19.00	17.00	6.00	8.00	8.00
JMSN12	4.00	20.00	0.00	6.18	8.00	8.00
JNTA11	12.45	6.36	16.85	12.00	0.00	0.00
JNTA12	22.00	14.00	16.00	0.00	21.98	21.98
JNVY11	24.03	19.54	21.16	6.31	8.00	8.00
JNVY12	8.00	4.77	1.25	8.00	9.00	9.00
JNVY31	2.00	2.35	0.00	9.84	11.35	11.35
LIME11	11.00	5.00	0.00	1.70	4.98	3.98
LIME12	3.00	0.00	4.00	0.00	0.00	0.00
MRBT41	0.00	0.60	0.68	0.00	0.00	0.00
MRBT42	4.62	1.08	4.07	2.00	0.00	0.00
NYSA11	0.07	0.00	0.00	0.00	8.00	8.00

Table 3 (continued)


Circuit	2009	2010	2011	2012	2013	2013 MAIFI_E MED Excluded
NYSA12	0.39	1.00	0.00	7.86	7.98	7.98
NYSA13	0.00	0.00	0.00	0.00	0.00	0.00
NYSA14	0.00	0.00	0.00	1.00	7.00	7.00
OBPR11	0.00	1.30	0.14	0.00	0.00	0.00
OBPR12	0.00	1.00	0.00	0.00	0.00	0.00
OIDA11	2.00	1.00	0.00	1.07	1.29	1.29
OIDA12	4.00	1.00	0.00	0.00	0.00	0.00
ONTO14	2.00	6.00	1.11	0.00	0.00	0.00
ONTO18	5.17	1.00	0.00	2.00	0.00	0.00
ONTO19	0.00	1.00	4.00	4.87	1.00	1.00
ONTO20	2.00	14.00	1.49	0.00	0.00	0.00
ONTO23	17.45	1.00	0.00	6.00	2.00	2.00
ONTO24	0.00	0.00	0.00	5.96	2.00	2.00
ONTO25	8.70	6.23	7.55	3.00	1.00	1.00
OYDM11	20.00	0.00	0.00	0.00	0.00	0.00
PNCK11	0.00	0.00	3.00	3.14	6.00	5.00
PNCK12	14.07	9.00	2.00	0.00	0.00	0.00
PRMA12	10.07	11.00	17.00	4.00	6.00	6.00
PRMA42	3.27	14.00	9.40	6.57	7.00	7.00
RKVL11	6.61	7.56	5.91	8.00	11.00	9.00
UNTY11	2.07	1.54	3.67	7.27	9.00	9.00
UNTY12	2.70	10.37	3.56	6.30	8.00	8.00
VALE11	0.52	2.00	0.00	2.68	0.00	0.00
VALE13	1.00	0.67	4.00	7.83	9.18	9.18
VALE14	0.52	3.79	0.00	9.00	0.00	0.00
VALE15	1.00	1.00	0.00	4.00	0.00	0.00
WESR13	0.00	0.00	0.00	1.00	2.00	2.00
WESR14	0.00	0.00	0.00	3.45	0.00	0.00

Table 4
2013 descending order sort of reliability indices by circuit


Circuit	SAIDI		Circuit	SAIFI		Circuit	MAIFI_E	
	SAIDI	MED Excluded		SAIFI	MED Excluded		MAIFI_E	MED Excluded
HFWY11	41.28	18.08	HFWY11	11.46	7.46	ADRN12	28.94	28.00
HFWY12	40.71	15.18	HFWY12	10.44	7.20	DWSY11	22.00	22.00
UNTY11	28.17	21.78	DUKE11	8.00	3.00	JNTA12	21.98	21.98
UNTY12	21.64	15.25	PNCK11	7.07	2.10	HRPR12	15.38	15.38
JMSN11	21.53	15.15	UNTY11	6.99	5.99	HFWY11	14.00	13.00
CWVY12	21.13	12.59	JMSN11	6.92	5.92	HFWY12	13.00	8.00
JNVY31	19.33	9.77	DWSY11	5.76	5.72	ADRN11	11.73	11.73
DWSY11	19.03	18.92	PRMA12	5.50	5.50	JNVY31	11.35	11.35
CWVY11	17.05	8.50	ESTN11	5.33	5.33	RKVL11	11.00	9.00
JMSN12	17.00	10.84	UNTY12	5.32	4.32	CWVY11	10.00	10.00
JNVY12	15.21	10.18	JMSN12	5.08	4.11	VALE13	9.18	9.18
RKVL11	15.12	13.04	JNTA11	5.05	5.05	JNVY12	9.00	9.00
JNTA12	13.97	13.97	JNTA12	5.00	5.00	UNTY11	9.00	9.00
JNVY11	13.73	8.52	JNVY12	4.89	3.93	CWVY12	8.31	8.31
JNTA11	13.45	13.45	RKVL11	4.81	3.89	JMSN11	8.00	8.00
HRPR12	11.67	11.67	JNVY31	4.51	3.52	JMSN12	8.00	8.00
DUKE11	9.82	5.01	CWVY12	4.38	3.38	JNVY11	8.00	8.00
HMDL12	9.62	9.62	JNVY11	4.14	3.14	NYSA11	8.00	8.00
PNCK11	9.06	4.25	ADRN12	4.10	3.42	UNTY12	8.00	8.00
HOPE11	8.34	8.34	CWVY11	4.07	3.07	NYSA12	7.98	7.98
ONTO14	8.26	8.26	PNCK12	4.00	2.00	NYSA14	7.00	7.00
PRMA42	8.15	8.13	HOPE11	3.40	3.40	PRMA42	7.00	7.00
NYSA12	8.13	8.13	PRMA42	3.30	3.28	PNCK11	6.00	5.00
PRMA12	7.59	7.59	NYSA12	3.27	3.27	PRMA12	6.00	6.00
ADRN12	7.31	6.23	HRPR12	3.00	3.00	DUKE11	5.00	4.00
DRKE11	6.25	6.25	OIDA12	3.00	3.00	HGTN11	5.00	3.00
VALE13	5.20	5.20	VALE11	2.52	2.52	HGTN12	5.00	3.00
ESTN11	4.99	4.99	DRKE11	2.34	2.34	HMDL12	5.00	5.00
PNCK12	4.97	2.40	ADRN11	2.28	2.28	LIME11	4.98	3.98
HOLY11	4.02	4.02	HMDL12	2.27	2.27	CARO12	4.77	3.77
NYSA14	3.77	3.77	OIDA11	2.10	2.10	CARO13	4.00	3.00
WESR13	3.57	3.57	HOLY12	2.08	2.08	HOLY11	4.00	4.00
ADRN11	3.49	3.49	HOLY13	2.05	2.05	CARO11	3.04	3.04
HRPR11	3.35	3.35	NYSA14	2.02	2.02	DRKE11	3.00	2.00
HOLY12	3.25	3.25	HRPR11	1.73	1.73	HOLY12	3.00	3.00

Table 4 (continued)

Circuit	SAIDI		Circuit	SAIFI		Circuit	MAIFI _E	
	SAIDI	MED Excluded		SAIFI	MED Excluded		MAIFI _E	MED Excluded
VALE11	3.23	3.23	NYSA13	1.36	1.36	HOLY13	3.00	3.00
OIDA12	3.07	3.07	VALE13	1.34	1.34	ONTO23	2.00	2.00
NYSA11	2.82	2.82	HOLY11	1.28	1.28	ONTO24	2.00	2.00
HOLY13	1.64	1.64	NYSA11	1.12	1.12	WESR13	2.00	2.00
ONTO20	1.63	1.63	ONTO20	1.06	1.06	OIDA11	1.20	1.20
CARO11	1.54	1.54	CARO13	1.05	1.05	ONTO19	1.00	1.00
CARO12	1.48	1.37	ONTO23	1.04	1.04	ONTO25	1.00	1.00
NYSA13	1.41	1.41	ONTO14	0.97	0.97	ESTN11	0.00	0.00
OIDA11	1.35	1.35	CARO12	0.77	0.74	HCSU11	0.00	0.00
HGTN11	1.33	1.26	VALE14	0.68	0.68	HOPE11	0.00	0.00
ONTO24	1.25	1.23	ONTO24	0.61	0.59	HRPR11	0.00	0.00
VALE14	0.94	0.94	CARO11	0.58	0.58	JNTA11	0.00	0.00
CARO13	0.85	0.85	WESR14	0.38	0.38	LIME12	0.00	0.00
ONTO23	0.68	0.68	HGTN11	0.30	0.28	MRBT41	0.00	0.00
WESR14	0.57	0.57	LIME11	0.29	0.29	MRBT42	0.00	0.00
ONTO19	0.42	0.42	WESR13	0.23	0.23	NYSA13	0.00	0.00
LIME11	0.38	0.38	VALE15	0.17	0.17	OBPR11	0.00	0.00
MRBT41	0.34	0.34	ONTO19	0.14	0.14	OBPR12	0.00	0.00
VALE15	0.33	0.33	MRBT41	0.11	0.11	OIDA12	0.00	0.00
ONTO18	0.19	0.19	ONTO25	0.09	0.09	ONTO14	0.00	0.00
ONTO25	0.15	0.15	ONTO18	0.07	0.07	ONTO18	0.00	0.00
HGTN12	0.03	0.03	HGTN12	0.02	0.02	ONTO20	0.00	0.00
HCSU11	0.00	0.00	HCSU11	0.00	0.00	OYDM11	0.00	0.00
LIME12	0.00	0.00	LIME12	0.00	0.00	PNCK12	0.00	0.00
MRBT42	0.00	0.00	MRBT42	0.00	0.00	VALE11	0.00	0.00
OBPR11	0.00	0.00	OBPR11	0.00	0.00	VALE14	0.00	0.00
OBPR12	0.00	0.00	OBPR12	0.00	0.00	VALE15	0.00	0.00
OYDM11	0.00	0.00	OYDM11	0.00	0.00	WESR14	0.00	0.00

**Figure 4**

2013 circuit SAIDI descending values

**Figure 5**

2013 circuit SAIFI descending values














Figure 6
2013 circuit MAIFI_E descending values



Circuit SAIDI Values
























































Circuit SAIFI Values















































































Circuit MAIFI_E Values













































Table 5

Five years of sustained interruption causes

Cause	Number of Sustained Interruptions					Percent of Total Sustained Interruptions				
	2009	2010	2011	2012	2013	2009	2010	2011	2012	2013
Adverse environment	12	99	161	104	107	2.09	11.47	22.24	15.23	12.23
Adverse weather	40	0	0	0	0	6.96	0.00	0.00	0.00	0.00
Customer equipment*	9	7	8	35	3	1.57	0.81	1.10	5.12	0.34
Equipment failure	110	216	162	173	226	19.13	25.03	22.38	25.33	25.83
Foreign interference	99	63	11	19	14	17.22	7.30	1.52	2.78	1.60
Human element	7	20	12	15	21	1.22	2.32	1.66	2.20	2.40
Lightning	19	16	15	15	104	3.30	1.85	2.07	2.20	11.89
Loss of supply	19	26	31	25	60	3.30	3.01	4.28	3.66	6.86
Major events**	0	0	0	2	5	0.00	0.00	0.00	0.29	0.57
Scheduled outages	64	155	149	136	192	11.13	17.96	20.58	19.91	21.94
Tree/Vegetation	25	49	45	59	63	4.35	5.68	6.22	8.64	7.20
Unknown	180	219	138	137	88	31.30	25.38	19.06	20.06	10.06
Total	575	863	724	683	875	100.00	100.00	100.00	100.00	100.00

*not included in calculations

**not included in calculations, see MED summary







Table 6
2013 sustained interruption cause ranking



Cause	Occurrences	Customer Hours Out	Occurrences Ranking	Hours Out Ranking
Equipment Failure	226	40229.70	1	1
Scheduled Outages	192	15531.85	2	4
Adverse Environment	107	8938.72	3	5
Lightning	104	18462.63	4	3
Unknown	88	4594.27	5	6
Tree/Vegetation	63	3975.36	6	7
Loss of Supply	60	32510.14	7	2
Human Element	21	2704.79	8	8
Foreign Interference	14	1367.04	9	9
Major Events**	5	0.00	0	12
Customer Equipment*	3	6.06	10	10
Adverse Weather	0	0.00	0	11
Total	875	128314.50		


*not included in calculations

**not included in calculations, see MED summary

SUSTAINED INTERRUPTIONS CAUSES





**Figure 7**

2013 causes for sustained interruptions

Table 7
2013 momentary events causes

Cause	Number of Interruptions	Percent of Total	Occurrences Ranking
Unknown	638	98.61	1
Adverse Environment	4	0.62	2
Loss of Supply	2	0.31	3
Equipment Failure	2	0.31	4
Lightning	1	0.15	5
Adverse Weather	0	0.00	0
Customer Equipment*	0	0.00	0
Foreign Interference	0	0.00	0
Human Element	0	0.00	0
Major Events**	0	0.00	0
Scheduled Outages	0	0.00	0
Tree/Vegetation	0	0.00	0
Total	647	100	

*not Included in calculations

**not Included in calculations see MED Summary

Table 8
Customer count voltage station

Circuit	Substation	Kilovolts (kV)	Customers*
ADRN11	ADRN	12.5	357
ADRN12	ADRN	12.5	572
BACP	BACP	46 KV or Greater	2
BDPK11	BDPK	12.5	1
CARO11	CARO	12.5	1,170
CARO12	CARO	12.5	95
CARO13	CARO	12.5	748
CWVY11	CWVY	12.5	47
CWVY12	CWVY	12.5	111
DRKE11	DRKE	12.5	166
DUKE11	DUKE	12.5	28
DWSY11	DWSY	12.5	173
ESTN11	ESTN	12.5	3
HCSU11	HCSU	12.5	2
HFWY11	HFWY	12.5	733
HFWY12	HFWY	12.5	532
HGTN11	HGTN	12.5	71
HGTN12	HGTN	12.5	301
HMDL12	HMDL	12.5	138
HOLY11	HOLY	12.5	179
HOLY12	HOLY	12.5	72
HOLY13	HOLY	12.5	163
HOPE11	HOPE	12.5	127
HRPR11	HRPR	12.5	95

Table 8 (continued)

Circuit	Substation	Kilovolts (kV)	Customers
HRPR12	HRPR	12.5	182
JMSN11	JMSN	12.5	383
JMSN12	JMSN	12.5	222
JNDY	JNDY	46 KV or Greater	2
JNTA11	JNTA	12.5	65
JNTA12	JNTA	12.5	45
JNYY11	JNYY	12.5	87
JNYY12	JNYY	12.5	81
JNYY31	JNYY	24	325
LIME11	LIME	12.5	107
MRBT41	MRBT	34.5	10
MRBT42	MRBT	34.5	7
NHTS	NHTS	46 KV or Greater	2
NPSS	NPSS	46 KV or Greater	1
NYSA11	NYSA	12.5	841
NYSA12	NYSA	12.5	539
NYSA13	NYSA	12.5	429
NYSA14	NYSA	12.5	246
OIDA11	OIDA	12.5	614
OIDA12	OIDA	12.5	1
ONTO14	ONTO	12.5	34
ONTO18	ONTO	12.5	849
ONTO19	ONTO	12.5	1,774
ONTO20	ONTO	12.5	1,202
ONTO23	ONTO	24	44

Table 8 (continued)

Circuit	Substation	Kilovolts (kV)	Customers
ONTO24	ONTO	24	661
ONTO25	ONTO	24	490
OYDM11	OYDM	12.5	16
PNCK11	PNCK	12.5	98
PNCK12	PNCK	12.5	2
PRMA12	PRMA	12.5	3
PRMA42	PRMA	34.5	175
RKVL11	RKVL	12.5	27
UNTY11	UNTY	12.5	143
UNTY12	UNTY	12.5	220
VALE11	VALE	12.5	1,025
VALE13	VALE	12.5	535
VALE14	VALE	12.5	334
VALE15	VALE	12.5	457
WESR13	WESR	12.5	187
WESR14	WESR	12.5	31
Total			18,367

* The customer counts represented here are not meant to match those represented on the various other charts/data as a different source was used in order to establish voltage.

Table 9

Five years of line/trench miles data

Year	Overhead (OH) Pole Miles	Underground (UG) Trench Miles	Distribution All Trench Miles	Transmission Line (Structure/Pole) Miles	Customer Counts	OH/UG %
2013	2,113.58	93.31	2,206.88	693.65	18,349.00	87/13
2012	2,112.38	92.65	2,205.03	686.66	18,296.00	87/13
2011	2,112.82	87.77	2,200.59	685.22	19,394.00	87/13
2010	2,114.69	92.13	2,206.82	675.12	19,447.00	87/13
2009	2,120.26	92.11	2,215.54	667.75	19,493.00	88/12


Transmission line miles include some lines that do not directly serve customer load.

Table 10

MED system summary

MED	Customers	Customer Duration (Min)	Customers Out	Day SAIDI	Day SAIFI	Day CAIDI	Cause
1/23/2013	18,308	4,551	568	14.03	0.03	480.76	Loss of supply
4/28/2013	18,308	8,561	1,399	27.99	0.08	367.15	Loss of supply
5/26/2013	18,366	7,524	1,397	24.54	0.08	323.16	Loss of supply
9/15/2013	18,352	7,516	1,124	24.54	0.06	401.22	Lightning/pole fire
12/7/2013	18,373	13,329	1,647	43.53	0.09	485.58	Loss of supply


**2013 SAIDI
MED Excluded
OREGON AREA**






N

0 5 10 20 30
Miles

3/3/2014






**2013 SAIDI
With MED
OREGON AREA**






3/3/2014

**2013 SAIFI
MED Excluded
OREGON AREA**




3/3/2014

**2013 SAIFI
With MED
OREGON AREA**



3/3/2014

**2013 MAIFIE
MED Excluded
OREGON AREA**





15.39 - 28.00
10.01 - 15.38
7.01 - 10.00
4.01 - 7.00
1.30 - 4.00
0.00 - 1.29
Med Feeders

N

0 5 10 20 30
Miles

3/3/2014

**2013 MAIFIE
With MED
OREGON AREA**



0 5 10 20 30
Miles

3/3/2014