ORDER NO. 20-483

ENTERED Dec 23 2020

BEFORE THE PUBLIC UTILITY COMMISSION

OF OREGON

UE 385

In the Matter of	
PORTLAND GENERAL ELECTRIC COMPANY,	ORDER
Advice No. 20-14 (ADV 1130), Schedule 300 Line Extension Allowance.	

DISPOSITION: STAFF'S RECOMMENDATION ADOPTED WITH MODIFICATIONS

This order memorializes our decision, made and effective at our December 15, 2020 Regular Public Meeting, to adopt Staff's recommendation in this matter, with modifications. We are concerned about incenting development of inefficient electric resistance heating systems that would add to the cost of meeting winter peak electric demand, in tension with the Commission's longstanding support for incentives that promote energy efficiency. To address our concern, we order Portland General Electric Company to exclude new dwellings that are primarily heated with electric resistance heat from eligibility for the residential "all electric" line extension allowance. In addition, we modify Staff's recommended condition to require that PGE provide a review of the line extension allowance using updated data by June 30, 2024. The Staff Report with the recommendation is attached as Appendix A.

le, entered, and effective	<u> </u>
Mega-W Decker	Letho Towney
Megan W. Decker Chair	Letha Tawney Commissioner
	Au " hu
TITY	Mark R. Thompson Commissioner



A party may request rehearing or reconsideration of this order under ORS 756.561. A request for rehearing or reconsideration must be filed with the Commission within 60 days of the date of service of this order. The request must comply with the requirements in OAR 860-001-0720. A copy of the request must also be served on each party to the proceedings as provided in OAR 860-001-0180(2). A party may appeal this order by filing a petition for review with the Circuit Court for Marion County in compliance with ORS 183.484.

ITEM NO. RA3

PUBLIC UTILITY COMMISSION OF OREGON STAFF REPORT PUBLIC MEETING DATE: December 15, 2020

PUBLIC MEETING DATE: December 15, 2020

REGULAR X CONSENT EFFECTIVE DATE February 1, 2021

DATE: December 8, 2020

TO: Public Utility Commission

FROM: Sabrinna Soldavini

THROUGH: Bryan Conway and John Crider SIGNED

SUBJECT: PORTLAND GENERAL ELECTRIC:

(Docket No. ADV 1130/Advice No. 20-14)

Updates Schedule 300 Line Extension Allowance, revising Residential

Line Extension Allowance.

STAFF RECOMMENDATION:

Approve Portland General Electric's (PGE or Company) Advice No. 20-14, which updates Schedule 300 Line Extension Allowance, to revise the residential line extension allowance (LEA) policy, effective with service rendered on and after January 1, 2021, subject to the following condition:

1. No later than June 30, 2025, the Company agrees to initiate a review, along with Staff and other interested parties, of the residential LEAs using updated PGE energy use data for newly constructed residential homes.

DISCUSSION:

Issue

Whether the Public Utility Commission of Oregon (Commission) should approve PGE's Advice No. 20-14, updating Schedule 300 Line Extension Allowance.

Applicable Rule or Law

ORS 757.205 requires public utilities to file schedules showing all rates, tolls, and charges for service that have been established and are in force at the time. Pursuant to

ORS 757.210, the Commission may approve tariff changes if they are deemed to be fair, just, and reasonable.

ORS 757.220 requires that any proposed change in rates, tolls, charges, rules, or regulations must be filed with the Commission by the utility at least 30 days before the effective date of the changes. ORS 757.220.

OAR 860-022-0025 requires that each energy utility changing existing tariffs or schedules must include in its filing a statement plainly indicating the increase, decrease, or other change made with the filing, the number of customers affected by the proposed change and the resulting change in annual revenue; and the reasons or grounds relied upon in support of the proposed change.

OAR 860-021-0045(1) states that an electric company shall, with the exceptions provided under its extension rules, furnish service connections to the customer's service entrance.

Analysis

Background

On June 8, 2020, PGE filed Advice No. 20-14, requesting updates to its residential LEA, as outlined in Schedule 300's Line Extension Allowance. PGE's filing seeks to substantively change the Company's current residential line extension policy. Currently, all new residential dwellings have the same maximum residential LEA, \$1,623. The Company's filing seeks to create two distinct categories for residential LEAs, each with their own LEA.

The first category, Residential Service All Electric (All Electric), would be available to dwellings where the primary heating source is provided by an active electric HVAC-system. The second category, Residential Service Primary Other (Other), would be available to dwellings where the active primary service is provided by an HVAC system using combustion furnaces fueled by natural gas, propane, oil, and biodiesel as well as all passive HVAC-system solutions.

In PGE's initial application, the Company requested an All Electric LEA of \$2,560 per dwelling/unit and an Other LEA of \$1,590 per dwelling/unit.

On August 20, 2020, the Company submitted a supplemental filing, lowering the amount of the Residential All Electric LEA to \$2,260 per dwelling/unit and committing to an automatic review to be conducted between Staff, the Company, and interested parties

Docket No. ADV 1130/Advice No. 20-14 December 8, 2020 Page 3

with updated PGE energy use data for newly constructed residential homes no later than June 2025.

On November, 19, 2020, PGE submitted a second supplemental filing requesting to modify the effective date from January 1, 2020, to February 1, 2020, with the understanding that Staff would bring this docket to the Commission for decision at the December 15, 2020, Public Meeting.

PGE's proposal sets the residential LEA to three times the annual distribution and basic charge revenues. The proposed LEAs are calculated using the average between PGE new home construction usage data and industry estimated consumption for specific end-uses in residential new construction.

In its filing, the Company asserts that this proposal to restructure its residential LEAs supports Oregon's decarbonization goals, as outlined in the Governor's Executive Order No. 20-04 (EO 20-04), by providing an incentive to electrify, and thereby decarbonizing residential load. However, Staff's analysis and recommendation does not rely on PGE's assertion, but instead relies only on applicable statutes and rules.

Line Extension Allowance Principles

An energy utility is assigned an exclusive service territory. Within the service territory, the utility is obligated to serve all customers. However, this obligation does not exempt the new customer from bearing the costs incurred to connect the customer to the system. A line extension allowance is the amount of money the customer is credited against the PGE-estimated cost of their line extension.

Line extension allowances are a common practice in the utility industry. Most electric utilities have a line extension policy that outlines how costs are allocated and incurred to extend service to new customers. Generally, the utility provides a credit against the cost for providing services up to the customer property location.

The amount of the credit is the amount not collected from the customer. This means that the credit is essentially the amount that is added to the utility's rate base and included in overall revenue requirements. Given that the new customer will contribute revenues to the system which help pay for common costs, PGE is recognizing that a larger use customer should provide greater margins and thus can be offered a greater line extension amount. A limiting factor in the amount of the credit is to ensure that

¹ Docket No. ADV 1130, PGE Initial Filing, page 2.

amount of the line extension does not result in higher rates to other customers since the credit is included in revenue requirements.^{2,3}

Staff affirms its position that a line extension allowance should hold other customers harmless – that is, in its review, Staff's goal is to ensure that the proposed line extension allowance does not result in higher residential rates. To ensure that, the expected incremental revenues from the new customers are compared to the amount of the line extension allowance. Another consideration is to treat customers equitably. Since all residential customers have likely been eligible for line extensions, there should be a consideration of equity among customers for the line extension allowances they received.

Staff's Analysis & Review

In order to determine the reasonableness of PGE's proposal to have a more granular residential LEA, Staff focused its review on determining if the proposed LEA's would ensure that other customers would not be harmed by creating a distinct LEA for All Electric and Other residential dwellings.

To do so, Staff met with the Company on several occasions, and sent two sets of information requests, to ensure the Company's proposal uses the appropriate load estimates (to reasonably estimate the expected incremental revenue) and cost data (to estimate the supportable LEA).

Load Data

As mentioned above, PGE's proposal will set the residential LEA to three times the expected annual distribution and basic charge revenues.⁴

PGE's proposal to split the residential LEAs into All Electric and Other categories is in part justified by the idea that a new all-electric customer is likely to have higher annual kWh usage than a new customer who uses another fuel source.

The proposed Other LEA assumes an annual usage of 9,100 kWh, and the proposed All Electric LEA assumes annual usage of 12,980 kWh. The LEA's are calculated using PGE's new home construction usage data, as well as industry estimated consumption for specific end-uses in residential new construction from the Northwest Power

² RAP Electric Cost Allocation for a New ERA, page 59: https://www.raponline.org/wp-content/uploads/2020/01/rap-lazar-chernick-marcus-lebel-electric-cost-allocation-new-era-2020-january.pdf.

³ This is similar in concept to an incentive rate and the discussion in Order No. 87-402.

⁴ Staff notes that PGE's current residential LEA is set at four times the expected annual distribution and basic charge revenues.

Council's Regional Technical Forum (RTF) and the US Energy Information Administration's 2015 Residential Consumption Survey.

After reviewing the Company's initial application, Staff and the Company met to review its proposal and associated workpapers on June 26, 2020. After this meeting, Staff requested additional information regarding the Company's proposed LEAs, including further clarification on the incremental difference in the LEA between the All Electric and Other categories.

Staff and PGE met again on July 11, 2020, to further discuss PGE's usage data and its proposed residential LEA's. Staff's main concern in its review was that while PGE new home construction usage data does suggest that there is a difference in the expected annual usage (and therefore revenue) between All Electric and Other customers, the PGE system usage data alone did not warrant as large of an incremental difference in the LEA's as PGE's initial application proposed (\$2,560 and \$1,593 per dwelling/unit). Staff expressed its preference that whenever possible, utility specific data be used rather than industry estimates.

PGE expressed that it was proposing to use the estimated annual usage data from the RTF (as opposed to PGE data) to calculate the All Electric LEA because of data reliability concerns including small sample sizes, improper tagging of a portion of the homes in its data set, and the utility's inability to verify the accuracy of information about appliances in a customer's home. PGE believes that the RTF data provides a more accurate estimate of a new All Electric customer's incremental annual usage.

On August 13, 2020, Staff, PGE, and the Citizens' Utility Board (CUB) met to discuss the Company's proposal. Subsequently, on August 20, 2020, the Company filed replacement sheets lowering the proposed All Electric LEA from \$2,560 to \$2,260 per dwelling/unit.

The updated estimated annual consumption for the All Electric category is 12,980 kWh. This represents the average of the RTF data (14,692 kWh) and PGE system data from 2010-2017 (11,269 kWh). In the revised filing, PGE also agrees to an automatic review of the residential LEAs, to take place no later than June 2025.

Staff finds that the proposal to use the midpoint between PGE's system usage data and the RTF estimates, with an automatic review to take place no later than June 30, 2025, is a reasonable compromise between Staff's preference to use Company-specific usage data and the Company's concerns that its data is not fully reliable or accurate at this time.

Using the midpoint between these two estimates allows PGE to achieve its goal to create two distinct residential LEA categories, while ensuring that the All Electric LEA meets the principle of not raising rates to other customers. Staff's intent is that the proposed automatic review will allow PGE sufficient time to collect accurate survey and usage data for newly constructed all electric homes within its survey territory so that the residential LEAs can be evaluated based on PGE specific kWh usage data, and have the LEA revised if necessary.

Cost Data

To determine whether PGE's proposal to use a multiplier of three times the annual distribution and basic charge revenues is justifiable, it is important to review the underlying cost data and any assumptions related to these estimated costs. As such, Staff issued six detailed data requests asking the Company to perform quantitative analysis demonstrating the reasonableness of its proposed revenue multiplier.

Staff requested that PGE perform this analysis using marginal cost data specific to residential customers from its most recent rate case, UE 335, and net book life and salvage value assumptions from its most recently approved depreciation study, UM 1809. Staff also requested and reviewed sample residential line extension allowance work order requests.

In response to Staff's requests, the Company performed a breakeven analysis demonstrating that the maximum supportable multiplier is approximately 8.5 as shown in the following table.⁵

⁵ Attachment A, Page 4, PGE Response to Staff IR 3.

Line No	Description	Residential Line Extension Allo Source	Units	Value
LIIIE NO	•	Jource	Offics	Value
	Revenue from Residential Schedule			
1	7	UE 335 Rev Prop	(\$000)	\$942,357
	Marginal Cost to Serve Residential			
2	Load from UE 335	UE 335	(\$/MWh)	\$93.93
3	Energy from Residential Sch 7	UE 335 Rev Prop	MWh	7,568,918
	Marginal Cost to Serve Residential			
4	Load from UE 335	Line 2 * Line 3/1000	(\$000)	\$710,912
5	Net Margin from Residential Sch 7	Line 1 - Line 4	(\$000)	\$ 231,446
6	Annualization Factor	Levelized Annual Rev Req		6.23%
7	Investment Supported by Revenue	Line 5/Line 6	(\$000)	\$ 3,712,405
	Basic and Distribution Revenue	Line 3* Distribution and Basic		
8	from Schedule 7	Charge Marginal Revenue	(\$000)	\$439,073
	Supportable Residential Line			
9	Extension Allowance	Line 7/Line 8	Multiplier	8.455097655

Staff has reviewed the Company's analysis and its responses to Staff's information requests, and finds that in this instance, the multiplier of three is justified and can be reasonably expected to not result in an increase in residential rates.

Staff notes that individual line extension projects have incremental costs and revenues that will vary, but the proposed All Electric and Other LEAs are based on aggregate data and remain constant and do not vary by project. Therefore, by proposing an LEA of three years of expected revenues, PGE creates a buffer between the proposed allowances and the breakeven point, which reduces the risk that other customers will see a rate increase as a result of the proposed LEAs.

Stakeholder Comments

At the time of this writing, three separate stakeholders have filed comments on PGE's proposal: Electrify Now, Oregon League of Conservation Voters (OLCV), and Northwest Natural Gas Company (NW Natural).

Both Electrify Now and OLCV expressed support for the proposal, stating that the proposed All Electric LEA is a meaningful mechanism to encourage electrification in Oregon's building sector, which the stakeholders assert is critical in meeting the goals of EO 20-04.

⁶ An important note is that while the All Electric and Other LEA remain constant for all projects, they represent a maximum, not a guarantee. For example, if the expected cost of a line extension is only \$1200, the customer would receive a \$1200 allowance, not the maximum LEA.

In its comments, NW Natural requests that the Commission not rely on PGE's characterization of EO 20-04 in making its determination of whether or not to approve PGE's application. NW Natural notes that it could not determine what analysis PGE relied on or performed in making its claims that its proposal will support EO 20-04 and asks that if the Commission does consider the merits of EO 20-04 in its decision, that it require PGE to support its claims with further analysis and provide an opportunity for stakeholders to review, seek discovery, and provide comment. As stated earlier, Staff gave no weight or consideration to PGE's characterization of EO 20-04 in determining a recommendation for the Commission.

Conclusion

Based on Staff's analysis of PGE's filing, associated workpapers, responses to Staff information requests, and virtual meetings with the Company, Staff finds that the Company's updates to Schedule 300 result in rates that are fair, just, and reasonable.

While Staff notes that PGE's proposal to create two separate categories of LEA based on whether the customer is an All Electric customer appears to be novel (Staff is unaware of another electric utility with a similar structure), Staff finds that this reasonably comports with the principles of LEAs to base the allowance on a multiple of expected annual revenues.

Finally, in making this recommendation, Staff reaffirms that it has not relied on PGE's assertion that it's proposed residential LEAs will support the goals of EO 20-04. Staff's recommendation is consistent with its past practice in evaluating LEAs on an economic basis.

PROPOSED COMMISSION MOTION:

Approve PGE's Advice No. 20-14, which updates Schedule 300 Line Extension Allowance, to revise the residential LEA policy, effective with service rendered on and after January 1, 2021, subject to the following condition:

1. No later than June 30, 2025, the Company agrees to initiate a review, along with Staff and other interested parties, of the residential LEAs using updated PGE energy use data for newly constructed residential homes.

November 9, 2020

TO: Sabrinna Soldavini

Public Utility Commission of Oregon

FROM: Robert Macfarlane

Manager, Pricing and Tariffs

PORTLAND GENERAL ELECTRIC ADV 1130 / Advice No. 20-14 PGE Response to OPUC Information Request No. 003 Dated October 26, 2020

Request:

Please reference the Company's supplemental application, which states that the appropriate revenue multiplier is three times the annual and basic distribution charge revenues.

- a. Please explain, in narrative form, why a multiple of three is appropriate.
- b. Please provide a quantitative analysis to support the statement that a revenue multiplier of three is justifiable. Please also separately show what the maximum supportable revenue multiplier would be. Please provide all workpapers in Excel spreadsheet format, formulae, sources, and definitions used in this analysis.

Response:

- A. Consistent with previous practice, PGE uses the "net revenues" approach to derive line extension allowances. It is derived from the added facility rate charge in which there is no capital recovery and which does not include components for rate based costs (rate of return, income tax, carrying cost of capital, and depreciation). The multiplier of three enables PGE to limit the LEA to the costs of the average installation. Those net revenues are economically justified based on the expected revenues provided by the new customer that "support" the distribution line and service extension.
- B. Please see attached spreadsheets IR3B.XLSX and IR3B&4A Marginal Costs.XLSX

The formula used to calculate PGE's previous Residential Line Extension Amounts in 2011 and 2001 is:

- 1. Basic Charge Revenues + Distribution Revenues/KWH forecast=\$/kWh.
- 2. KWH forecast/Customer forecast=Average customer kwh usage
- 3. \$\frac{1}{kWh} * Average customer kWh usage * Revenue years= Line Extension Allowance.

Using the methodology described above and updating the Residential Line Extension based on the updated Basic and Distribution Charge Revenues, the average KWH from PGE's

RA 3 - ADV 1130

RA 3 - ADV 1130 PGE Response to Staff IR 3, Attachment IR 3B&4A Marginal Costs.XLX $\begin{tabular}{c} RDER & NO. \end{tabular}$

20-483

ADV 1130 PGE Response to OPUC IR 003 October 26, 2020

Page 2

last General Rate Case UE 335 and applying a multiplier of 3, the line extension allowance would be \$1684. If PGE continued to use a multiplier of 4 the maximum supportable line extension would be \$2,245.

In Advice Filing 1130 PGE did not use the total Average customer kWh usage from UE 335 to calculate its Residential Line Extension Allowance. Instead PGE used 9,110 kWh for Residential Service Primary Other (this is the average yearly load of residential customers who do not use electricity as their primary heating source) and 12,980 kWh for Residential All Electric (this is the Reginal Technical Form Data and the PGE midpoint) This resulted in a Residential Line Extension Allowance of \$1590 for "Other" and \$2260 for "All Electric"

PGE has calculated a supportable residential line extension allowance of 8 years. This is derived from using similar methodology that Pacific Power used in Advice 1148 for their Transportation Electrification Line Extension Allowance. However, as discussed above PGE divides the investment supported by revenue by the basic and distribution revenues to calculate the supportable residential line extension multiplier instead of using the total revenues which Pacific Power does. This is appropriate because PGE's multiple is based on Basic and Distribution Charge revenues rather than total revenues.

Prior to filing Advice Filing 1130, PGE reviewed the work orders received for residential new construction between November 2014 and July 2019. The average cost to install new residential service was \$2,005 per dwelling/unit. Based on those work orders, the total amount of investment under PGE's revised proposed would not increase.

PGE Response to Staff IR 3, Attachment IR 3B&4A Marginal Costs.XLX ORDER NO. Page 3 20-483

Portland General Electric Marginal Cost Summary (000)s

		Generation	Generation							Real	Other		Real
	cos	Energy	Capacity	Transmission	Substation	Subtransmission	Meter	Customer	Subtotal	Levelized	Dist	Total	Levelized
	MWh	MC	MC	MC	MC	MC	MC	MC	MC	MC \$/kWh	MC	MC	MC \$/kWh
Schedule 7	7,568,915	\$307,309	\$142,662	\$17,436	\$4,207	\$4,237	\$15,214	\$49,618	\$540,682	\$0.0714	\$170,229	\$710,912	\$0.0939
Schedule 32	1,631,912	\$65,236	\$23,824	\$3,167	\$670	\$675	\$3,711	\$7,557	\$104,840	\$0.0642	\$38,351	\$143,191	\$0.0877
Schedule 38	31,497	\$1,298	\$319	\$50	\$28	\$29	\$46	\$62	\$1,833	\$0.0582	\$1,104	\$2,936	\$0.0932
Schedule 83	2,887,308	\$116,524	\$41,074	\$5,697	\$1,264	\$1,273	\$1,443	\$2,880	\$170,155	\$0.0589	\$39,182	\$209,337	\$0.0725
Schedule 85	2,714,651	\$107,903	\$34,884	\$4,989	\$1,395	\$1,404	\$654	\$2,151	\$153,380	\$0.0565	\$23,013	\$176,393	\$0.0650
Schedule 89	454,957	\$17,521	\$4,660	\$698	\$411	\$488	\$47	\$336	\$24,160	\$0.0531	\$2,699	\$26,859	\$0.0590

LEA Annual Margin	al Costs
Other Electric Annual KWH	9108
Other Electric Annual Cost	\$855,4703

LEA Annual Marginal Costs
All Electric Annual KWH 12980
All Electric Annual Cost \$1,219.1485

Other Electric	Monti Jan	0.112830729 1028	Feb 0.08	9199115 812	Mar 0.0	8798784 801	Apr 0.0	7566315 689		1288 649	Jun 0.0674	85112 615	Ju l y 0.076	814389 700	Aug	0.07853296 715		06856497 624	Oct 0.0	070783 645	Nov 0.08652	25107 788	Dec 0.11432595 104	1	9107	Energy Price Block 1 Energy Price Block 2	0.06329 0.07051
Block 1 Block 2		1,000 28		812 0		801 0		689 0		649 0		615 0		700 0		715 0		624 0		645 0		788 0	1,000 41		9,038 69	Transmission Price Distribution Price	0.00243 0.04652
Energy Block 1 Energy Block 2 Transmision Distribution Basic Charge Total	\$ \$ \$ \$ \$	1.97 2.50 47.82	\$ \$ \$ \$ \$ \$	-	\$ \$ \$	50.70 1.95 37.26 11.00 100.90	\$ \$	1.67 32.05	\$ 1	1.58 0.19 1.00	\$ \$ \$	38 92 1 49 28 61 11 00 80 03	\$ \$ \$	1.70 32.56 11.00 89.57	\$ \$ \$	45.25 1.74 33.26 11.00 91.25	\$ \$ \$	1.52 29.03 11.00	\$ \$ \$	1.57 30.01 11.00 83.39	\$ \$ \$ \$ \$		\$ 2.89 \$ 2.53 \$ 48.43 \$ 11.00	\$ \$ \$	572.02 4.87 22.13 423.66 132.00 1,154.67		
All Electric Mo	nthly Jan		Feb		Mar		Apr		May		Jun		July		Aug		Sep		Oct		Nov		Dec	То	tal		
kWh/mo Block 1 Block 2		0.112830729 1,465 1,000 465	0.08	9199115 1,158 1,000 158	0.0	8798784 1,142 1,000 142	0.0	982 982 982 0		1288 925 925 0	0.0674	85112 876 876 0	0.076	814389 997 997 0		0.07853296 1,019 1,000 19	0.0	06856497 890 890 0	0.0	919 919 919 0	1	25107 1,123 1,000 123	0.11432595 1,484 1,000 484		12,980 11,589 1,391	\$ 444.25	
Energy Block 1 Energy Block 2 Transmision Distribution Basic Charge Total		3.56	\$ \$ \$ \$ \$ \$ \$	63.29 11.14 2.81 53.87 11.00 142.11	\$ \$ \$	63.29 10.01 2.78 53.13 11.00 140.20	\$	45.68	\$ \$ \$ 4 \$ 1	2.25 3.03 1.00	\$ \$ \$ \$	2 13 40 75 11 00 09 32	\$ \$ \$	63.10 2.42 46.38 11.00 122.90	\$ \$ \$	63.29 1.34 2.48 47.40 11.00 125.51	\$ \$ \$	2.16 41.40 11.00	\$ \$ \$	58.16 2.23 42.75 11.00 114.15	\$ \$ \$ \$ \$	83.29 8.67 2.73 52.24 11.00 37.93	\$ 34.13 \$ 3.61 \$ 69.04 \$ 11.00	\$ \$ \$	733.47 98.08 31.54 603.83 132.00 1,598.92		

 $\begin{array}{c} \text{RA 3-ADV 1130} \\ \text{PGE Response to Staff IR 3, Attachment IR 3B\&4A Marginal Costs.XLX} \\ \text{ORDER NO.} \\ \text{Page 4} \\ \textbf{20-483} \\ \text{Calculation of Proposed Residential Line Extension Allowance} \end{array}$

Line No Description	Source	Units	Value	
 Revenue from Residential Schedule 7 Marginal Cost to Serve Residential 	UE 335 Rev Prop		(\$000)	\$942,357
2 Load from UE 335	UE 335	(\$/MwH)		\$93.93
3 Energy from Residenital Sch 7 Marginal Cost to Serve Residential	UE 335 Rev Prop	MWh		7,568,918
4 Load from UE 335	Line 2 * Line 3/1000		(\$000)	\$710,912
5 Net Margin from Residential Sch 7	Line 1 -Line 4 Levelized Annual Rev		(\$000) \$	231,446
6 Annualization Factor	Req			6.38%
7 Investment Supported by Revenue	Line 5/ Line 6 Line 3* Distribution and		(\$000) \$	3,629,364
Basic and Distribution Revenue from	Basic Charge Marginal			
8 Schedule 7 Supportable Residential Line	Revenue		(\$000)	\$439,073
9 Extension Allowance	Line 7/ Line 8	Multiplier		8.265970238

Carrying Cost Calculation: Schedule 7 Residential Service

Key Assumptions:					
30% Depreciation Incentive			no		
Book Investment			1		
Tax Book Investment			1		
Book Life			48		
Salvage Rate			-30.00%		
Tax Life			7	Choices are 1	,3,5,7,15, or 20
Composite Income Tax Rate			26.99%		
Property Tax Rate			1.45%		
Inflation Rate			2.00%		
Capitalization:					
Preferred	0.00%		0.00%		
Common	50.00%	9.50%	4.75%		
All Equity	50.00%		4.75%		
Debt	50,00%	5,10%	2.55%		
Cost of Capital			7.30%		
After-Tax Nominal Cost of Capital			6.61%		
After-Tax Real Cost of Capital			4.52%		
Results - Capital Recovery Factors					
Net Present Value of Revenue Req	uirements			\$1	
Levelized Annual Rev. Requirement	t			\$0.06	6.38%

1	Λ	-183
Z	U	-483

				Year by Year Re	venue Requireme	ents			Unadjusted	Adjusted	
	Book	Salvage	Return	Income	Deferred	Property		Investment.	Tax	Tax Rates	Tax
r	Depr	Value	Reqmis	Tax	Tax	Taxes	Rev Reqmts	Base	Rates		Depr
1	0	0	0	(0)	0	0	0	1	14.29%	14,29%	0
2	0	0	0	(0)	0	0	0	1	24,49%	24.49%	0
3	0	0	0	(0)	0	0	0	1	17.49%		0
4	0	0	0		0		0	í			0
-		-	_	(0)		0	_		12,49%		
5	0	0	0	(0)	0	0	0	1	8.93%		0
6	0	0	0	(0)	0	0	0	1	8.92%	8.92%	0
7	0	0	0	(0)	0	0	0	1	8.93%	8.93%	0
8	0	0	0	0	0	0	0	1	4.46%	4.46%	0
9	0	0	0	0	0	0	0	1	0.00%	0.00%	-
10	0	0	0	0	0	0	0	1	0,00%		_
11	0	0	0	0	0	0	0	1	0.00%		_
12	0	0	0	0	0	0	0		0.00%		
											-
13	0	0	0	0	0	0	0	1	0.00%		•
14	0	0	0	0	0	0	0	1	0.00%		
15	0	0	0	0	0	0	0	1	0.00%	0.00%	-
16	0	0	0	0	0	0	0	0	0.00%	0.00%	
17	0	0	0	0	0	0	0	0	0.00%	0.00%	
18	0	0	0	0	0	0	0	0	0,00%	0,00%	
19	0	0	0	0	0	0	0	0	0,00%		
20	0	0	0	0	0	0	0	0	0.00%		
	0	0	0	0	0		0	0	0.00%		•
21						0					•
22	0	0	0	0	(0)	0	0	0	0.00%		
23	0	0	0	0	(0)	0	0	0	0.00%	0.00%	-
24	0	0	0	0	(0)	0	0	0	0.00%	0.00%	-
25	0	0	0	0	(0)	0	0	0	0.00%	0.00%	-
26	0	0	0	0	(0)	0	0	0	0.00%	0.00%	-
27	0	0	0	0	(0)	0	0	0	0.00%	0.00%	_
28	0	0	0	0	(0)	0	0	0	0.00%		_
29	0	0	0	0	(0)	0	0	0	0.00%		
											-
30	0	0	0	0	(0)	0	0	0	0,00%		
31	0	0	0	0	(0)	0	0	0	0.00%		-
32	0	0	0	0	(0)	0	0	0	0,00%	0.00%	-
33	0	0	0	0	(0)	0	0	0	0.00%	0.00%	-
34	0	0	0	0	(0)	0	0	0	0.00%	0.00%	-
35	0	0	0	0	(0)	0.0	0	0	0.00%	0.00%	-
36	0	0	(0)	0	(0)	0	0	(0)	0.00%	0.00%	
37	0	0	(0)	0	(0)	0	0	(0)	0.00%		
38	0	0	(0)	0	(0)	0	0	(0)	0.00%		
39	0	0	(0)	0	(0)		0		0.00%		-
								(0)			•
40	0	0	(0)	0	(0)	0	0	(0)	0.00%		•
41	0	0	(0)	0	(0)	0	0	(0)	0.00%		•
42	0	0	(0)	0	(0)	0	0	(0)	0.00%		-
43	0	0	(0)	0	(0)	0	0	(0)	0.00%	0.00%	
44	0	0	(0)	0	(0)	0	0	(0)	0.00%	0.00%	
45	0	0	(0)	0	(0)	0	0	(0)	0.00%	0.00%	
46	0	0	(0)	0	(0)	0	0	(0)	0.00%		
47	0	0	(0)	0	(0)	0	0	(0)	0.00%		
											_
48	0	0	(0)	(0)	(0)	0	(0)	(0)	0.00%		0
49	0	0	0	0	0	0	0	0	0,00%		
50	0	0	0	0	0	0	0	0	0.00%	0.00%	-
51	0	0	0	0	0	0	0	0	0,00%	0.00%	
52	0	0	0	0	0	0	0	0	0.00%	0.00%	-
53	0	0	0	0	0	0	0	0	0.00%	0.00%	_
	0	0	0	0	0	0	0	0	0.00%		
54											_
54 55	0	0	0	0	0	0	0	0	0.00%	0.00%	

Nominal Levelized
Real Levelized

20-483

Income Tax Rates by Tax Property Life

Year	1-year	3-year	5-year	7-year	10-year	15-year	20-year
1	100.00%	33.33%	20.00%	14.29%	10.00%	5.00%	3.75%
2		44.45%	32.00%	24.49%	18.00%	9.50%	7.22%
3		14.81%	19.20%	17.49%	14.40%	8.55%	6.68%
4	•	7.41%	11.52%	12.49%	11.52%	7.70%	6.18%
5			11.52%	8.93%	9.22%	6.93%	5.71%
6	i		5.76%	8.92%	7.37%	6.23%	5.29%
7				8.93%	6.55%	5.90%	4.89%
8	1			4.46%	6.55%	5.90%	4.52%
9	1				6.56%	5.91%	4.46%
10	1				6.55%	5.90%	4.46%
11					3.28%	5.91%	4.46%
12						5.90%	4.46%
13						5.91%	4.46%
14						5.90%	4.46%
15						5.91%	4.46%
16	i					2.95%	4.46%
17							4.46%
18	1						4.46%
19	ı						4.46%
20	1						4.46%
21							2.23%

RA 3 - ADV 1130 PGE Response to Staff IR 3, Attachment IR 3B&4A Marginal Costs.XLX ORDER NO. Page 8

20-483

UKDEK NO. 17 305

ESI 1809 / Sidpolating Fording / 105 From - Fording - Special S

PORTLAND GENERAL ELECTRIC TABLE 1. SUMMARY OF ESTIMATED SURVIVOR GURZES, RET SALVAGE, CRIGMAL COST, BOOK RESERVE AND CALCULATED ANNUAL DEPRECIATION ACCURATED TO ELECTRIC PLANTAT DECEMBER 31,7918

	ACCOUNT	BURWVOR	NET SALVAGE PERCENT	CHIGHNAL COST AS OF DECEMBER 31, 1915	BOOK	PUTURE	ANNUAL A		GOMPOSITE REMAINING LIFE
	(6)	(2)	(2)	(4)	(6)	(4)	(2)	(8)=(7)/(4)	(03=(0343)
346.01	MISCELLANEOUS PLANT EQUIPMENT - WIND BIGLOW CANYON WIND FARM TUCANNON RIVER WIND FARM TOTAL ACCESSORY ELECTRIC EQUIPMENT - WIND	40 - R2.5 40 - R2.5	(%) (7)	1,223,570.00 486,405,43 1,010,000.03	287,760 16,218 297,970	1,181,967 606,302 1,857,029	41,642 13,577 56,219	3.15 2.79 3.05	27.0 37.2 30.2
3	TOTAL OTHER PRODUCTION FLANT			2,369,365,262,46	101,515,259	1,057,601,786	01,700,015	3,42	21.0
	TOTAL PRODUCTION			3,887,804,859.08	1,527,720,885	2,016,691,804	140,500,825	3,49	
7	TRANSMISSION PLANT								
352.00 353.00 353.00 354.00 355.00 358.00 358.00	BITRUCTURES AND IMPROVEMENTS OTATION EQUIPMENT TO OVARDIMAN TOWERS AND FIXITIES ON ESTAND FORTURES OMERICAN CONDUCTORS AND DEVICES MADD AND HAVE	55 - 142.5 57 - 142 57 - 152 70 - 153 50 - 163 65 - 122.5 65 - 163	(15) (15) (15) (15) (16) (16)	19,312,917.31 267,004,001.60 5,500,401.62 46,819,209.47 25,714,205.61 73,514,306.69 206,032.52	7,936,981 04,987,961 4,777,980 24,317,309 11,698,906 80,343,434 150,597	14,272,874 213,722,884 2,916,782 27,203,979 26,288,998 24,108,694 125,745	344,407 5,616,835 415,797 881,028 844,683 615,014 3,967	1.78 9.21 7.04 1.88 3.28 6.70 1.96	41.4 36.1 4.9 31.0 29.0 46.0 36.0
3	TOTAL TRANSMISSION PLANT			439,460,019.01	293,760,847	306,918,624	11,524,678	2.03	34,4
	HISTRIBUTION PLANT								
361,60 362,60 363,60 364,60 366,00 366,00 366,00 367,00 369,01 369,01 370,00 371,00 373,01 373,01 373,01	CYTHIC AND IMPROVEMENTS STATION EQUIPMENT STORAGE BASTIERY STORAGE BASTIERY PACE OF TOWNS AND POTUNESS OVERSEAD COMMUNICATE AND DEVICES UNDESCRICTION COMMUNICATED AND DEVICES UNDESCRICTION COMMUNICATED AND DEVICES UNDESCRICTION COMMUNICATED AND DEVICES UNDESCRICTION COMMUNICATED AND DEVICES UNDESCRICTION OF THE AND DEVICES METTERS - RETAINED METTERS - RETAINED METTERS - RETAINED METTERS - RETAINED CITICATES - OTHER CONTINUES OF THE AND DEVICES OF THE AND THE AND THE AND DEVICES OF THE AND THE AND THE AND DEVICES OF THE AND THE A	65 - R2 55 - 50 16 - L2 60 - 50,5 60 - 50,5 80 - 84 65 - 31,6 50 - R2 65 - R2 66 - R2 76 - R2 76 - L2 76 - L2 76 - L2 76 - L2 76 - L2 77 - L0 77 - L0	(25) (20) (45) (70) (46) (70) (10) (10) (10) (10) (10) (10) (10) (1	25,801,374,33 472,200,678,52 397,215,63 349,616,645,77 587,305,162,37 587,305,162,37 587,909,44 151,300,422,74 66,4770,100,00 177,331,441,10 376,133,46 21,800,380,75 50,000,670,76	14,827,007 146,6306,170 201,126,126,126,126,126,126,126,126,126,12	36, 124,621 421, 136, 641 127, 136, 641 127, 136, 719 160, 507, 656 6, 527, 660 74, 560, 660	86.4,126 13,465.428 3,2653 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461 10,871,461	2,22 2,05 2,74 3,56 0,94 1,76 1,76 1,76 1,74 5,96 7,95 8,98 1,71 2,05 4,51	59,7 51,3 10,8 26,5 30,0 48,0 33,0 33,0 48,0 16,2 10,0 7,0 14,4 23,2 16,2 16,2
	OTAL DISTRIBUTION PLANT		3005	1.161.854.679.97	1,813,824,908	2,653,649,435	92.428.361	2.02	28.8

PORTLAND GENERAL ELECTRIC 2019 Test Period Functionalized Revenue Requirement

Function	Amount	Spread
PRODUCTION TRANSMISSION ANCILLARY	\$1,031,772 \$32,362 \$4,832	\$1,031,772 \$32,362 \$4,832
DISTRIBUTION METERING BILLING CONSUMER TOTALS	\$623,465 \$10,238 \$68,913 \$59,799 \$1,831,381	\$623,465 \$10,238 \$68,913 \$59,799 \$1,831,381
Schedule 129 Employee Discou Partial Requireme	nt ents Transmission	(\$20,751) \$924 \$0 \$0
Spread Total		\$1,811,554

Note: Employee discount is allocated to distribution

PORTLAND GENERAL ELECTRIC UNBUNDLED 2019 COSTS (\$000)

	Unbundled Costs	Adjusted to Cycle
Fixed Generation Revenue Requirement	\$670,245	\$670,276
Net Variable Power Costs	<u>\$361,528</u>	\$361,545
Production Costs	\$1,031,772	\$1,031,821
Ancillary Services	\$4,832	\$4,832
Transmission		
Transmission	\$32,362	
Partial Requirements Daily Demand	<u>\$0</u>	
Transmission Costs	\$32,362	\$32,364
Distribution Services	\$623,465	
Franchise	(\$46,473)	
Uncollectibles	(\$5,977)	
Trojan Decommissioning	(\$1,900)	
Partial Requirements Daily Demand	\$0	
Employee Discount	<u>\$924</u>	\$924
Distribution Costs	\$570,038	\$570,049
Consumer Services		
Metering Services	\$10,238	\$10,238
Billing Services	\$68,913	\$68,915
Other Consumer Services	\$59,799	\$59,800
Franchise Fees	\$46,473	\$46,474
Uncollectibles	\$5,977	\$5,977
Trojan Decommissioning	\$1,900	\$1,900
Schedule 129	(\$20,751)	(\$20,751)
Totals	\$1,811,554	\$1,811,619
Net of employee discount	\$1,810,630	\$1,810,695
Net of Sch 129	\$1,831,381	\$1,831,446
Calendar MWH (COS & ESS)	19,400,134	
Cycle MWH (COS & ESS)	19,400,511	
Cycle/Cal Ratio	100.00%	
COS Calendar Energy MWH	17,311,501	
COS Cycle MWH	17,312,384	
Cycle/Cal Ratio	100.01%	
5,510,0ai 1 tatio	100.0170	

20-483

TABLE 4 PORTLAND GENERAL ELECTRIC ESTIMATED EFFECT ON CONSUMERS' TOTAL ELECTRIC BILLS 2019

		Forecast SSEP18E19		TOTAL ELEC	PROPOSED			
	RATE		MWH	with all supplementals	with all supplementals _	Change		
CATEGORY	SCHEDULE	CUSTOMERS	SALES	except LIA & PPC	except LIA & PPC	AMOUNT	PCT.	
Residential Employee Discount Subtotal	7	782,981	7,568,918	\$928,180,528 (\$892,151) \$927,288,377	\$942,357,498 (<u>\$923,927)</u> \$941,433,570	\$14,176,970 (<u>\$31,776)</u> \$14,145,193	1.5% 1.5%	124 . 50 124.38
Outdoor Area Lighting	15	0	15,774	\$3,568,386	\$3,485,781	(\$82,605)	-2.3%	220.98
General Service <30 kW	32	93,765	1,633,156	\$189,640,551	\$190,024,014	\$383,464	0.2%	116.35
Opt. Time-of-Day G.S. >30 kW	38	383	31,475	\$4,350,858	\$4,248,375	(\$102,483)	-2.4%	134.98
Irrig. & Drain. Pump. < 30 kW	47	3,061	21,633	\$4,296,902	\$4,334,828	\$37,926	0.9%	200.38
Irrig. & Drain. Pump. > 30 kW	49	1,274	64,540	\$9,292,165	\$9,175,362	(\$116,803)	-1.3%	142.16
General Service 31-200 kW	83	11,529	2,884,961	\$272,232,731	\$268,892,282	(\$3,340,449)	-1.2%	93.20
General Service 201-4,000 kW Secondary Primary	85-S 85-P	1,166 187	2,122,422 591,424	\$176,801,651 \$45,816,258	\$171,539,680 \$44,470,925	(\$5,261,972) (\$1,345,333)	-3.0% -2.9%	80 . 82 75 . 19
Schedule 89 > 4 MW Primary Subtransmission	89-P 89-T	11 5	401,176 62,759	\$26,138,522 \$4,705,037	\$25,463,982 \$4,614,815	(\$674,539) (\$90,223)	-2.6% -1.9%	63.47 73.53
Schedule 90	90-P	4	1,861,066	\$108,870,263	\$106,319,848	(\$2,550,415)	-2.3%	57.13
Street & Highway Lighting	91/95	203	50,583	\$11,383,176	\$11,346,574	(\$36,602)	-0.3%	224.32
Traffic Signals	92	16	2,496	\$214,980	\$211,860	(\$3,120)	-1.5%	84.88
COS TOTALS		894,585	17,312,384	\$1,784,599,856	\$1,785,561,897	\$962,040	0.1%	103.14
Direct Access Service 201-4,000 kt Secondary Primary	N 485 - S 485-P	233 49	595,102 331,338	\$16,932,699 \$7,923,918	\$15,171,471 \$7,115,507	(\$1,761,228) (\$808,411)		
Direct Access Service > 4 MW Secondary Primary Subtransmission	489-S 489-P 489-T	1 15 3	13,482 961,033 187,171	\$346,455 \$19,048,674 \$1,277,969	\$271,105 \$17,124,259 \$1,257,386	(\$75,350) (\$1,924,415) (\$20,584)		
DIRECT ACCESS TOTALS		301	2,088,126	\$45,529,716	\$40,939,728	(\$4,589,988)		
COS AND DA CYCLE TOTALS		894,886	19,400,511	\$1,830,129,572	\$1,826,501,625	(\$3,627,947)	-0.2%	

20-483

TABLE 3 PORTLAND GENERAL ELECTRIC ESTIMATED EFFECT ON CONSUMERS' TOTAL ELECTRIC BILLS 2019

		Forecast SSEP18E19		TOTAL ELEC	CTRIC BILLS			
				CURRENT	PROPOSED			
	RATE		MWH	all supplementals except LIA, PPC &	all supplementals except LIA, PPC & _	Change		
CATEGORY	SCHEDULE	CUSTOMERS	SALES	Sch 109	Sch 109	AMOUNT	PCT.	
Residential Employee Discount Subtotal	7	782,981	7,568,918	\$890,865,762 (\$892.151) \$889,973,611	\$912,308,893 (\$923,927) \$911,384,966	\$21,443,131 (\$31,776) \$21,411,355	2.4% 2.4%	120.53 120.41
Odbiolai				ψουσ,στο,στι	ψ311,004,000	Ψ21,411,000	2.470	120.41
Outdoor Area Lighting	15	0	15,774	\$3,438,566	\$3,378,518	(\$60,048)	-1.7%	214.18
General Service <30 kW	32	93,765	1,633,156	\$182,233,850	\$184,134,546	\$1,900,695	1.0%	112.75
Opt. Time-of-Day G.S. >30 kW	38	383	31,475	\$4,187,958	\$4,120,001	(\$67,957)	-1.6%	130.90
Irrig. & Drain, Pump. < 30 kW	47	3,061	21,633	\$4,127,080	\$4,198,754	\$71,674	1.7%	194.09
Irrig. & Drain, Pump. > 30 kW	49	1,274	64,540	\$8,935,285	\$8,886,000	(\$49,285)	-0.6%	137.68
General Service 31-200 kW	83	11,529	2,884,961	\$261,716,224	\$260,870,257	(\$845,968)	-0.3%	90.424
General Service 201-4,000 kW								
Secondary	85-S	1,166	2,122,422	\$170,792,784	\$166,995,474	(\$3,797,310)	-2.2%	78.68
Primary	85-P	187	591,424	\$44,851,167	\$43,741,075	(\$1,110,092)	-2.5%	73.96
Schedule 89 > 4 MW								
Primary	89-P	11	401,176	\$26,138,522	\$25,463,982	(\$674,539)	-2.6%	63.47
Subtransmission	89-T	5	62,759	\$4,705,037	\$4,614,815	(\$90,223)	-1.9%	73.53
Schedule 90	90 - P	4	1,861,066	\$108,870,263	\$106,319,848	(\$2,550,415)	-2.3%	57.13
Street & Highway Lighting	91/95	203	50,583	\$11,005,321	\$10,999,575	(\$5,746)	-0.1%	217.46
Traffic Signals	92	16	2,496	\$206,943	\$205,446	(\$1,498)	-0.7%	82,31
COS TOTALS		894,585	17,312,384	\$1,721,182,611	\$1,735,313,255	\$14,130,644	0.8%	100.24
Direct Access Service 201-4,000 k	w							
Secondary	485 - S	233	595,102	\$15,162,194	\$13,832,527	(\$1,329,667)		
Primary	485 - P	49	331,338	\$7,558,054	\$6,838,822	(\$719,231)		
Direct Access Service > 4 MW								
Secondary	489 - S	1	13,482	\$346,455	\$271,105	(\$75,350)		
Primary	489 - P	15	961,033	\$19,048,671	\$17,124,257	(\$1,924,414)		
Subtransmission	489-T	3	187,171	\$1,277,969	\$1,257,386	(\$20,584)		
DIRECT ACCESS TOTALS		301	2,088,126	\$43,393,344	\$39,324,097	(\$4,069,246)		
COS AND DA CYCLE TOTALS		894,886	19,400,511	\$1,764,575,955	\$1,774,637,352	\$10,061,397	0.6%	

TABLE 2 PORTLAND GENERAL ELECTRIC ESTIMATED EFFECT ON CONSUMERS' TOTAL ELECTRIC BILLS 2019

Forecast SSEP18E19 **TOTAL ELECTRIC BILLS** CURRENT **PROPOSED** RATE MWH Change w/ Sch. 125, 122, w/ Sch. 125, 122, AMOUNT PCT. CATEGORY **SCHEDULE** CUSTOMERS SALES 146, 102 146, 102 Residential 7 782,981 7,568,918 \$883,523,912 \$898,230,706 \$14,706,794 1.7% (\$884,717) Employee Discount (\$12,539) \$882,639,195 \$897,333,450 \$14,694,255 Subtotal 1.7% **Outdoor Area Lighting** 15 0 15,774 \$3,431,783 \$3,405,807 (\$25,976) -0.8% General Service <30 kW 32 93,765 1,633,156 \$182,134,741 \$186,647,295 \$4,512,555 2.5% Opt. Time-of-Day G.S. >30 kW -1.0% 38 383 31,475 \$4,164,980 \$4,124,117 (\$40,863)Irrig, & Drain, Pump, < 30 kW 47 3,061 21,633 \$4,106,095 \$4,213,032 \$106,937 2.6% Irrig. & Drain. Pump. > 30 kW 49 1,274 64,540 \$8,895,265 \$8,902,199 \$6,934 0.1% General Service 31-200 kW 83 11,529 2,884,961 \$260,300,580 \$260,219,296 (\$81,284)0.0% General Service 201-4,000 kW Secondary 85-S 1,166 2,122,422 \$169,806,684 \$166,377,461 (\$3,429,222)-2.0% **Primary** 85-P 187 591,424 \$44,573,432 \$43,588,792 (\$984,641)-2.2% Schedule 89 > 4 MW -2.2% **Primary** 89-P 11 401,176 \$25,953,980 \$25,387,759 (\$566,222)Subtransmission 89-T 5 62,759 \$4,676,168 \$4,612,304 (\$63,864)-1.4% Schedule 90 90-P 4 1,861,066 \$108,051,394 \$105,835,971 (\$2,215,423) -2.1% 91/95 203 50,583 \$10,987,111 \$98,455 Street & Highway Lighting \$11,085,566 0.9% Traffic Signals 92 16 2,496 \$205,446 \$204,497 (\$948)-0.5% **COS TOTALS** 894,585 17,312,384 \$1,709,926,854 \$1,721,937,546 \$12,010,692 0.7% Direct Access Service 201-4,000 kW Secondary 485-S 233 595,102 \$15,341,561 \$14,118,265 (\$1,223,296) **Primary** 485-P 49 331,338 \$7,661,795 \$7,001,266 (\$660,529) Direct Access Service > 4 MW 489-S 13.482 \$350.904 \$278,385 (\$72,519)Secondary **Primary** 489-P 15 961,033 \$19,356,202 \$17,591,061 (\$1,765,141)489-T \$1,300,435 Subtransmission 3 187,171 \$1,337,864 (\$37,429)**DIRECT ACCESS TOTALS** 301 2,088,126 \$44,048,327 \$40,289,413 (\$3,758,914)

894,886

19,400,511

\$1,753,975,181

\$1,762,226,959

COS AND DA CYCLE TOTALS

\$8,251,778

0.5%

TABLE 1 PORTLAND GENERAL ELECTRIC ESTIMATED EFFECT ON CONSUMERS' TOTAL ELECTRIC BILLS 2019

		Forecast SSEP18E19		TOTAL ELEC	CTRIC BILLS		
				CURRENT	PROPOSED		
	RATE		MWH	w/ Sch. 125, 122,	w/ Sch. 125, 122, _	Change	
CATEGORY	SCHEDULE	CUSTOMERS	SALES	146	146	AMOUNT	PCT.
Residential	7	782,981	7,568,918	\$947,435,349	\$962,557,267	\$15,121,918	1.6%
Employee Discount Subtotal				(\$944,818) \$946,490,531	(<u>\$960,453)</u> \$961,596,814	(\$15,635) \$15,106,283	1.6%
Outdoor Area Lighting	15	0	15,774	\$3,459,005	\$3,433,551	(\$25,454)	-0.7%
General Service <30 kW	32	93,765	1,633,156	\$184,212,064	\$188,764,472	\$4,552,407	2.5%
Opt. Time-of-Day G.S. >30 kW	38	383	31,475	\$4,170,414	\$4,129,655	(\$40,759)	-1.0%
Irrig. & Drain. Pump. < 30 kW	47	3,061	21,633	\$4,269,396	\$4,379,465	\$110,069	2.6%
Irrig. & Drain. Pump. > 30 kW	49	1,274	64,540	\$9,348,582	\$9,364,212	\$15,631	0.2%
General Service 31-200 kW	83	11,529	2,884,961	\$262,184,861	\$262,139,726	(\$45,135)	0.0%
General Service 201-4,000 kW							
Secondary	85-S	1,166	2,122,422	\$170,083,395	\$166,659,481	(\$3,423,914)	-2.0%
Primary	85-P	187	591,424	\$44,610,009	\$43,626,070	(\$983,939)	-2.2%
Schedule 89 > 4 MW							
Primary	89-P	11	401,176	\$25,953,980	\$25,387,759	(\$566,222)	-2.2%
Subtransmission	89-T	5	62,759	\$4,676,168	\$4,612,304	(\$63,864)	-1.4%
Schedule 90	90 - P	4	1,861,066	\$108,051,394	\$105,835,971	(\$2,215,423)	-2.1%
Street & Highway Lighting	91/95	203	50,583	\$10,987,111	\$11,085,566	\$98,455	0.9%
Traffic Signals	92	16	2,496	\$205,446	\$204,497	(\$948)	- 0.5%
COS TOTALS		894,585	17,312,384	\$1,778,702,355	\$1,791,219,543	\$12,517,188	0.7%
Di							
Direct Access Service 201-4,000 kV Secondary	V 485 - S	233	595,102	\$15,341,561	\$14,118,265	(\$1,223,296)	-8.0%
Primary	485 - P	49	331,338	\$7,661,795	\$7,001,266	(\$660,529)	-8.6%
Direct Access Service > 4 MW							
Secondary	489-S	1	13,482	\$350,904	\$278,385	(\$72,519)	-20.7%
Primary	489 - P	15	961,033	\$19,356,202	\$17,591,061	(\$1,765,141)	9.1%
Subtransmission	489 - T	3	187,171	\$1,337,864	\$1,300,435	(\$37,429)	-2.8%
DIRECT ACCESS TOTALS		301	2,088,126	\$44,048,327	\$40,289,413	(\$3,758,914)	

894,886 19,400,511

\$1,822,750,682

\$1,831,508,956

COS AND DA CYCLE TOTALS

\$8,758,274

0.5%

	Billing			Curre	ent	Prop	osed
Schedule	Determinant	Units	Price		Revenues	Price	Revenues
Schedule 7 Residential Service							
Monthly Basic Charge							
Single Phase	9,395,591	bills	\$11.00		\$103,351,501	\$11.00	\$103,351,501
Three Phase	180	bills	\$11.00		\$1,980	\$11.00	\$1,980
Transmission & Related Services Charge TOU Decrement Transmission	7,568,918	MWh	2.09	mills	\$15,819,039	2.43 mills	\$18,392,471 (\$9,508)
Distribution Charge	7,568,918	MWh	43.11	mills	\$326,296,057	46.62 mills	\$352,862,959
TOU Decrement Distribution							(\$182,196)
Energy Charge							
Block 1 (first 500 kWh)	4,150,373	MWh	65.10	mills	\$270,189,253	63 . 29 mills	\$262,677,079
Block 2 (501-1,000 kWh)	2,140,123	MWh	65.10	mills	\$139,322,024	63 . 29 mills	\$135,448,401
Block 3 (over 1,000 kWh)	1,278,422	MWh	72.32	mills	\$92,455,495	70.51 mills	\$90,141,551
TOU Decrement Generation							(\$126,972)
Schedule 122	7,568,918	MWh	0.00	mills	\$0	0.00 mills	\$0
Schedule 125	7,568,918	MWh	0.00	mills	\$0	0.00 mills	\$0
Schedule 145	7,568,918	MWh	0.27	mills	\$2,043,608	0.26 mills	\$1,967,919
Schedule 146	7,568,918	MWh	0.00	mills	\$0	0.00 mills	\$0
Schedule 102							
1,000 and under	6,290,496	MWh	(10.16)	mills	(\$63,911,438)	(9.22) mills	(\$57,998,371)
Over 1,000	1,278,422	MWh	0.00	mills	\$0	(4.95) mills	(\$6,328,190)
Schedule 105	7,568,918	MWh	(0.16)	mills	(\$1,211,027)	0.13 mills	\$983,959
Schedule 109	7,568,918	MWh	4.93	mills	\$37,314,766	3.97 mills	\$30,048,605
Schedule 110	7,568,918	MWh	0.05	mills	\$378,446	0.05 mills	\$378,446
Schedule 123	7,568,918	MWh	0.09	mills	\$681,203	2.00 mills	\$15,137,836
Schedule 126	7,568,918	MWh	0.00	mills	\$0	0.00 mills	\$0
Schedule 135	7,568,918	MWh		mills	\$1,059,649	0.44 mills	\$3,330,324
Schedule 137	7,568,918	MWh	0.47	mills	\$3,557,391	0.47 mills	\$3,557,391
Schedule 143	7,568,918	MWh	(0.19)	mills	(\$1,438,094)	(0.17) mills	(\$1,286,716)
Schedule 112	7,568,918	MWh	0.30	mills	\$2,270,675	0.30 mills	\$2,270,675
Employee Discount					(\$892,151)		(\$923,927)
Totals	7,568,918	MWh			\$927,288,377		\$953,695,218
					Change		\$26,406,840
					Percent Change		2.85%

PORTLAND GENERAL ELECTRIC

Cost of Service Cycle Billing Determinants & Revenues (with supplementals)

	Billing			Curre	ent	Proposed		
Schedule	Determinant	Units	Price		Revenues	Price	F	Revenues
Schedule 15 Outdoor Area Lighting								
Transmission & Related Services Charge	15,774	MWh	1.29	mills	\$20,348	1.52	mills	\$23,976
Distribution Charge	15,774	MWh	167.46	mills	\$2,641,438	167.17	mills	\$2,636,964
(includes fixed and sys. usage charges)								
Energy Charge	15,774	MWh	50.54		\$797,218	48.98		\$772,611
Schedule 122	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	15,774	MWh	0.22	mills	\$3,470	0.20	mills	\$3,155
Schedule 146	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	3,264	MWh	(8.34)	mills	(\$27,222)	(8.50)	mills	(\$27,744)
Schedule 105	15,774	MWh	(0.39)	mills	(\$6,152)	0.10	mills	\$1,577
Schedule 109	15,774	MWh	8.23	mills	\$129,820	6.80	mills	\$107,263
Schedule 110	15,774	MWh	0.10	mills	\$1,577	0.10	mills	\$1,577
Schedule 123	15,774	MWh	(0.08)	mills	(\$1,262)	0.21	mills	\$3,313
Schedule 126	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	15,774	MWh	0.11	mills	\$1,735	0.33	mills	\$5,205
Schedule 137	15,774	MWh	0.37	mills	\$5,836	0.37	mills	\$5,836
Schedule 143	15,774	MWh	(0.15)	mills	(\$2,366)	(0.13)	mills	(\$2,051)
Schedule 112	15,774	MWh	0.25	mills	\$3,944	0.25	mills	\$3,944
Totals	15,774	MWh			\$3,568,386			\$3,535,627
					Change			(\$32,759)
				- 1	Percent Change			-0.92%

	Billing			Curr	ent		Propo	sed
Schedule	Determinant	Units	Price		Revenues	Price		Revenues
Schedule 32								
Small Non-residential Service								
Monthly Basic Charge								
Single Phase	672,008	bills	\$17.00		\$11,424,136	\$20.00		\$13,440,160
Three Phase	453,173	bills	\$23.00		\$10,422,979	\$29.00		\$13,142,017
Transmission & Related Services Charge	1,633,156	MWh	1.76	mills	\$2,874,354	2.06	mills	\$3,364,301
Distribution Charge								
Block 1	1,427,418	MWh	41.80	mills	\$59,666,073	42.32	mills	\$60,408,330
Block 2	205,738	MWh	8.92	mills	\$1,835,180	14.87	mills	\$3,059,319
Energy Charge	1,633,156	MWh	60.00	mills	\$97,989,342	58.42	mills	\$95,408,956
TOU Decrement								(\$58,612)
Schedule 122	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	1,633,156	MWh	0.25	mills	\$408,289	0.24	mills	\$391,957
Schedule 146	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	249,080	MWh	(8.34)	mills	(\$2,077,324)	(8.50)	mills	(\$2,117,177)
Schedule 105	1,633,156	MWh	(0.15)	mills	(\$244,973)	0.12	mills	\$195,979
Schedule 109	1,631,432	MWh	4.54	mills	\$7,406,700	3.61	mills	\$5,889,469
Schedule 110	1,631,432	MWh	0.05	mills	\$81,572	0.05	mills	\$81,572
Schedule 123	1,631,432	MWh	(0.70)	mills	(\$1,142,002)	(1.39)	mills	(\$2,267,690)
Schedule 126	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	1,633,156	MWh	0.13	mills	\$212,310	0.40	mills	\$653,262
Schedule 137	1,633,156	MWh	0.44	mills	\$718,589	0.44	mills	\$718,589
Schedule 143	1,633,156	MWh	(0.17)	mills	(\$277,636)	(0.15)	mills	(\$244,973)
Schedule 112	1,633,156	MWh	0.21	mills	\$342,963	0.21	mills	\$342,963
Totals	1,633,156	MWh			\$189,640,551			\$192,408,421
					Change			\$2,767,871
					Percent Change			1.46%

	Billing			Curren	t		Propos	ed
Schedule	Determinant	Units	Price	R	evenues	Price	R	evenues
Schedule 38								
Large Non-residential Service Time-of-Day	,							
Monthly Basic Charge								
Single Phase	660	bills	\$25.00		\$16,500	\$30.00		\$19,800
Three Phase	3,935	bills	\$25.00		\$98,375	\$30.00		\$118,050
Transmission & Related Services Charge	31,475	MWh	1.46 n	mills	\$45,953	1.71	mills	\$53,822
Distribution Charge	31,475	MWh	71 . 18 n	mills	\$2,240,362	70.41	mills	\$2,216,126
Reactive Power Charge	54,201	kVar	\$0.50		\$27,101	\$0.50		\$27,101
Energy Charge								
Block 1	17,091	MWh	59.92 r	nills	\$1,024,101	60.70	mills	\$1,037,433
Block 2	14,383	MWh	49 . 92 n	nills	\$718,022	45.70	mills	\$657,324
Schedule 122	31,475	MWh	0.00 n	nills	\$0	0.00	mills	\$0
Schedule 125	31,475	MWh	0.00 n	nills	\$0	0.00	mills	\$0
Schedule 145	31,475	MWh	0.23 r	nills	\$7,239	0.22	mills	\$6,924
Schedule 146	31,475	MWh	0.00 n	nills	\$0	0.00	mills	\$0
Schedule 102	652	MWh	(8.34) r	nills	(\$5,434)	(8.50)	mills	(\$5,538)
Schedule 105	31,475	MWh	(0.26) n	nills	(\$8,183)	0.11	mills	\$3,462
Schedule 109	31,387	MWh	5.19 n	nills	\$162,900	4.09	mills	\$128,374
Schedule 110	31,387	MWh	0.06 n	nills	\$1,883	0.06	mills	\$1,883
Schedule 123	31,387	MWh	(0.08) n	nills	(\$2,511)	0.21	mills	\$6,591
Schedule 126	31,475	MWh	0.00 n	nills	\$0	0.00	mills	\$0
Schedule 135	31,475	MWh	0.12 n	nills	\$3,777	0.37	mills	\$11,646
Schedule 137	31,475	MWh	0.44 r	nills	\$13,849	0.44	mills	\$13,849
Schedule 143	31,475	MWh	(0.17) n	mills	(\$5,351)	(0.14)	mills	(\$4,406)
Schedule 112	31,475	MWh	0.39 n	mills	\$12,275	0.39	mills	\$12,275
Totals	31,475	MWh			\$4,350,858			\$4,304,715
				CI	hange			(\$46,143)
				Pe	ercent Change			-1.06%

	Billing			Curre	nt		Propos	ed
Schedule	Determinant	Units	Price	_ <u>F</u>	Revenues	Price	R	evenues
Schedule 47								
Small Non-residential Irrigation & Pumpin	g Service							
Monthly Basic Charge								
Single Phase	1,344	bills	\$35.00		\$47,040	\$37.00		\$49,728
Three Phase	17,022	bills	\$35.00		\$595,770	\$37.00		\$629,814
Transmission & Related Services Charge	21,633	MWh	1.82	mills	\$39,373	2.13	mills	\$46,079
Distribution Charge								
Block 1	7,536	MWh	108.78	mills	\$819,753	110.99	mills	\$836,407
Block 2	14,098	MWh	88.78	mills	\$1,251,582	90.99	mills	\$1,282,738
Reactive Power Charge	45	kVar	\$0.50		\$23	\$0.50		\$23
Energy Charge								
Block 1	7,536	MWh	70.07	mills	\$528,039	70.94	mills	\$534,595
Block 2	14,098	MWh	70.07	mills	\$987,816	70.94	mills	\$1,000,081
Schedule 122	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	21,633	MWh	0.29	mills	\$6,274	0.29	mills	\$6,274
Schedule 146	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	19,580	MWh	(8.34)	mills	(\$163,301)	(8.50)	mills	(\$166,434)
Schedule 105	21,633	MWh	(0.31)	mills	(\$6,706)	0.14	mills	\$3,029
Schedule 109	21,633	MWh	7.85	mills	\$169,823	6.29	mills	\$136,074
Schedule 110	21,633	MWh	0.09	mills	\$1,947	0.09	mills	\$1,947
Schedule 123	21,633	MWh	(0.08)	mills	(\$1,731)	0.21	mills	\$4,543
Schedule 126	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	21,633	MWh	0.15	mills	\$3,245	0.48	mills	\$10,384
Schedule 137	21,633	MWh	0.53	mills	\$11,466	0.53	mills	\$11,466
Schedule 143	21,633	MWh	(0.20)	mills	(\$4,327)	(0.18)	mills	(\$3,894)
Schedule 112	21,633	MWh	0.50	mills	\$10,817	0.50	mills	\$10,817
Totals	21,633	MWh			\$4,296,902			\$4,393,671
				(Change			\$96,769
				F	Percent Change			2.25%

	Billing			Curr	ent	Proposed		
Schedule	Determinant	Units	Price		Revenues	Price	R	evenues
Schedule 49								
Large Non-residential Irrigation & Pumpin	g Service							
Monthly Basic Charge								
Single Phase	36	bills	\$40.00		\$1,440	\$45.00		\$1,620
Three Phase	7,608	bills	\$40.00		\$304,320	\$45.00		\$342,360
Transmission & Related Services Charge	64,540	MWh	1.82	mills	\$117,463	2.12	mills	\$136,825
Distribution Charge								
Block 1	19,051	MWh	82.39	mills	\$1,569,644	80.99	mills	\$1,542,972
Block 2	45,489	MWh	62.39	mills	\$2,838,055	60.99	mills	\$2,774,370
Reactive Power Charge	8,709	kVar	\$0.50		\$4,355	\$0.50		\$4,355
Energy Charge								
Block 1	19,051	MWh	69.93	mills	\$1,332,264	70.68	mills	\$1,346,552
Block 2	45,489	MWh	69.93	mills	\$3,181,041	70.68	mills	\$3,215,158
Schedule 122	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	64,540	MWh	0.29	mills	\$18,717	0.29	mills	\$18,717
Schedule 146	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	54,354	MWh	(8.34)	mills	(\$453,316)	(8.50)	mills	(\$462,013)
Schedule 105	64,540	MWh	(0.26)	mills	(\$16,780)	0.14	mills	\$9,036
Schedule 109	64,303	MWh	5.55	mills	\$356,880	4.50	mills	\$289,362
Schedule 110	64,303	MWh	0.06	mills	\$3,858	0.06	mills	\$3,858
Schedule 123	64,303	MWh	(0.08)	mills	(\$5,144)	0.21	mills	\$13,504
Schedule 126	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	64,540	MWh	0.15	mills	\$9,681	0.48	mills	\$30,979
Schedule 137	64,540	MWh	0.51	mills	\$32,916	0.51	mills	\$32,916
Schedule 143	64,540	MWh	(0.20)	mills	(\$12,908)	(0.18)	mills	(\$11,617)
Schedule 112	64,540	MWh	•	mills	\$9,681	0.15	mills	\$9,681
Totals	64,540	MWh			\$9,292,165			\$9,298,634
					Change			\$6,469
					Percent Change			0.07%

	Billing		Current			Proposed		
Schedule	Determinant	Units	Price	!	Revenues	Price	<u> </u>	Revenues
Schedule 83 Secondary Delivery Voltage 3 Large Non-residential Standard Service	31-200 kW							
Monthly Basic Charge								
Single Phase	8,194	bills	\$30.00		\$245,820	\$35.00		\$286,790
Three Phase	130,152	bills	\$40.00		\$5,206,080	\$45.00		\$5,856,840
Transmission & Related Services Charge								
On-peak	8,606,661	kW	\$0.65		\$5,594,330	\$0.78		\$6,713,196
Off-peak	3,366	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
Block 1 (first 30 kW)	4,150,380	faccap	\$3.61		\$14,982,872	\$3.50		\$14,526,330
Block 2 (over 30 kW)	6,980,663	faccap	\$3.51		\$24,502,127	\$3.40		\$23,734,254
Distribution Demand Charge								
On-peak	8,606,661	kW	\$2.68		\$23,065,851	\$2,61		\$22,463,385
Off-peak	3,366	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	2,884,961	MWh	6.02	mills	\$17,367,468	6.99	mills	\$20,165,880
Reactive Power Charge	538,563	kVar	\$0.50		\$269,282	\$0.50		\$269,282
Energy Charge	•							
On-peak	1,909,059	MWh	64.33		\$122,809,761	63.35	mills	\$120,938,883
Off-peak	975,902	MWh	49.33		\$48,141,270	48.35	mills	\$47,184,886
Schedule 122	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	2,884,961	MWh	0.25	mills	\$721,240	0.24	mills	\$692,391
Schedule 146	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	225,933	MWh	(8.34)	mills	(\$1,884,280)	(8.50)	mills	(\$1,920,430)
Schedule 105	2,884,961	MWh	(0.17)		(\$490,443)	0.12		\$346,195
Schedule 109	2,834,638	MWh		mills	\$10,516,507	2.83	mills	\$8,022,025
Schedule 110	2,834,638	MWh	0.04	mills	\$113,386	0.04	mills	\$113,386
Schedule 123	2,834,638	MWh	(0.08)	mills	(\$226,771)	0.21	mills	\$595,274
Schedule 126	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	2,884,961	MWh	0.13	mills	\$375,045	0.40	mills	\$1,153,985
Schedule 137	2,884,961	MWh	0.43	mills	\$1,240,533	0.43	mills	\$1,240,533
Schedule 143	2,884,961	MWh	(0.17)		(\$490,443)	(0.15)		(\$432,744)
Schedule 112	2,884,961	MWh	0.06	mills	\$173,098	0.06	mills	\$173,098
Totals	2,884,961	MWh			\$272,232,731			\$272,123,439
				(Change			(\$109,292)
				F	Percent Change			-0.04%

Schedule	Billing	Units		Curre	nt	Proposed		
	Determinant		Price	<u> </u>	Revenues	Price	Revenues	
Schedule 85 Secondary Delivery Voltage 2 Large Non-residential Standard Service	201-4,000 kW							
Monthly Basic Charge								
Single Phase	0	bills	\$500.00		\$0	\$560.00	\$0	
Three Phase	13,993	bills	\$500.00		\$6,996,500	\$560.00	\$7,836,080	
Transmission & Related Services Charge								
On-peak	5,711,975	kW	\$0.65		\$3,712,784	\$0.78	\$4,455,341	
Off-peak	6,572	kW	\$0.00		\$0	\$0.00	\$0	
Distribution Facilities Charge								
Block 1 (first 200 kW)	2,798,600	faccap	\$3.39		\$9,487,254	\$3.17	\$8,871,562	
Block 2 (over 200 kW)	3,878,207	faccap	\$2.49		\$9,656,735	\$1.97	\$7,640,068	
Distribution Demand Charge								
On-peak	5,711,975	kW	\$2,68		\$15,308,093	\$2,61	\$14,908,255	
Off-peak	6,572	kW	\$0.00		\$0	\$0.00	\$0	
System Usage Charge	2,122,422	MWh	1.12	mills	\$2,377,113	0.97 mi	lls \$2,058,749	
Reactive Power Charge	927,749	kVar	\$0.50		\$463,875	\$0.50	\$463,875	
Energy Charge	,-		•		* 7	*	*,	
On-peak	1,390,849	MWh	62.69	mills	\$87,192,302	61.91 mi	lls \$86,107,440	
Off-peak	731,573	MWh	47.69	mills	\$34,888,739	46 . 91 mi		
Schedule 122	2,122,422	MWh	0.00	mills	\$0	0.00 mi	, ,	
Schedule 125	2,122,422	MWh	0.00	mills	\$0	0.00 mi	lls \$0	
Schedule 145	2,122,422	MWh	0.24	mills	\$509,381	0.23 mi	lls \$488,157	
Schedule 146	2,122,422	MWh	0.00	mills	\$0	0.00 mi		
Schedule 102	33,179	MWh	(8.34)	mills	(\$276,711)	(8.50) mi	lls (\$282,020)	
Schedule 105	2,122,422	MWh	(0.15)		(\$318,363)	0.11 mi		
Schedule 109	1,877,771	MWh	3.20		\$6,008,867	2.42 mi		
Schedule 110	1,877,771	MWh	0.04		\$75,111	0.04 mi	· · · · · · · · · · · · · · · · · · ·	
Schedule 123	1,877,771	MWh	(0.08)		(\$150,222)	0.21 mi		
Schedule 126	2,122,422	MWh	0.00		\$0	0.00 mi	, ,	
Schedule 135	2,122,422	MWh	0.12		\$254,691	0.38 mi		
Schedule 137	2,122,422	MWh	0.42		\$891,417	0.42 mi		
Schedule 143	2,122,422	MWh	(0.17)		(\$360,812)	(0.15) mi	, ,	
Schedule 112	2,122,422	MWh	0.04		\$84,897	0.04 mi	V	
Totals	2,122,422	MWh			\$176,801,651		\$173,577,205	
				C	Change		(\$3,224,446)	
				F	Percent Change		-1.82%	

	Billing	Units	Current			Proposed		
Schedule	Determinant		Price		Revenues	Price	F	Revenues
Schedule 85 Primary Delivery Voltage 201 Large Non-residential Standard Service	-4,000 kW							
Monthly Basic Charge								
Single Phase	0	bills	\$470.00		\$0	\$470.00		\$0
Three Phase	2,248	bills	\$470.00		\$1,056,560	\$470.00		\$1,056,560
Transmission & Related Services Charge								
On-peak	1,490,713	kW	\$0.63		\$939,149	\$0.76		\$1,132,942
Off-peak	4,859	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
Block 1 (first 200 kW)	449,600	faccap	\$3.14		\$1,411,744	\$3.10		\$1,393,760
Block 2 (over 200 kW)	1,503,786	faccap	\$2.24		\$3,368,481	\$1.90		\$2,857,193
Distribution Demand Charge								
On-peak	1,490,713	kW	\$2.60		\$3,875,854	\$2.53		\$3,771,504
Off-peak	4,859	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	591,424	MWh		mills	\$638,738	0.93	mills	\$550,025
Reactive Power Charge	255,584	kVar	\$0.50		\$127,792	\$0.50		\$127,792
Energy Charge								
On-peak	374,238	MWh	61.63		\$23,064,300	60.86		\$22,776,136
Off-peak	217,186	MWh	46.63		\$10,127,391	45.86		\$9,960,158
Schedule 122	591,424	MWh	0.00		\$0		mills	\$0
Schedule 125	591,424	MWh	0.00		\$0		mills	\$0
Schedule 145	591,424	MWh		mills	\$141,942	0.22		\$130,113
Schedule 146	591,424	MWh		mills	\$0	0.00		\$0
Schedule 102	4,386	MWh	, ,	mills	(\$36,577)	(8.50)		(\$37,278)
Schedule 105	591,424	MWh		mills	(\$88,714)	0.11		\$65,057
Schedule 109	301,591	MWh		mills	\$965,092	2.42		\$729,851
Schedule 110	301,591	MWh		mills	\$12,064	0.04		\$12,064
Schedule 123	301,591	MWh		mills	(\$24,127)		mills	\$63,334
Schedule 126	591,424	MWh		mills	\$0		mills	\$0
Schedule 135	591,424	MWh		mills	\$70,971	0.38		\$224,741
Schedule 137	591,424	MWh		mills	\$242,484	0.41		\$242,484
Schedule 143	591,424	MWh	. ,	mills	(\$100,542)	(0.14)		(\$82,799)
Schedule 112	591,424	MWh	0.04	mills	\$23,657	0.04	mills	\$23,657
Totals	591,424	MWh			\$45,816,258			\$44,997,293
					Change			(\$818,965)
					Percent Change			-1.79%

	Billing			Curr	rent		Proposed
Schedule	Determinant	Units	Price	_	Revenues	Price	Revenues
Schedule 89 Secondary Delivery Voltage (Large Non-residential Standard Service	GT 4,000 kW						
Monthly Basic Charge	0	bills	\$3,160.00		\$0	\$3,340.00	\$0
Transmission & Related Services Charge							
On-peak	0	kW	\$0.65		\$0	\$0.78	\$0
Off-peak	0	kW	\$0.00		\$0	\$0.00	\$0
Distribution Facilities Charge							
First 1,000 kW	0	faccap	\$1.59		\$0	\$1.53	\$0
1,001 to 4,000 kW	0	faccap	\$1.59		\$0	\$1.53	\$0
Over 4,000 kW	0	faccap	\$1.28		\$0	\$1.22	\$0
Distribution Demand Charge							
On-peak	0	kW	\$2.68		\$0	\$2.61	\$0
Off-peak	0	kW	\$0.00		\$0	\$0.00	\$0
System Usage Charge	0	MWh	1.15	mills	\$0	1.02	mills \$0
Reactive Power Charge	0	kVar	\$0.50		\$0	\$0.50	\$0
Energy Charge							
On-peak	0	MWh	60.01	mills	\$0	58.69	mills \$0
Off-peak	0	MWh	45.01	mills	\$0	43.69	mills \$0
Schedule 122	0	MWh	0.00	mills	\$0	0.00	mills \$0
Schedule 125	0	MWh	0.00	mills	\$0	0.00	mills \$0
Schedule 145	0	MWh	0.23	mills	\$0	0.21	mills \$0
Schedule 146	0	MWh	0.00	mills	\$0	0.00	mills \$0
Schedule 102	0	MWh	(8.34)	mills	\$0	(8.50)	mills \$0
Schedule 105	0	MWh	(0.13)	mills	\$0	0.11	mills \$0
Schedule 109	0	MWh	2.87	mills	\$0	1.46	mills \$0
Schedule 110	0	MWh	0.04	mills	\$0	0.04	mills \$0
Schedule 123	0	MWh	(0.08)	mills	\$0	0.21	mills \$0
Schedule 126	0	MWh	0.00	mills	\$0	0.00	mills \$0
Schedule 135	0	MWh	0.12	mills	\$0	0.36	mills \$0
Schedule 137	0	MWh	0.40	mills	\$0	0.40	mills \$0
Schedule 143	0	MWh	(0.17)	mills	\$0	(0.14)	mills \$0
Schedule 112	0	MWh	0.01	mills	\$0	0.01	mills \$0
Totals	0	MWh			\$0		\$0
					Change		\$0
					Percent Change		

Schedule	Billing	Units		Curr	ent	Proposed		
	Determinant		Price		Revenues	Price	Revenues	
Schedule 89 Primary Delivery Voltage GT Large Non-residential Standard Service	4,000 kW							
Monthly Basic Charge	132	bills	\$1,770.00		\$233,640	\$1,890.00	\$249,480	
Transmission & Related Services Charge								
On-peak	820,489	kW	\$0.63		\$516,908	\$0.76	\$623,572	
Off-peak	5,091	kW	\$0.00		\$0	\$0.00	\$0	
Distribution Facilities Charge								
First 1,000 kW	120,000	faccap	\$1. 55		\$186,000	\$1.49	\$178,800	
1,001 to 4,000 kW	360,000	faccap	\$1.55		\$558,000	\$1.49	\$536,400	
Over 4,000 kW	480,157	faccap	\$1.24		\$595,395	\$1.18	\$566,585	
Distribution Demand Charge								
On-peak	820,489	kW	\$2. 60		\$2,133,271	\$2.53	\$2,075,837	
Off-peak	5,091	kW	\$0.00		\$0	\$0.00	\$0	
System Usage Charge	401,176	MWh	1.12	mills	\$449,317	0.99 mil	ls \$397,164	
Reactive Power Charge	66,969	kVar	\$0.50		\$33,485	\$0.50	\$33,485	
Energy Charge								
On-peak	238,945	MWh	59.03	mills	\$14,104,945	57.73 mil	ls \$13,794,316	
Off-peak	162,231	MWh	44.03	mills	\$7,143,019	42.73 mil	ls \$6,932,119	
Schedule 122	401,176	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 125	401,176	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 145	401,176	MWh	0.23	mills	\$92,271	0.21 mil	ls \$84,247	
Schedule 146	401,176	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 102	0	MWh	(8.34)	mills	\$0	(8.50) mil	ls \$0	
Schedule 105	401,176	MWh	(0.13)	mills	(\$52,153)	0.11 mil	ls \$44,129	
Schedule 109	0	MWh	2.87	mills	\$0	1.46 mil	ls \$0	
Schedule 110	0	MWh	0.04	mills	\$0	0.04 mil	ls \$0	
Schedule 123	0	MWh	(0.08)	mills	\$0	0.21 mil	ls \$0	
Schedule 126	401,176	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 135	401,176	MWh	0.12	mills	\$48,141	0.35 mil	ls \$140,412	
Schedule 137	401,176	MWh	0.39	mills	\$156,459	0.39 mil		
Schedule 143	401,176	MWh	(0,16)	mills	(\$64,188)	(0,13) mil	ls (\$52,153)	
Schedule 112	401,176	MWh	,	mills	\$4,012	0.01 mil	(, , ,	
Totals	401,176	MWh			\$26,138,522		\$25,764,864	
					Change		(\$373,657)	
					Percent Change		-1.43%	

Schedule	Billing	Units		Curr	ent	Proposed		
	Determinant		Price	_	Revenues	Price	Revenues	
Schedule 90 Primary Delivery Voltage Large Non-residential Standard Service								
Monthly Basic Charge	48	bills	\$5,200.00		\$249,600	\$6,100.00	\$292,800	
Transmission & Related Services Charge								
On-peak	2,701,624	kW	\$0.63		\$1,702,023	\$0.76	\$2,053,234	
Off-peak	85	kW	\$0.00		\$0	\$0.00	\$0	
Distribution Facilities Charge								
First 1,000 kW	24,000	faccap	\$1.38		\$33,120	\$1.61	\$38,640	
1,001 to 4,000 kW	72,000	faccap	\$1.38		\$99,360	\$1.61	\$115,920	
Over 4,000 kW	2,730,257	faccap	\$1.07		\$2,921,375	\$1.30	\$3,549,334	
Distribution Demand Charge								
On-peak	2,701,624	kW	\$2.60		\$7,024,222	\$2.53	\$6,835,109	
Off-peak	85	kW	\$0.00		\$0	\$0.00	\$0	
System Usage Charge	1,861,066	MWh	0.69	mills	\$1,284,136	0.54 mil	ls \$1,004,976	
Reactive Power Charge	21,436	kVar	\$0.50		\$10,718	\$0.50	\$10,718	
Energy Charge								
On-peak	1,070,638	MWh	57 . 27	mills	\$61,315,416	55.77 mil	ls \$59,709,460	
Off-peak	790,429	MWh	42.27	mills	\$33,411,423	40.77 mil	ls \$32,225,780	
Schedule 122	1,861,066	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 125	1,861,066	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 145	1,861,066	MWh	0.22	mills	\$409,435	0.20 mil	ls \$372,213	
Schedule 146	1,861,066	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 102	0	MWh	(8.34)	mills	\$0	(8.50) mil	ls \$0	
Schedule 105	1,861,066	MWh	(0.13)	mills	(\$241,939)	0.10 mil	ls \$186,107	
Schedule 109	0	MWh	2.87	mills	\$0	1.46 mil	ls \$0	
Schedule 110	0	MWh	0.04	mills	\$0	0.04 mil	ls \$0	
Schedule 123	0	MWh	(0.08)	mills	\$0	0.21 mil	ls \$0	
Schedule 126	1,861,066	MWh	0.00	mills	\$0	0.00 mil	ls \$0	
Schedule 135	1,861,066	MWh	0.11	mills	\$204,717	0.34 mil	ls \$632,763	
Schedule 137	1,861,066	MWh	0.38	mills	\$707,205	0.38 mil	ls \$707,205	
Schedule 143	1,861,066	MWh	(0.15)	mills	(\$279,160)	(0.13) mil	ls (\$241,939)	
Schedule 112	1,861,066	MWh	0.01	mills	\$18,611	0.01 mil	ls \$18,611	
Totals	1,861,066	MWh			\$108,870,263		\$107,510,930	
					Change		(\$1,359,332)	
					Percent Change		-1.25%	

	Billing			Curre	ent		Propos	sed
Schedule	Determinant	Units	Price		Revenues	Price	<u> </u>	Revenues
Schedule 89 Subtransmission Delivery Vo Large Non-residential Standard Service	ltage							
Monthly Basic Charge	60	bills	\$3,850.00		\$231,000	\$3,970.00		\$238,200
Transmission & Related Services Charge								
On-peak	272,521	kW	\$0.62		\$168,963	\$0. 75		\$204,391
Off-peak	0	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
First 1,000 kW	60,000	faccap	\$1.55		\$93,000	\$1.49		\$89,400
1,001 to 4,000 kW	180,000	faccap	\$1.55		\$279,000	\$1.49		\$268,200
Over 4,000 kW	115,908	faccap	\$1 . 24		\$143,726	\$1.18		\$136,771
Distribution Demand Charge								
On-peak	272,521	kW	\$1.26		\$343,376	\$1.27		\$346,102
Off-peak	0	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	62,759	MWh	1.09	mills	\$68,407	0.97	mills	\$60,876
Reactive Power Charge	32,382	kVar	\$0.50		\$16,191	\$0.50		\$16,191
Energy Charge								
On-peak	41,003	MWh	58.30	mills	\$2,390,492	57.02	mills	\$2,338,008
Off-peak	21,755	MWh	43.30	mills	\$942,013	42.02	mills	\$914,166
Schedule 122	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	62,759	MWh	0.23	mills	\$14,435	0.21	mills	\$13,179
Schedule 146	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 105	62,759	MWh	(0.13)	mills	(\$8,159)	0.11	mills	\$6,903
Schedule 109	0	MWh	2.87	mills	\$0	1.46	mills	\$0
Schedule 110	0	MWh	0.04	mills	\$0	0.04	mills	\$0
Schedule 123	0	MWh	(0.08)	mills	\$0	0.21	mills	\$0
Schedule 126	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	62,759	MWh	0.12	mills	\$7,531	0.35	mills	\$21,966
Schedule 137	62,759	MWh	0.39	mills	\$24,476	0.39	mills	\$24,476
Schedule 143	62,759	MWh	(0.16)	mills	(\$10,041)	(0.13)	mills	(\$8,159)
Schedule 112	62,759	MWh	, ,	mills	\$628	0.01		\$628
Totals	62,759	MWh			\$4,705,037			\$4,671,298
					Change			(\$33,740)
					Percent Change			-0.72%

	Billing			Current			Propose	d
Schedule	Determinant	Units	Price	Rev	venues	Price	Re	venues
Schedule 75 Subtransmission Delivery Vo	ltage							
Partial Requirements Service	mage							
Monthly Basic Charge	0	bills	\$3,850.00		\$0	\$3,970.00		\$0
Transmission & Related Services Charge						, . ,		
On-peak	0	kW	\$0.62		\$0	\$0.75		\$0
Off-peak	0	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge			·			•		
First 1,000 kW	0	faccap	\$1.55		\$0	\$1.49		\$0
1,001 to 4,000 kW	0	faccap	\$1,55		\$0	\$1.49		\$0
Over 4,000 kW	0	faccap	\$1.24		\$0	\$1.18		\$0
Distribution Demand Charge	·	шоосьр	4		**	4.1. 0		**
On-peak	0	kW	\$1.26		\$0	\$1.27		\$0
Off-peak	Ö	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	0	MWh	1.09	mille	\$0		mills	\$0
Reactive Power Charge	0	kVar	\$0.50	IIIIII	\$0	\$0.50	IIIIIIS	\$0 \$0
Energy Charge (Schedule 75 only)	U	KVai	φ0.30		Ψ0	Ψ0.50		ΨΟ
On-peak	0	MWh	58.30	mille	\$0	57.02	millo	\$0
Off-peak	0	MWh		mills	\$0 \$0	42.02		\$0 \$0
Schedule 122	0	MWh	0.00		\$0 \$0		mills	\$0 \$0
	-				• •			* -
Schedule 125	0	MWh		mills	\$0	0.00	mills	\$0
Schedule 145	0	MWh		mills	\$0	0.21		\$0
Schedule 146	0	MWh		mills	\$0	0.00	mills	\$0
Schedule 102	0	MWh	0.00		\$0	0.00		\$0
Schedule 105	0	MWh	(0.13)		\$0	0.11	mills	\$0
Schedule 109	0	MWh	2.87		\$0	1.46		\$0
Schedule 110	0	MWh	0.04		\$0	0.04		\$0
Schedule 123	0	MWh	(80.08)	mills	\$0	0.21	mills	\$0
Schedule 126	0	MWh	0.00		\$0	0.00		\$0
Schedule 135	0	MWh	0.12	mills	\$0	0.35	mills	\$0
Schedule 137	0	MWh	0.39		\$0	0.39	mills	\$0
Schedule 143	0	MWh	(0.16)	mills	\$0	(0.13)	mills	\$0
Schedule 112	0	MWh	0.01		\$0	0.01	mills	\$0
Totals	0	MWh			\$0			\$0
				Cha	ange			\$0
				Per	cent Change			
Total Subtransmission	62,759	MWh			\$4,705,037			\$4,671,298
Total Subtransmission				Che	ange			(\$33,740
Total Gubu attornission					cent Change			-0.72%

	Billing			Curre	ent		Propo	sed
Schedule	Determinant	Units	Price		Revenues	Price		Revenues
Schedule 91/95 Street & Highway Lighting								
Transmission & Related Services Charge	50,583	MWh	1.29	mills	\$65,252	1.52	mills	\$76,886
Distribution Charge	50,583	MWh	165.38	mills	\$8,365,394	168.66	mills	\$8,531,124
(includes fixed and sys. usage charges)								
Energy Charge	50,583	MWh	50.54	mills	\$2,556,465	48.98	mills	\$2,477,555
Schedule 122	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	50,583	MWh	0.22	mills	\$11,128	0.20	mills	\$10,117
Schedule 146	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 105	50,583	MWh	(0.46)	mills	(\$23,268)	0.10	mills	\$5,058
Schedule 109	50,583	MWh	7.47	mills	\$377,855	6.86	mills	\$346,999
Schedule 110	50,583	MWh	0.10	mills	\$5,058	0.10	mills	\$5,058
Schedule 123	50,583	MWh	(0.08)	mills	(\$4,047)	0.21	mills	\$10,622
Schedule 126	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	50,583	MWh	0.11	mills	\$5,564	0.33	mills	\$16,692
Schedule 137	50,583	MWh	0.37	mills	\$18,716	0.37	mills	\$18,716
Schedule 143	50,583	MWh	(0.15)	mills	(\$7,587)	(0.13)	mills	(\$6,576)
Schedule 112	50,583	MWh	0.25	mills	\$12,646	0.25	mills	\$12,646
Totals	50,583	MWh			\$11,383,176			\$11,504,899
					Change Percent Change			\$121,723 1.07%

	Billing			Curre	ent		Propos	sed
Schedule	Determinant	Units	Price		Revenues	Price	F	Revenues
Schedule 92								
Traffic Signals								
Transmission & Related Services Charge	2,496	MWh	1.36	mills	\$3,395	1.59	mills	\$3,969
Volumetric Distribution Charge	2,496	MWh	28.93	mills	\$72,209	29.25	mills	\$73,008
Energy Charge	2,496	MWh	52.02	mills	\$129,842	51.09	mills	\$127,521
Schedule 122	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 145	2,496	MWh	0.22	mills	\$549	0.21	mills	\$524
Schedule 146	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 102	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 105	2,496	MWh	(0.16)	mills	(\$399)	0.10	mills	\$250
Schedule 109	2,496	MWh	3.22	mills	\$8,037	2.57	mills	\$6,415
Schedule 110	2,496	MWh	0.04	mills	\$100	0.04	mills	\$100
Schedule 123	2,496	MWh	(0.08)	mills	(\$200)	0.21	mills	\$524
Schedule 126	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	2,496	MWh	0.11	mills	\$275	0.35	mills	\$874
Schedule 137	2,496	MWh	0.39	mills	\$973	0.39	mills	\$973
Schedule 143	2,496	MWh	(0.15)	mills	(\$374)	(0.13)	mills	(\$324)
Schedule 112	2,496	MWh	0.23	mills	\$574	0.23	mills	\$574
Totals	2,496	MWh			\$214,980			\$214,406
					Change			(\$574)
					Percent Change			-0.27%

	Billing			Curi	rent		Proposed	1
Schedule	Determinant	Units	Price	_	Revenues	Price	Rev	enues
Schedule 76R Economic Replacement Power Partial Requirements Service	•							
Energy Charge (market based) On-peak Off-peak								
System Usage Charge Daily Transmission Charges Daily Distribution Charges	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 125	0	MWh	0.00		\$0	0.00		\$0
Schedule 145	Õ	MWh	0.00		\$0	0.00		\$0
Schedule 146	0	MWh	0.00		\$0	0.00	mills	\$0
Schedule 102	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 105	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 109	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 110	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 123	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 126	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 135	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 137	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 143	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 112	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	0	MWh			\$0			\$0
					Change			\$0

	Billing			Current	Pi	roposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues	
COS & Partial Requirements Revenue C	ategory			_			
Basic Charge Revenues				\$140,483,241	\$0	\$146,913,780	\$0.0
Transmission & Related Charges				\$31,619,334	\$0	\$37,271,496	\$0.0
Volumetric Distribution Charges				\$407,595,747	(\$0)	\$436,042,123	\$0.0
Facilities Charges				\$68,318,189	\$0	\$64,503,218	(\$0.0)
Distribution Demand Charges				\$51,750,669	(\$0)	\$50,400,191	\$0.0
System Usage Charges				\$22,185,179		\$24,237,671	
Reactive Power Charges				\$952,819	\$0	\$952,819	\$0.0
Energy Charges				\$1,056,741,996	\$0	\$1,031,858,698	(\$0.0)
Schedule 122				\$0	\$0	\$0	\$0.0
Schedule 125				\$0	\$0	\$0	\$0.0
Schedule 145				\$4,387,977	\$0	\$4,185,887	\$0.0
Schedule 146				\$0	\$0	\$0	\$0.0
Schedule 102				(\$68,835,602)	(\$0)	(\$69,345,194)	(\$0.0)
Schedule 105				(\$2,717,260)	\$0	\$2,084,208	\$0.0
Schedule 109				\$63,417,246	\$0	\$50,248,642	\$0.0
Schedule 110				\$675,001	\$0	\$675,001	\$0.0
Schedule 123				(\$876,814)	\$0	\$13,962,183	(\$0.0)
Schedule 126				\$0	\$0	\$0	\$0.0
Schedule 135				\$2,257,332	\$0	\$7,039,753	(\$0.0)
Schedule 137				\$7,622,310	\$0	\$7,622,310	\$0.0
Schedule 143				(\$3,053,831)	\$0	(\$2,696,715)	\$0.0
Schedule 112				\$2,968,476	\$0	\$2,968,476	\$0.0
Employee Discount				(\$892,151)	<u>\$0</u>	(\$923,927)	\$0.0
COS & Partial Requirements Totals				\$1,784,599,856	\$0	\$1,808,000,620	(\$0.0)

Page 33

	Billing			Curre	ent		Propos	sed
Schedule	Determinant	Units	Price		Revenues	Price		Revenues
Schedule 7 Residential Service								
Monthly Basic Charge								
Single Phase	9,395,591	bills	\$11.00		\$103,351,501	\$11.00		\$103,351,501
Three Phase	180	bills	\$11.00		\$1,980	\$11.00		\$1,980
Transmission & Related Services Charge TOU Decrement Transmission	7,568,918	MWh	2.09	mills	\$15,819,039	2.43	mills	\$18,392,471 (\$9,508)
Distribution Charge TOU Decrement Distribution	7,568,918	MWh	43.11	mills	\$326,296,057	46.62	mills	\$352,862,959 (\$182,196)
Energy Charge								
Block 1 (first 500 kWh)	4,150,373	MWh	65.10		\$270,189,253	63.29		\$262,677,079
Block 2 (501-1,000 kWh)	2,140,123	MWh MWh	65.10		\$139,322,024	63 . 29 70 . 51		\$135,448,401
Block 3 (over 1,000 kWh) TOU Decrement Generation	1,278,422	MAALU	72.32	mills	\$92,455,495	70.51	milis	\$90,141,551 (\$126,972)
Schedule 125	7,568,918	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	7,568,918	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	7,568,918	MWh	0.00	mills	\$0	0.00	mills	\$0
Employee Discount					(\$944,818)			(\$960,453)
Totals	7,568,918	MWh			\$946,490,531			\$961,596,814
					Change Percent Change			\$15,106,283 1 . 60%

	Billing			Curr	ent		Propos	sed
Schedule	Determinant	Units	Price	Revenues		Price		Revenues
Schedule 15 Outdoor Area Lighting								
Transmission & Related Services Charge	15,774	MWh	1.29	mills	\$20,348	1.52	mills	\$23,976
Distribution Charge (includes fixed and sys. usage charges)	15,774	MWh	167.46	mills	\$2,641,438	167.17	mills	\$2,636,964
Energy Charge	15,774	MWh	50 . 54	mills	\$797,218	48.98	mills	\$772,611
Schedule 125	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	15,774	MWh	0.00	mills	\$0	0.00	mills	\$0
Tota l s	15,774	MWh			\$3,459,005			\$3,433,551
					Change Percent Change			(\$25,454) -0.74%

	Billing			Curre	ent		Propos	Proposed	
Schedule	Determinant	Units	Price		Revenues	Price	Revenues		
Schedule 32 Small Non-residential Service									
Monthly Basic Charge									
Single Phase	672,008	bills	\$17.00		\$11,424,136	\$20.00		\$13,440,160	
Three Phase	453,173	bills	\$23.00		\$10,422,979	\$29.00		\$13,142,017	
Transmission & Related Services Charge	1,633,156	MWh	1.76	mills	\$2,874,354	2.06	mills	\$3,364,301	
Distribution Charge									
Block 1	1,427,418	MWh	41.80		\$59,666,073	42.32		\$60,408,330	
Block 2	205,738	MWh	8.92	mills	\$1,835,180	14.87	mills	\$3,059,319	
Energy Charge TOU Decrement	1,633,156	MWh	60.00	mills	\$97,989,342	58.42	mills	\$95,408,956 (\$58,612)	
Schedule 125	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 122a	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 146	1,633,156	MWh	0.00	mills	\$0	0.00	mills	\$0	
Totals	1,633,156	MWh			\$184,212,064			\$188,764,472	
					Change Percent Change			\$4,552,407 2 . 47%	

	Billing			Curre	ent		Propos	oosed	
Schedule	Determinant	Units	Price		Revenues	Price	F	levenues	
Schedule 38 Large Non-residential Service Time-of-Day									
Monthly Basic Charge									
Single Phase	660	bills	\$25.00		\$16,500	\$30.00		\$19,800	
Three Phase	3,935	bills	\$25.00		\$98,375	\$30.00		\$118,050	
Transmission & Related Services Charge	31,475	MWh	1.46	mills	\$45,953	1.71	mills	\$53,822	
Distribution Charge	31,475	MWh	71.18	mills	\$2,240,362	70.41	mills	\$2,216,126	
Reactive Power Charge	54,201	kVar	\$0.50		\$27,101	\$0.50		\$27,101	
Energy Charge									
Block 1	17,091	MWh	59.92	mills	\$1,024,101	60.70	mills	\$1,037,433	
Block 2	14,383	MWh	49.92		\$718,022	45.70	mills	\$657,324	
Schedule 125	31,475	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 122a	31,475	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 146	31,475	MWh	0.00	mills	\$0	0.00	mills	\$0	
Totals	31,475	MWh			\$4,170,414			\$4,129,655	
					Change Percent Change			(\$40,759) -0,98%	

ORDER NO.

20-483

	Billing			Curr	ent		Propos	ed
Schedule	Determinant	Units	Price		Revenues	Price	<u>F</u>	Revenues
Schedule 47								
Small Non-residential Irrigation & Pumping	g Service							
Monthly Basic Charge								
Single Phase	1,344	bills	\$35.00		\$47,040	\$37.00		\$49,728
Three Phase	17,022	bills	\$35.00		\$595,770	\$37.00		\$629,814
Transmission & Related Services Charge	21,633	MWh	1.82	mills	\$39,373	2,13	mills	\$46,079
Distribution Charge								
Block 1	7,536	MWh	108.78	mills	\$819,753	110.99	mills	\$836,407
Block 2	14,098	MWh	88.78	mills	\$1,251,582	90.99	mills	\$1,282,738
Reactive Power Charge	45	kVar	\$0. 50		\$23	\$0.50		\$23
Energy Charge								
Block 1	7,536	MWh	70.07	mills	\$528,039	70.94	mills	\$534,595
Block 2	14,098	MWh	70.07	mills	\$987,816	70.94	mills	\$1,000,081
Schedule 125	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	21,633	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	21,633	MWh			\$4,269,396			\$4,379,465
					Change Percent Change			\$110,069 2 . 58%

	Billing			Curre	nt		Propose	ed
Schedule	Determinant	Units	Price		Revenues	Price	R	evenues
Schedule 49 Large Non-residential Irrigation & Pumping	g Service							
Monthly Basic Charge								
Single Phase	36	bills	\$40.00		\$1,440	\$45.00		\$1,620
Three Phase	7,608	bills	\$40.00		\$304,320	\$45.00		\$342,360
Transmission & Related Services Charge	64,540	MWh	1.82	mills	\$117,463	2,12	mills	\$136,825
Distribution Charge								
Block 1	19,051	MWh	82.39	mills	\$1,569,644	80.99	mills	\$1,542,972
Block 2	45,489	MWh	62.39	mills	\$2,838,055	60.99	mills	\$2,774,370
Reactive Power Charge	8,709	kVar	\$0. 50		\$4,355	\$0.50		\$4,355
Energy Charge								
Block 1	19,051	MWh	69.93	mills	\$1,332,264	70.68	mills	\$1,346,552
Block 2	45,489	MWh	69.93	mills	\$3,181,041	70.68	mills	\$3,215,158
Schedule 125	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	64,540	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	64,540	MWh			\$9,348,582			\$9,364,212
					Change Percent Change			\$15,631 0,17%

	Billing			Curi	rent	Proposed		
Schedule	Determinant	Units	Price	_	Revenues	Price		Revenues
Schedule 83 Secondary Delivery Voltage 3 Large Non-residential Standard Service	1-200 kW							
Monthly Basic Charge								
Single Phase	8,194	bills	\$30.00		\$245,820	\$35.00		\$286,790
Three Phase	130,152	bills	\$40.00		\$5,206,080	\$45.00		\$5,856,840
Transmission & Related Services Charge								
On-peak	8,606,661	kW	\$0.65		\$5,594,330	\$0.78		\$6,713,196
Off-peak	3,366	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
Block 1 (first 30 kW)	4,150,380	faccap	\$3.61		\$14,982,872	\$3.50		\$14,526,330
Block 2 (over 30 kW)	6,980,663	faccap	\$3.51		\$24,502,127	\$3.40		\$23,734,254
Distribution Demand Charge								
On-peak	8,606,661	kW	\$2.68		\$23,065,851	\$2.61		\$22,463,385
Off-peak	3,366	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	2,884,961	MWh	6.02	mills	\$17,367,468	6.99	mills	\$20,165,880
Reactive Power Charge	538,563	kVar	\$0. 50		\$269,282	\$0.50		\$269,282
Energy Charge								
On-peak	1,909,059	MWh	64.33	mills	\$122,809,761	63.35	mills	\$120,938,883
Off-peak	975,902	MWh	49.33	mills	\$48,141,270	48.35	mills	\$47,184,886
Schedule 125	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	2,884,961	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	2,884,961	MWh			\$262,184,861			\$262,139,726
					Change			(\$45,135)
					Percent Change			-0.02%

	Billing			Curr	rent		Proposed		
Schedule	Determinant	Units	Price	_	Revenues	Price		Revenues	
Schedule 85 Secondary Delivery Voltage Large Non-residential Standard Service	201-4,000 kW								
Monthly Basic Charge									
Single Phase	0	bills	\$500.00		\$0	\$560.00		\$0	
Three Phase	13,993	bills	\$500.00		\$6,996,500	\$560.00		\$7,836,080	
Transmission & Related Services Charge									
On-peak	5,711,975	kW	\$0.65		\$3,712,784	\$0.78		\$4,455,341	
Off-peak	6,572	kW	\$0.00		\$0	\$0.00		\$0	
Distribution Facilities Charge									
Block 1 (first 200 kW)	2,798,600	faccap	\$3.39		\$9,487,254	\$3,17		\$8,871,562	
Block 2 (over 200 kW)	3,878,207	faccap	\$2.49		\$9,656,735	\$1.97		\$7,640,068	
Distribution Demand Charge									
On-peak	5,711,975	kW	\$2.68		\$15,308,093	\$2.61		\$14,908,255	
Off-peak	6,572	kW	\$0.00		\$0	\$0.00		\$0	
System Usage Charge	2,122,422	MWh	1.12	mills	\$2,377,113	0.97	mills	\$2,058,749	
Reactive Power Charge	927,749	kVar	\$0 . 50		\$463,875	\$0.50		\$463,875	
Energy Charge									
On-peak	1,390,849	MWh	62.69	mills	\$87,192,302	61.91	mills	\$86,107,440	
Off-peak	731,573	MWh	47.69	mills	\$34,888,739	46.91	mills	\$34,318,112	
Schedule 125	2,122,422	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 122a	2,122,422	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 146	2,122,422	MWh	0.00	mills	\$0	0.00	mills	\$0	
Tota l s	2,122,422	MWh			\$170,083,395			\$166,659,481	
					Change			(\$3,423,914)	
					Percent Change			-2.01	

	Billing			Curre	ent	Proposed		
Schedule	Determinant	Units	Price		Revenues	Price		Revenues
Schedule 85 Primary Delivery Voltage 201- Large Non-residential Standard Service	-4,000 kW							
Monthly Basic Charge								
Single Phase	0	bills	\$470.00		\$0	\$470.00		\$0
Three Phase	2,248	bills	\$470.00		\$1,056,560	\$470.00		\$1,056,560
Transmission & Related Services Charge								
On-peak	1,490,713	kW	\$0.63		\$939,149	\$0.76		\$1,132,942
Off-peak	4,859	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
Block 1 (first 200 kW)	449,600	faccap	\$3.14		\$1,411,744	\$3.10		\$1,393,760
Block 2 (over 200 kW)	1,503,786	faccap	\$2.24		\$3,368,481	\$1.90		\$2,857,193
Distribution Demand Charge								
On-peak	1,490,713	kW	\$2.60		\$3,875,854	\$2.53		\$3,771,504
Off-peak	4,859	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	591,424	MWh	1.08	mills	\$638,738	0.93	mills	\$550,025
Reactive Power Charge	255,584	kVar	\$0.50		\$127,792	\$0.50		\$127,792
Energy Charge								
On-peak	374,238	MWh	61.63	mills	\$23,064,300	60.86	mills	\$22,776,136
Off-peak	217,186	MWh	46.63	mills	\$10,127,391	45.86	mills	\$9,960,158
Schedule 125	591,424	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	591,424	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	591,424	MWh	0.00	mills	\$0	0.00	mills	\$0
Tota l s	591,424	MWh			\$44,610,009			\$43,626,070
					Change			(\$983,939)
					Percent Change			-2.21%

	Billing			Current			Proposed
Schedule	Determinant	Units	Price	Rev	venues	Price	Revenues
Schedule 89 Secondary Delivery Voltage G Large Non-residential Standard Service	ST 4,000 kW						
Monthly Basic Charge	0	bills	\$3,160.00		\$0	\$3,340.00	\$
Transmission & Related Services Charge							
On-peak	0	kW	\$0.65		\$0	\$0.78	\$
Off-peak	0	kW	\$0.00		\$0	\$0.00	\$
Distribution Facilities Charge							
First 1,000 kW	0	faccap	\$1.59		\$0	\$1.53	\$
1,001 to 4,000 kW	0	faccap	\$1.59		\$0	\$1.53	\$
Over 4,000 kW	0	faccap	\$1.28		\$0	\$1.22	\$
Distribution Demand Charge							
On-peak	0	kW	\$2.68		\$0	\$2.61	\$
Off-peak	0	kW	\$0.00		\$0	\$0.00	\$
System Usage Charge	0	MWh	1.15	mills	\$0	1.02	mills \$
Reactive Power Charge	0	kVar	\$0. 50		\$0	\$0.50	\$
Energy Charge							
On-peak	0	MWh	60.01	mills	\$0	58.69	mills \$
Off-peak	0	MWh	45.01	mills	\$0	43.69	mills \$
Schedule 125	0	MWh	0.00	mills	\$0	0.00	mills \$
Schedule 122a	0	MWh	0.00	mills	\$0	0.00	mills \$
Schedule 146	0	MWh	0.00	mills	\$0	0.00	mills \$
Tota l s	0	MWh			\$0		\$
					ange cent Change		\$

	Billing			Curre	nt	Proposed		
Schedule	Determinant	Units	Price	F	Revenues	Price		Revenues
Schedule 89 Primary Delivery Voltage GT Large Non-residential Standard Service	4,000 kW							
Monthly Basic Charge	132	bills	\$1,770.00		\$233,640	\$1,890.00		\$249,480
Transmission & Related Services Charge								
On-peak	820,489	kW	\$0.63		\$516,908	\$0.76		\$623,572
Off-peak	5,091	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
First 1,000 kW	120,000	faccap	\$1.55		\$186,000	\$1.49		\$178,800
1,001 to 4,000 kW	360,000	faccap	\$1.55		\$558,000	\$1.49		\$536,400
Over 4,000 kW	480,157	faccap	\$1.24		\$595,395	\$1.18		\$566,585
Distribution Demand Charge								
On-peak	820,489	kW	\$2.60		\$2,133,271	\$2.53		\$2,075,837
Off-peak	5,091	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	401,176	MWh	1.12	mills	\$449,317	0.99	mills	\$397,164
Reactive Power Charge	66,969	kVar	\$0.50		\$33,485	\$0.50		\$33,485
Energy Charge								
On-peak	238,945	MWh	59.03	mills	\$14,104,945	57.73	mills	\$13,794,316
Off-peak	162,231	MWh	44.03	mills	\$7,143,019	42.73	mills	\$6,932,119
Schedule 125	401,176	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	401,176	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	401,176	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	401,176	MWh			\$25,953,980			\$25,387,759
				c	Change			(\$566,222)
				F	Percent Change			-2.18%

	Billing			Curre	nt	Proposed		
Schedule	Determinant	Units	Price	R	levenues	Price		Revenues
Schedule 90 Primary Delivery Voltage Large Non-residential Standard Service								
Monthly Basic Charge	48	bills	\$5,200.00		\$249,600	\$6,100.00		\$292,800
Transmission & Related Services Charge								
On-peak	2,701,624	kW	\$0.63		\$1,702,023	\$0.76		\$2,053,234
Off-peak	85	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
First 1,000 kW	24,000	faccap	\$1.38		\$33,120	\$1.61		\$38,640
1,001 to 4,000 kW	72,000	faccap	\$1.38		\$99,360	\$1.61		\$115,920
Over 4,000 kW	2,730,257	faccap	\$1.07		\$2,921,375	\$1.30		\$3,549,334
Distribution Demand Charge								
On-peak	2,701,624	kW	\$2.60		\$7,024,222	\$2.53		\$6,835,109
Off-peak	85	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	1,861,066	MWh	0.69	mills	\$1,284,136	0.54	mills	\$1,004,976
Reactive Power Charge	21,436	kVar	\$0 . 50		\$10,718	\$0.50		\$10,718
Energy Charge								
On-peak	1,070,638	MWh	57,27	mills	\$61,315,416	55.77	mills	\$59,709,460
Off-peak	790,429	MWh	42.27	mills	\$33,411,423	40.77	mills	\$32,225,780
Schedule 125	1,861,066	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	1,861,066	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	1,861,066	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	1,861,066	MWh			\$108,051,394			\$105,835,971
					Change Percent Change			(\$2,215,423) -2,05%

	Billing			Curr	ent	Proposed		
Schedule	Determinant	Units	Price	_	Revenues	Price		Revenues
Schedule 89 Subtransmission Delivery Vo Large Non-residential Standard Service	ltage							
Monthly Basic Charge	60	bills	\$3,850.00		\$231,000	\$3,970.00		\$238,200
Transmission & Related Services Charge								
On-peak	272,521	kW	\$0.62		\$168,963	\$0.75		\$204,391
Off-peak	0	kW	\$0.00		\$0	\$0.00		\$0
Distribution Facilities Charge								
First 1,000 kW	60,000	faccap	\$1.55		\$93,000	\$1.49		\$89,400
1,001 to 4,000 kW	180,000	faccap	\$1.55		\$279,000	\$1.49		\$268,200
Over 4,000 kW	115,908	faccap	\$1.24		\$143,726	\$1.18		\$136,771
Distribution Demand Charge								
On-peak	272,521	kW	\$1.26		\$343,376	\$1.27		\$346,102
Off-peak	0	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	62,759	MWh	1.09	mills	\$68,407	0.97	mills	\$60,876
Reactive Power Charge	32,382	kVar	\$0.50		\$16,191	\$0.50		\$16,191
Energy Charge								
On-peak	41,003	MWh	58.30	mills	\$2,390,492	57.02	mills	\$2,338,008
Off-peak	21,755	MWh	43.30	mills	\$942,013	42.02	mills	\$914,166
Schedule 125	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	62,759	MWh	0.00	mills	\$0	0.00	mills	\$0
Totals	62,759	MWh			\$4,676,168			\$4,612,304
					Change Percent Change			(\$63,864 -1.37%

	Billing			Cur	rent		Propose	ed
Schedule	Determinant	Units	Price	_	Revenues	Price	R	evenues
Schedule 75 Subtransmission Delivery Vo Partial Requirements Service	ltage							
Monthly Basic Charge	0	bills	\$3,850.00		\$0	\$3,970.00		\$0
Transmission & Related Services Charge								
On-peak Off-peak	0	kW kW	\$0.62 \$0.00		\$0 \$0	\$0.75 \$0.00		\$0 \$0
Distribution Facilities Charge								
First 1,000 kW	0	faccap	\$1.55		\$0	\$1.49		\$0
1,001 to 4,000 kW	0	faccap	\$1.55		\$0	\$1.49		\$0
Over 4,000 kW	ō	faccap	\$1.24		\$0	\$1.18		\$0
Distribution Demand Charge								
On-peak	0	kW	\$1.26		\$0	\$1.27		\$0
Off-peak	0	kW	\$0.00		\$0	\$0.00		\$0
System Usage Charge	0	MWh	1.09	mills	\$0	0.97	mills	\$0
Reactive Power Charge	0	kVar	\$0.50		\$0	\$0.50		\$0
Energy Charge (Schedule 75 only)								
On-peak	0	MWh	58.30			57.02		\$0
Off-peak	0	MWh	43.30	mills	\$0	42.02	mills	\$0
Schedule 125	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 122a	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Schedule 146	0	MWh	0.00	mills	\$0	0.00	mills	\$0
Tota l s	0	MWh			\$0			\$0
					Change Percent Change			\$0
Total Subtransmission	62,759	MWh			\$4,676,168			\$4,612,304
Total Subtransmission					Change			(\$63,864)
					Percent Change			-1.37%

	Billing			Curi	rent		Proposed		
Schedule	Determinant	Units	Price	-	Revenues	Price		Revenues	
Schedule 91/95 Street & Highway Lighting									
Transmission & Related Services Charge	50,583	MWh	1.29	mills	\$65,252	1.52	mills	\$76,886	
Distribution Charge (includes fixed and sys. usage charges)	50,583	MWh	165.38	mills	\$8,365,394	168.66	mills	\$8,531,124	
Energy Charge	50,583	MWh	50.54	mills	\$2,556,465	48.98	mills	\$2,477,555	
Schedule 125	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 122a	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 146	50,583	MWh	0.00	mills	\$0	0.00	mills	\$0	
Totals	50,583	MWh			\$10,987,111			\$11,085,566	
					Change Percent Change			\$98,455 0 <u>.</u> 90%	
Schedule 92 Traffic Signals									
Transmission & Related Services Charge	2,496	MWh	1.36	mills	\$3,395	1.59	mills	\$3,969	
Volumetric Distribution Charge	2,496	MWh	28.93	mills	\$72,209	29.25	mills	\$73,008	
Energy Charge	2,496	MWh	52.02	mills	\$129,842	51.09	mills	\$127,521	
Schedule 125	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 122a	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0	
Schedule 146	2,496	MWh	0.00	mills	\$0	0.00	mills	\$0	
Tota l s	2,496	MWh			\$205,446			\$204,497	
					Change Percent Change			(\$948) -0.46%	
System COS Totals	17,312,384	MWh			\$1,778,702,355			\$1,791,219,543	
					System COS Change System COS Percent			\$12,517,188 0.70%	

	Billing			Current			Propo	sed	
Schedule	Determinant	Units	Price	Revenues		Price		Revenues	
Schedule 76R Economic Replacement Power Partial Requirements Service	r								
Energy Charge (not applicable) On-peak Off-peak									
System Usage Charge Daily Transmission Charges Daily Distribution Charges	0	MWh	0.00	mills	\$0		0.00 mills		\$0
Totals	0	MWh			\$0				\$0
				Change					\$0

	Billing		Cu	urrent	Propos	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2003 Secondary Delivery V Large Non-residential Optional Service (D	•	V				
Monthly Basic Charge						
Single Phase	0	bills	\$500.00	\$0	\$560.00	\$0
Three Phase	24	bills	\$500.00	\$12,000	\$560.00	\$13,440
Transmission & Related Services Charge						
On-peak	22,540	kW		\$0		\$0
Off-peak	172	kW		\$0		\$0
Distribution Facilities Charge						
Block 1 (first 200 kW)	4,800	faccap	\$3.39	\$16,272	\$3.17	\$15,216
Block 2 (over 200 kW)	21,708	faccap	\$2.49	\$54,053	\$1.97	\$42,765
Distribution Demand Charge						
On-peak	22,540	kW	\$2.68	\$60,407	\$2.61	\$58,829
Off-peak	172	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	11,734	MWh	(0.15) mil	ls (\$1,760)	(0.28) mills	(\$3,286
Reactive Power Charge	5,614	kVar	\$0.50	\$2,807	\$0. 50	\$2,807
Energy Charge (not applicable)		MWh	mil	ls \$0	mills	\$0
Schedule 129	11,734	MWh	0.00 mil	ls \$0	0.00 mills	\$0
Totals	11,734	MWh		\$143,779		\$129,772
				Change		(\$14,007

	Billing		c	urrent	Propo	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2010 Secondary Delivery V Large Non-residential Optional Service (Di	•	v				
Monthly Basic Charge						
Single Phase	0	bills	\$0.00	\$0	\$560.00	\$0
Three Phase	96	bills	\$500.00	\$48,000	\$560.00	\$53,760
Transmission & Related Services Charge						
On-peak	59,970	kW		\$0		\$0
Off-peak	269	kW		\$0		\$0
Distribution Facilities Charge						
Block 1 (first 200 kW)	19,200	faccap	\$3.39	\$65,088	\$3.17	\$60,864
Block 2 (over 200 kW)	58,871	faccap	\$2.49	\$146,589	\$1.97	\$115,976
Distribution Demand Charge						
On-peak	59,970	kW	\$2.68	\$160,720	\$2.61	\$156,522
Off-peak	269	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	32,240	MWh	(0.15) mi	lls (\$4,836)	(0.28) mills	(\$9,027
Reactive Power Charge	5,957	kVar	\$0.50	\$2,979	\$0.50	\$2,979
Energy Charge (not applicable)		MWh	mi	lls \$0	mills	\$0
Schedule 129	32,240	MWh	0 . 00 mi	lls \$0	0 . 00 mills	\$0
Totals	32,240	MWh		\$418,539		\$381,073
				Change		(\$37,466

	Billing			Current	Prop	osed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2011 Secondary Delivery Large Non-residential Optional Service (I	•	V				
Monthly Basic Charge						
Single Phase	0	bills	\$0.00	\$0	\$560.00	\$0
Three Phase	96	bills	\$500.00	\$48,000	\$560.00	\$53,760
Transmission & Related Services Charge						
On-peak	70,528	kW		\$0		\$0
Off-peak	195	kW		\$0		\$0
Distribution Facilities Charge						
Block 1 (first 200 kW)	19,200	faccap	\$3,39	\$65,088	\$3,17	\$60,864
Block 2 (over 200 kW)	71,825	faccap	\$2.49	\$178,844	\$1.97	\$141,495
Distribution Demand Charge						
On-peak	70,528	kW	\$2.68	\$189,015	\$2.61	\$184,078
Off-peak	195	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	34,163	MWh	(0 . 15) r	nills (\$5,124)	(0.28) mills	(\$9,566)
Reactive Power Charge	4,311	kVar	\$0.50	\$2,156	\$0.50	\$2,156
Energy Charge (not applicable)		MWh	r	nills \$0	mills	\$0
Schedule 129	34,163	MWh	0 . 00 r	nills \$0	0.00 mills	\$0
Totals	34,163	MWh		\$477,978		\$432,787
				Change		(\$45,191)

ORDER NO.

PORTLAND GENERAL ELECTRIC Cycle Billing Determinants & Base Revenues (Base Rates)

Billing Current Proposed Schedule Determinant Units Price Revenues Price Revenues Schedule 485 V2012 Secondary Delivery Voltage 201-4,000 kW Large Non-residential Optional Service (Direct Access) Monthly Basic Charge Single Phase 0 bills \$0.00 \$0 \$560,00 \$0 Three Phase 1,188 bills \$500.00 Transmission & Related Services Charge On-peak 417,254 kW Off-peak 3,457 kW Distribution Facilities Charge

237,600

299,709

417,254

192,487

25.204

192,487

192,487

3,457

faccap

faccap

kW

kW

MWh

kVar

MWh

MWh

MWh

Block 1 (first 200 kW)

Block 2 (over 200 kW)

System Usage Charge

Reactive Power Charge

Energy Charge (not applicable)

On-peak

Off-peak

Schedule 129

Totals

Distribution Demand Charge

\$0.00	\$0	\$560.00	\$0
500.00	\$594,000	\$560.00	\$665,280
	\$0		\$0
	\$0		\$0
\$3.39	\$805,464	\$3.17	\$753,192
\$2.49	\$746,275	\$1.97	\$590,427
\$2.68	\$1,118,241	\$2.61	\$1,089,033
\$0.00	\$0	\$0.00	\$0
(0.15) mills	(\$28,873)	(0.28)	mills (\$53,896)
\$0.50	\$12,602	\$0.50	\$12,602
mills	\$0		mills \$0
0.00	0.0	0.00	60
0.00	\$0	0.00	\$0
	\$3,247,709		\$3,056,637
	Change		(\$191,072)

	Billing		Cu	urrent	Prop	osed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2013 Secondary Delivery V Large Non-residential Optional Service (Di	•	V				
Monthly Basic Charge						
Single Phase	0	bills	\$0.00	\$0	\$560.00	\$0
Three Phase	384	bills	\$500.00	\$192,000	\$560.00	\$215,040
Transmission & Related Services Charge						
On-peak	205,520	kW		\$0		\$0
Off-peak	521	kW		\$0		\$0
Distribution Facilities Charge						
Block 1 (first 200 kW)	76,800	faccap	\$3,39	\$260,352	\$3.17	\$243,456
Block 2 (over 200 kW)	187,580	faccap	\$2.49	\$467,074	\$1.97	\$369,533
Distribution Demand Charge						
On-peak	205,520	kW	\$2.68	\$550,794	\$2. 61	\$536,407
Off-peak	521	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	107,529	MWh	(0.15) mil	ls (\$16,129)	(0.28) mills	(\$30,108)
Reactive Power Charge	10,503	kVar	\$0.50	\$5,252	\$0.50	\$5,252
Energy Charge (not applicable)		MWh	mil	ls \$0	mills	\$0
Schedule 129	107,529	MWh	0.00	\$0	0.00	\$0
Totals	107,529	MWh		\$1,459,342		\$1,339,579
				Change		(\$119,763)

	Billing		Cı	urrent	Propo	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2014 Secondary Delivery V Large Non-residential Optional Service (Di	•	V				
Monthly Basic Charge						
Single Phase	0	bills	\$0.00	\$0	\$560.00	\$0
Three Phase	36	bills	\$500.00	\$18,000	\$560.00	\$20,160
Transmission & Related Services Charge						
On-peak	22,476	kW		\$0		\$0
Off-peak	306	kW		\$0		\$0
Distribution Facilities Charge						
Block 1 (first 200 kW)	7,200	faccap	\$3,39	\$24,408	\$3,17	\$22,824
Block 2 (over 200 kW)	20,821	faccap	\$2.49	\$51,844	\$1.97	\$41,017
Distribution Demand Charge						
On-peak	22,476	kW	\$2.68	\$60,236	\$2.61	\$58,662
Off-peak	306	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	10,866	MWh	(0 . 15) mil	lls (\$1,630)	(0.28) mills	(\$3,043)
Reactive Power Charge	3,675	kVar	\$0.50	\$1,838	\$0.50	\$1,838
Energy Charge (not applicable)		MWh	mil	lls \$0	mills	\$0
Schedule 129	10,866	MWh	11.54	\$125,395	0.00	\$0
Totals	10,866	MWh		\$280,091		\$141,459
				Change		(\$138,632)

	Billing		Cui	rrent	Pro	oposed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2015 Secondary Delivery \ Large Non-residential Standard Service ([kW				
Monthly Basic Charge						
Single Phase		bills	\$500.00	\$0	\$560.00	\$0
Three Phase	12	bills	\$500.00	\$6,000	\$560.00	\$6,720
Transmission & Related Services Charge						
On-peak	10,533	kW		\$0		\$0
Off-peak	6	kW		\$0		\$0
Distribution Facilities Charge						
First 200 kW	2,400	faccap	\$3,39	\$8,136	\$3,17	\$7,608
Over 200 kW	8,988	faccap	\$2.49	\$22,380	\$1.97	\$17,706
Distribution Demand Charge						
On-peak	10,533	kW	\$2.68	\$28,228	\$2,61	\$27,491
Off-peak	6	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	4,779	MWh	(0.15) mills	s (\$717) mil	s (0.28)	(\$1,338)
Reactive Power Charge	2,678	kVar	\$0.50	\$1,339	\$0.50	\$1,339
Energy Charge (not applicable)			mills	S	m	ills
Schedule 129	4,779	MWh	23.47	\$112,160	21.72	\$103,797
Tota l s	4,779	MWh		\$177,527		\$163,323
	.,		Cha			4.00,020
						(\$14,203)

	Billing			Current		Prop	osed
Schedule	Determinant	Units	Price Revenues		Price Revenues		
Schedule 485 V2016 Secondary Delivery V Large Non-residential Optional Service (Di	•	V					
Monthly Basic Charge							
Single Phase	0	bills	\$0.00		\$0	\$560.00	\$0
Three Phase	84	bills	\$500.00		\$42,000	\$560.00	\$47,040
Fransmission & Related Services Charge							
On-peak	22,340	kW			\$0		\$0
Off-peak	41	kW			\$0		\$0
Distribution Facilities Charge							
Block 1 (first 200 kW)	16,800	faccap	\$3.39		\$56,952	\$3.17	\$53,256
Block 2 (over 200 kW)	8,771	faccap	\$2.49		\$21,840	\$1.97	\$17,279
Distribution Demand Charge							
On-peak	22,340	kW	\$2.68		\$59,871	\$2.61	\$58,307
Off-peak	41	kW	\$0.00		\$0	\$0.00	\$0
System Usage Charge	12,453	MWh	(0.15)	mills	(\$1,868)	(0.28) mills	(\$3,487
Reactive Power Charge	649	kVar	\$0 . 50		\$325	\$0.50	\$325
Energy Charge (not applicable)		MWh		mills	\$0	mills	\$0
Schedule 129	12,453	MWh	30.41		\$378,683	28.66	\$356,891
Tota l s	12,453	MWh			\$557,802		\$529,611
				Cha	ange		(\$28,192
Schedule 485 V2017 Secondary Delivery V Large Non-residential Optional Service (Di		v					
Monthly Basic Charge							
Single Phase	0	bills	\$0.00		\$0	\$560.00	\$0
Three Phase	456	bills	\$500.00		\$228,000	\$560.00	\$255,360
Fransmission & Related Services Charge							
On-peak		kW			\$0		\$0
Off-peak		kW			\$0		\$0
Distribution Facilities Charge						_	_
Block 1 (first 200 kW)	91,200	faccap	\$3.39		\$309,168	\$3.17	\$289,104
Block 2 (over 200 kW)	157,390	faccap	\$2.49		\$391,901	\$1. 97	\$310,058
Distribution Demand Charge			_				_
On-peak	192,582	kW	\$2.68		\$516,120	\$2.61	\$502,639

Billing		Curi	rent	Propose	d
Determinant	Units	Price	Revenues		evenues
1,314	kW	\$0.00	\$0	\$0.00	\$0
104,545	MWh	(0.15) mills	(\$15,682)	(0.28) mills	(\$29,273)
5,548	kVar	\$0.50	\$2,774	\$0.50	\$2,774
	MWh	mills	\$0	mills	\$0
104,545	MWh	31.13	\$3,254,487	28.46	\$2,975,351
	MWh		\$4,686,768		\$4,306,014
			Change		(\$380,754)
•	v				
0 312	bills bills	\$0.00 \$500.00	\$0 \$156,000	\$560.00 \$560.00	\$0 \$174,720
			•		•
	kW kW		\$0 \$0		\$0 \$0
,	faccap			*	\$197,808 \$214,037
100,048	Тассар	Ψ2.43	\$270,334	φ1 . 91	φ2 14,037
91 202	F/W	¢2.60	¢217 624	\$2.61	\$211,940
52,953	kW	\$0.00	\$217, 024 \$0	\$0.00	\$211,940
63,692	MWh	(0.15) mills	(\$9,554)	(0.28) mills	(\$17,834)
12,120	kVar	\$0.50	\$6,060	\$0.50	\$6,060
	MWh	mills	\$0	mills	\$0
63,692	MWh	33.39	\$2,126,674	30.72	\$1,956,616
63,692	MWh		\$2,978,873		\$2,743,347
			Change		(\$235,527)
	Determinant 1,314 104,545 5,548 104,545 /oltage 201-4,000 kV /irect Access) 0 312 62,400 108,648 81,203 52,953 63,692 12,120 63,692	Determinant	Determinant	Determinant	Determinant Units Price Revenues So \$0.00 R

Schedule 485 V2019 Secondary Delivery Voltage 201-4,000 kW arge Non-residential Optional Service (Direct Access) Aborthly Basic Charge Single Phase 0 bills \$0,00 \$50,00 \$560,00 \$60,00		Billing		Cu	ırrent	Propo	osed
April Pasic Charge Single Phase O bills \$0.00 \$0 \$560.00 \$	Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Single Phase 0 bills \$0.00 \$0.00 \$560.00 \$660.00 \$660.60 \$		•	'				
Three Phase 108 bills \$500.00 \$54,000 \$560.00 \$60.48 Transmission & Related Services Charge On-peak (WW \$0 \$0 \$0 \$1.50	Monthly Basic Charge						
Transmission & Related Services Charge	Single Phase	0	bills	\$0.00	\$0	\$560.00	\$0
Cn-peak	Three Phase	108	bills	\$500.00	\$54,000	\$560.00	\$60,480
Coff-peak	Transmission & Related Services Charge						
Off-peak kW \$0 \$1 Distribution Facilities Charge Block 1 (first 200 kW) 21,600 faccap \$3.39 \$73,224 \$3.17 \$68,477 Block 1 (first 200 kW) 29,443 faccap \$2.49 \$70,623 \$1.197 \$56,031 Distribution Demand Charge On-peak 39,250 kW \$2.68 \$105,190 \$2.61 \$102,444 Off-peak 0 kW \$0.00 \$0 \$0.00 \$0 \$0.00 \$102,444 Off-peak 0 kW \$0.00 \$0 \$0.00 \$102,444 \$0.50 \$0.00 \$0 \$0.00 \$102,444 \$0.50 \$0.00 \$0 \$0.00 \$102,444 \$0.50 \$0.00 \$0 \$0.00 \$0 \$0.00 \$0 \$0.00 \$0 \$0 \$0.00 \$0 \$0 \$0.00 \$0 \$0 \$0.00 \$0 \$0 \$0.00 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0	On-peak		kW		\$0		\$0
Block 1 (first 200 kW)	Off-peak		kW		\$0		\$0
Block 2 (over 200 kW) 28,443 faccap \$2.49 \$70,823 \$1.97 \$56,03	Distribution Facilities Charge						
Block 2 (over 200 kW) 28,443 faccap \$2.49 \$70,823 \$1.97 \$56,03	Block 1 (first 200 kW)	21,600	faccap	\$3.39	\$73,224	\$3,17	\$68,472
Cn-peak		28,443	faccap	\$2.49	\$70,823	\$1.97	\$56,033
Cn-peak	Distribution Domand Charge						
Off-peak 0 kW \$0.00 \$0.00 \$0.0		20.250	F/V/	\$2.69	\$105.100	\$2.61	\$102.442
System Usage Charge 20,614 MWh (0.15) mills (\$3,092) (0.28) mills (\$5,777. Reactive Power Charge 714 kVar \$0.50 \$357 \$0.50 \$357 \$0.50 \$357. Schedule 129 714 kVar \$0.50 \$357 \$0.50 \$357. Schedule 129 20,614 MWh 29.72 \$612,651 29.72 \$612,655. Schedule 129 20,614 MWh \$913,153 \$894,665. Change (\$18,49) \$3.60 \$6.00 \$1.50 \$3.60 \$1.50 \$3.60 \$	•	,			,		
Reactive Power Charge 714 kVar \$0.50 \$357 \$0	Оп-реак	0	KVV	\$0.00	\$0	\$0.00	ΦC
Energy Charge (not applicable) MWh mills \$0 mills \$1 Schedule 129 20,614 MWh 29.72 \$612,651 29.72 \$612,65 Totals 20,614 MWh \$913,153 \$894,665 Change (\$18,496) Change (\$1,596)	System Usage Charge	20,614	MWh	(0.15) mill	s (\$3,092)	(0.28) mills	(\$5,772
Schedule 129 20,614 MWh 29.72 \$612,651 29.72 \$612,65 Totals 20,614 MWh \$913,153 \$894,66: Change (\$18,49) Schedule 489 V2014 Secondary Delivery Voltage GT 4,000 kW Large Non-residential Standard Service (Direct Access) Monthly Basic Charge 12 bills \$3,160.00 \$37,920 \$3,340.00 \$40,080 Fransmission & Related Services Charge On-peak 42,817 kW \$0 \$0 \$\$ Off-peak 0 kW \$0 \$0 Sithibution Facilities Charge First 1,000 kW \$0 \$1,53 \$18,360 1,001 to 4,000 kW 36,000 faccap \$1.59 \$19,080 \$1.53 \$18,360 1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge	Reactive Power Charge	714	kVar	\$0.50	\$357	\$0.50	\$357
Totals 20,614 MWh \$913,153 \$894,665 Change (\$18,496) Change (\$18	Energy Charge (not applicable)		MWh	mill	s \$0	mills	\$0
Change (\$18,496	Schedule 129	20,614	MWh	29.72	\$612,651	29.72	\$612,651
Schedule 489 V2014 Secondary Delivery Voltage GT 4,000 kW Large Non-residential Standard Service (Direct Access) Monthly Basic Charge 12 bills \$3,160.00 \$37,920 \$3,340.00 \$40,080 Fransmission & Related Services Charge On-peak 42,817 kW \$0 \$0 \$1 Off-peak 0 kW \$0 \$0 Distribution Facilities Charge First 1,000 kW \$1,000 kW \$1,53 \$18,360 1,001 to 4,000 kW \$1,59 \$57,240 \$1.53 \$55,080 Over 4,000 kW \$1,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge	Tota l s	20,614	MWh		\$913,153		\$894,663
Anothly Basic Charge 12 bills \$3,160.00 \$37,920 \$3,340.00 \$40,080 Fransmission & Related Services Charge On-peak 42,817 kW \$0 \$0 \$1 Off-peak 0 kW \$0 \$0 Off-peak 50 kW \$0 Off-peak 12,000 faccap \$1.59 \$19,080 \$1.53 \$18,360 1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Oistribution Demand Charge					Change		(\$18,490
Cransmission & Related Services Charge 42,817 kW \$0 \$1 On-peak Off-peak 0 kW \$0 \$1 Distribution Facilities Charge \$1.59 \$19,080 \$1.53 \$18,360 First 1,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,08 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge							
On-peak Off-peak 42,817 0 kW \$0 \$0 \$1 \$0 Oistribution Facilities Charge First 1,000 kW 12,000 1,001 to 4,000 kW 12,000 1,001 to 4,000 kW \$1,59 36,000 1,001 to 4,000 kW \$1,53 36,000 36,000 41,172 \$15,99 41,28 \$57,240 41,28 \$57,240 41,22 \$55,080 41,22 \$50,230 41,22 <	Monthly Basic Charge	12	bills	\$3,160.00	\$37,920	\$3,340.00	\$40,080
Off-peak 0 kW \$0 \$1 Distribution Facilities Charge First 1,000 kW 12,000 faccap \$1.59 \$19,080 \$1.53 \$18,360 1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge \$1.28 \$1.20<	Transmission & Related Services Charge						
Off-peak 0 kW \$0 \$1 Distribution Facilities Charge First 1,000 kW 12,000 faccap \$1.59 \$19,080 \$1.53 \$18,360 1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge \$1.28 \$1.20<	On-peak	42,817	kW		\$0		\$0
First 1,000 kW 12,000 faccap \$1.59 \$19,080 \$1.53 \$18,360 1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge	•						\$0
1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge	Distribution Facilities Charge						
1,001 to 4,000 kW 36,000 faccap \$1.59 \$57,240 \$1.53 \$55,080 Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge	First 1,000 kW	12,000	faccap	\$1.59	\$19,080	\$1.5 3	\$18,360
Over 4,000 kW 41,172 faccap \$1.28 \$52,700 \$1.22 \$50,230 Distribution Demand Charge	1,001 to 4,000 kW		faccap	\$1.59	\$57,240	\$1.53	\$55,080
					, , ,		\$50,230
	Distribution Demand Charge						
	On-peak	42,817	kW	\$2.68	\$114,750	\$2.61	\$111,752

	Billing		C	urrent	Propo	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	13,482	MWh	(0.05) m	ills (\$674)	(0.14) mills	(\$1,887)
Reactive Power Charge	9,541	kVar	\$0.50	\$4,771	\$0.50	\$4,771
Energy Charge (not applicable)			m	ills	mills	
Schedule 129	13,482	MWh	4.83 m	ills \$65,118	0.00 mills	\$0
Tota i s	13,482			\$350,904		\$278,385
				Change		(\$72,519)

	Billing		Cı	urrent	Propo	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2010 Primary Delivery Volta Large Non-residential Standard Service (Di		'				
Monthly Basic Charge	12	bills	\$470.00	\$5,640	\$470.00	\$5,640
Transmission & Related Services Charge						
On-peak	44,256	kW		\$0		\$0
Off-peak	0	kW		\$0		\$0
Distribution Facilities Charge						
Block 1 (first 200 kW)	2,400	faccap	\$3.14	\$7,536	\$3.10	\$7,440
Block 2 (over 200 kW)	45,768	faccap	\$2.24	\$102,520	\$1.90	\$86,959
Distribution Demand Charge						
On-peak	44,256	kW	\$2.60	\$115,066	\$2.53	\$111,968
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	24,415	MWh	(0.16) mil	lls (\$3,906)	(0.29) mills	(\$7,080)
Reactive Power Charge	11,460	kVar	\$0.50	\$5,730	\$0.50	\$5,730
Energy Charge (not applicable)			mil	lls	mills	
Schedule 129	24,415	MWh	0 . 00 mil	lls \$0	0 . 00 mills	\$0
Totals	24,415			\$232,585		\$210,656
				Change		(\$21,929)

	Billing		Cu	urrent	Propo	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2012 Primary Delivery Volta Large Non-residential Standard Service (Di	•	1				
Monthly Basic Charge	60	bills	\$470.00	\$28,200	\$470.00	\$28,200
Transmission & Related Services Charge	70.400	1.347		**		**
On-peak Off-peak	76,469 45	kW kW		\$0 \$0		\$0 \$0
Distribution Facilities Charge						
Block 1 (first 200 kW) Block 2 (over 200 kW)	12,000 64,514	faccap faccap	\$3.14 \$2.24	\$37,680 \$144,511	\$3.10 \$1.90	\$37,200 \$122,577
Distribution Demand Charge						
On-peak Off-peak	76,469 0	kW kW	\$2.60 \$0.00	\$198,819 \$0	\$2.53 \$0.00	\$193,467 \$0
System Usage Charge	35,086	MWh	(0.16) mil	lls (\$5,614)	(0.29) mills	(\$10,175)
Reactive Power Charge	1,848	kVar	\$0.50	\$924	\$0.50	\$924
Energy Charge (not applicable)			mil	lls	mills	
Schedule 129	35,086	MWh	0.00 mil	lls \$0	0.00 mills	\$0
Tota l s	35,086			\$404,521		\$372,192
				Change		(\$32,329)

illing		Cui	rrent	Propos	sed
eterminant	Units	Price	Revenues	Price	Revenues
	1				
336	bills	\$470.00	\$157,920	\$470.00	\$157,920
269,885 626	kW kW		\$0 \$0		\$0 \$0
67,200	faccap	\$3.14	\$211,008	\$3.10	\$208,320
203,310	taccap	\$2.24	\$455,414	\$1.90	\$386,289
269,885	kW	\$2.60	\$701,701	\$2.53	\$682,809
626	kW	\$0.00	\$0	\$0.00	\$0
128,740	MWh	(0.16) mills	(\$20,598)	(0.29) mills	(\$37,335)
36,474	kVar	\$0.50	\$18,237	\$0.50	\$18,237
		mills	5	mills	
128,740	MWh	0.00	\$0	0.00	\$0
			\$1,523,682		\$1,416,240
			Change		(\$107,442)
	269,885 626 67,200 203,310 269,885 626 128,740 36,474	269,885 kW 626 kW 269,885 kW 626 kW 269,885 kW 626 kW 47,200 faccap faccap 203,310 faccap 269,885 kW 626 kW 128,740 MWh 36,474 kVar	No.50 No.5	Price Revenues	Price Revenues Price P

Schedule Determinant Units Price Revenues Price Revenues Schedule 485 V2014 Primary Delivery Voltage 201 to 4,000 kW Large Non-residential Standard Service (Direct Access) Monthly Basic Charge 24 bills \$470.00 \$11,280 \$470.00 \$11,280 Transmission & Related Services Charge On-peak \$15,663 kW \$0 \$0 \$0 Off-peak 33 kW \$0 \$14,880 \$14,880 \$14,880 \$14,880 \$14,880 \$14,880 \$14,880 \$14,880 \$14,880 \$14,880 \$14,480 \$14,480 \$14,880 \$14,480 \$14,480 \$14,480 \$14,480 \$14,480 \$14,480 \$14		Billing		Cui	rrent	Propos	sed
Large Non-residential Standard Service (Direct Access) Monthly Basic Charge 24 bills \$470.00 \$11,280 \$470.00 \$11,280 Transmission & Related Services Charge On-peak 15,663 kW \$0 \$0 \$0 Off-peak 33 kW \$0 \$0 \$0 \$0 Distribution Facilities Charge Block 1 (first 200 kW) 4,800 faccap faccap faccap \$3.14 \$15,072 \$3.10 \$14,880 \$14,890 \$14,880 \$14,800 \$14,890 \$14,800 \$14,800 \$14,800 \$14,800 \$14,800	Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Transmission & Related Services Charge			•				
On-peak Off-peak 15,663 kW \$W \$0 \$1.4880 kg.0 \$1.4880 kg.0 \$1.490 kg.0 \$2.244 kg.0 \$1.90 kg.0 \$2.0702 kg.0 \$2.0702 kg.0 \$2.244 kg.0 \$1.90 kg.0 \$2.0702 k	Monthly Basic Charge	24	bills	\$470.00	\$11,280	\$470.00	\$11,280
Off-peak 33 kW \$0 \$0 Distribution Facilities Charge Block 1 (first 200 kW) 4,800 10,896 faccap faccap \$3.14 \$2.24 \$15,072 \$24,407 \$3.10 \$1.90 \$14,880 \$20,702 Distribution Demand Charge On-peak Off-peak 15,663 33 kW \$2.60 \$0.00 \$40,724 \$0.00 \$2.53 \$0.00 \$39,627 \$0 System Usage Charge 8,879 MWh (0.16) mills (\$1,421) (0.29) mills (\$2,575) Reactive Power Charge 2,931 kVar \$0.50 \$1,466 \$0.50 \$1,466 Energy Charge (not applicable) mills mills mills Totals \$193,366 \$85,380	Transmission & Related Services Charge						
Distribution Facilities Charge Block 1 (first 200 kW)	•	,					
Block 1 (first 200 kW)	Off-peak	33	kW		\$0		\$0
Block 2 (over 200 kW) 10,896 faccap \$2.24 \$24,407 \$1.90 \$20,702 Distribution Demand Charge On-peak Off-peak 15,663 kW \$2.60 \$40,724 \$2.53 \$39,627 Off-peak 33 kW \$0.00 \$0 \$0.00 \$0 System Usage Charge 8,879 MWh (0.16) mills (\$1,421) (0.29) mills (\$2,575) Reactive Power Charge 2,931 kVar \$0.50 \$1,466 \$0.50 \$1,466 Energy Charge (not applicable) mills mills mills mills Schedule 129 8,879 MWh 11.47 \$101,838 0.00 \$0 Totals \$85,380	Distribution Facilities Charge						
Distribution Demand Charge On-peak Off-peak 15,663 kW \$2.60 \$40,724 \$2.53 \$39,627 Off-peak \$2.53 kW \$0.00 \$0.00 \$0 \$30,000 \$0 System Usage Charge 8,879 MWh (0.16) mills (\$1,421) (0.29) mills (\$2,575) Reactive Power Charge 2,931 kVar \$0.50 \$1,466 \$0.50 \$1,466 \$0.50 \$1,466 Energy Charge (not applicable) mills mills Schedule 129 8,879 MWh 11,47 \$101,838 0.00 \$0.50 \$85,380 Totals \$193,366 \$85,380	Block 1 (first 200 kW)	4,800	faccap	\$3.14	\$15,072	\$3.10	\$14,880
On-peak Off-peak 15,663 kW \$2.60 \$40,724 \$2.53 \$39,627 \$0 Off-peak 8,879 MWh \$0.00 \$0 \$0 \$0.00 \$0 \$1,466 \$0.50 \$1,466 \$0.50 \$1,466 \$0.50 \$1,466 \$0.50 \$1,466 \$0.50 \$1,466 \$0.50 \$1,466 \$0.50 \$0 <t< td=""><td>Block 2 (over 200 kW)</td><td>10,896</td><td>faccap</td><td>\$2.24</td><td>\$24,407</td><td>\$1.90</td><td>\$20,702</td></t<>	Block 2 (over 200 kW)	10,896	faccap	\$2.24	\$24,407	\$1.90	\$20,702
Off-peak 33 kW \$0.00 \$0 \$0.00 \$0 System Usage Charge 8,879 MWh (0.16) mills (\$1,421) (0.29) mills (\$2,575) Reactive Power Charge 2,931 kVar \$0.50 \$1,466 \$0.50 \$1,466 Energy Charge (not applicable) mills mills mills Schedule 129 8,879 MWh 11.47 \$101,838 0.00 \$0 Totals \$193,366 \$85,380	Distribution Demand Charge						
System Usage Charge 8,879 MWh (0.16) mills (\$1,421) (0.29) mills (\$2,575) Reactive Power Charge 2,931 kVar \$0.50 \$1,466 \$0.50 \$1,466 Energy Charge (not applicable) mills mills mills Schedule 129 8,879 MWh 11.47 \$101,838 0.00 \$0 Totals \$193,366 \$85,380	On-peak	15,663	kW	\$2.60	\$40,724	\$2.53	\$39,627
Reactive Power Charge 2,931 kVar \$0.50 \$1,466 \$0.50 \$1,466 Energy Charge (not applicable) mills mills mills Schedule 129 8,879 MWh 11.47 \$101,838 0.00 \$0 Totals \$193,366 \$85,380	Off-peak	33	kW	\$0.00	\$0	\$0.00	\$0
Energy Charge (not applicable) mills mills Schedule 129 8,879 MWh 11.47 \$101,838 0.00 \$0 Totals \$193,366 \$85,380	System Usage Charge	8,879	MWh	(0.16) mills	s (\$1,421)	(0.29) mills	(\$2,575)
Schedule 129 8,879 MWh 11.47 \$101,838 0.00 \$0 Totals \$193,366 \$85,380	Reactive Power Charge	2,931	kVar	\$0. 50	\$1,466	\$0.50	\$1,466
Totals \$193,366 \$85,380	Energy Charge (not applicable)			mills	5	mills	
V	Schedule 129	8,879	MWh	11.47	\$101,838	0.00	\$0
Change (\$107.986)	Totals				\$193,366		\$85,380
Charge (a) 107.3001					Change		(\$107,986)

	Billing		Current		Proposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 485 V2015 Primary Delivery Volta Large Non-residential Standard Service (Di	•	'				
Monthly Basic Charge	24	bills	\$470.00	\$11,280	\$470.00	\$11,280
Transmission & Related Services Charge						
On-peak Off-peak	73,223 0	kW kW		\$0 \$0		\$0 \$0
Distribution Facilities Charge						
Block 1 (first 200 kW) Block 2 (over 200 kW)	4,800 73,513	faccap faccap	\$3.14 \$2.24	\$15,072 \$164,669	\$3.10 \$1.90	\$14,880 \$139,675
Distribution Demand Charge						
On-peak	73,223	kW kW	\$2.60 \$0.00	\$190,380 \$0	\$2.53	\$185,254
Off-peak	0	KVV	\$0.00	\$0	\$0.00	\$0
System Usage Charge	35,096	MWh	(0.16) mills	(\$5,615)	(0.29) mills	(\$10,178)
Reactive Power Charge	9,359	kVar	\$0.50	\$4,680	\$0 <u>.</u> 50	\$4,680
Energy Charge (not applicable)			mills	3	mills	
Schedule 129	35,096	MWh	23.26	\$816,334	21.53	\$755,618
Totals	35,096	MWh		\$1,196,799		\$1,101,209
				Change		(\$95,591)

	Billing		Curre	nt	Proposed	
Schedule	Determinant	Units	Price I	Revenues	Price	Revenues
Schedule 485 V2016 Primary Delivery Volta arge Non-residential Standard Service (Di	•	1				
Monthly Basic Charge	0	bills	\$470.00	\$0	\$470.00	\$
Transmission & Related Services Charge						
On-peak	0	kW		\$0		;
Off-peak	0	kW		\$0		
Distribution Facilities Charge						
Block 1 (first 200 kW)	0	faccap	\$3.14	\$0	\$3.10	
Block 2 (over 200 kW)	0	faccap	\$2.24	\$0	\$1.90	:
Distribution Demand Charge						
On-peak	0	kW	\$2.60	\$0	\$2.53	
Off-peak	0	kW	\$0.00	\$0	\$0.00	
System Usage Charge	0	MWh	(0.16) mills	\$0	(0.29) mills	
Reactive Power Charge	0	kVar	\$0. 50	\$0	\$0 . 50	
Energy Charge (not applicable)			mills		mills	
Schedule 129	0	MWh	30.07	\$0	28.34	
otals	0	MWh		\$0		
	Change					
Schedule 485 V2017 Primary Delivery Volta Large Non-residential Standard Service (Di		1				
Monthly Basic Charge	96	bills	\$470.00	\$45,120	\$470.00	\$45,1
Fransmission & Related Services Charge						
On-peak	112,749	kW		\$0		
Off-peak	100	kW		\$0		
Distribution Facilities Charge						
Block 1 (first 200 kW)	19,200	faccap	\$3.14	\$60,288	\$3.10	\$59,5
Block 2 (over 200 kW)	93,649	faccap	\$2.24	\$209,774	\$1.90	\$177,9
Distribution Demand Charge						
On-peak	112,749	kW	\$2.60	\$293,147	\$2.53	\$285,2
	100	1.147	60.00	•	00.00	
Off-peak	100	kW	\$0.00	\$0	\$0.00	

	Billing		Cur	rent	Proposed		
Schedule	Determinant	Units	Price	Revenues	Price	Revenues	
Reactive Power Charge	12,227	kVar	\$0.50	\$6,114	\$0.50	\$6,114	
Energy Charge (not applicable)			mills		mills	s	
Schedule 129	65,259	MWh	30.63	\$1,998,877	28.00	\$1,827,247	
Tota l s	65,259	MWh		\$2,602,879		\$2,382,263	
				Change		(\$220,615)	
Schedule 485 V2018 Primary Delivery Volt Large Non-residential Standard Service (D		v					
Monthly Basic Charge	12	bills	\$470.00	\$5,640	\$470.00	\$5,640	
Transmission & Related Services Charge On-peak Off-peak	22,453 0	kW kW		\$0 \$0		\$0 \$0	
Distribution Facilities Charge Block 1 (first 200 kW) Block 2 (over 200 kW)	2,400 26,472	faccap faccap	\$3 . 14 \$2.24	\$7,536 \$59,297	\$3.10 \$1.90	\$7,440 \$50,297	
Distribution Demand Charge On-peak Off-peak	22,453 0	kW kW	\$2.60 \$0.00	\$58,378 \$0	\$2.53 \$0.00	\$56,806 \$0	
System Usage Charge	12,047	MWh	(0.16) mills	(\$1,928)	(0.29) mill	s (\$3,494)	
Reactive Power Charge	0	kVar	\$0.50	\$0	\$0.50	\$0	
Energy Charge (not applicable)			mills		mill	s	
Schedule 129	12,047	MWh	32.94	\$396,826	30.31	\$365,142	
Totals	12,047	MWh		\$525,749		\$481,832	
				Change		(\$43,918)	

	Billing		Current		Proposed		
Schedule	Determinant	Units	Price	Revenues	Price	Revenues	
Schedule 485 V2019 Primary Delivery Volt Large Non-residential Standard Service (D							
Monthly Basic Charge	24	bills	\$470.00	\$11,280	\$470.00	\$11,280	
Transmission & Related Services Charge							
On-peak	59,353	kW		\$0		\$0	
Off-peak	0	kW		\$0		\$0	
Distribution Facilities Charge							
Block 1 (first 200 kW)	4,800	faccap	\$3.14	\$15,072	\$3.10	\$14,880	
Block 2 (over 200 kW)	69,228	faccap	\$2.24	\$155,071	\$1.90	\$131,533	
Distribution Demand Charge							
On-peak	59,353	kW	\$2.60	\$154,318	\$2.53	\$150,163	
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0	
System Usage Charge	21,816	MWh	(0.16) mills	(\$3,491)	(0.29) mills	(\$6,327	
Reactive Power Charge	9,292	kVar	\$0. 50	\$4,646	\$0. 50	\$4,646	
Energy Charge (not applicable)			mills		mills		
Schedule 129	21,816	MWh	29.58	\$645,317	29.58	\$645,317	
Γota l s	21,816	MWh		\$982,213		\$951,493	
		Change					
Schedule 489 V2004 Primary Delivery Volt Large Non-residential Standard Service (D	-						
Monthly Basic Charge	12	bills	\$1,770.00	\$21,240	\$1,890.00	\$22,680	
Transmission & Related Services Charge							
On-peak	128,295	kW		\$0		\$0	
Off-peak	0	kW		\$0		\$0	
Distribution Facilities Charge							
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880	
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640	
Over 4,000 kW	93,240	faccap	\$1.24	\$115,618	\$1.18	\$110,023	
Distribution Demand Charge							
On-peak	128,295	kW	\$2.60	\$333,567	\$2.53	\$324,586	
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0	

	Billing		Cur	rent	Propo	sed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
System Usage Charge	75,020	MWh	(0.05) mills	(\$3,751)	(0.15) mills	(\$11,253)
Reactive Power Charge	35,972	kVar	\$0.50	\$17,986	\$0.50	\$17,986
Energy Charge (not applicable)			mills		mills	
Schedule 129	75,020	MWh	0.00 mills	\$0	0.00 mills	\$0
Totals	75,020			\$559,060		\$535,543
				Change		(\$23,517)

	Billing		Cı	urrent	Proposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2010 Primary Delivery Volt Large Non-residential Standard Service (D	•					
Monthly Basic Charge	12	bills	\$1,770.00	\$21,240	\$1,890.00	\$22,680
Transmission & Related Services Charge						
On-peak	142,095	kW		\$0		\$0
Off-peak	0	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	106,284	faccap	\$1.24	\$131,792	\$1.18	\$125,415
Distribution Demand Charge						
On-peak	142,095	kW	\$2.60	\$369,447	\$2.53	\$359,500
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	73,367	MWh	(0.05) mil	lls (\$3,668)	(0.15) mills	s (\$11,005)
Reactive Power Charge	44,824	kVar	\$0.50	\$22,412	\$0.50	\$22,412
Energy Charge (not applicable)			mil	lls	mills	5
Schedule 129	73,367	MWh	0.00 mil	lls \$0	0.00 mills	s \$0
Tota l s	73,367			\$615,623		\$590,522
				Change		(\$25,100)

	Billing		Cı	Current		Proposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues	
Schedule 489 V2011 Primary Delivery Volta Large Non-residential Standard Service (D	•						
Monthly Basic Charge	24	bills	\$1,770.00	\$42,480	\$1,890.00	\$45,360	
Transmission & Related Services Charge							
On-peak	263,601	kW		\$0		\$0	
Off-peak	0	kW		\$0		\$0	
Distribution Facilities Charge							
First 1,000 kW	24,000	faccap	\$1.55	\$37,200	\$1.49	\$35,760	
1,001 to 4,000 kW	72,000	faccap	\$1.55	\$111,600	\$1.49	\$107,280	
Over 4,000 kW	190,320	faccap	\$1.24	\$235,997	\$1.18	\$224,578	
Distribution Demand Charge							
On-peak	263,601	kW	\$2.60	\$685,363	\$2.53	\$666,911	
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0	
System Usage Charge	179,170	MWh	(0.05) mil	lls (\$8,958)	(0.15) mills	(\$26,875)	
Reactive Power Charge	34,160	kVar	\$0.50	\$17,080	\$0.50	\$17,080	
Energy Charge (not applicable)			mil	lls	mills	3	
Schedule 129	179,170	MWh	0.00 mil	lls \$0	0.00 mills	\$0	
Totals	179,170	MWh		\$1,120,761		\$1,070,093	
				Change		(\$50,668)	

	Billing		Current		Proposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2012 Primary Delivery Volt Large Non-residential Standard Service (D	•					
Monthly Basic Charge	36	bills	\$1,770.00	\$63,720	\$1,890.00	\$68,040
Transmission & Related Services Charge						
On-peak	170,006	kW		\$0		\$0
Off-peak	46	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
1,001 to 4,000 kW	108,000	faccap	\$1.55	\$167,400	\$1.49	\$160,920
Over 4,000 kW	54,825	faccap	\$1.24	\$67,983	\$1.18	\$64,694
Distribution Demand Charge						
On-peak	170,006	kW	\$2.60	\$442,016	\$2.53	\$430,115
Off-peak	46	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	87,123	MWh	(0.05) mills	s (\$4,356)	(0.15) mills	(\$13,068)
Reactive Power Charge	2,846	kVar	\$0.50	\$1,423	\$0.50	\$1,423
Energy Charge (not applicable)			mills	S	mills	
Schedule 129	87,123	MWh	0.00 mills	s \$0	0.00 mills	\$0
Tota l s	87,123	MWh		\$793,985		\$765,763
				Change		(\$28,222)

	Billing		Cur	rrent	Proposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2013 Primary Delivery Volta Large Non-residential Standard Service (D	•					
Monthly Basic Charge	12	bills	\$1,770.00	\$21,240	\$1,890.00	\$22,680
Transmission & Related Services Charge						
On-peak	89,545	kW		\$0		\$0
Off-peak	31	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	49,932	faccap	\$1.24	\$61,916	\$1.18	\$58,920
Distribution Demand Charge						
On-peak	89,545	kW	\$2.60	\$232,817	\$2.53	\$226,549
Off-peak	31	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	56,400	MWh	(0.05) mills	(\$2,820)	(0.15) mill	s (\$8,460)
Reactive Power Charge	203	kVar	\$0.50	\$102	\$0.50	\$102
Energy Charge (not applicable)			mills	:	mill	s
Schedule 129	56,400	MWh	0.00	\$0	0.00	\$0
Totals		MWh		\$387,654		\$371,310
				Change		(\$16,344)

	Billing		Cur	rent	Prop	osed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2014 Primary Delivery Volta Large Non-residential Standard Service (D	•					
Monthly Basic Charge	12	bills	\$1,770.00	\$21,240	\$1,890.00	\$22,680
Transmission & Related Services Charge						
On-peak	102,973	kW		\$0		\$0
Off-peak	222	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	63,900	faccap	\$1.24	\$79,236	\$1.18	\$75,402
Distribution Demand Charge						
On-peak	102,973	kW	\$2.60	\$267,730	\$2.53	\$260,522
Off-peak	222	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	68,114	MWh	(0.05) mills	(\$3,406)	(0.15) mills	(\$10,217)
Reactive Power Charge	1,298	kVar	\$0.50	\$649	\$0.50	\$649
Energy Charge (not applicable)			mills		mills	
Schedule 129	68,114	MWh	9.21	\$627,334	0.00	\$0
Tota l s		MWh		\$1,067,183		\$420,556
				Change		(\$646,628)

	Billing		Current		Proposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2016 Primary Delivery Volt arge Non-residential Standard Service ([•					
Monthly Basic Charge	12	bills	\$1,770.00	\$21,240	\$1,890.00	\$22,680
Transmission & Related Services Charge						
On-peak	98,417	kW		\$0		\$0
Off-peak	0	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	51,106	faccap	\$1.24	\$63,371	\$1.18	\$60,305
Distribution Demand Charge						
On-peak	98,417	kW	\$2.60	\$255,884	\$2.53	\$248,995
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	66,250	MWh	(0.05) mills	(\$3,312)	(0.15) mills	(\$9,937)
Reactive Power Charge	0	kVar	\$0. 50	\$0	\$0.50	\$0
Energy Charge (not applicable)			mills		mills	
Schedule 129	66,250	MWh	27.62	\$1,829,822	26.05	\$1,725,810
Tota l s	66,250	MWh		\$2,241,405		\$2,119,373
				(\$122,033		
Schedule 489 V2017 Primary Delivery Volt Large Non-residential Standard Service (I						
Monthly Basic Charge	24	bills	\$1,770.00	\$42,480	\$1,890.00	\$45,360
Transmission & Related Services Charge						
On-peak	228,766	kW		\$0		\$0
Off-peak	596	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	24,000	faccap	\$1.55	\$37,200	\$1.49	\$35,760
1,001 to 4,000 kW	72,000	faccap	\$1. 55	\$111,600	\$1.49	\$107,280
Over 4,000 kW	156,890	faccap	\$1.24	\$194,544	\$1.18	\$185,130
Distribution Demand Charge						
On-peak	228,766	kW	\$2.60	\$594,792	\$2.53	\$578,778

	Billing		Curre	nt	Propose	ed
Schedule	Determinant	Units	Price F	Revenues		evenues
System Usage Charge	143,156	MWh	(0.05) mills	(\$7,158)	(0.15) mills	(\$21,473)
Reactive Power Charge	55,222	kVar	\$0.50	\$27,611	\$0.50	\$27,611
Energy Charge (not applicable)			mills		mills	
Schedule 129	143,156	MWh	28.47	\$4,075,642	26.05	\$3,729,205
Totals	143,156	MWh		\$5,076,710		\$4,687,651
			C	Change		(\$389,059)
Schedule 489 V2018 Primary Delivery Vol Large Non-residential Standard Service (_					
Monthly Basic Charge	24	bills	\$1,770.00	\$42,480	\$1,890.00	\$45,360
Transmission & Related Services Charge						
On-peak Off-peak	253,351 20	kW kW		\$0 \$0		\$0 \$0
On-peak	20	KVV		ΨΟ		ΨΟ
Distribution Facilities Charge	24.000	f	\$4.55	¢27.200	64.40	\$25.760
First 1,000 kW 1,001 to 4,000 kW	24,000 72,000	faccap faccap	\$1.55 \$1.55	\$37,200 \$111,600	\$1.49 \$1.49	\$35,760 \$107,280
Over 4,000 kW	178,446	faccap	\$1.24	\$221,273	\$1.18	\$210,566
Distribution Demand Charge						
On-peak	253,351	kW	\$2.60	\$658,713	\$2.53	\$640,978
Off-peak	20	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	166,555	MWh	(0.05) mills	(\$8,328)	(0.15) mills	(\$24,983)
Reactive Power Charge	31,808	kVar	\$0.50	\$15,904	\$0.50	\$15,904
Energy Charge (not applicable)			mills		mills	
Schedule 129	166,555	MWh	29.53	\$4,918,360	27.11	\$4,515,297
Totals	166,555	MWh		\$5,997,202		\$5,546,162
			C	Change		(\$451,039)
Schedule 489 V2019 Primary Delivery Vol Large Non-residential Standard Service (•					
Monthly Basic Charge	12	bills	\$1,770.00	\$21,240	\$1,890.00	\$22,680

	Billing		Curre	ent	Propos	ed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Transmission & Related Services Charge						
On-peak	69.873	kW		\$0		\$0
Off-peak	80	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1 . 55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1. 55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	26,844	faccap	\$1.24	\$33,287	\$1. 18	\$31,676
Distribution Demand Charge						
On-peak	69,873	kW	\$2.60	\$181,670	\$2.53	\$176,779
Off-peak	80	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	45,879	MWh	(0.05) mills	(\$2,294)	(0.15) mills	(\$6,882)
Reactive Power Charge	12,928	kVar	\$0. 50	\$6,464	\$0.50	\$6,464
Energy Charge (not applicable)			mills		mills	
Schedule 129	45,879	MWh	25.76	\$1,181,852	25.76	\$1,181,852
Tota l s	45,879	MWh		\$1,496,618		\$1,484,088
			(Change		(\$12,530)
Schedule 489 V2007 Subtransmission Deli Large Non-residential Standard Service (D		000 kW				
Monthly Basic Charge	12	bills	\$3,850.00	\$46,200	\$3,970.00	\$47,640
Transmission & Related Services Charge						
On-peak	10,708	kW		\$0		\$0
Off-peak	0	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	48,000	faccap	\$1. 55	\$74,400	\$1. 49	\$71,520
1,001 to 4,000 kW	12	faccap	\$1.55	\$19	\$1.49	\$18
Over 4,000 kW	0	faccap	\$1. 24	\$0	\$1. 18	\$0
Distribution Demand Charge						
On-peak	10,708	kW	\$1.26	\$13,492	\$1.27	\$13,599
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	1,733	MWh	(0.06) mills	(\$104)	(0.15) mills	(\$260)
Reactive Power Charge	890	kVar	\$0.50	\$445	\$0.50	\$445

	Billing		Cur	rent	P	roposed
Schedule Energy Charge (not applicable)	Determinant	Units	Price mills	Revenues	Price	Revenues mills
Schedule 129	1,733	MWh	0.00 mills	\$0	0.00 r	mills \$0
Tota l s	1,733	MWh		\$134,452		\$132,962
				Change		(\$1,490)

	Billing		Cu	urrent	Prop	osed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2012 Subtransmission Deli Large Non-residential Standard Service (D		000 kW				
Monthly Basic Charge	12	bills	\$3,850.00	\$46,200	\$3,970.00	\$47,640
Transmission & Related Services Charge						
On-peak	162,339	kW		\$0		\$0
Off-peak	0	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	164,544	faccap	\$1.24	\$204,035	\$1.18	\$194,162
Distribution Demand Charge						
On-peak	162,339	kW	\$1.26	\$204,547	\$1.27	\$206,171
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	100,778	MWh	(0.06) mil	ls (\$6,047)	(0.15) mills	(\$15,117)
Reactive Power Charge	29,693	kVar	\$0.50	\$14,847	\$0.50	\$14,847
Energy Charge (not applicable)			mil	ls	mills	
Schedule 129	100,778	MWh	0.00 mil	ls \$0	0.00 mills	\$0
Totals	100,778	MWh		\$537,982		\$519,222
				Change		(\$18,759)

	Billing		Cur	rent	Prop	osed
Schedule	Determinant	Units	Price	Revenues	Price	Revenues
Schedule 489 V2013 Subtransmission Del Large Non-residential Standard Service (I		000 kW				
Monthly Basic Charge	12	bills	\$3,850.00	\$46,200	\$3,970.00	\$47,640
Transmission & Related Services Charge						
On-peak	198,357	kW		\$0		\$0
Off-peak	0	kW		\$0		\$0
Distribution Facilities Charge						
First 1,000 kW	12,000	faccap	\$1.55	\$18,600	\$1.49	\$17,880
1,001 to 4,000 kW	36,000	faccap	\$1.55	\$55,800	\$1.49	\$53,640
Over 4,000 kW	168,410	faccap	\$1. 24	\$208,828	\$1.18	\$198,724
Distribution Demand Charge						
On-peak	198,357	kW	\$1.26	\$249,930	\$1.27	\$251,913
Off-peak	0	kW	\$0.00	\$0	\$0.00	\$0
System Usage Charge	84,661	MWh	(0.06) mills	(\$5,080)	(0.15) mills	(\$12,699)
Reactive Power Charge	182,305	kVar	\$0.50	\$91,153	\$0. 50	\$91,153
Energy Charge (not applicable)			mills		mills	
Schedule 129	84,661	MWh	0.00	\$0	0.00	\$0
Totals	84,661	MWh		\$665,431		\$648,251
				Change		(\$17,181)
System DA Totals	1,999,817	MWh		\$40,656,342		\$40,289,413

	Billing			Current	Pr	oposed	
Schedule	Determinant	Units	Price	Revenues	Price	Revenues	
Summary of Revenues: Current and Propos	ed						
System COS Totals System VPO Totals System DA Totals Totals	17,312,384 0 <u>1,999,817</u> 19,312,201	MWh MWh MWh		\$1,778,702,355 \$0 <u>\$40,656,342</u> \$1,819,358,698 Change		\$1,791,219,543 \$0 \$40,289,413 \$1,831,508,956 \$12,150,258	
Revenue Category Basic Charge Revenues Transmission & Related Charges Volumetric Distribution Charges Facilities Charges Distribution Demand Charges System Usage Charges Reactive Power Charges Energy Charges Schedule 125 Schedule 122a Schedule 129 Employee Discount Totals				\$142,652,721 \$31,619,334 \$407,595,747 \$77,407,080 \$61,174,362 \$21,982,944 \$1,253,946 \$1,056,741,996 \$0 \$0 \$23,267,370 (\$944,818) \$1,822,750,682	\$0 \$0 (\$0) \$0 (\$0) \$0 \$0 \$0 \$0 \$0	\$149,279,100 \$37,271,496 \$436,042,123 \$72,623,375 \$59,589,040 \$23,800,836 \$1,253,946 \$1,031,858,698 \$0 \$0 \$20,750,795 (\$960,453) \$1,831,508,956	\$0 \$0 \$0 (\$0) (\$0) \$0 \$0 \$0 \$0 \$0
Reconcile to Cycle-adjusted Revenue Requirer Delta Employee Discount (difference between to Rounding of Prices						\$0 \$0 (\$63,001) (\$36,525) \$99,526 (\$0.000)	

*** The color of t	\$1100 \$1101	\$11.00 \$11.00		\$20.00 \$20.00	\$20.00 \$20.00	\$30.00 \$30.00	\$17.00 \$17.00	\$45.00 \$44.00	\$35.00 \$49.00	fewn on	8470.00	REMINE	\$1 MID TO	\$1 HA1 G1	\$6 tonon			\$400 m	6401.00	81 341 01	\$1 MID DD	AN OFD DD	Se too oo				\$20.00 \$20.00	\$30.00 \$30.00	\$45.00 \$45.00	
*** The state of t	243 Block 2 Block 3 M Block 1	3 97 - 34 d Page)	1.62	206	206	171	213	2 12	\$0 TB	\$0.76	\$0.76	\$0 TB	\$0.76	\$0.75	\$0.76	152	1 59													
The column	etrie 40 02 Block 2	74 16 MAPPING	63 23	42 32 14 87	42 32 14 97	20.41	110 99 90 99	50 50 50 50								63 89	29.25							62 63	27 60	~~	40.77 10.00	ra se	79.12 69.12	
*** Same and the state of the s	Stock 1 Stock 2 Stock 3 History 1	000 (ORPasio							\$3.40 \$0.00	\$1 97 \$0 00	\$1.90 90.00	\$1.53 \$1.92	\$1.40 \$1.18	\$1.43 \$1.18	\$1.01 \$1.00			\$1.97 \$0.00	\$1.90 \$0.00	\$1.53 \$1.22	\$1.40 \$1.18	\$140 \$118	\$1.61 \$1.90							
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1																														
**************************************	63.29 70.51 Flat On-Park	72.61 344 Peaco	49 99	58.42	5842 (Mid-Post)	59.79	70.94	70 68	63 35 48 35	51 91 46 91		55 (3) 43 (3)	57 73 42 73	67 02 42 02		41 14	61.09													
1 1 1 1 2 2 2 2 3 3 3 5 4 5 5	Selections	"(in Districte)	VioDistrates 1	inflator)	*On Distrate)	Selection	Yo Distrates	Section and	6.99	0.67	0.83	102	0.66	0.97	0.64	Satistica	Nie Diet onei	80.996	0.20	0.50	0.16	(0.16)	mm	Softetalo	No fine care	Nistratei	MoDistrato	Sin Distriction	in Distrates	
*** 11 11	centalkWh																													
*** A 20	11					30 30	37 37	45 45	35 45	560	470	3340	1990	3970	6100			560	470	3340	1890	3970	6100				20 29	30 30	45 45	
- 078 078 078 079 078 078 078 078 078 078 078 078 078 078	0.243	0.387 Min-Paul	0,152	0,206	0.208	0,171	0.213	0.212								0.152	0.159													
442 788 664-44 198 429 429 429 744 1189 509 509 510 510 510 510 510 510 510 510 510 510									0.78	0.78	0.76	0.78	0.76	0.75	0.76															
250 310 100 100 140 140 150 150 150 150 150 150 150 150 150 15	4 002	7,616 (Md-Peak	6.329	4 232 1,487	4 232 1 487	7041	11 (22) 9,720	8 099 8 099								6 399	2 925							6 269	2 789	6 202	4 077 1,132	E 8588 31	7 912 5.912	
240 260 260 260 260 260 260 260 260 260 26									3 500 3 400	3 170 1 970	3 100 1 900	1 530	1.490	1 490	1 610			3 170 1 970	3 900 1 900	1.530	1.490	1.480	1.610							
9:39 12:39 (InC-New) 19:39 (InC-New) 19:39 (InC-New) 19:39 (InC-New) 19:39 10:39 (InC-New) 19:30 12:39 13:30 1	'								2 610	2 610	2 530	2 610	2 530	1 270	2 530			2 610	2 530	2610	2 530	1 270	2 530							
4.998 5.842 7.094 7.269 4.916 5.009 5.009 5.009 5.773 5.702 5.577	6 329	7 051 (Mit Pack)			5 842 (Mid-Peak																									
			4,998	5,842		6 070 4 570	7,094	7.008	6 335 4 835				5 773 4 273		5 577 4 077	4,898	5,109													

	Α	ВС	D	E	F	G	Н	ı	J	K	L	М	N	0	$oldsymbol{oldsymbol{oldsymbol{\Box}}}$
1	لَــا		A												
			O GENERAL ELECTRIC												
	201	9 GRC I	Prices				B	.							+
4	\vdash	-		B1-	D	V-1 T	Demand	Demand	V-I	V-I	Value				
5	\vdash	+		Basic	Basic	Vol. Trans	Transmission	Transmission	Volumetric	Volumetric	Volumetric	Facilities	Facilities	Facilities	Dist
7	Gro	uping		Charge	Charge	& Related	& Related	& Related Price Block 2	Dist. Price Block 1	Dist. Price Block 2	Dist. Price Block 3	Facilities Price Block 1	Facilities Price Block 2	Facilities Price Block 3	Di
8	910	aping		Price 1-phase	Price 3-phase	Price	Price Block 1	Price Block 2	Price Block 1	Price Block 2	Luce Block 3	Price Block 1	Price Block 2	Price Block 3	Price
	Sch	edule 7	7	\$11.00	\$11.00	2.43	\$0.00	\$0.00	44.44	44.44	44.44	\$0.00	\$0.00	\$0.00	,
			5 Residentia	\$0.00	\$0.00	1.52	\$0.00	\$0.00	53.55	53.55	77.47	\$0.00	\$0.00	\$0.00	
11				+====	7		7.1.50	, , , ,	11111			72.30	720	, , , ,	+
12															
			5 Commercial	\$0.00	\$0.00	1.52	\$0.00	\$0.00	53.55	53.55		\$0.00	\$0.00	\$0.00	
	-	edule 3		\$20.00	\$29.00	2.06	\$0.00	\$0.00	40.45	13.00		\$0.00	\$0.00	\$0.00	
		edule 3		\$30.00	\$30.00	1.71	\$0.00	\$0.00	68.07	68.07		\$0.00	\$0.00	\$0.00	
		edule 4		\$37,00	\$37.00	2.13	\$0.00	\$0.00	106.84	86,84		\$0.00	\$0,00	\$0.00	
		edule 4		\$45.00	\$45.00	2.12	\$0.00	\$0.00	78.28	58,28		\$0.00	\$0.00	\$0.00	
		edule 8 edule 8		\$35.00	\$45,00 \$560,00	0.00	\$0.78 \$0.78	\$0.00	0.00	0.00		\$3,50 \$3,17	\$3.40 \$1.07	\$0.00 \$0.00	
		edule 8 edule 8			\$3,340,00	0.00	\$0.78	\$0.00 \$0.00	0.00	0,00		\$3.17	\$1 . 97 \$1 . 53	\$1,22	
		edule 9		\$0.00	\$0.00	1,52	\$0.00	\$0.00	61.31	61,31		\$0.00	\$0.00	\$0.00	
		edule 9		\$0.00	\$0.00	1.59	\$0.00	\$0.00	28.15	28.15		\$0.00	\$0.00	\$0.00	
		edule 9		\$0.00	\$0.00	1.52	\$0.00	\$0.00	61.31	61.31		\$0.00	\$0.00	\$0.00	
24															
25															
		edule 8			\$470.00	0.00	\$0.76	\$0.00	0.00	0.00		\$3.10	\$1.90	\$0.00	
	-	edule 8			\$1,890.00	0.00	\$0.76	\$0.00	0.00	0.00		\$1.49	\$1.49	\$1.18	
	Sch	edule 9	10-P		\$6,100.00	0.00	\$0.76	\$0.00	0.00	0.00		\$1.61	\$1.61	\$1.30	1
29	\vdash	+													+
30	Sah	edule 8	10. T		\$3,970.00	0.00	\$0.75	\$0.00	0.00	0.00		\$1.49	\$1.49	\$1.18	
		edule 7		+	\$3,970.00	0.00	\$0.75	\$0.00	0.00	0.00		\$1.49	\$1.49	\$1.18	
		edule 7		+	\$3,970.00	0.00	\$0.75	\$0.00	0.00	0.00		\$1,49	\$1,49	\$1.18	
34					75,01010	0.00	\$0170	\$5,50	3,50	5,50		\$1,70	4.1.10	\$.110	+
35	\Box														
			85-S V2003	\$0.00	\$560.00	0.00	\$0,00	\$0.00	0.00	0,00		\$3.17	\$1.97	\$0.00	J
			185-S V2010	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			185-S V2011	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			185-S V2012	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			185-S V2013	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			185-S V2014 185-S V2015	\$0.00 \$0.00	\$560.00 \$560.00	0.00	\$0.00 \$0.00	\$0.00 \$0.00	0.00	0.00		\$3.17 \$3.17	\$1 <u>.</u> 97 \$1 <u>.</u> 97	\$0.00 \$0.00	
			185-S V2016	\$0.00	\$560.00 \$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			185-S V2017	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			185-S V2018	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
			85-S V2019	\$0.00	\$560.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.17	\$1.97	\$0.00	
47	Sch	edule 4	189-S V2014	\$0.00	\$3,340.00	0.00	\$0.00	\$0.00	0.00	0.00		\$1.53	\$1.53	\$1.22	2
48															
49	\Box														\perp
			185-P V2010	\$0.00	\$470.00	0.00	\$0.00	\$0.00	0,00	0,00		\$3.10	\$1.90	\$0.00	
			185-P V2011	\$0.00		0.00	\$0.00		0.00	0.00		\$3.10			
			185-P V2012 185-P V2013	\$0.00 \$0.00		0.00	\$0.00 \$0.00	\$0.00	0.00	0,00		\$3.10	\$1 . 90 \$1 . 90	\$0.00 \$0.00	
			185-P V2013	\$0.00		0.00	\$0.00	\$0.00 \$0.00	0.00	0.00		\$3.10 \$3.10	\$1.90	\$0.00	
			185-P V2015	\$0.00	\$470.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.10	\$1.90	\$0.00	
			185-P V2016	\$0.00	\$470.00	0.00	\$0.00	\$0.00	0.00	0.00		\$3.10	\$1.90	\$0.00	
			85-P V2017	\$0.00	_	0.00	\$0.00	\$0.00	0.00	0.00		\$3.10	\$1.90	\$0.00	_
			85-P V2018	\$0.00		0.00	\$0.00	\$0.00	0.00	0.00		\$3.10	\$1.90	\$0.00	
			185-P V2019	\$0.00		0.00	\$0.00	\$0.00	0.00	0.00		\$3.10	\$1.90	\$0.00	
_			189-P V2004	\$0.00		0.00	\$0.00	\$0.00	0.00	0.00		\$1.49	\$1.49	\$1.18	
			189-P V2010	\$0.00		0.00	\$0.00	\$0.00	0.00	0.00		\$1.49	\$1.49		
62	Sch	edule 4	189-P V2011	\$0.00	\$1,890.00	0.00	\$0.00	\$0.00	0.00	0.00		\$1.49	\$1.49	\$1.18	j

\Box	Α	В	C D	Х	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	Al	AJ	AK	工
1	Ļ	\Box	NB AEVES															\perp
-			ND GENERAL ELECTRIC										ļ					\bot
-	201	9 GR	C Prices															+
4	\vdash	_		0#	14/1											0-b 400	0-1-100	+
5	\vdash	_		Off-peak	Wheeling	Donath.	Eine d	0-b 440	0-h 400	0 - h 4001	0-b 405	0-b 445	0-b 400	0 - k 4001	0-b 440	Sch 128	Sch 128	+
6 7	G-	Numine.	<u> </u>	Energy	Demand	Reactive	Fixed	Sch 146	Sch 122a	Sch 122b	Sch 125	Sch 145	Sch 132a	Sch 132b	Sch 143	Block 1	Block 2	+-
8	3	ouping	9	Price	Price	Price	Price	Price	Price	Price	Price	Price	Price	Price	Price	Price	Price	+
	90	nedule	0.7	0.00	\$0.00	\$0.00	0.00					0.26	(1.62)		(0.17)			+
$\overline{}$			e 15 Residential	0.00	\$0.00	\$0.00	103.18					0.20	(3.16)		(0.17)			+
11	-	Judie	- 10 110 Jimorisias	0.00	ψ0.00	\$0.50	100.10					5.20	(0.10)		(0.10)			+
12	\vdash			1														+
_	Sc	nedule	e 15 Commercial	0.00	\$0.00	\$0.00	103.18					0.20	(3.16)		(0.13)			\top
		nedule		0.00	\$0.00	\$0.00	0.00					0.24	(1.46)		(0.15)			\top
15	Sc	nedule	e 38	45.70	\$0.00	\$0.50	0.00					0.22	(1.79)		(0.14)			I
$\overline{}$	-	nedule		0.00	\$0,00	\$0,50	0.00					0,29	(2.72)		(0.18)			
-	_	nedule		0,00	\$0.00	\$0.50	0.00					0,29	(1.91)		(0.18)			\perp
	_		e 83-S	48.35	\$0,00	\$0.50	0.00					0,24	(1.12)		(0.15)			\perp
-	-		e 85-S	46,91	\$0.00	\$0.50	0.00					0,23	(0.96)		(0.15)			+
-			e 89-S	43.69	\$0.00	\$0.50	0.00					0,21	(0.76)		(0.14)			+
		nedule nedule		0.00	\$0.00	\$0.00	104.67 0.00					0.20	(3.13)		(0.13)			+
		nedule nedule		0.00	\$0.00 \$0.00	\$0.00 \$0.00	104.67					0.21	(1.02)		(0.13) (0.13)			+
24	30	edule	9.99	0.00	φυ.υυ	\$0.00	104.07					0.20	(3.13)		(0.13)			+
25	Н	+																+
-	Sc	nedule	e 85-P	45.86		\$0.50	0.00					0.22	(0.89)		(0.14)			+
-	-		e 89-P	42.73		\$0.50	0.00					0.21	(0.75)		(0.13)			\top
			e 90-P	40.77		\$0.50	0.00					0.20	(0.64)		(0.13)			\top
29																		
30																		
\blacksquare			e 89-T	42.02	\$0.00	\$0.50	0.00					0.21	(0.90)		(0.13)			
			e 75-T	42.02		\$0.50	0.00					0.21	(0.90)		(0.13)			_
	Sc	nedule	e 76R			\$0.50												+
34 35	\vdash	_																+
	Sc	neduk	e 485-S V2003	1	\$0,00	\$0.50	0.00						(0,23)		(0.15)			+-
	_		e 485-S V2010		\$0.00	\$0.50	0.00						(0.23)		(0.15)			+
	_		e 485-S V2011		\$0.00	\$0.50	0.00						(0.23)		(0.15)			+
			e 485-S V2012		\$0.00	\$0.50	0.00						(0.23)		(0.15)			\top
	_		e 485-S V2013		\$0.00	\$0.50	0.00						(0.23)		(0.15)			I
			e 485-S V2014		\$0.00	\$0.50	0.00						(0.23)	(0.18)	(0.15)			\perp
-	-		e 485-S V2015		\$0.00	\$0.50	0.00						(0.23)	· /	(0.15)			
			e 485-S V2016		\$0.00	\$0.50	0.00						(0.23)	(0.61)	(0.15)			\perp
-			e 485-S V2017		\$0.00	\$0.50	0.00						(0.23)		(0.15)			+
-	_		e 485-S V2018	1	\$0.00	\$0.50	0.00						(0.23)	. ,	(0.15)			+
			e 485-S V2019 e 489-S V2014	1	\$0.00 \$0.00	\$0.50 \$0.50	0.00						(0.23)		(0.15)			+
48	30	edule	6 403-3 ¥2014	1	φυ.υυ	\$0.50	0.00						(0.33)	(0.08)	(0.14)			+
49	\vdash	+																+
	Sc	nedule	e 485-P V2010	1	\$0.00	\$0,50	0.00						(0,17)		(0.14)			+
= :	_		e 485-P V2011		\$0.00	\$0,50	0.00						(0.17)		(0.14)			+
52	Sc	nedule	e 485-P V2012		\$0.00	\$0.50	0.00						(0.17)		(0.14)			\perp
			e 485-P V2013		\$0.00	\$0.50	0.00						(0.17)		(0.14)			
			e 485-P V2014		\$0.00	\$0.50	0.00						(0.17)		(0.14)			\perp
			e 485-P V2015		\$0.00	\$0.50	0.00						(0.17)		(0.14)			_
			e 485-P V2016		\$0.00	\$0.50	0.00						(0.17)		(0.14)			_
			e 485-P V2017		\$0.00	\$0.50	0.00						(0.17)		(0.14)			+
			e 485-P V2018	1	\$0.00	\$0.50 \$0.50	0.00						(0.17)		(0.14)			+
			e 485-P V2019 e 489-P V2004	1	\$0.00 \$0.00	\$0.50	0.00						(0.17) (0.11)		(0.14) (0.13)			+
			e 489-P V2010	1	\$0.00	\$0.50	0.00						(0.11)		(0.13)			+
			e 489-P V2010		\$0.00	\$0.50	0.00						(0.11)		(0.13)			+
02	90	cuult	0 TOO T VAUII		φυ.υυ	\$0.50	0.00						(0.11)		(0.13)			\bot

1	A B C	D	AT	AU	AV	AW
1						
		GENERAL ELECTRIC				
_	019 GRC F	Prices				
4						
5						
6			Sch 123	Sch 126	Sch 135	Sch 137
7 0	Grouping		Price	Price	Price	Price
8						
9 S	Schedule 7		2.00		0.44	0.47
10 S	Schedule 1	5 Residential	0.21		0.33	0.37
11						
12						
_		5 Commercial	0.21		0.33	0.3
	Schedule 3		(1.39)		0.40	0.4
15 S	Schedule 3	8	0.21		0.37	0.4
16 S	Schedule 4	7	0,21		0.48	0.5
_	Schedule 4		0,21		0.48	0.5
18 S	Schedule 8	3 - S	0.21		0.40	0.4
19 S	Schedule 8	5-S	0.21		0.38	0.4
20 S	Schedule 8	9 - S	0.21		0.36	0.4
21 S	Schedule 9	1	0.21		0.33	0.3
22 S	Schedule 9	2	0.21		0.35	0.3
23 S	Schedule 9	5	0.21		0.33	0.3
24						
25						
26 S	Schedule 8	5=P	0.21		0.38	0.4
	Schedule 8		0.21		0.35	0.3
_	Schedule 9	0-P	0.21		0.34	0.3
29						
30						
_	Schedule 8	9-T	0.21		0.35	0.39
	Schedule 7		0.21		0.35	0.3
	Schedule 7					
34						
35					-	
_	Schedule 4	85-S V2003	0.04			
		85-S V2010	0.04			
_		85-S V2011	0.04			
_		85-S V2012	0.04			
_		85-S V2013	0.04			
_		85-S V2014	0.04			
_		85-S V2015	0.04			
_		85-S V2016	0.04			
		85-S V2017	0.04			
_		85-S V2018	0.04		-	
		85-S V2019	0.04			
		89-S V2014	0.04			
48		-			-	
49						
_	Schedule 4	85-P V2010	0.04			
		85-P V2011	0.04			
		85-P V2012	0.04			
		85-P V2013	0.04			
_		85-P V2014	0,04			
_		85-P V2015	0.04			
_		85-P V2016	0.04			
_		85-P V2017	0.04		-	
_		85-P V2018	0.04		-	
_		85-P V2019	0.04			
_		89-P V2004	0.04		-	
		89-P V2004	0.04			
_		89-P V2010	0.04			
	ochedule 4	00-F VZUII	0.04			

20-483

		,	Ш		·	j		÷	_		L	Η				·	7			-	.00	A A	Air	At	×	ă		Ai	N	A	- 4			N N
Section Control																		=	Ш															
	Brid Brid	TAXOS TO	min Translation				To Man	No.			Spin-	244	800 B					erie De		1175	50/25 5	all law	1000		14.50			1 553		50.00 Ex	n 5075	10/10 10		500 500
Freis.	THE WHITE PER MANUAL																	NSA PS	N POL	PRO	PM.	FIG. FIG.	196	PRO PRO	NO.	-	ras ras	PRO	P. SE	196 19	n Pin	100 0	n Phi	ras ras
The second second	10 10	-	100	- 110	66		-	-	-	-	-	-	78	-	Ξ	-	-		•		=	_=		- 11		=	18 1	-		-	**			
TOTAL STREET	A10 A10	18	12 10	- 88	48	- 60	- 80	88	88	59	19	- 18	18	-		-	88	88 7			_	- 11		- 41			18			-	10 10	10		#11 #2E
														-	-		2.0	12.	-			⇉		- 1			#			200		161		
- Contract	MA .000	18	12 86	18	18	- 85	81	- 88	- 88	- 53	- 11	- 110	18	=	- 11	- 11	- 82	111	-		=	- 18		- 1		=	10	- 10		80	10 10	18		13 13
T months	58 59		9 65		42		- 63					- 10				- 19						- 1									10	16		=
-	20 50	18	100	60	44	- 60	- 50	50	50	- 10	100	-10	18		-	-	80	88 4				- 1		4.9			10			5.5		in		211 219
200 C	768		S 60		18		84			#3		- 18	18		- 11	Ī		88 8				- 58		- 49			18 6	98			18 18			E 85
	P.SEE	72	- HH	10	12		F-10	- 10	2750	F19	100				107	H in		H-4 1	-			- "		- 10			10	-		8.0	100	10	-	10
T 1000 100 100	6,000		S 88	18	18		611					- 18	18		11	100						- 56		- 41		=	18			88	16 16	12		18 18
2004	N-POLIS		DEC NO.	10	12		2.0	111	818	-			_	_			=	N. or	_		\rightarrow	_		_	=	_		_		_		_		
2 mark 2 m 100	E 101		22 50	18	12	83					- 12						88		4					- 13			10	1 10			10 10			
40000	20 100	- 100	2 22	- 12	18	- 59	- 88	- 60	#		- 12	=	_	_		=	- 10	-	-	=	\Rightarrow	_	=	- #	\vdash	_	-	15	=	-	8 18	- 2		_
2 may 12 mg	E8 1011		2 10	18	18		85																	- 1			110	- 18					*	
2 200 40 100	20 100	18	100	- 12	191	- 59	- 68	- 88	-	- 69	-		_				- 10	-	_	=	=	_	=	- #	=	=	10	- 12	I	-	100	- 6		
2000 10 MI	88 298	18	12 10	18	18	- 11	25	- ##	HH	62	- 12		_	_	-		83	88 1	-	=	=	_	=	- 13		_	40	- 18	=		10		*	=
-	EX 800						F5						_	_		=	80	E .	-		=	_		-	=		-19				10 10			_
2 Cod 17 CO	E8 838	- 12	2 12	- 18	10	100		- 22	-	- 50	- #	=	_	_	-	=	-	12	-	=	=	_	=	- #			## #	12		-				=
		100			181	100 100 100	- 22	- 10	-								- 001	12	-		=			-			***	18		-	10	- 6		_
	20 200	10	100 H 10	- 12	10		- 55	- 22	-	_	- #	=	_		=		8.0		-	=	=	_	=	- 1				- 12	=	-		- 12		=
	- 10 AM	70		- 12	10				- 11	22			_	=			9.0				7	-					72	- 1		-		- 10		=
	E 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	100	2 E	- 12	10												22	-	-								#	- 10		B TO		100		
	20 100	10		12	10		2.0	- 12	- 22	20							800	59	-		=			- #			#	- 1		-	12			
	20 K 20 K		2 60	- 12	18		- 55				- 5						90				==							1 15		10		- 6		
4																																		
E 100 (100 (100 (100 (100 (100 (100 (100			100 MM		100		6.0											64 1						- 43			12					12	100	

PORTLAND GENERAL ELECTRIC 2019 Price Changes relative to 2018 Prices

Grouping	Basic Charge Price 1-phase	Basic Charge Price 3-phase	Vol. Trans & Related Price	Demand Transmission & Related Price Block 1	Demand Transmission & Related Price Block 2	Volumetric Dist. Price Block 1	Volumetric Dist. Price Block 2
Schedule 7	\$0.00	\$0.00	0.34	\$0.00	\$0.00	3.58	3.58
Schedule 15 Residential	\$0.00	\$0.00	0.23	\$0.00	\$0.00	(1.75)	(1.75)
Schedule 15 Commercial	\$0.00	\$0.00	0.23	\$0.00	\$0.00	(1.75)	(1.75)
Schedule 32	\$3.00	\$6.00	0.30	\$0.00	\$0.00	0.57	6.00
Schedule 38 Schedule 47	\$5.00 \$2.00	\$5.00 \$2.00	0.25 0.31	\$0.00 \$0.00	\$0.00 \$0.00	(0.62) 2.23	(0.62) 2.23
Schedule 49	\$5.00	\$5.00	0.30	\$0.00	\$0.00	(1.27)	(1.27)
Schedule 83-S	\$5.00	\$5.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 85-S	\$0.00	\$60.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 89-S	\$0.00	\$180.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 91	\$0.00	\$0.00	0.23	\$0.00	\$0.00	2.23	2.23
Schedule 92 Schedule 95	\$0.00 \$0.00	\$0.00 \$0.00	0.23 0.23	\$0.00 \$0.00	\$0.00 \$0.00	0.43 2.23	0.43 2.23
Schedule 85-P	\$0.00	\$0.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 89-P	\$0.00	\$120.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 90-P	\$0.00	\$900.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 89-T	\$0.00	\$120.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 75-T	\$0.00	\$120.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 76R	\$0.00	\$120.00	0.00	\$0.13	\$0.00	0.00	0.00
Schedule 485-S V2003	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-S V2010 Schedule 485-S V2011	\$0.00 \$0.00	\$60.00 \$60.00	0.00 0.00	\$0.00 \$0.00	\$0.00 \$0.00	0.00 0.00	0.00 0.00
Schedule 485-S V2011	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-S V2013	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-S V2014	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-S V2015	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-S V2016	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-S V2017 Schedule 485-S V2018	\$0.00 \$0.00	\$60.00 \$60.00	0.00 0.00	\$0.00 \$0.00	\$0.00 \$0.00	0.00 0.00	0.00 0.00
Schedule 485-S V2019	\$0.00	\$60.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-S V2014	\$0.00	\$180.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2010	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2011	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2012	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2013 Schedule 485-P V2014	\$0.00 \$0.00	\$0.00 \$0.00	0.00 0.00	\$0.00 \$0.00	\$0.00 \$0.00	0.00 0.00	0.00
Schedule 485-P V2014	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2016	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2017	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2018	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 485-P V2019	\$0.00	\$0.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-P V2004 Schedule 489-P V2010	\$0.00 \$0.00	\$120.00 \$120.00	0.00 0.00	\$0.00 \$0.00	\$0.00 \$0.00	0.00 0.00	0.00 0.00
Schedule 489-P V2010	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-P V2012	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-P V2013	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-P V2014	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-P V2016 Schedule 489-P V2017	\$0.00 \$0.00	\$120.00 \$120.00	0.00 0.00	\$0.00 \$0.00	\$0.00 \$0.00	0.00 0.00	0.00 0.00
Schedule 489-P V2017 Schedule 489-P V2018	\$0.00	\$120.00 \$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-P V2019	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-T V2007	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-T V2012	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00
Schedule 489-T V2013	\$0.00	\$120.00	0.00	\$0.00	\$0.00	0.00	0.00

Volumetric Dist. Price Block 3	Facilities Price Block 1	Facilities Price Block 2	Facilities Price Block 3	Distribution Demand Price Block 1	Distribution Demand Price Block 2	Implicit System Usage Price	Block 1 Energy Price	Block 2 Energy Price	Block 3 Energy Price	Flat Energy Price
3.58	0.00	0.00	0.00	0.00	0.00	(0.07)	(1.81)	(1.81)	(1.81)	0.00
0.00	0.00	0.00	0.00	0.00	0.00	2.97	0.00	0.00	0.00	(1.56)
										` '
0.00	0.00	0.00	0.00	0.00	0.00	2.97	0.00	0.00	0.00	(1.56)
0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	(0.05) (0.15)	0.00 0.00	0.00 0.00	0.00 0.00	(1.58) 0.00
0.00	0.00	0.00	0.00	0.00	0.00	(0.13)	0.00	0.00	0.00	0.87
0.00	0.00	0.00	0.00	0.00	0.00	(0.13)	0.00	0.00	0.00	0.75
0.00	(0.11)	(0.11)	0.00	(0.07)	0.00	0.97	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.15)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	(1.01)	0.00	0.00	0.00	(1.56)
0.00	0.00	0.00	0.00	0.00	0.00	(0.11)	0.00	0.00	0.00	(0.93)
0.00	0.00	0.00	0.00	0.00	0.00	(1.01)	0.00	0.00	0.00	(1.56)
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.15)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	0.23	0.23	0.23	(0.07)	0.00	(0.15)	0.00	0.00	0.00	0.00
0.00	(0.00)	(0.00)	(0.00)	0.04	0.00	(0.40)	0.00	0.00	0.00	0.00
0.00 0.00	(0.06) (0.06)	(0.06) (0.06)	(0.06) (0.06)	0.01 0.01	0.00 0.00	(0.12) (0.12)	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00
0.00	(0.06)	(0.06)	(0.06)	0.01	0.00	0.00	0.00	0.00	0.00	0.00
0.00	(0.00)	(0.00)	(0.00)	0.01	0.00	0.00	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00 0.00	(0.22) (0.22)	(0.52) (0.52)	0.00 0.00	(0.07) (0.07)	0.00 0.00	(0.13) (0.13)	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.22)	(0.52)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.09)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00 0.00	(0.04) (0.04)	(0.34) (0.34)	0.00 0.00	(0.07) (0.07)	0.00 0.00	(0.13) (0.13)	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.04)	(0.34)	0.00	(0.07)	0.00	(0.13)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00 0.00	(0.06) (0.06)	(0.06) (0.06)	(0.06) (0.06)	(0.07) (0.07)	0.00 0.00	(0.10) (0.10)	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	(0.07)	0.00	(0.10)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	0.01	0.00	(0.09)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	0.01	0.00	(0.09)	0.00	0.00	0.00	0.00
0.00	(0.06)	(0.06)	(0.06)	0.01	0.00	(0.09)	0.00	0.00	0.00	0.00
	()	()	(- /-/		· · ·	()				

On-peak Energy Price	Off-peak Energy Price	Wheeling Demand Price	Reactive Price	Fixed Price	Sch 146 Price	Sch 122a Price	Sch 122b Price	Sch 125 Price	Sch 145 Price	Sch 143 Price	Sch 128 Block 1 Price	Sch 128 Block 2 Price
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.02	0.00	0.00
0.00	0.00	0.00	0.00	(1.50)	0.00	0.00	0.00	0.00	(0.01)	0.02	0.00	0.00
0.00	0.00	0.00	0.00	(1.00)	0.00	0.00	0.00	0.00	(0.02)	0.02	0.00	0.00
0.00	0.00	0.00	0.00	(1.50)	0.00	0.00	0.00	0.00	(0.02)	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.02	0.00	0.00
0.78	(4.22)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
(0.98)	(0.98)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.02	0.00	0.00
(0.78)	(0.78)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.01)	0.02	0.00	0.00
(1.32)	(1.32)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.03	0.00	0.00
0.00	0.00	0.00	0.00	2.06	0.00	0.00	0.00	0.00	(0.02)	0.02	0.00	0.00
0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 2.06	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	(0.01)	0.02 0.02	0.00 0.00	0.00 0.00
0.00	0.00	0.00	0.00	2.06	0.00	0.00	0.00	0.00	(0.02)	0.02	0.00	0.00
(0.77)	(0.77)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.03	0.00	0.00
(1.30)	(1.30)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.03	0.00	0.00
(1.50)	(1.50)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.02	0.00	0.00
(1.28)	(1.28)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.03	0.00	0.00
(1.28)	(1.28)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	(0.02)	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.02 0.02	0.00 0.00	0.00 0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.00 0.00	0.03 0.03	0.00 0.00	0.00 0.00
0.00 0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00

Sch 129 Price	Sch 102 Block 1 Price	Sch 102 Block 2 Price	Sch 102 Block 3 Price	Sch 105 Price	Sch 109 Price	Sch 110 Price	Sch 144 Price	Sch 123 Price	Sch 126 Price	Sch 135 Price	Sch 137 Price
0.00	0.94	0.94	(4.0E)	0.29	(0.06)	0.00	0.00	1.01	0.00	0.30	0.00
0.00	(0.16)	0.00	(4.95) 0.00	0.49	(0.96) (1.43)	0.00	0.00	1.91 0.29	0.00	0.30	0.00
0.00	(0.16)	0.00	0.00	0.49	(1.43)	0.00	0.00	0.29	0.00	0.22	0.00
0.00	(0.16)	0.00	0.00	0.27	(0.93)	0.00	0.00	(0.69)	0.00	0.27	0.00
0.00	(0.16)	0.00	0.00	0.37	(1.10)	0.00	0.00	0.29	0.00	0.25	0.00
0.00 0.00	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.45 0.40	(1.56) (1.05)	0.00 0.00	0.00 0.00	0.29 0.29	0.00 0.00	0.33 0.33	0.00 0.00
0.00	(0.16)	0.00	0.00	0.40	(0.88)	0.00	0.00	0.29	0.00	0.33	0.00
0.00	(0.16)	0.00	0.00	0.26	(0.78)	0.00	0.00	0.29	0.00	0.26	0.00
0.00	(0.16)	0.00	0.00	0.24	(1.41)	0.00	0.00	0.29	0.00	0.24	0.00
0.00	0.00	0.00	0.00	0.56	(0.61)	0.00	0.00	0.29	0.00	0.22	0.00
0.00	0.00	0.00	0.00	0.26	(0.65)	0.00	0.00	0.29	0.00	0.24	0.00
0.00	0.00	0.00	0.00	0.56	(0.61)	0.00	0.00	0.29	0.00	0.22	0.00
0.00	(0.16)	0.00	0.00	0.26	(0.78)	0.00	0.00	0.29	0.00	0.26	0.00
0.00 0.00	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.24 0.23	(1.41) (1.41)	0.00 0.00	0.00 0.00	0.29 0.29	0.00 0.00	0.23 0.23	0.00 0.00
0.00	(0.10)	0.00	0.00	0.20	(1.41)	0.00	0.00	0.23	0.00	0.23	0.00
0.00	0.00	0.00	0.00	0.24	(1.41)	0.00	0.00	0.29	0.00	0.23	0.00
0.00	0.00	0.00	0.00	0.24	(1.41)	0.00	0.00	0.29	0.00	0.23	0.00
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00 0.00	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.19 0.19	(0.78) (0.78)	0.00 0.00	0.00 0.00	0.06 0.06	0.00 0.00	0.00 0.00	0.00 0.00
(11.54)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(1.75)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(1.75)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(2.67)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(2.67) 0.00	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.19 0.19	(0.78) (0.78)	0.00 0.00	0.00 0.00	0.06 0.06	0.00 0.00	0.00 0.00	0.00 0.00
(4.83)	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(11.47)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(1.73) (1.73)	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.19 0.19	(0.78) (0.78)	0.00 0.00	0.00 0.00	0.06 0.06	0.00 0.00	0.00 0.00	0.00 0.00
(2.63)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
(2.63)	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.19	(0.78)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
0.00 0.00	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.17 0.17	(1.41) (1.41)	0.00 0.00	0.00 0.00	0.06 0.06	0.00 0.00	0.00 0.00	0.00 0.00
0.00	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
(9.21)	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
(1.57)	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
(2.42) (2.42)	(0.16) (0.16)	0.00 0.00	0.00 0.00	0.17 0.17	(1.41) (1.41)	0.00 0.00	0.00 0.00	0.06 0.06	0.00 0.00	0.00 0.00	0.00 0.00
0.00	(0.16)	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	0.00	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	0.00	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00
0.00	0.00	0.00	0.00	0.17	(1.41)	0.00	0.00	0.06	0.00	0.00	0.00

PORTLAND GENERAL ELECTRIC Changes in Revenues Resulting from 2019 Price Changes (\$000)

Category	2018 Current	2019 Proposed	Change
COS/VPO	\$1,778,702	\$1,791,220	\$12,517
Direct Access	\$40,656	\$40,289	(\$367)
Adjust for Employee Discount Base Rate Delta		<u>\$37</u>	
Cycle Totals	\$1,819,359	\$1,831,545	
Calendar Adjustment	0.99996	0.99996	
Calendar Basis Retail Revenues	\$1,819,294	\$1,831,480	\$12,186

Reconciliation of Revenues and Revenue Requirement

Revenue Requirement	\$1,831,381
Calendar Revenues	\$1,831,480
Base Rate Difference Schedule 146 Total	\$100 <u>\$0</u> \$100
FF VTOU Rate Design CIO Total Adjust Delta to Calendar	\$0 (<mark>\$9</mark>) \$78 <u>\$31</u> \$100 \$100

Contribution to 2019 System Peak by COS Rate Schedule

														12-CP	4-CP	12-CP
Schedule	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Sum		Percent	Percent
Sch 7	1,814.5	1,661.1	1,384.1	1,256.6	1,124.9	1,180.7	1,538.1	1,658.6	1,235.0	1,170.1	1,504.0	1,937.6	17,465.3	1,455.4	52.97%	49.70%
Sch 15	4.1	4.2	2.7	0.0	0.0	0.0	0.0	0.0	0.0	2.8	4.1	4.1	22.0	1.8	0.06%	0.06%
Sch 32	244.4	250.9	229.8	220.4	258.9	283.7	318.5	321.5	284.9	230.9	252.3	276.1	3,172.3	264.4	8.85%	9.03%
Sch 38	3.2	5.4	6.4	4.1	3.0	2.3	4.1	3.5	3.0	5.1	5.1	4.7	50.0	4.2	0.12%	0.14%
Sch 47	0.6	0.7	0.7	0.9	2.1	6.3	11.5	11.4	6.4	0.9	0.4	0.4	42.3	3.5	0.18%	0.12%
Sch 49	0.5	0.8	1.5	1.8	6.3	22.1	37.4	31.9	20.1	1.5	0.7	0.5	125.3	10.4	0.54%	0.36%
Sch 83	340.2	443.1	381.5	419.6	502.5	587.3	596.4	600.6	539.8	417.7	414.3	463.4	5,706.3	475.5	15.25%	16.24%
Sch 85	320.6	394.6	365.3	398.0	448.1	493.2	504.0	502.9	442.1	381.8	375.1	371.6	4,997.3	416.4	12.95%	14.22%
Sch 89	55.7	59.9	56.2	56.6	60.6	62.2	59.1	66.0	64.5	57.8	54.2	46.1	699.1	58.3	1.73%	1.99%
Sch 90	214.2	227.7	214.7	217.1	232.2	242.2	248.3	253.6	249.4	229.3	237.9	221.5	2,788.0	232.3	7.15%	7.93%
Sch 91/95	13.1	13.6	8.8	0.0	0.0	0.0	0.0	0.0	0.0	9.0	13.1	13.1	70.6	5.9	0.20%	0.20%
Sch 92	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	3.7	0.3	0.01%	0.01%
Totals	3.011.3	3.062.4	2.652.1	2.575.5	2.638.9	2.880.2	3.317.7	3.450.3	2.845.5	2,507.1	2.861.5	3.339.6	35.142.1	2.928.5	100.0%	100.0%

		Generation	
		Capacity	Substations
2021	1	0	0
2022	2	0	0
2023	3	0	0
2024	4	0	0
2025	5	1	0
2026	6	1	0
2027	7	1	0
2028	8	1	0
2029	9	1	0
2030	10	1	0
2031	11	1	0
2032	12	1	0
2033	13	1	0
2034	14	1	0
2035	15	1	0
2036	16	1	0
2037	17	1	1
2038	18	1	1
2039	19	1	1
2040	20	1	1
		0.77	0.17
		•	3

Inflation 2.05%

PORTLAND GENERAL ELECTRIC ALLOCATION OF GENERATION REVENUE REQUIREMENT TO COS CUSTOMERS 2019

Schedules	COS Calendar Energy	Marginal Energy Costs (\$000)	Generation Capacity Allocation	Marginal Capacity Costs (\$000)	Marginal Capacity & Energy Costs (\$000)	Capacity & Energy Allocation Percent	Allocation of Load Following (\$000)	Allocated Capacity & Energy Costs (\$000)	Cycle Basis Costs (\$000)	Cycle Basis Pct.	Capacity Marginal Costs	Energy Marginal Costs	Capacity Percent	Energy Percent
Schedule 7	7,568,915	\$307,309	52.97%	\$186,172	\$493,481	47.23%	\$773	\$488,086	\$488,086	47.3%	\$186,172	\$307,309	37.7%	62.3%
Schedule 15	15,774	\$562	0.06%	\$219	\$781	0.07%	\$1	\$773	\$773	0.1%	\$219	\$562	28.0%	72.0%
Schedule 32	1,631,912	\$65,236	8.85%	\$31,089	\$96,325	9.22%	\$151	\$95,272	\$95,345	9.2%	\$31,089	\$65,236	32.3%	67.7%
Schedule 38	31,497	\$1,298	0.12%	\$416	\$1,715	0.16%	\$3	\$1,696	\$1,695	0.2%	\$416	\$1,298	24.3%	75.7%
Schedule 47	21,670	\$912	0.18%	\$643	\$1,554	0.15%	\$2	\$1,537	\$1,535	0.1%	\$643	\$912	41.3%	58.7%
Schedule 49	64,510	\$2,725	0.54%	\$1,885	\$4,610	0.44%	\$7	\$4,560	\$4,562	0.4%	\$1,885	\$2,725	40.9%	59.1%
Schedule 83	2,887,308	\$116,524	15.25%	\$53,601	\$170,124	16.28%	\$266	\$168,264	\$168,128	16.3%	\$53,601	\$116,524	31.5%	68.5%
Schedule 85	2,714,651	\$107,903	12.95%	\$45,523	\$153,426	14.68%	\$1,707	\$153,216	\$153,171	14.8%	\$45,523	\$107,903	29.7%	70.3%
Schedule 89	454,957	\$17,521	1.73%	\$6,081	\$23,602	2.26%	\$209	\$23,515	\$23,979	2.3%	\$6,081	\$17,521	25.8%	74.2%
Schedule 90	1,867,228	\$71,461	7.15%	\$25,119	\$96,579	9.24%	(\$3,124)	\$92,248	\$91,944	8.9%	\$25,119	\$71,461	26.0%	74.0%
Schedule 91/95	50,583	\$1,803	0.20%	\$702	\$2,505	0.24%	\$4	\$2,478	\$2,478	0.2%	\$702	\$1,803	28.0%	72.0%
Schedule 92	2,496	\$97	0.01%	\$32	\$129	0.01%	\$0	\$128	\$128	0.0%	\$32	\$97	24.9%	75.1%
TOTAL	17,311,501	\$693,350	100.0%	\$351,482	\$1,044,832	100.00%	(\$0)	\$1,031,772	\$1,031,821		\$351,482	\$693,350	33.6%	66.4%
Simple Cycle Proxy Projected Peak Load Marginal Capacity C	d			\$101.87 3,450 \$351,482		TARGET		\$1,031,772						

PORTLAND GENERAL ELECTRIC Marginal Energy Costs: 2019 Test Period

Schedules	Marginal Energy Cost	Energy Percent
	# 007.000.074	44.000/
Schedule 7	\$307,308,874	44.32%
Schedule 15	\$562,193	0.08%
Schedule 32	\$65,235,679	9.41%
Schedule 38	\$1,298,219	0.19%
Schedule 47	\$911,680	0.13%
Schedule 49	\$2,725,411	0.39%
Schedule 83	\$116,523,932	16.81%
Schedule 85	\$107,903,245	15.56%
Schedule 89	\$17,520,672	2.53%
Schedule 90	\$71,460,657	10.31%
Schedule 91/95	\$1,802,803	0.26%
Schedule 92	\$96,792	0.01%
TOTAL	\$693,350,157	100.00%

Load Following/Integration Allocation

							UE 335	UE 335				
				UE 319	UE 319	UE 319	Settlement	Settlement	Total	Tota		
		Generation	Adjusted	Load follow	Load follow	Transfer	Load follow	Load follow	Load follow	Transfer		Cycle
Schedul	e Calendar MWh	Allocation	Allocation	Allocation	Price	Payment	Allocation	Price	Price	Payment	Cycle MWh	Revenues
Sch 7	7,568,915	47.23%	52.04%	\$772,717	0.10	\$772,717			0.10	\$772,717	7,568,918	\$772,717
Sch 15	15,774	0.07%	0.08%	\$1,223	0.08	\$1,223			0.08	\$1,223	15,774	\$1,223
Sch 32	1,631,912	9.22%	10.16%	\$150,830	0.09	\$150,830			0.09	\$150,830	1,633,156	\$150,945
Sch 38	31,497	0.16%	0.18%	\$2,685	0.09	\$2,685			0.09	\$2,685	31,475	\$2,683
Sch 47	21,670	0.15%	0.16%	\$2,434	0.11	\$2,434			0.11	\$2,434	21,633	\$2,430
Sch 49	64,510	0.44%	0.49%	\$7,219	0.11	\$7,219			0.11	\$7,219	64,540	\$7,222
Sch 83	2,887,308	16.28%	17.94%	\$266,389	0.09	\$266,389			0.09	\$266,389	2,884,961	\$266,173
Sch 85	2,714,651	14.68%	16.18%	\$240,242	0.09	\$240,242	\$1,467,240	0.54	0.63	\$1,707,482	2,713,846	\$1,706,976
Sch 89	454,957	2.26%	2.49%	\$259,326	0.57	\$259,326	(\$50,751)	(0.11)	0.46	\$208,575	463,935	\$212,691
Sch 90	1,867,228			(\$1,707,189)	(0.91)	(\$1,707,189)	(\$1,416,489)	(0.76	(1.67)	(\$3,123,679)	1,861,066	(\$3,113,371)
Sch 91/9	50,583	0.24%	0.26%	\$3,922	0.08	\$3,922			0.08	\$3,922	50,583	\$3,922
Sch 92	2,496	0.01%	0.01%	\$202	0.08	\$202			0.08	\$202	2,496	\$202
Totals	17,311,501	90.76%	100.00%	(\$0)		(\$0))				17,312,384	\$13,813

Load Following Allocation:

MWh 1,314,000

Price (mills/kWh) 1.13 (UE 319 settlement)

Allocation \$1,484,820

MWh 1,314,000

Price (mills/kWh) 0.25 (maximum price)

Allocation \$222,369

328,500

UE 335 Settlement Load Follow Allocation

		_		Change		
		Current	Proposed	Before	Equal %	
Schedule	MWh	Revenues	Revenues	Equalizing	Change	Difference
Sch 85	2,714,651	\$214,693,404	\$210,285,551	(\$4,407,853)	(\$4,406,789)	\$1,064
Sch 89	454,957	\$30,630,149	\$30,000,063	(\$630,086)	(\$628,713)	\$1,372
Sch 90	1,867,228	\$108,051,394	\$105,835,971	(\$2,215,423)	(\$2,217,859)	(\$2,436)
Total		\$353,374,946	\$346,121,585	(\$7,253,361)		
				-2.05%		

Fixed and NVPC Prices

		Generation	Generation		Fixed	Fixed	NVPC			
Schedule	Cal. MWh	Allocation	Fixed	NVPC	mills/kWh	Revenues	mills/kWh			
Sch 7	7,568,915	47.23%	\$316,561,014	\$170,751,844	41.82	\$316,532,034	22.56	64.38	\$170,754,727	\$487,286,761
Sch 15	15,774	0.07%	\$501,088	\$270,285	31.77	\$501,140	17.13	48.90	\$270,209	\$771,349
Sch 32	1,631,912	9.22%	\$61,791,153	\$33,329,920	37.86	\$61,784,176	20.42	58.28	\$33,323,637	\$95,107,813
Sch 38	31,497	0.16%	\$1,099,956	\$593,312	34.92	\$1,099,881	18.84	53.76	\$593,406	\$1,693,287
Sch 47	21,670	0.15%	\$997,052	\$537,806	46.01	\$997,042	24.82	70.83	\$537,852	\$1,534,894
Sch 49	64,510	0.44%	\$2,957,360	\$1,595,189	45.84	\$2,957,138	24.73	70.57	\$1,595,332	\$4,552,470
Sch 83	2,887,308	16.28%	\$109,132,384	\$58,865,606	37.80	\$109,140,257	20.39	58.19	\$58,872,218	\$168,012,475
Sch 85 - S	2,115,981	11.49%	\$77,016,237	\$41,542,274	36.40	\$77,021,717	19.63	56.03	\$41,536,711	\$118,558,428
Sch 85-P	598,670	3.19%	\$21,404,592	\$11,545,558	35.75	\$21,402,437	19.29	55.04	\$11,548,336	\$32,950,773
Sch 89-S	0	0.00%	\$0	\$0	33.97	\$0	18.32	52.29	\$0	\$0
Sch 89-P	392,599	1.95%	\$13,088,821	\$7,060,062	33.34	\$13,089,236	17.98	51.32	\$7,058,922	\$20,148,159
Sch 89-T	62,359	0.31%	\$2,051,246	\$1,106,434	32.89	\$2,050,980	17.74	50.63	\$1,106,245	\$3,157,225
Sch 90-P	1,867,228	9.24%	\$61,954,179	\$33,417,856	33.18	\$61,954,614	17.90	51.08	\$33,423,375	\$95,377,989
Sch 91/95	50,583	0.24%	\$1,606,866	\$866,738	31.77	\$1,607,022	17.13	48.90	\$866,487	\$2,473,509
Sch 92	2,496	0.01%	\$82,715	\$44,616	33.14	\$82,717	17.88	51.02	\$44,628	\$127,346
Totals	17,311,501	100.00%	\$670,244,663	\$361,527,500	38.72	\$670,220,391	20.88			

31.83

Category	Rev. Req.	Percent
Fixed	\$670,245	64.96%
Variab l e	\$361,528	<u>35.04%</u>
Total	\$1,031,772	100.00%

Busbar Loads

Sch 85-S	2,260,926
Sch 85-P	628,364
Sch 89-S	0
Sch 89-P	412,071
Sch 89 - T	64,579
Totals	3.365.940

PORTLAND GENERAL ELECTRIC ALLOCATION OF TRANSMISSION REVENUE REQUIREMENT

Schedules	12 CP MW	Unit Marginal Cost	Marginal Cost	Transmission Allocation Percent	Class Revenue Requirement
Schedule 7	1,455.4	\$11.98	\$17,436	49.70%	\$16,084
Schedule 15	1.8	\$11.98	\$22	0.06%	\$20
Schedule 32	264.4	\$11.98	\$3,167	9.03%	\$2,921
Schedule 38	4.2	\$11.98	\$50	0.14%	\$46
Schedule 47	3.5	\$11.98	\$42	0.12%	\$39
Schedule 49	10.4	\$11.98	\$125	0.36%	\$115
Schedule 83	475.5	\$11.98	\$5,697	16.24%	\$5,255
Schedule 85	416.4	\$11.98	\$4,989	14.22%	\$4,602
Schedule 89	58.3	\$11.98	\$698	1.99%	\$644
Schedule 90-P	232.3	\$11.98	\$2,783	7.93%	\$2,568
Schedules 91/95	5.9	\$11.98	\$71	0.20%	\$65
Schedule 92	0.3	\$11.98	\$4	0.01%	\$3
Totals	2,928.5		\$35,084		
Target				100.00%	\$32,364
Unit Marginal Cost \$/kW		\$11.98			

PORTLAND GENERAL ELECTRIC ALLOCATION OF ANCILLARY SERVICE REVENUE REQUIREMENT 2019

Schedules	Production Allocation Percent	Class Revenue Requirement
Schedule 7	47.23%	\$2,282
Schedule 15	0.07%	\$4
Schedule 32	9.22%	\$445
Schedule 38	0.16%	\$8
Schedule 47	0.15%	\$7
Schedule 49	0.44%	\$21
Schedule 83	16.28%	\$787
Schedule 85	14.68%	\$710
Schedule 89	2.26%	\$109
Schedule 90-P	9.24%	\$447
Schedules 91/95	0.24%	\$12
Schedule 92	0.01%	\$1
TOTAL	100.00%	\$4,832
	TARGET	\$4,832

PORTLAND GENERAL ELECTRIC Calculation of Generation Revenues for Trojan Allocation

	2019	Proposed	2019 Base
	Cycle	Energy	Energy
Schedule	MWh	Price	Revenues
Sch 7			
Block 1	6,290,496	63.29	\$398,125,480
Block 2	1,278,422	70.51	\$90,141,551
Sch 15	15,774	48.98	\$772,611
Sch 32	1,633,156	58.42	\$95,408,956
Sch 38			
On-peak	17,091	60.70	\$1,037,433
Off-peak	14,383	45.70	\$657,324
Sch 47	21,633	70.94	\$1,534,677
Sch 49	64,540	70,68	\$4,561,710
Sch 83-S			
On-peak	1,909,059	63.35	\$120,938,883
Off-peak	975,902	48.35	\$47,184,886
Sch 85-S			
On-peak	1,390,849	61.91	\$86,107,440
Off-peak	731,573	46.91	\$34,318,112
Sch 85-P			
On-peak	374,238	60.86	\$22,776,136
Off-peak	217,186	45.86	\$9,960,158
Sch 89-S			
On-peak	0	58.69	\$0
Off-peak	0	43.69	\$0
Sch 89-P			
On-peak	238,945	57.73	\$13,794,316
Off-peak	162,231	42.73	\$6,932,119
Sch 89-T			
On-peak	41,003	57.02	\$2,338,008
Off-peak	21,755	42.02	\$914,166
Sch 90-P			
On-peak	1,070,638	55.77	\$59,709,460
Off-peak	790,429	40.77	\$32,225,780
Sch 91/95	50,583	48.98	\$2,477,555
Sch 92	2,496	51.09	\$127,521
Totals	17,312,384		\$1,032,044,281

Note: includes DA priced at COS

	2019		2019 Base
	Cycle	Energy	Energy
Schedule	MWh	Price	Revenues
Sch 485-S			
On-peak	368,393	61.91	\$22,807,224
Off-peak	226,709	46.91	\$10,634,905
Sch 485-P			
On-peak	203,247	60.86	\$12,369,587
Off-peak	128,091	45.86	\$5,874,268
Sch 489-S GT 4 MW	1		
On-peak	8,771	58.69	\$514,779
Off-peak	4,711	43.69	\$205,816
Sch 489-P GT MW			
On-peak	559,151	57.73	\$32,279,764
Off-peak	401,882	42.73	\$17,172,439
Sch 489-T			
On-peak	110,242	57.02	\$6,285,993
Off-peak	76,929	42.02	\$3,232,575
Tota l s	2,088,126		\$111,377,350

ORDER NO. 20-483

PORTLAND GENERAL ELECTRIC ALLOCATION OF FRANCHISE FEES 2019

						Distribution	Transmission	Generation	Schedule 129	Tota
	Distribution	Transmission	Generation	Schedule 129	Subtotal	Fran. Fee	Fran, Fee	Fran Fee	Fran. Fee	Fran, Fee
Schedules	Allocations	Allocations	Allocations	Allocations	Allocations	Allocations	Allocations	Allocations	Allocations	Allocations
Schedule 7	\$440,429	\$18,367	\$488,086		\$946,881	\$11,330	\$472	\$12,556		\$24,358
Schedule 15	\$2,473	\$24	\$773		\$3,270	\$64	\$1	\$20		\$84
Schedule 32	\$87,137	\$3,367	\$95,345		\$185,848	\$2,242	\$87	\$2,453		\$4,781
Schedule 38	\$2,310	\$54	\$1,695		\$4,059	\$59	\$1	\$44		\$104
Schedule 47	\$2,711	\$46	\$1,535		\$4,292	\$70	\$1	\$39		\$110
Schedule 49	\$4,498	\$137	\$4,562		\$9,196	\$116	\$4	\$117		\$237
Schedule 83	\$84,410	\$6,042	\$168,128		\$258,580	\$2,171	\$155	\$4,325		\$6,652
Schedule 85	\$61,282	\$5,312	\$153,171	\$9,599	\$229,363	\$1,576	\$137	\$3,940	\$237	\$5,890
Schedule 89	\$12,819	\$1,085	\$23,979	\$11,152	\$49,035	\$330	\$28	\$617	\$297	\$1,271
Schedule 90-P	\$10,339	\$2,682	\$91,944		\$104,965	\$266	\$69	\$2,365		\$2,700
Schedules 91/95	\$8,400	\$77	\$2,478		\$10,954	\$216	\$2	\$64		\$282
Schedule 92	\$70	\$4	\$128		\$202	\$2	\$0	\$3		\$5
TOTALS	\$716,879	\$37,196	\$1,031,821	\$20,751	\$1,806,646	\$18,441	\$957	\$26,543	\$534	\$46,474

Franchise Fee Revenue Requirement

\$46,474

											Difference
	Distribution	Distribution	Transmission	Transmission	Generation	Generation	Schedule 129	Schedule 129	Total COS	Total DA	COS/DA
Schedu l es	MWh	mills/kWh	MWh	mills/kWh	MWh	mills/kWh	MWh	mills/kWh	mills/kWh	mills/kWh	mills/kWh
Schedule 7	7,568,918	1.50	7,568,918	0.06	7,568,918	1.66	0		3.22		
Schedule 15	15,774	4.03	15,774	0.04	15,774	1_26	0		5.33	4.03	1.30
Schedule 32	1,633,156	1.37	1,633,156	0.05	1,633,156	1_50	0		2.93	1.37	1.55
Schedule 38	31,475	1,89	31,475	0.04	31,475	1,39	0		3,32	1.89	1.43
Schedule 47	21,633	3.22	21,633	0.05	21,633	1.82	0		5.10		
Schedule 49	64,540	1.79	64,540	0.05	64,540	1_82	0		3.67	1.79	1.87
Schedule 83	2,884,961	0,75	2,884,961	0.05	2,884,961	1_50	0		2,31	0.75	1.55
Schedule 85-S	2,717,524	0.44	2,122,422	0.05	2,122,422	1.46	595,102	0.26	1.94	0.69	1.25
Schedule 89-S	13,482	0.21	0	0.06	0	1_36	13,482	0.26	1.63	0.46	1.16
Schedule 85-P	922,762	0.43	591,424	0.05	591,424	1.43	331,338	0.26	1,91	0.68	1.22
Schedule 89-P	1,362,209	0.20	401,176	0.06	401,176	1.33	961,033	0.26	1.60	0.46	1.14
Schedule 89-T	249,930	0.20	62,759	0.06	62,759	1_31	187,171	0.26	1.57	0.46	1.12
Schedule 90-P	1,861,066	0.14	1,861,066	0.04	1,861,066	1_27			1.45	0.14	1,31
Schedule 91/95	50,583	4.27	50,583	0.04	50,583	1_26	0		5.57	4_27	1.30
Schedule 92	2,496	0.73	2,496	0.04	2,496	1_31	0		2.08	0.73	1.36
TOTALS	19,400,511		17,312,384		17,312,384		2,088,126				

Revenues

Revenues			F F
Schedules	MWh	Fran. Fee mills/kWh	Fran, Fee Revenues
Schedule 7	7,568,918	3,22	\$24,358
Schedule 15	15,774	5.33	\$84
Schedule 32	1,633,156	2.93	\$4,781
Schedule 38	31,475	3,32	\$104
Schedule 47	21,633	5.10	\$110
Schedule 49	64,540	3.67	\$237
Schedule 83	2,884,961	2,31	\$6,652
Schedule 85-S	2,122,422	1.94	\$4,125
Schedule 485-S	595,102	0.69	\$411
Schedule 89-S	0	1.63	\$0
Schedule 489-S	13,482	0.46	\$6
Schedule 85-P	591,424	1.91	\$1,128
Schedule 485 P	331,338	0.68	\$226
Schedule 89-P	401,176	1,60	\$640
Schedule 489-P	961,033	0.46	\$441
Schedule 89-T	62,759	1.57	\$99
Schedule 489 T	187,171	0.46	\$85
Schedule 90-P	1,861,066	1.45	\$2,700
Schedule 91/95	50,583	5.57	\$282
Schedu l e 92	2,496	2.08	\$5
TOTALS	19,400,511		\$46,474

PORTLAND GENERAL ELECTRIC ALLOCATION OF TROJAN DECOMMISSIONING COSTS 2019

Schedules	Cycle Generation Revenues	Allocation Percent	Class Revenue Requirement	MWh	mills/kWh
Schedule 7	\$488,267,031	42.70%	\$811	7,568,918	0.11
Schedule 15	\$772,611	0.07%	\$1	15,774	0.08
Schedule 32	\$95,408,956	8.34%	\$159	1,633,156	0.10
Schedule 38	\$1,694,756	0.15%	\$3	31,475	0.09
Schedule 47	\$1,534,677	0.13%	\$3	21,633	0.12
Schedule 49	\$4,561,710	0.40%	\$8	64,540	0.12
Schedule 83	\$168,123,769	14.70%	\$279	2,884,961	0.10
Schedule 85-S	\$153,867,681	13.46%	\$256	2,717,524	0.09
Schedule 89-S	\$720,594	0.06%	\$1	13,482	0.09
Schedule 85-P	\$50,980,149	4.46%	\$85	922,762	0.09
Schedule 89-P	\$70,178,639	6.14%	\$117	1,362,209	0.09
Schedule 89-T	\$12,770,742	1.12%	\$21	249,930	0.08
Schedule 90-P	\$91,935,240	8.04%	\$153	1,861,066	0.08
Schedule 91/95	\$2,477,555	0.22%	\$4	50,583	0.08
Schedule 92	\$127,521	0.01%	\$0	2,496	0.08
TOTAL	\$1,143,421,631		\$1,900	19,400,511	
		TARGET	\$1,900		

PORTLAND GENERAL ELECTRIC ALLOCATION OF SCHEDULE 129 TRANSITION ADJUSTMENT 2019

Schedules	Cycle Energy	Percent	Allocations (\$000)	mills/kWh
Schedule 85-S	2,717,524	38.1%	\$0	0.00
Schedule 89-S	13,482	0.2%	\$0	0.00
Schedule 85-P	922,762	12.9%	\$0	0.00
Schedule 89-P	1,362,209	19.1%	\$0	0.00
Schedule 90-P	1,861,066	26.1%	\$0	0.00
Schedule 89-T	249,930	3.5%	\$0	0.00
TOTAL	7,126,974	100.00%	\$0	
		TARGET	\$0	0.00

ALLOCATION OF TRANSITION ADJUSTMENT FOR POST 2013 VINTAGE CUSTOMERS

	Cycle		Allocations	
Schedules	Energy	Percent	(\$000)	mills/kWh
Schedu l e 7	7,568,918	39.0%	(\$8,096)	(1.07)
Schedule 15	15,774	0.1%	(\$17)	(1.07)
Schedule 32	1,633,156	8.4%	(\$1,747)	(1.07)
Schedu l e 38	31,475	0.2%	(\$34)	(1.07)
Schedule 47	21,633	0.1%	(\$23)	(1.07)
Schedule 49	64,540	0.3%	(\$69)	(1.07)
Schedule 83	2,884,961	14.9%	(\$3,086)	(1.07)
Schedu l e 85-S	2,717,524	14.0%	(\$2,907)	(1.07)
Schedule 89-S	13,482	0.1%	(\$14)	(1.07)
Schedule 85-P	922,762	4.8%	(\$987)	(1.07)
Schedule 89	1,362,209	7.0%	(\$1,457)	(1.07)
Schedule 89-T	249,930	1.3%	(\$267)	(1.07)
Schedule 90-P	1,861,066	9.6%	(\$1,991)	(1.07)
Schedules 91/95	50,583	0.3%	(\$54)	(1.07)
Schedu l e 92	2,496	0.0%	(\$3)	(1.07)
TOTAL	19,400,511	100.00%	(\$20,751)	(1.07)
	•	TARGET	(\$20,751)	

		20	119			
Grouping		Usages	Units & Basis	Marginal Unit Cost	Marginal Cost Revenues	Class Revenue Requirement
Schedule 7 Resi						
CUSTOMER		=		440.40	0.5 0.0	A 04.400
	Single-Phase Customers		Customers	\$19.43	\$15,213	\$21,132
	Three-Phase Customers	15	Customers	\$58.07	\$1	\$1
	Transformer & Service Single-Phase Customers	782 066	Customers	\$83.97	\$65,746	\$91,324
	Three-Phase Customers		Customers	\$140.51	\$05,740	\$3
FACILITIES	Feeder Backbone					
TAGILITIES	Single-Phase Customers	2 034 751	kW, rateclass peak	\$20.41	\$41,529	\$57,687
	Three-Phase Customers		kW, rateclass peak	\$20.41	\$1	\$1
	Feeder Local Facilities	00	KVV, ratoolado poak	Ψ20.11	Ψ.	Ψ,
	Single-Phase Customers	3.131.864	Design Demand	\$20.10	\$62,950	\$87,442
	Three-Phase Customers		Design Demand	\$20.10	\$1	\$2
DEMAND	Outstand and in the	0.004.004	LAM materilana manda	#40.45	COE 004	#04.000
DEMAND	Subtransmission Substation		kW, rateclass peak kW, rateclass peak	\$12.15 \$12.24	\$25,081 \$24,906	\$34,839 \$34,596
	Substation	2,034,790	kvv, rateciass peak	φ12.24	\$24,900	φ34,590
SUBTOTAL					\$235,430	\$327,026
Schedule 15 Res	sidential Outdoor Area Lighting					
CUSTOMER	Customer Service	9,847	Lights	\$3.89	\$38	\$53
	Transformer & Service	9,847	Lights	\$2.89	\$28	\$40
FACILITIES	Feeder Backbone	931	kW, rateclass peak	\$21.38	\$18	\$25
FACILITIES	Feeder Local Facilities	831	· ·	\$20.78	\$17	\$25 \$24
	r ocuor Ecour r domineo	001	Boolgii Bolliana	Ψ20.70	Ψι	Ψ2.
DEMAND	Subtransmission		kW, rateclass peak	\$12.15	\$10	\$14
	Substation	831	kW, rateclass peak	\$12.24	\$10	\$14
FIXED	Luminaires & Poles					\$337
SUBTOTAL					\$122	\$506
Schedule 15 Cor	nmercial Outdoor Area Lighting					
CUSTOMER	Customer Service	10,600	Lights	\$3.89	\$41	\$57
	Transformer & Service	10,600	Lights	\$2.89	\$31	\$43
FACILITIES	Feeeder Backbone	3 187	kW, rateclass peak	\$21.38	\$68	\$95
17101211120	Feeder Local Facilities		Design Demand	\$20.78	\$66	\$92
DEMAND	Subtransmission	2 222	k/M rataalass paak	\$12.15	\$39	\$55
DEMAND	Substation		kW, rateclass peak kW, rateclass peak	\$12.13	\$39	\$55 \$54
		, ,	,	·	• • • •	
FIXED	Luminaires & Poles				***	\$1,291
SUBTOTAL					\$284	\$1,686
Schedule 15 Ou	tdoor Area Lighting					
CUSTOMER	Customer Service					\$110
	Transformer & Service					\$82
EACH ITIES	Foreder Doolsham					£440
FACILITIES	Feeeder Backbone Feeder Local Facilities					\$119 \$116
	reeder Local racinities					\$110
DEMAND	Subtransmission					\$69
	Substation					\$68
FIVES	Luccinaina Bal					04.000
FIXED SUBTOTAL	Luminaires & Poles					\$1,628
SUBTUTAL						\$2,192

		20	119			
Grouping		Usages	Units & Basis	Marginal Unit Cost	Marginal Cost Revenues	Class Revenue Requirement
Schodulo 32 Sm	nall Non-residential General Service					
CUSTOMER						
	Single-Phase Customers	56,001	Customers	\$17.23	\$965	\$1,340
	Three-Phase Customers	37,764	Customers	\$72.71	\$2,746	\$3,814
	Transformer & Service					
	Single-Phase Customers		Customers	\$150.15	\$8,409	\$11,680
	Three-Phase Customers	37,764	Customers	\$236.86	\$8,945	\$12,425
FACILITIES	Feeder Backbone			***		
	Single-Phase Customers		kW, rateclass peak	\$24.70	\$3,088	\$4,289
	Three-Phase Customers	199,163	kW, rateclass peak	\$24.70	\$4,919	\$6,833
	Feeder Local Facilities	000 000	D i D I	007.04	#7.000	#40.474
	Single-Phase Customers		Design Demand	\$27.24	\$7,322	\$10,171
	Three-Phase Customers	438,067	Design Demand	\$12.94	\$5,669	\$7,874
DEMAND	Subtransmission		kW, rateclass peak	\$12.15	\$3,996	\$5,550
	Substation	324,174	kW, rateclass peak	\$12.24	\$3,968	\$5,512
SUBTOTAL					\$50,026	\$69,489
Schedule 38 Ge	neral Service					
CUSTOMER	Meters					
	Single-Phase Customers	55	Customers	\$58.07	\$3	\$4
	Three-Phase Customers	328	Customers	\$130.80	\$43	\$60
	Transformer & Service					
	Single-Phase Customers	55	Customers	\$196.72	\$11	\$15
	Three-Phase Customers	328	Customers	\$581.00	\$191	\$265
FACILITIES	Feeder Backbone					
	Single-Phase Customers		kW, rateclass peak	\$24.54	\$18	\$25
	Three-Phase Customers	13,029	kW, rateclass peak	\$24.54	\$320	\$444
	Feeder Local Facilities					
	Single-Phase Customers		Design Demand	\$26.38	\$69	\$96
	Three-Phase Customers	37,809	Design Demand	\$13.09	\$495	\$687
DEMAND	Subtransmission		kW, rateclass peak	\$12.15	\$170	\$236
	Substation	13,769	kW, rateclass peak	\$12.24	\$169	\$234
SUBTOTAL					\$1,488	\$2,067
	gation & Drainage Service - < 30 kW					
CUSTOMER		004	Customans	Φ Ε 7 7 0	#40	640
	Single-Phase Customers		Customers	\$57.73	\$13	\$18
	Three-Phase Customers	2,837	Customers	\$86.54	\$246	\$341
	Transformer & Service	004	Cuatamana	#40 77	ф О	^
	Single-Phase Customers		Customers	\$10.77	\$2	\$3
	Three-Phase Customers	2,837	Customers	\$21.43	\$61	\$84
FACILITIES	Feeder Backbone	500	kW ratodasa nask	\$24.70	\$12	\$17
	Single-Phase Customers Three-Phase Customers		kW, rateclass peak kW, rateclass peak		\$12 \$311	
	Feeder Local Facilities	12,591	rvv, rateciass peak	\$24.70	कुउ।।	\$432
	Single-Phase Customers	ა ვაი	Design Demand	\$23.90	\$56	\$77
	Three-Phase Customers		Design Demand	\$23.90 \$11.35	\$506	\$77 \$702
DEMAND	Subtransmission	13 280	kW, rateclass peak	\$12.15	\$161	\$224
DEMAND	Substation		kW, rateclass peak	\$12.13	\$160	\$223
	Cassialion	10,091	ATT, Tatodiass poak	Ψ12.24	Ψ100	ΨΖΖΟ
SUBTOTAL					\$1,528	\$2,122
002101/kL					\$1,020	Ψ2,122

		20	119			
Grouping		Usages	Units & Basis	Marginal Unit Cost	Marginal Cost Revenues	Class Revenue Requirement
Schedule 49 Irri	gation & Drainage Service - > 30 kW					
COSTONLIN	Single-Phase Customers	6	Customers	\$58.07	\$0	\$0
	Three-Phase Customers	-	Customers	\$71.36	\$90	\$126
	Transformer & Service	1,200	Customers	φ/1.30	\$90	\$120
		6	Customers	\$144.93	\$1	\$1
	Single-Phase Customers Three-Phase Customers			\$144.93		
	Three-Phase Customers	1,200	Customers	\$144.93	\$184	\$255
FACILITIES	Feeder Backbone					
AOILITILO	Single-Phase Customers	171	kW, rateclass peak	\$24.54	\$4	\$6
	Three-Phase Customers		kW, rateclass peak	\$24.54	\$886	\$1,230
	Feeder Local Facilities	30,003	KVV, rateciass peak	Ψ24.04	\$000	Ψ1,200
	Single-Phase Customers	223	Design Demand	\$24.34	\$5	\$8
	Three-Phase Customers		•	\$12.08		
	Three-Phase Customers	71,133	Design Demand	\$12.00	\$859	\$1,194
DEMAND	Subtransmission	36 782	kW, rateclass peak	\$12.15	\$447	\$621
DEMAND	Substation		kW, rateclass peak	\$12.24	\$444	\$616
	Substation	30,230	KW, rateciass peak	\$12.24	φ 444	φ010
SUBTOTAL					\$2,921	\$4,057
	neral Service (31-200 kW)					
CUSTOMER						
	Single-Phase Customers	683	Customers	\$57.73	\$39	\$55
	Three-Phase Customers	10,846	Customers	\$129.44	\$1,404	\$1,950
	Transformer & Service					
	Single-Phase Customers	683	Customers	\$388.14	\$265	\$368
	Three-Phase Customers	10,846	Customers	\$1,050.66	\$11,395	\$15,829
FACILITIES	Feeder Backbone					
FACILITIES		10 2/1	kW rataalaaa naak	\$24.54	\$450	\$625
	Single-Phase Customers		kW, rateclass peak	· ·		
	Three-Phase Customers	595,032	kW, rateclass peak	\$24.54	\$14,553	\$20,215
	Feeder Local Facilities	07.000	Danis Danis d	#00.00	Ф70 Г	#4.004
	Single-Phase Customers		Design Demand	\$26.38	\$735	\$1,021
	Three-Phase Customers	900,218	Design Demand	\$13.09	\$11,784	\$16,368
DEMAND	Subtransmission	620 238	kW, rateclass peak	\$12.15	\$7,536	\$10,468
52.00	Substation		kW, rateclass peak	\$12.24	\$7,483	\$10,395
	Cabolation	011,070	KTT, Tatoolado poak	Ψ12.21	ψ1,100	Ψ10,000
SUBTOTAL					\$55,645	\$77,294
Schadula 85 Ga	neral Service (201-4,000 kW)					
CUSTOMER	• • •					
CCCTOWLIN	Secondary Customers	1 300	Customers	\$162.33	\$227	\$315
	Primary Customers	,	Customers	\$1,805.54	\$427	\$593
		230	Customers	\$1,000.04	Φ42 1	φυθυ
	Transformer & Service	4 200	0	CO 440 00	#0.000	¢4.700
	Secondary Customers		Customers	\$2,419.89	\$3,386	\$4,703
	Primary Customers	236	Customers	\$0.00	\$0	\$0
FACILITIES	Feeder Backbone	674 496	kW, rateclass peak	\$19.54	\$13,180	\$18,307
TAGILITILO	Feeder Local Facilities		Design Demand	\$7.12	\$6,447	\$8,956
	1 Journ Local Lacillies	505,550	Design Demand	Ψ1.12	ΨΟ,++7	ψυ,330
DEMAND	Subtransmission	684 276	kW, rateclass peak	\$12.15	\$8,314	\$11,549
DEIMAIND						
	Substation	074,496	kW, rateclass peak	\$12.24	\$8,256	\$11,468
SUBTOTAL					\$40,236	\$55,890
SUBTUTAL					φ 4 υ,230	φ55,690

			119	Marginal Unit	Marginal Cost	Class Revenue
Grouping		Usages	Units & Basis	Cost	Revenues	Requirement
Schedule 89 Ger	neral Service (4,000 plus kW)					
CUSTOMER	Meters					
	Secondary Meters	1	Customers	\$175.85	\$0	\$0
	Primary Meters	26	Customers	\$1,809.13	\$47	\$65
	Substation Meters	8	Customers	\$19,774.56	\$158	\$220
	Transformer & Service					
	Secondary Customers	1	Customers	\$14,124.26	\$14	\$20
	Primary Customers	26	Customers	\$0.00	\$0	\$0
FACILITIES	Feeder Backbone					
	Secondary Customers	1	Customers	\$76,614.00	\$77	\$106
	Primary Customers	26	Customers	\$76,614.00	\$1,992	\$2,767
	Subtransmission 115 kV Feeder	8	Customers	\$77,041.00	\$616	\$856
DEMAND	Subtransmission	237,755	kW, rateclass peak	\$12.15	\$2,889	\$4,013
	Substation (Sec. & Prim. Only)	198,570	kW, rateclass peak	\$12.24	\$2,430	\$3,376
SUBTOTAL					\$8,224	\$11,423
Schedule 90 Prir	nary Voltage Service					
CUSTOMER	Meters					
	Primary Meters	4	Customers	\$1,805.54	\$7	\$10
FACILITIES	Feeder Backbone					
	Primary Customers	4	Customers	\$365,087.00	\$1,460	\$2,029
DEMAND	Subtransmission		kW, rateclass peak	\$12.15	\$3,040	\$4,222
	Substation (Sec. & Prim. Only)	246,600	kW, rateclass peak	\$12.24	\$3,018	\$4,193
SUBTOTAL					\$7,526	\$10,453
Schedules 91 &	95 Streetlighting & Highway Lighting					
CUSTOMER	Customer Service	155,807	Lights	\$3.89	\$605	\$841
	Transformer & Service	155,807	Lights	\$2.89	\$450	\$625
FACILITIES	Feeder Backbone		kW, rateclass peak	\$21.38	\$275	\$383
	Feeder Local Facilities	12,884	Design Demand	\$23.11	\$298	\$414
DEMAND	Subtransmission	13,071	,	\$12.15	\$159	\$221
	Substation	12,884	kW, rateclass peak	\$12.24	\$158	\$219
FIXED	Luminaires & Poles					\$5,294
SUBTOTAL					\$1,945	\$7,997

		20	119	Marginal	Marginal	Class
				Unit	Cost	Revenue
Grouping		Usages	Units & Basis	Cost	Revenues	Requirement
Schedule 92 Traf	ffic Signals					
CUSTOMER	Transformer & Service	1,248	Intersections	\$9.19	\$11	\$16
FACILITIES	Feeder Backbone	294	kW, rateclass peak	\$21.38	\$6	\$9
	Feeder Local Facilities	294	Design Demand	\$10.44	\$3	\$4
DEMAND	Subtransmission	298	kW, rateclass peak	\$12.15	\$4	\$5
	Substation	294	kW, rateclass peak	\$12.24	\$4	\$5
SUBTOTAL					\$28	\$39
Summary						
CUSTOMER	Meters Transformer & Service	894,667	Customers Customers		\$21,630 \$99.131	\$30,045 \$137.699
	Customer Service	176,254	Lights		\$685	\$951
FACILITIES	Feeder Backbone	3,725,145	kW, rateclass peak		\$83,784	\$116,380
	Feeder Local Facilities	5,848,265	Design Demand		\$97,283	\$135,132
DEMAND	Subtransmission	4,267,089	· · · · · · · · · · · · · · · · · · ·		\$51,845	\$72,016
	Substation	4,170,315	kW rateclass peak		\$51,045	\$70,904
FIXED	Luminaires & Poles					\$6,922
TOTALS					\$405,403	\$570,049
				EQUAL PERCENT	TARGET	\$570,049 138.9%

PORTLAND GENERAL ELECTRIC ALLOCATION OF UNCOLLECTIBLES 2019

	Marginal Cost Allocation	Class Revenue
Grouping	Percent	Requirement
Schedule 7		
Single Phase	92.60%	\$5,534
Three Phase	0.00%	\$0
Schedule 15		
Residential	0.47%	\$28
Commercial	0.34%	\$20
Schedule 32		
Single Phase	2.81%	\$168
Three Phase	1.89%	\$113
Schedule 38		
Single Phase	0.00%	\$0
Three Phase	0.00%	\$0
Schedule 47		
Single Phase	0.01%	\$0
Three Phase	0.09%	\$5
Schedule 49		
Single Phase	0.00%	\$0
Three Phase	0.09%	\$6
Schedule 83		
Single Phase	0.07%	\$4
Three Phase	1.05%	\$63
Schedule 85		
Secondary	0.50%	\$30
Primary	0.08%	\$5
Schedule 89		
Secondary	0.00%	\$0
Primary	0.00%	\$0
Subtransmission	0.00%	\$0
Schedule 90-P	0.00%	\$0
Schedules 91/95	0.00%	\$0
Schedule 92	0.00%	\$0
TOTAL	100.00%	\$5,977
	TARGET	\$5,977

20-483

		Marginal Unit Cost	Marginal Cost	Class Revenue
Grouping	Customers	\$ per Customer	Revenues	Requirement
Schedule 7				
Single Phase	782,966	\$0.31	\$243	\$6,796
Three Phase	15	\$0.31	\$0	\$0
Schedule 15				
Residential	5,491	\$0.00	\$0	\$0
Commercial	3,995	\$0.00	\$0	\$0
Schedule 32				
Single Phase	56,001	\$0.69	\$39	\$1,082
Three Phase	37,764	\$0.69	\$26	\$730
Schedule 38				
Single Phase	55	\$11.27	\$1	\$17
Three Phase	328	\$11.27	\$4	\$103
Schedule 47				
Single Phase	224	\$1.05	\$0	\$7
Three Phase	2,837	\$1.05	\$3	\$83
Schedule 49				
Single Phase	6	\$1.18	\$0	\$0
Three Phase	1,268	\$1.18	\$1	\$42
Schedule 83				
Single Phase	683	\$2.57	\$2	\$49
Three Phase	10,846	\$2.57	\$28	\$780
Schedule 85				
Secondary	1,399	\$11.93	\$17	\$467
Primary	236	\$11.93	\$3	\$79
Schedule 89				
Secondary	1	\$1.48	\$0	\$0
Primary	26	\$1.48	\$0	\$1
Subtransmission	8	\$1.48	\$0	\$0
Schedule 90-P	4	\$0.21	\$0	\$0
Schedules 91/95	203	\$0.00	\$0	\$0
Schedule 92	16	\$0.00	\$0	\$0
TOTAL	004 270		ተ ጋራር	¢ 40.220
TOTAL	904,372		\$366	\$10,238
		EQUAL PERCENT	TARGET	\$10,238 2800%

		Marginal Unit Cost	Marginal Cost	Class Revenue
Grouping	Customers	\$ per Customer	Revenues	Requirement
Schedule 7				
Single Phase	782,966	\$39.01	\$30,544	\$60,633
Three Phase	15	\$39.01	\$1	\$1
Cabadula 45				
Schedule 15 Residential	5,491	\$6.28	\$34	\$68
Commercial	3,995	\$8.06	\$34 \$32	\$64
Commercial	0,000	ψ0.00	ΨΟΖ	ΨΟΨ
Schedule 32				
Single Phase	56,001	\$33.09	\$1,853	\$3,679
Three Phase	37,764	\$33.09	\$1,250	\$2,481
Schedule 38				
Single Phase	55	\$41.14	\$2	\$4
Three Phase	328	\$41.14	\$13	\$27
		·	,	·
Schedule 47				
Single Phase	224	\$33.15	\$7	\$15
Three Phase	2,837	\$33.15	\$94	\$187
Schedule 49				
Single Phase	6	\$36.48	\$0	\$0
Three Phase	1,268	\$36.48	\$46	\$92
Schedule 83				
Single Phase	683	\$41.59	\$28	\$56
Three Phase	10,846	\$41.59	\$451	\$895
THI GOT THE GO	10,010	Ψ11100	Ψίσι	φοσο
Schedule 85				
Secondary	1,399	\$83.38	\$117	\$232
Primary	236	\$83.38	\$20	\$39
Schedule 89				
Secondary	1	\$181.76	\$0	\$0
Primary	26	\$181.76	\$5	\$9
Subtransmission	8	\$181.76	\$1	\$3
Schedule 90-P	4	\$17.96	\$0	\$0
Scriedule 30-1	4	ψ17.90	ΨΟ	ΨΟ
Schedules 91/95	203	\$984.82	\$200	\$397
Schedule 92	16	\$981.15	\$16	\$31
TOTAL	904,372		\$34,715	\$68,915
		EQUAL PERCENT	TARGET	\$68,915 199%

PORTLAND GENERAL ELECTRIC ALLOCATION OF CONSUMER REVENUE REQUIREMENT 2019

	_	Marginal Unit Cost	Marginal Cost	Class Revenue
Grouping	Customers	\$ per Customer	Revenues	Requirement
Schedule 7				
Single Phase	782,966	\$24.05	\$18,830	\$39,625
Three Phase	15	\$24.05	\$0	\$1
Schedule 15				
Residential	5,491	\$4.95	\$27	\$57
Commercial	3,995	\$4.95	\$20	\$42
Schedule 32				
Single Phase	56,001	\$46.82	\$2,622	\$5,517
Three Phase	37,764	\$46.82	\$2,022 \$1,768	\$3,721
Tillee Tillase	01,104	Ψ10.02	Ψ1,700	Ψ0,721
Schedule 38				*
Single Phase	55	\$109.69	\$6	\$13
Three Phase	328	\$109.69	\$36	\$76
Schedule 47				
Single Phase	224	\$44.91	\$10	\$21
Three Phase	2,837	\$44.91	\$127	\$268
Schedule 49				
Single Phase	6	\$109.48	\$1	\$1
Three Phase	1,268	\$109.48	\$139	\$292
Schedule 83				
Single Phase	683	\$205.64	\$140	\$295
Three Phase	10,846	\$205.64	\$2,230	\$4,693
Schedule 85				
Secondary	1,399	\$1,220.21	\$1,707	\$3,592
Primary	236	\$1,220.21	\$288	\$607
Schedule 89				
Secondary	1	\$9,411.51	\$9	\$20
Primary	26	\$9,411.51	\$245	\$515
Subtransmission	8	\$9,411.51	\$75	\$158
Schedule 90-P	4	\$33,521.59	\$134	\$282
Schedule 91/95	203	\$4.95	\$1	\$2
Schedule 92	16	\$4.95	\$0	\$0
TOTAL	904,372		\$28,418	\$59,800
		EQUAL PERCENT	TARGET	\$59,800 210%

PORTLAND GENERA ELECTRIC

Suballocation of Schedule 89/90 Costs Based on Billing Demand

Initial Cost Allocations

Cost Category	Sch 89	Sch 90	Totals
Transmission	\$644	\$2,568	\$3,211
Ancillary	\$109	\$447	\$556
Subtransmission	\$4,013	\$4,222	\$8,235
Substations	\$3,376	\$4,193	\$7,569
Totals	\$8,142	\$11,429	\$19,571

Billing Demand

Cost Category	Sch 89	Sch 90	Totals
Transmission	1,093,010	2,701,624	3,794,634
Ancillary	1,093,010	2,701,624	3,794,634
Subtransmission	3,054,153	2,701,624	5,755,777
Substations	2,410,228	2,701,624	5,111,852

Reallocation of Costs

Cost Category	Sch 89	Sch 90	Tota l s
Transmission	\$925	\$2,286	\$3,211
Ancillary	\$160	\$396	\$556
Subtransmission	\$4,370	\$3,865	\$8,235
Substations	\$3,569	\$4,000	\$7,569
Totals	\$9,023	\$10,547	\$19,571

PORTLAND GENERAL ELECTRIC RATE DESIGN INPUT SUMMARY - ALLOCATION OF 2019 COSTS TO RATE SCHEDULES (\$000)

		Enero	y-Based Cha	raes		Trans. &	Related C	harges		Distribution D	emand & Fa	cilities Charg	ies		
	Power	Franchise	,				Ancillary				Feeder	Feeder	,,,,,		
Grouping	Supply	Fees	Trojan	Sch 129	Subtotal	Transmission	Services	Subtota	Substation	Subtrans.	Backbone	Facilities	Subtotal	Subtotal	Total
Schedu l e 7	\$488,086	\$24,358	\$811	(\$8,096)	\$17,073	\$16,084	\$2,282	\$18,367	\$34,596	\$34,839	\$57,688	\$87,443	\$214,566	\$738,092	\$963,143
Schedule 15	\$773	\$84	\$1	(\$17)	\$69	\$20	\$4	\$24	\$68	\$69	\$119	\$116	\$372	\$1,237	\$3,337
Schedule 32	\$95,345	\$4,781	\$159	(\$1,747)	\$3,192	\$2,921	\$445	\$3,367	\$5,512	\$5,550	\$11,122	\$18,045	\$40,229	\$142,133	\$188,882
Schedule 38	\$1,695	\$104	\$3	(\$34)	\$74	\$46	\$8	\$54	\$234	\$236	\$469	\$784	\$1,723	\$3,545	\$4,130
Schedule 47	\$1,535	\$110	\$3	(\$23)	\$90	\$39	\$7	\$46	\$223	\$224	\$449	\$780	\$1,675	\$3,346	\$4,379
Schedule 49	\$4,562	\$237	\$8	(\$69)	\$175	\$115	\$21	\$137	\$616	\$621	\$1,236	\$1,201	\$3,674	\$8,548	\$9,364
Schedule 83 Secondary	\$168,128	\$6,652	\$279	(\$3,086)	\$3,845	\$5,255	\$787	\$6,042	\$10,395	\$10,468	\$20,840	\$17,389	\$59,092	\$237,107	\$262,146
Schedule 85 Secondary Primary Class Total	\$153,171	\$4,536 \$1,354	\$256 \$85	(\$2,907) (\$987)		\$4,602	\$710	\$5,312	\$11,468	\$11,549	\$18,307	\$8,956	\$50,279	\$1,885 \$452 \$208,762	\$11,225 \$1,774 \$208,762
Schedule 89 Secondary Primary Subtransmission Class Total	\$23,979	\$6 \$1,081 \$184	\$1 \$117 \$21	(\$14) (\$1,457) (\$267)	(\$259)		\$160	\$1,085	\$3,569	\$4,370	\$106 \$2,767 \$856		\$106 \$2,767 \$856 \$7,938	\$99 \$2,508 \$794 \$33,003	\$140 \$3,098 \$1,176 \$33,003
Schedule 90-P	\$91,944	\$2,700	\$153	(\$1,991)	\$862	\$2,286	\$396	\$2,682	\$4,000	\$3,865	\$2,029		\$9,894	\$105,382	\$105,675
Schedules 91 & 95	\$2,478	\$282	\$4	(\$54)	\$232	\$65	\$12	\$77	\$219	\$221	\$383	\$414	\$1,236	\$4,022	\$11,182
Schedules 92	\$128	\$5	\$0	(\$3)	\$3	\$3	\$1	\$4	\$5	\$5	\$9	\$4	\$23	\$157	\$205
Totals	\$1,031,821	\$46,474	\$1,900	(\$20,751)	\$27,624	\$32,364	\$4,832	\$37,196	\$70,904	\$72,016	\$116,380	\$135,132	\$394,432	\$1,491,072	\$1,811,619

ORDER NO. **20-483**

PORTLAND GENERAL ELECTRIC RATE DESIGN INPUTS (CONTINUED) SUMMARY - ALLOCATION OF 2019 COSTS TO RATE SCHEDULES (\$000)

	Dist. Custon	ner-Related TSM	Uncoll	ectibles	Me	tering	Ві	lling	Other	Consumer	Sub	total	-		Total
	Single	Three	Single	Three	Single	Three	Single	Three	Single	Three	Single	Three	Fixed		Cost
Grouping	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Costs	Subtota	Allocations
Schedule 7	\$112,456	\$4	\$5,534	\$0	\$6,796	\$0	\$60,633	\$1	\$39,625	\$1	\$225,045	\$6		\$225,052	\$963,143
Schedule 15	\$192		\$49		\$0		\$132		\$99		\$472	\$0	\$1,628	\$2,100	\$3,337
Schedule 32	\$13,020	\$16,239	\$168	\$113	\$1,082	\$730	\$3,679	\$2,481	\$5,517	\$3,721	\$23,466	\$23,283		\$46,749	\$188,882
Schedule 38	\$19	\$324	\$0	\$0	\$17	\$103	\$4	\$27	\$13	\$76	\$54	\$530		\$584	\$4,130
Schedule 47	\$21	\$425	\$0	\$5	\$7	\$83	\$15	\$187	\$21	\$268	\$64	\$969		\$1,033	\$4,379
Schedule 49	\$2	\$381	\$0	\$6	\$0	\$42	\$0	\$92	\$1	\$292	\$4	\$812		\$816	\$9,364
Schedule 83 Secondary	\$423	\$17,779	\$4	\$63	\$49	\$780	\$56	\$895	\$295	\$4,693	\$828	\$24,211		\$25,039	\$262,146
Schedule 85 Secondary Primary		\$5,018 \$593		\$30 \$5		\$467 \$79		\$232 \$39		\$3,592 \$607	\$0 \$0	\$9,339 \$1,323		\$9,339 \$1,323	\$221,761
Schedule 89 Secondary Primary Subtransmission		\$20 \$65 \$220		\$0 \$0 \$0		\$0 \$1 \$0		\$0 \$9 \$3		\$20 \$515 \$158		\$40 \$591 \$381		\$40 \$591 \$381	\$37,416
Schedule 90-P		\$10		\$0		\$0		\$0		\$282	\$0	\$292		\$292	\$105,675
Schedules 91 & 95	\$1,466			\$0		\$0	\$397		\$2		\$1,865	\$0	\$5,294	\$7,160	\$11,182
Schedule 92		\$16		\$0		\$0		\$31		\$0	\$0	\$47		\$47	\$205
Totals	\$127,601	\$41,095	\$5,755	\$222	\$7,951	\$2,287	\$64,917	\$3,997	\$45,574	\$14,226	\$251,799	\$61,826	\$6,922	\$320,547	\$1,811,619

Reconcile to Ratespread \$0.0

Lighting Additional O&M

	Lights	Intersections
Schedule 15R	9,847	
Schedule 15C	10,600	
Schedule 91 & 95	155,807	
Schedule 92		1,248
Limbto	47C 0E4	
Lights	176,254	1 0 4 0
Intersections		1,248

Lighting Services Test Period O&M

Lighting O&M \$684,845

O&M per light \$3.89

Design Demand per Rate Schedule

		Average	Design
Grouping	Design	Customers	Demand
Schedule 7 1-phase	4.0	782,966	3,131,864
Schedule 7 3-phase	4.0	15	60
Schedule 32 1-phase	4.8	56,001	268,803
Schedule 32 3-phase	11.6	37,764	438,067
Schedule 38 1-phase	47.8	55	2,629
Schedule 38 3 phase	115.3	328	37,809
Schedule 47 1-phase	10.4	224	2,330
Schedule 47 3 phase	15.7	2,837	44,541
Schedule 49 1-phase	37.2	6	223
Schedule 49 3 phase	56.1	1,268	71,135
Schedule 83 1-phase	40.8	683	27,860
Schedule 83 3 phase	83.0	10,846	900,218
Schedule 85	553.7	1,635	905,530
Commercial LTE 30 kW	/ Design	NCP	
1-phase	4.8	2.2	
3-phase	11.9	5.2	
Commercial 31-200 kW	I		
1-phase	41.3	25.9	
3-phase	81.1	51.6	
2016 Sch 32 1-phase	12,242	(from 2016)	
Schedule 7 per custom		(from 2016 W	A)
Ratio	1.21		

Determination of 2019 Class Non-coincident Peaks (115 kV)

Determination of 2019 Class Non-coincident Peaks (Primary)

Grouping	Load Factor	MWH	Load Factor times Hrs/Year	Class Peak (MW)		Grouping	Load Factor	MWH	Load Factor times Hrs/Year	Class Peak (MW)	
Schedu l e 7	43.84%	7,927,682	3,840	2,064.3	2,064,294	Schedule 7	43.84%	7,814,373	3,840	2,034.8	2,034,790
Schedule 15	46.27%	16,522	4,053	4.1	4,076	Schedule 15	46.27%	16,286	4,053	4.0	4,018
Schedule 32	59,33%	1,709,264	5,197	328,9	328,875	Schedule 32	59,33%	1,684,834	5,197	324.2	324,174
Schedu l e 38	26.96%	32,990	2,362	14.0	13,969	Schedu l e 38	26.96%	32,519	2,362	13.8	13,769
Schedule 47	19.51%	22,697	1,709	13.3	13,280	Schedule 47	19.51%	22,373	1,709	13.1	13,091
Schedu l e 49	20.97%	67,568	1,837	36.8	36,782	Schedu l e 49	20.97%	66,602	1,837	36.3	36,256
Schedule 83	55.66%	3,024,167	4,876	620.2	620,238	Schedule 83	55.66%	2,980,943	4,876	611.4	611,373
Schedu l e 85	63,33%	3,796,164	5,548	684.3	684,276	Schedule 85	63,33%	3,741,906	5,548	674.5	674,496
Schedu l e 89	79.70%	1,659,936	6,982	237.8	237,755	Schedu l e 89	79.70%	1,386,364	6,982	198.6	198,570
Schedule 90	87.63%	1,920,444	7,676	250.2	250,175	Schedule 90	87.63%	1,892,995	7,676	246.6	246,600
Schedules 91 & 95	46.27%	52,981	4,053	13.1	13,071	Schedu l es 91 & 95	46.27%	52,223	4,053	12.9	12,884
Schedule 92	100.00%	2,614	8,760	0.3	298	Schedu l e 92	100.00%	2,577	8,760	0.3	294
Totals		20,233,028		4,267		Totals		19,693,995		4,170	

Schedule Rate Class Peak per Customer

Commission	Class Peak (MW)	Average Accounts	Deak (MM)		
Grouping Schedule 7	2,034.8	782,981	Peak (kW) 2.60	-	
Scriedule /	2,034.0	702,301	2.00		
Schedule 32	324.2	93,765	3.50		
Schedule 38	13.8	383	36.00		
Schedu l e 47	13.1	3,061	4.30		
Schedu l e 49	36.3	1,274	28.50		
Schedule 83	611.4	11,529	53.00		
Schedule 85	674.5	1,635	412.40		
Schedule 89	198.6	35	5,673.40		
	Customer BD			NCP NO	CP
Schedule 7 1-phase	9,395,591			2.034.8	2.6
Schedule 7 3-phase	180			0.0	2.6
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	9,395,771			2,034.79	
		Energy		NCP	
Scheddule 15R		3,264		0.8	
Scheddule 15C		12,510		3.2	
		15,774		4.0	
	Customer BD				CP
Schedule 32 1-phase	672,008	11,641	651,930	125.0	2_2
Schedule 32 3-phase	453,173	27,503	1,038,628	199.2	5.3
	1,125,181		1,690,558	324.17	

00.000

NCP

NÇP

PORTLAND GENERAL ELECTRIC

2019 Projection of Schedule 485/489 Loads & Schedule 129 Revenues

Sahadulaa 9 Vintagaa	Meter	Cycle Meter	Schedule 129	Schedule 129
Schedules & Vintages Schedule 485-S V2003	MWa 1.3	MWH 11,734	mills/kWh 0.00	Revenues (\$000) \$0
Schedule 485-S V2003	3.7	32,240	0.00	\$0 \$0
Schedule 485-S V2010	3.9	34,163	0.00	\$0 \$0
Schedule 485-S V2011	22.0	192,487	0.00	\$0 \$0
Schedule 485-S V2012	12.3	107,529	0.00	\$0 \$0
Schedule 485-S V2014	1.2	107,329	0.00	\$0 \$0
Schedule 485-S V2014 Schedule 485-S V2015	0.5	4,779	21.72	\$104
Schedule 485-S V2016	1.4	12,453	28.66	\$357
Schedule 485-S V2017	11.9	104,545	28.46	\$2,975
Schedule 485-S V2018	7.3	63,692	30.72	\$1,957
Schedule 485-S V2019	2.4	20,614	29.72	\$613
Schedule 489-S V2014	1.5	13,482	0.00	\$0
Schedule 485-P V2010	2.8	24,415	0.00	\$0
Schedule 485-P V2010	0.0	24,413	0.00	\$ 0
Schedule 485-P V2012	4.0	35,086	0.00	\$ 0
Schedule 485-P V2013	14.7	128,740	0.00	\$0 \$0
Schedule 485-P V2014	1.0	8,879	0.00	\$0
Schedule 485-P V2015	4.0	35,096	21.53	\$756
Schedule 485-P V2016	0.0	0	28.34	\$0
Schedule 485-P V2017	7.4	65,259	28.00	\$1,827
Schedule 485-P V2018	1.4	12,047	30.31	\$365
Schedule 485-P V2019	2.5	21,816	29.58	\$645
Schedule 489-P V2004	8.6	75,020	0.00	\$0 \$0
Schedule 489-P V2010	8.4	73,367	0.00	\$0
Schedule 489-P V2011	20.5	179,170	0.00	\$0
Schedule 489-P V2012	9.9	87,123	0.00	\$0
Schedule 489-P V2013	6.4	56,400	0.00	\$0
Schedule 489-P V2014	7.8	68,114	0.00	\$0
Schedule 489-P V2016	7.6	66,250	26.05	\$1,726
Schedule 489-P V2017	16.3	143,156	26.05	\$3,729
Schedule 489-P V2018	19.0	166,555	27.11	\$4,515
Schedule 489-P V2019	5.2	45,879	25.76	\$1,182
Schedule 489-T V2007	0.2	1,733	0.00	\$0
Schedule 489-T V2012	11.5	100,778	0.00	\$0
Schedule 489-T V2013	9.7	84,661	0.00	\$0
Total	238.4	2,088,126	0.00	\$20,751
Pre 2014 Amounts Post 2014 Amounts				\$0 \$20,751
Schedule 485 Schedule 489				\$9,599 \$11,152

PORTLAND GENERAL ELECTRIC Revenue Changes

Demand Demand Vol. Trans Transmission Volumetric Basic Basic Transmission Volumetric Volumetric Charge Charge & Related Dist. Dist_ Facilities Grouping Schedule 7 \$0 \$0 \$2,563,925 \$0 \$0 \$14,758,428 \$7,610,125 \$4,545,978 \$0 Schedule 15 Residential \$4,545,978 \$0 \$0 \$2.564,675 \$0 \$0 \$14,752,716 \$7.610.125 \$0 Schedule 15 Commercial \$0 \$0 \$2.877 \$0 (\$21.893) \$0 \$0 Schedule 32 Schedule 38 \$0 \$2,016,024 \$2,719,038 \$489,947 \$0 \$813,628 \$1,234,426 \$0 \$3,300 \$19.675 \$7.869 \$0 (\$10,597) \$0 \$0 \$0 \$0 \$0 \$0 \$6,706 \$0 \$16,805 \$31,438 \$0 Schedule 49 \$180 \$38,040 \$19,362 \$0 \$0 \$0 \$1,118,866 \$0 \$40,970 \$650,760 542) Schedule 85-S \$0 \$0 \$839.580 \$0 \$742,557 \$0 \$0 \$0 \$0 \$0 (\$615.692) Schedule 89-S Schedule 91 \$0 \$0 \$0 \$0 \$6.184 \$0 \$0 \$0 \$59.960 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$1,073 \$0 \$0 \$574 Schedule 95 \$5,450 \$52,840 \$0 \$4,301,137 Schedule 85-P Schedule 89-P \$193,793 \$0 \$0 \$15,840 \$n \$106,664 \$0 \$0 SO \$0 (\$7,200) Schedule 90-P \$5,520 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$59.040 Schedule 89-T \$0 \$0 \$7,200 \$0 \$35,428 \$0 \$0 \$0 \$0 \$0 \$0 (\$3,600)\$0 \$0 \$0 \$0 Schedule 76R Schedule 485-S V2003 Schedule 485-S V2010 \$0 \$1,440 \$0 \$0 (\$1,056) \$5,760 \$5,760 (\$4,224) (\$4,224) \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 Schedule 485-S V2011 \$0 Schedule 485-S V2012 \$71,280 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$52,272) \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$23,040 \$0 \$0 (\$16,896) Schedule 485-S V2014 \$2,160 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$1,584) Schedule 485-S V2015 \$720 (\$528) Schedule 485-S V2016 \$5.040 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$3.696) Schedule 485-S V2017 \$27,360 (\$20,064) Schedule 485-S V2018 \$18,720 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$13,728) Schedule 485-S V2019 \$0 \$6,480 (\$4,752) Schedule 489-S V2014 \$2,160 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$169,920 \$0 \$0 \$0 \$0 \$0 Schedule 485-P V2011 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 Schedule 485-P V2012 \$0 \$0 \$0 (\$480) Schedule 485-P V2013 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$2,688) Schedule 485-P V2014 (\$192) Schedule 485-P V2015 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$192) \$0 \$0 Schedule 485-P V2017 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$768) (\$96) Schedule 485-P V2018 Schedule 485-P V2019 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$192) Schedule 489-P V2004 (\$720) \$1,440 Schedule 489-P V2010 \$0 \$0 \$1,440 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$720) Schedule 489-P V2011 \$2,880 (\$1,440) Schedule 489-P V2012 \$0 \$0 \$4,320 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$2,160) Schedule 489-P V2013 \$1,440 (\$720) \$1,440 \$1,440 Schedule 489-P V2014 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$720) Schedule 489-P V2016 (\$720) \$2,880 \$2,880 (\$1,440) (\$1,440) Schedule 489-P V2017 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$0 Schedule 489-P V2018 \$0 Schedule 489-P V2019 \$1,440 \$0 \$0 \$0 \$0 \$0 \$0 \$0 Schedule 489-T V2007 DAX \$1,440 (\$2,880)\$1,440 \$1,440 Schedule 489-T V2012 DAX \$0 \$0 \$0 \$0 \$0 \$0 \$0 (\$720) Schedule 489-T V2013 DAX \$0 \$0 \$0 \$0 \$0 \$0 \$0 \$4,320 \$0 COS Totals \$2.063.162 \$4,367,377 \$3,103,645 \$2.548.518 \$0 \$15,640,338 \$8,809,300 \$4,545,978 (\$1.095.498) \$0 Market Totals \$0 \$0 \$0 \$0 \$0 **Direct Access Totals** \$195,840 \$2,063,162 \$8,809,300 \$4,563,217 \$15,640,338

Faci l ities Revenues	Facilities Revenues	Distribution Demand Revenues	Distribution Demand Revenues	Explicit/ Implicit System Usage Revenues	Block 1 Energy Revenues	Block 2 Energy Revenues	Block 3 Energy Revenues	Flat Energy Revenues	On-peak Energy Revenues	Off-peak Energy Revenues	Wheeling Demand Revenues	Reactive Revenues
\$0	\$0	\$0	\$0	(\$529,824)	(\$7,512,174)	(\$3,873,623)	(\$2,313,944)	\$0	\$0	(\$126,972)	\$0	\$0
\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$9,694 (\$520,130)	\$0 (\$7,512,174)	\$0 (\$3,873,623)	(\$2,313,944)	(\$5,092) (\$5,092)	\$0 \$0	\$0 (\$126,972)	\$0 \$0	\$0 \$0
\$0	\$0	\$0	\$0	\$37,155	\$0	\$0	(42,212,217)	(\$19,516)	\$0	\$0	\$0	\$0
\$0	\$0	\$0	\$0	(\$81,658)	\$0	\$0		(\$2,580,386)	\$0	(\$58,612)	\$0	\$0
\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$4,721) (\$433)	\$0 \$0	\$0 \$0		\$0 \$18,821	\$13,331 \$0	(\$60,698) \$0	\$0 \$0	\$0 \$0
\$0	\$0	\$0	\$0	(\$8,390)	\$0	\$0		\$48,405	\$0	\$0	\$0	\$0
(\$767,873) (\$2,016,668)	\$0 \$0	(\$602,466) (\$399,838)	\$0 \$0	\$2,798,413 (\$318,363)	\$0 \$0	\$0 \$0		\$0 \$0	(\$1,870,878) (\$1,084,862)	(\$956,384) (\$570,627)	\$0 \$0	\$0 \$0
\$0	\$0	\$0	\$0	\$0	\$0	\$0		\$0	\$0	\$0	\$0	\$0
\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$27,157) (\$275)	\$0 \$0	\$0 \$0		(\$41,945) (\$2,321)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
\$0	\$0	\$0	\$0	(\$23,932)	\$0	\$0		(\$36,964)	\$0	\$0	\$0	\$0
(\$2,784,541)	\$0	(\$1,002,305)	\$0	\$2,370,639	\$0	\$0	\$0	(\$2,613,906)	(\$2,942,409)	(\$1,646,322)	\$0	\$0
(\$511,287)	\$0	(\$104,350)	\$0	(\$88,714)	\$0	\$0		\$0	(\$288,163)	(\$167,233)	\$0	\$0
(\$21,600) \$16,560	(\$28,809) \$627,959	(\$57,434) (\$189,114)	\$0 \$0	(\$52,153) (\$279,160)	\$0 \$0	\$0 \$0		\$0 \$0	(\$310,629) (\$1,605,956)	(\$210,900) (\$1,185,643)	\$0 \$0	\$0 \$0
(\$516,327)	\$599,150	(\$350,898)	\$0	(\$420,027)	\$0	\$0	\$0	\$0	(\$2,204,749)	(\$1,563,776)	\$0	\$0
(\$10,800)	(\$6,954)	\$2,725	\$0	(\$7,531)	\$0	\$0		\$0	(\$52,484)	(\$27,847)	\$0	\$0
\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$10,800)	(\$6,954)	\$2,725	\$0	(\$7,531)	\$0	\$0	\$0	\$0	(\$52,484)	(\$27,847)	\$0	\$0
(\$11,288)	\$0	(\$1,578)	\$0	(\$1,525)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$30,613)	\$0	(\$4,198)	\$0	(\$4,191)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$37,349) (\$155,849)	\$0 \$0	(\$4,937) (\$29,208)	\$0 \$0	(\$4,441) (\$25,023)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$97,542)	\$0	(\$14,386)	\$0	(\$13,979)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$10,827) (\$4,674)	\$0 \$0	(\$1,573) (\$737)	\$0 \$0	(\$1,413) (\$621)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$4,561)	\$0	(\$1,564)	\$0	(\$1,619)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$81,843) (\$56,497)	\$0 \$0	(\$13,481) (\$5,684)	\$0 \$0	(\$13,591) (\$8,280)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$14,790)	\$0	(\$2,748)	\$0	(\$2,680)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$2,160) (\$507,992)	(\$2,470) (\$2,470)	(\$2,997) (\$83,091)	\$0 \$0	(\$1,213) (\$78,577)	\$0 \$0	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$15,561)	\$0	(\$3,098)	\$0	(\$3,174)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
\$0	\$0	\$0	\$0	\$0	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$21,935) (\$69,125)	\$0 \$0	(\$5,353) (\$18,892)	\$0 \$0	(\$4,561) (\$16,736)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$3,705)	\$0	(\$1,096)	\$0	(\$1,154)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$24,994) \$0	\$0 \$0	(\$5,126) \$0	\$0 \$0	(\$4,562) \$0	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$31,841)	\$0	(\$7,892)	\$0	(\$8,484)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$9,000) (\$23,538)	\$0 \$0	(\$1,572) (\$4,155)	\$0 \$0	(\$1,566) (\$2,836)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$2,160)	(\$5,594)	(\$8,981)	\$0	(\$7,502)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$2,160) (\$4,320)	(\$6,377) (\$11,419)	(\$9,947) (\$18,452)	\$0 \$0	(\$7,337) (\$17,917)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$6,480)	(\$3,290)	(\$11,900)	\$0	(\$8,712)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$2,160) (\$2,160)	(\$2,996) (\$3,834)	(\$6,268) (\$7,208)	\$0 \$0	(\$5,640) (\$6,811)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$2,160)	(\$3,066)	(\$6,889)	\$0	(\$6,625)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$4,320) (\$4,320)	(\$9,413) (\$10,707)	(\$16,014) (\$17,735)	\$0 \$0	(\$14,316) (\$16,655)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$2,160)	(\$1,611)	(\$4,891)	\$0	(\$4,588)	\$0	\$0	a.c	\$0	\$0	\$0	\$0	\$0
(\$232,099)	(\$58,307)	(\$155,468)	\$0	(\$139,177)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
(\$1) (\$2,160)	\$0 (\$9,873)	\$107 \$1,623	\$0 \$0	(\$156) (\$9,070)	\$0 \$0	\$0 \$0		\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$2,160)	(\$9,873) (\$10,105)	\$1,984	\$0	(\$7,619)	\$0	\$0		\$0	\$0	\$0	\$0	\$0
(\$4,321)	(\$19,977)	\$3,714	\$0	(\$16,845)	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
(\$3,311,668)	\$592,195	(\$1,350,477)	\$0	\$1,422,951	(\$7,512,174)	(\$3,873,623)	(\$2,313,944)	(\$2,618,998)	(\$5,199,642)	(\$3,364,917)	\$0	\$0
\$0 (\$744,412)	\$0 (\$80,755)	\$0 (\$234,845)	\$0 \$0	\$0 (\$234,599)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
(\$4,056,080)	\$511,440	(\$1,585,322)	\$0	\$1,188,352	(\$7,512,174)	(\$3,873,623)	(\$2,313,944)	(\$2,618,998)	(\$5,199,642)	(\$3,364,917)	\$0	\$0

Fixed		h 146 venues	Sch 122a Revenues	Sch 122b Revenues	Sch 125 Revenues	Sch 145 Revenues	Sch 132 Revenues	Sch 143 Revenues	Sch 128 Block 1 Revenues	Sch 128 Block 2 Revenues	Sch 129 Revenues	Sch 102 Block 1 Revenues	Sch 102 Block 2 Revenues	Sch 102 Block 3 Revenues
10.4	\$0	\$0	\$0	\$0	\$0		(\$12,261,647)	\$151,378	\$0	\$0	\$0	\$3,901,350	\$2,011,716	(\$6,328,190)
(\$4, (\$4,	908)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$65) (\$75,754)	(\$10,314) (\$12,271,961)	\$65 \$151,444	\$0 \$0	\$0 \$0	\$0 \$0	(\$522) \$3,900,828	\$0 \$2,011,716	\$0 (\$6,328,190)
(\$18,	811)	\$0	\$0	\$0	\$0	(\$250)	(\$39,532)	\$250	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	(\$16,332)	(\$2,384,407)	\$32,663	\$0	\$0	\$0	(\$39,853)	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	(\$315)	(\$56,340)	\$944	\$0	\$0	\$0	(\$104)	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$58,843)	\$433	\$0	\$0	\$0	(\$3,133)	\$0	\$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 (\$28,850)	(\$123,272) (\$3,231,157)	\$1,291 \$57,699	\$0 \$0	\$0 \$0	\$0 \$0	(\$8,697) (\$36,149)	\$0 \$0	\$0 \$0
	\$0	\$0	\$0 \$0	\$0	\$0	(\$20,050)	(\$2,037,525)	\$42,448	\$0	\$0	\$0	(\$5,309)	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
\$55,		\$0	\$0	\$0	\$0	(\$538)	(\$84,159)	\$538	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	(\$25)	(\$2,546)	\$50	\$0	\$0	\$0	\$0	\$0	\$0
\$48,		\$0	\$0	\$0	\$0	(\$474)	(\$74,165)	\$474	\$0	\$0	\$0	\$0	\$0	\$0
\$85,	208	\$0	\$0	\$0	\$0	(\$68,007)	(\$8,091,946)	\$136,790	\$0	\$0	\$0	(\$93,244)	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	(\$11,828)	(\$526,368)	\$17,743	\$0	\$0	\$0	(\$702)	\$0	\$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$8,024) (\$37,221)	(\$300,882) (\$1,191,082)	\$12,035 \$37,221	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
	\$0	\$0	\$0	\$0	\$0	(\$57,073)		\$66,999	\$0	\$0	\$0	(\$702)	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	(\$1,255)	(\$56,483)	\$1,883	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 (\$1,255)	\$0 (\$56,483)	\$0 \$1,883	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$2,699) (\$7,415)	\$235 \$645	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$7,413)	\$683	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$44,272)	\$3,850	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$24,732)	\$2,151	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$4,455)	\$217	\$0	\$0	(\$125,395)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$4,014)	\$96	\$0	\$0	(\$8,363)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$10,460)	\$249	\$0	\$0	(\$21,792)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$87,818)	\$2,091	\$0	\$0	(\$279,135)	\$0	\$0	\$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$53,501) (\$17,316)	\$1,274 \$412	\$0 \$0	\$0 \$0	(\$170,057) \$0	\$0 \$0	\$0 \$0	\$0 \$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$5,528)	\$404	\$0	\$0	(\$65,118)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$270,067)	\$12,306	\$0	\$0	(\$669,861)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$4,151)	\$732	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$5,965)	\$1,053	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$21,886)	\$3,862	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$3,108)	\$266	\$0 \$0	\$0 \$0	(\$101,838)	\$0 \$0	\$0 \$0	\$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0	(\$27,024) \$0	\$1,053 \$0	\$0 \$0	\$0 \$0	(\$60,716) \$0	\$0 \$0	\$0 \$0	\$0 \$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$50,249)	\$1,958	\$0	\$0	(\$171,631)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$9,276)	\$361	\$0	\$0	(\$31,683)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$16,798)	\$654	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$8,252)	\$2,251	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$8,070)	\$2,201	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$19,709)	\$5,375	\$0	\$0	\$0	\$0	\$0	\$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$9,583) (\$6,204)	\$2,614 \$1,692	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$6,204)	\$2,043	\$0 \$0	\$0 \$0	(\$627,334)	\$0 \$0	\$0 \$0	\$0 \$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$44,387)	\$1,987	\$0	\$0	(\$104,012)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$95,914)	\$4,295	\$0	\$0	(\$346,437)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$111,592)	\$4,997	\$0	\$0	(\$403,062)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$30,739)	\$1,376	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$489,936)	\$38,771	\$0	\$0	(\$1,846,715)	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$191)	\$52	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$11,086)	\$3,023	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0 \$0	(\$9,313)	\$2,540	\$0	\$0 \$0	\$0	\$0	\$0	\$0 \$0
	\$0	\$0	\$0	\$0	\$0	\$0	(\$20,589)	\$5,615	\$0		\$0	\$0	\$0	\$0
\$80,		\$0 \$0	\$0 \$0	\$0 \$0	\$0	(\$202,090) \$0		\$357,116	\$0 \$0	\$0 \$0	\$0 \$0	\$3,806,882 \$0	\$2,011,716 \$0	(\$6,328,190)
	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 (\$780,592)	\$0 \$56,693	\$0 \$0	\$0 \$0	\$0 (\$2,516,575)	\$0 \$0	\$0 \$0	\$0 \$0
\$80,		\$0	\$0	\$0	\$0		(\$23,219,315)	\$413,809	\$0	\$0	(\$2,516,575)	\$3,806,882	\$2,011,716	(\$6,328,190)

Sch 105 Revenues	Sch 109 Revenues	Sch 110 Revenues	Sch 112 Revenues	Sch 123 Revenues	Sch 126 Revenues	Sch 135 Revenues	Sch 137 Revenues	Revenues Without Supplementals	Revenues With Sch 102	Supplemental Revenues	Total Revenues	Revenues Without Sch 109
\$2,194,986	(\$7,266,161)	\$0	\$0	\$14,456,633	\$0	\$2,270,675	\$0	\$15,121,918	\$14,706,794	(\$944,948)	\$14,176,970	\$21,443,131
\$1,599 \$2,196,586	(\$4,668) (\$7,270,829)	\$0 \$0	\$0 \$0	\$947 \$14,457,580	\$0 \$0	\$718 \$2,271,393	\$0 \$0	(\$5,267) \$15,116,651	(\$5,789) \$14,701,005	(\$12,240) (\$957,188)	(\$17,507) \$14,159,463	(\$12,839) \$21,430,292
\$6,130	(\$17,889)	\$0	\$0	\$3,628	\$0	\$2,752	\$0	(\$20,187)	(\$20,187)	(\$44,911)	(\$65,098)	(\$47,208)
\$440,952	(\$1,517,232)	\$0	\$0	(\$1,125,688)	\$0	\$440,952	\$0	\$4,552,407	\$4,512,555	(\$4,168,944)	\$383,464	\$1,900,695
\$11,646	(\$34,526)	\$0	\$0	\$9,102	\$0	\$7,869	\$0	(\$40,759)	(\$40,863)	(\$61,724)	(\$102,483)	(\$67,957)
\$9,735	(\$33,748)	\$0	\$0	\$6,274	\$0	\$7,139	\$0	\$110,069	\$106,937	(\$72,144)	\$37,926	\$71,674
\$25,816	(\$67,518)	\$0	\$0	\$18,648	\$0	\$21,298	\$0	\$15,631	\$6,934	(\$132,434)	(\$116,803)	(\$49,285)
\$836,639	(\$2,494,481)	\$0	\$0	\$822,045	\$0	\$778,940	\$0	(\$45,135)	(\$81,284)	(\$3,295,314)	(\$3,340,449)	(\$845,968)
\$551,830	(\$1,464,661)	\$0	\$0	\$544,554	\$0	\$551,830	\$0	(\$3,423,914)	(\$3,429,222)	(\$1,838,058)	(\$5,261,972)	(\$3,797,310)
\$0	\$0	\$0 \$0	\$0 \$0	\$0	\$0 \$0	\$0	\$0 \$0	\$0	\$0	\$0	\$0	\$0
\$15,057 \$649	(\$16,402) (\$1,622)	\$0	\$0	\$7,798 \$724	\$0	\$5,915 \$599	\$0	\$52,335 (\$948)	\$52,335 (\$948)	(\$71,791) (\$2,172)	(\$19,456) (\$3,120)	(\$3,055) (\$1,498)
\$13,269	(\$14,454)	\$0	\$0	\$6,872	\$0	\$5,213	\$0	\$46,120	\$46,120	(\$63,266)	(\$17,146)	(\$2,692)
\$1,911,723	(\$5,662,534)	\$0	\$0	\$293,955	\$0	\$1,822,507	\$0	\$1,245,620	\$1,152,375	(\$9,750,756)	(\$8,505,136)	(\$2,842,603)
\$153,770	(\$235,241)	\$0	\$0	\$87,461	\$0	\$153,770	\$0	(\$983,939)	(\$984,641)	(\$361,394)	(\$1,345,333)	(\$1,110,092)
\$96,282	\$0	\$0	\$0	\$0	\$0	\$92,271	\$0	(\$566,222)	(\$566,222)	(\$108,318)	(\$674,539)	(\$674,539)
\$428,045	\$0	\$0	\$0	\$0	\$0	\$428,045	\$0	(\$2,215,423)	(\$2,215,423)	(\$334,992)	(\$2,550,415)	(\$2,550,415)
\$678,098	(\$235,241)	\$0	\$0	\$87,461	\$0	\$674,086	\$0	(\$3,765,584)	(\$3,766,285)	(\$804,704)	(\$4,570,287)	(\$4,335,046)
\$15,062	\$0	\$0	\$0	\$0	\$0	\$14,435	\$0	(\$63,864)	(\$63,864)	(\$26,359)	(\$90,223)	(\$90,223)
\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
\$15,062	\$0	\$0	\$0	\$0	\$0	\$14,435	\$0	(\$63,864)	(\$63,864)	(\$26,359)	(\$90,223)	(\$90,223)
\$2,229	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$14,007)	(\$14,007)	(\$235)	(\$14,242)	(\$14,242)
\$6,126	(\$10,794)	\$0	\$0	\$830	\$0	\$0	\$0	(\$37,466)	(\$37,466)	(\$10,608)	(\$48,074)	(\$37,281)
\$6,491	(\$26,647)	\$0	\$0	\$2,050	\$0	\$0	\$0	(\$45,191)	(\$45,191)	(\$25,281)	(\$70,472)	(\$43,825)
\$36,573	(\$150,140)	\$0	\$0	\$11,549	\$0	\$0	\$0	(\$191,072)	(\$191,072)	(\$142,440)	(\$333,512)	(\$183,372)
\$20,431	(\$74,760)	\$0	\$0	\$5,751	\$0	\$0	\$0	(\$119,763)	(\$119,763)	(\$71,160)	(\$190,922)	(\$116,163)
\$2,065 \$908	(\$8,476) (\$3,728)	\$0 \$0	\$0 \$0	\$652 \$287	\$0 \$0	\$0 \$0	\$0 \$0	(\$138,632) (\$14,203)	(\$138,632) (\$14,203)	(\$9,997) (\$6,451)	(\$148,629) (\$20,655)	(\$140,153) (\$16,927)
\$2,366	(\$9,713)	\$0	\$0	\$747	\$0	\$0	\$0	(\$28,192)	(\$28,192)	(\$16,811)	(\$45,003)	(\$15,927)
\$19,864	(\$81,545)	\$0	\$0	\$6,273	\$0	\$0	\$0	(\$380,754)	(\$380,754)	(\$141,136)	(\$521,889)	(\$440,344)
\$12,101	(\$49,680)	\$0	\$0	\$3,822	\$0	\$0	\$0	(\$235,527)	(\$235,527)	(\$85,984)	(\$321,511)	(\$271,831)
\$3,917	(\$16,079)	\$0	\$0	\$1,237	\$0	\$0	\$0	(\$18,490)	(\$18,490)	(\$27,829)	(\$46,319)	(\$30,240)
\$2,292	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$72,519)	(\$72,519)	(\$2,831)	(\$75,350)	(\$75,350)
\$115,361	(\$431,561)	\$0	\$0	\$33,197	\$0	\$0	\$0	(\$1,295,815)	(\$1,295,815)	(\$540,763)	(\$1,836,578)	(\$1,405,017)
\$4,639	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$21,929)	(\$21,929)	\$1,221	(\$20,708)	(\$20,708)
\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
\$6,666	(\$6,559)	\$0	\$0	\$505	\$0	\$0	\$0	(\$32,329)	(\$32,329)	(\$4,300)	(\$36,629)	(\$30,070)
\$24,461	(\$63,032)	\$0 \$0	\$0 \$0	\$4,849	\$0 \$0	\$0 \$0	\$0 \$0	(\$107,442)	(\$107,442)	(\$51,746)	(\$159,188)	(\$96,156)
\$1,687 \$6,668	(\$6,925) \$0	\$0 \$0	\$0 \$0	\$533 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$107,986) (\$95,591)	(\$107,986) (\$95,591)	(\$7,547) (\$19,303)	(\$115,533) (\$114,894)	(\$108,607) (\$114,894)
\$0,000	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$85,581)	(\$95,591)	(\$19,303)	(\$114,684)	(\$114,084)
\$12,399	(\$12,663)	\$0	\$0	\$974	\$0	\$0	\$0	(\$220,615)	(\$220,615)	(\$47,581)	(\$268,197)	(\$255,534)
\$2,289	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$43,918)	(\$43,918)	(\$6,626)	(\$50,544)	(\$50,544)
\$4,145	(\$1)	\$0	\$0	\$0	\$0	\$0	\$0	(\$30,720)	(\$30,720)	(\$12,000)	(\$42,720)	(\$42,719)
\$12,753	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$23,517)	(\$23,517)	\$6,752	(\$16,765)	(\$16,765)
\$12,472	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$25,100)	(\$25,100)	\$6,603	(\$18,497)	(\$18,497)
\$30,459	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$50,668)	(\$50,668)	\$16,125	(\$34,543)	(\$34,543)
\$14,811	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$28,222)	(\$28,222)	\$7,841	(\$20,381)	(\$20,381)
\$9,588	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$16,344)	(\$16,344)	\$5,076	(\$11,268)	(\$11,268)
\$11,579 \$11,262	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$646,628) (\$122,033)	(\$646,628) (\$122,033)	(\$3,406) (\$31,137)	(\$650,034) (\$153,170)	(\$650,034) (\$153,170)
\$11,262	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0	\$0 \$0	(\$389,059)	(\$389,059)	(\$67,283)	(\$456,342)	(\$153,170)
\$28,314	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$451,039)	(\$451,039)	(\$78,281)	(\$529,320)	(\$529,320)
\$7,799	(\$1)	\$0	\$0	\$0	\$0	\$0	\$0	(\$12,530)	(\$12,530)	(\$21,565)	(\$34,094)	(\$34,093)
\$226,330	(\$89,181)	\$0	\$0	\$6,860	\$0	\$0	\$0	(\$2,425,670)	(\$2,425,670)	(\$307,156)	(\$2,732,826)	(\$2,643,645)
\$295	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$1,490)	(\$1,490)	\$156	(\$1,334)	(\$1,334)
\$17,132	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$18,759)	(\$18,759)	\$9,070	(\$9,689)	(\$9,689)
\$14,392	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$17,181)	(\$17,181)	\$7,619	(\$9,561)	(\$9,561)
\$31,819	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$37,429)	(\$37,429)	\$16,845	(\$20,584)	(\$20,584)
\$4,801,468 \$0	(\$13,168,603) \$0	\$0 \$0	\$0 \$0	\$14,838,997 \$0	\$0 \$0	\$4,782,421 \$0	\$0 \$0	\$12,532,823 \$0	\$12,023,231 \$0	(\$11,539,007) \$0	\$993,817 \$0	\$14,162,420 \$0
\$373.510	(\$520,741)	\$0	\$0	\$40,057	\$0	\$0	\$0	(\$3,758,914)	(\$3,758,914)	(\$831,074)	(\$4,589,988)	(\$4,069,246)
	(\$13,689,345)	\$0	\$0	\$14,879,054	\$0	\$4,782,421	\$0	\$8,773,909	\$8,264,317	(\$12,370,080)	(\$3,596,171)	

	A B C D	E	F	G	Н	I	J	K	L	М	N	0	Р
1													
2	PORTLAND GENERAL ELECTRIC												
3	Revenues at Proposed Prices												
4					Demand	Demand							
5		Basic	Basic	Vol. Trans	Transmission	Transmission	Volumetric	Volumetric	Volumetric				Distribution
6		Charge	Charge	& Related	& Related	& Related	Dist.	Dist.	Dist.	Facilities	Facilities	Facilities	Demand
7	Grouping	1-phase	3-phase	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues
8	Outrodule 7	\$400.0E4.E04	64.000	# 40 000 000	**	to.	6404040050	* 05 055 500	650 700 040	**	**	**	ėo.
9 10	Schedule 7	\$103,351,501 \$0	\$1,980	\$18,382,963	\$0 \$0	\$0 \$0	\$184,342,650 \$174,787	\$95,055,562	\$56,782,310 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
11	Schedule 15 Residential	\$103,351,501	\$0 \$1,980	\$4,961 \$18,387,925	\$0	\$0	\$184,517,437	\$95,055,562	\$56,782,310	\$0 \$0	\$0	\$0	\$0
12	Subtotal	\$103,331,301	\$1,500	\$10,507,525	ΨΟ	ΨΟ	\$104,517,457	\$95,055,50Z	\$30,702,510	40	40	40	40
13	Schedule 15 Commercial	\$0	\$0	\$19,015	\$0	\$0	\$669,911	\$0	\$0	\$0	\$0	\$0	\$0
14		\$13,440,160	\$13,142,017	\$3,364,301	\$0	\$0	\$57,739,059	\$2,674,590	\$0	\$0	\$0	\$0	\$0
15		\$19,800	\$118,050	\$53,822	\$0	\$0	\$1,163,394	\$979,082	\$0	\$0	\$0	\$0	\$0
16	Schedule 47	\$49,728	\$629,814	\$46,079	\$0	\$0	\$805,133	\$1,224,233	\$0	\$0	\$0	\$0	\$0
17	Schedule 49	\$1,620	\$342,360	\$136,825	\$0	\$0	\$1,491,343	\$2,651,095	\$0	\$0	\$0	\$0	\$0
18		\$286,790	\$5,856,840	\$0	\$6,713,196	\$0	\$0	\$0	\$0	\$14,526,330	\$23,734,254	\$0	\$22,463,385
19		\$0	\$7,836,080	\$0	\$4,455,341	\$0	\$0	\$0	\$0	\$8,871,562	\$7,640,068	\$0	\$14,908,255
20	Schedule 89-S	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	Schedule 91	\$0	\$0	\$40,870	\$0	\$0	\$1,648,503	\$0	\$0	\$0	\$0	\$0	\$0
22	Schedule 92	\$0	\$0	\$3,969	\$0	\$0	\$70,262	\$0	\$0	\$0	\$0	\$0	\$0
23	Schedule 95	\$13.709.009	\$0	\$36,016	\$11,169,536	\$0 \$0	\$1,452,740	\$7.539.000	\$0 \$0	\$0 \$23,397,892	\$0 \$31,374,322	\$0 \$0	\$0
25	Subtotal	\$13,798,098	\$27,925,161	\$3,700,897	\$11,168,536	φU	\$65,040,346	\$7,528,999	φU	923,381,08Z	φ31,314,322	φU	\$37,371,640
26	Schedule 85-P	\$0	\$1,056,560	\$0	\$1,132,942	\$0	\$0	\$0	\$0	\$1,393,760	\$2,857,193	\$0	\$3,771,504
	Schedule 89-P	\$0	\$249,480	\$0	\$623,572	\$0	\$0	\$0	\$0	\$178,800	\$536,400	\$566,585	\$2,075,837
28	Schedule 90-P	\$0	\$292,800	\$0	\$2,053,234	\$0	\$0	\$0	\$0	\$38,640	\$115,920	\$3,549,334	\$6,835,109
29	Subtotal	\$0	\$1,598,840	\$0	\$3,809,748	\$0	\$0	\$0	\$0	\$1,611,200	\$3,509,513	\$4,115,919	\$12,682,450
30													
31	Schedule 89-T	\$0	\$238,200	\$0	\$204,391	\$0	\$0	\$0	\$0	\$89,400	\$268,200	\$136,771	\$346,102
32	Schedule 75-T	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
33	Schedule 76R	\$0	\$0	\$0		\$0	\$0	\$0	\$0	\$0	\$0	\$0	
34		\$0	\$238,200	\$0	\$204,391	\$0	\$0	\$0	\$0	\$89,400	\$268,200	\$136,771	\$346,102
35		**	610.110	60	**	**	**	40	40	645.040	640.705	**	#50.000
36 37	Schedule 485-S V2003 Schedule 485-S V2010	\$0 \$0	\$13,440 \$53,760	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$15,216 \$60,864	\$42,765 \$115,976	\$0 \$0	\$58,829 \$156,522
38		\$0 \$0	\$53,760	\$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$60,864	\$141,495	\$0 \$0	\$184,078
39	Schedule 485-S V2012	\$0	\$665,280	\$0	\$0	\$0	\$0	\$0	\$0	\$753,192	\$590,427	\$0	\$1,089,033
40	Schedule 485-S V2013	\$0	\$215,040	\$0	\$0	\$0	\$0	\$0	\$0	\$243,456	\$369,533	\$0	\$536,407
41	Schedule 485-S V2014	\$0	\$20,160	\$0	\$0	\$0	\$0	\$0	\$0	\$22,824	\$41,017	\$0	\$58,662
42	Schedule 485-S V2015	\$0	\$6,720	\$0	\$0	\$0	\$0	\$0	\$0	\$7,608	\$17,706	\$0	\$27,491
43	Schedule 485-S V2016	\$0	\$47,040	\$0	\$0	\$0	\$0	\$0	\$0	\$53,256	\$17,279	\$0	\$58,307
44	Schedule 485-S V2017	\$0	\$255,360	\$0	\$0	\$0	\$0	\$0	\$0	\$289,104	\$310,058	\$0	\$502,639
45	Schedule 485-S V2018	\$0	\$174,720	\$0	\$0	\$0	\$0	\$0	\$0	\$197,808	\$214,037	\$0	\$211,940
46	Schedule 485-S V2019	\$0	\$60,480	\$0	\$0	\$0	\$0	\$0	\$0	\$68,472	\$56,033	\$0	\$102,443
47	Schedule 489-S V2014	\$0	\$40,080	\$0	\$0	\$0	\$0	\$0	\$0	\$18,360	\$55,080	\$50,230	\$111,752
48	Subtotal	\$0	\$1,605,840	\$0	\$0	\$0	\$0	\$0	\$0	\$1,791,024	\$1,971,405	\$50,230	\$3,098,104
50	Schedule 485-P V2010	\$0	\$5,640	\$0	\$0	\$0	\$0	\$0	\$0	\$7,440	\$86,959	\$0	\$111,968
51	Schedule 485-P V2010	\$0 \$0	\$5,640 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$7,440 \$0	\$66,959 \$0	\$0 \$0	\$111,968
52		\$0	\$28,200	\$0	\$0	\$0	\$0	\$0 \$0	\$0	\$37,200	\$122,577	\$0 \$0	\$193,467
53	Schedule 485-P V2013	\$0	\$157,920	\$0	\$0	\$0	\$0	\$0	\$0	\$208,320	\$386,289	\$0	\$682,809
54	Schedule 485-P V2014	\$0	\$11,280	\$0	\$0	\$0	\$0	\$0	\$0	\$14,880	\$20,702	\$0	\$39,627
55	Schedule 485-P V2015	\$0	\$11,280	\$0	\$0	\$0	\$0	\$0	\$0	\$14,880	\$139,675	\$0	\$185,254
56	Schedule 485-P V2016	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
57	Schedule 485-P V2017	\$0	\$45,120	\$0	\$0	\$0	\$0	\$0	\$0	\$59,520	\$177,933	\$0	\$285,255
	Schedule 485-P V2018	\$0	\$5,640	\$0	\$0	\$0	\$0	\$0	\$0	\$7,440	\$50,297	\$0	\$56,806
	Schedule 485-P V2019	\$0	\$11,280	\$0	\$0	\$0	\$0	\$0	\$0	\$14,880	\$131,533	\$0	\$150,163
	Schedule 489-P V2004	\$0	\$22,680	\$0	\$0	\$0	\$0	\$0	\$0	\$17,880	\$53,640	\$110,023	\$324,586
	Schedule 489-P V2010	\$0	\$22,680	\$0	\$0	\$0	\$0	\$0	\$0	\$17,880	\$53,640	\$125,415	\$359,500
	Schedule 489-P V2011	\$0 \$0	\$45,360	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$35,760 \$53,640	\$107,280	\$224,578	\$666,911 \$430,115
	Schedule 489-P V2012 Schedule 489-P V2013	\$0 \$0	\$68,040 \$22,680	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$53,640 \$17,880	\$160,920 \$53,640	\$64,694 \$58,920	\$430,115 \$226,549
	Schedule 489-P V2013	\$0 \$0	\$22,680 \$22,680	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$17,880 \$17,880	\$53,640 \$53,640	\$56,920 \$75,402	\$260,522
	Schedule 489-P V2016	\$0	\$22,680	\$0	\$0	\$0	\$0 \$0	\$0 \$0	\$0	\$17,880	\$53,640	\$60,305	\$248,995
	Schedule 489-P V2017	\$0	\$45,360	\$0	\$0	\$0	\$0 \$0	\$0	\$0	\$35,760	\$107,280	\$185,130	\$578,778
Ų,		\$0	\$40,000	ΨU	Ψ	ΨU	ΨU	ΨU	Ψ0	400,100	¥ 101 ,200	¥ 100, 100	ψοι ο,ι ι ο

	A B C D	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	A	AJ	AK	AL
1			•					•			•				•
2	PORTLAND GENERAL ELECTRIC														
3	Revenues at Proposed Prices														
4															
5		Wheeling										Sch 128	Sch 128		Sch 102
6		Demand	Reactive	Fixed	Sch 146	Sch 122a	Sch 122b	Sch 125	Sch 145	Sch 132	Sch 143	Block 1	Block 2	Sch 129	Block 1
7	Grouping	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues F
8															
9	Schedule 7	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,967,919	(\$12,261,647)	(\$1,286,716)	\$0	\$0	\$0	(\$38,266,435)
10		\$0	\$0	\$336,785	\$0	\$0	\$0	\$0	\$653	(\$10,314)	(\$424)	\$0	\$0	\$0	(\$27,744)
11		\$0	\$0	\$336,785	\$0	\$0	\$0	\$0	\$1,968,571	(\$12,271,961)	(\$1,287,140)	\$0	\$0	\$0	(\$38,294,179)
12															
13		\$0	\$0	\$1,290,801	\$0	\$0	\$0	\$0	\$2,502	(\$39,532)	(\$1,626)	\$0	\$0	\$0	\$0
14		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$391,957	(\$2,384,407)	(\$244,973)	\$0	\$0	\$0	(\$2,117,177)
	Schedule 38	\$0	\$27,101	\$0	\$0	\$0	\$0	\$0	\$6,924	(\$56,340)	(\$4,406)	\$0	\$0	\$0	(\$5,538)
	Schedule 47	\$0	\$23	\$0	\$0	\$0	\$0	\$0	\$6,274	(\$58,843)	(\$3,894)	\$0	\$0	\$0	(\$166,434)
	Schedule 49	\$0	\$4,355	\$0	\$0	\$0	\$0	\$0	\$18,717	(\$123,272)	(\$11,617)	\$0	\$0	\$0	(\$462,013)
	Schedule 83-S	\$0	\$269,282	\$0	\$0	\$0	\$0	\$0	\$692,391	(\$3,231,157)	(\$432,744)	\$0	\$0	\$0	(\$1,920,430)
	Schedule 85-S	\$0	\$463,875	\$0	\$0	\$0	\$0	\$0	\$488,157	(\$2,037,525)	(\$318,363)	\$0	\$0	\$0	(\$282,020)
20		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	Schedule 91	\$0 \$0	\$0 \$0	\$2,814,258 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$5,378	(\$84,159)	(\$3,495)	\$0 \$0	\$0 *0	\$0 \$0	\$0 \$0
22		\$0 \$0			\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$524 \$4.720	(\$2,546)	(\$324)	\$0 \$0	\$0 \$0		\$0 \$0
	Subtotal	\$0	\$0 \$764,634	\$2,480,060 \$6,585,119	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$4,739	(\$74,165)	(\$3,080)	\$0	\$0	\$0 \$0	(\$4,953,611)
25		Φ0	\$764,634	\$6,565,119	\$0	\$0	\$0	\$0	\$1,617,563	(\$8,091,946)	(\$1,024,525)	\$0	\$0	\$0	(\$4,955,611)
	Schedule 85-P	\$0	\$127,792	\$0	\$0	\$0	\$0	\$0	\$130,113	(\$526,368)	(\$82,799)	\$0	\$0	\$0	(\$37,278)
	Schedule 89-P	\$0	\$33,485	\$0	\$0	\$0	\$0	\$0	\$84,247	(\$300,882)	(\$52,153)	\$0	\$0	\$0	\$0
28		\$0	\$10,718	\$0	\$0	\$0	\$0	\$0	\$372,213	(\$1,191,082)	(\$241,939)	\$0	\$0	\$0	\$0
29		\$0	\$171,995	\$0	\$0	\$0	\$0	\$0	\$586,574	(\$2,018,332)	(\$376,891)	\$0	\$0	\$0	(\$37,278)
30		ΨΟ	Ψ171,000	ΨΟ	•••	ΨΟ	40	40	\$000,014	(42,010,002)	(\$610,001)	40	40	••	(401,210)
31		\$0	\$16,191	\$0	\$0	\$0	\$0	\$0	\$13,179	(\$56,483)	(\$8,159)	\$0	\$0	\$0	\$0
	Schedule 75-T	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
33		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
34		\$0	\$16,191	\$0	\$0	\$0	\$0	\$0	\$13,179	(\$56,483)	(\$8,159)	\$0	\$0	\$0	\$0
35		**	4.5,	**	**	**	**	*-	4.0,	(400).00)	(4-1)	**	**	**	*-
36		\$0	\$2,807	\$0	\$0	\$0	\$0	\$0	\$0	(\$2,699)	(\$1,760)	\$0	\$0	\$0	\$0
37		\$0	\$2,979	\$0	\$0	\$0	\$0	\$0	\$0	(\$7,415)	(\$4,836)	\$0	\$0	\$0	\$0
38		\$0	\$2,156	\$0	\$0	\$0	\$0	\$0	\$0	(\$7,858)	(\$5,124)	\$0	\$0	\$0	\$0
39	Schedule 485-S V2012	\$0	\$12,602	\$0	\$0	\$0	\$0	\$0	\$0	(\$44,272)	(\$28,873)	\$0	\$0	\$0	\$0
40	Schedule 485-S V2013	\$0	\$5,252	\$0	\$0	\$0	\$0	\$0	\$0	(\$24,732)	(\$16,129)	\$0	\$0	\$0	\$0
41	Schedule 485-S V2014	\$0	\$1,838	\$0	\$0	\$0	\$0	\$0	\$0	(\$4,455)	(\$1,630)	\$0	\$0	\$0	\$0
42	Schedule 485-S V2015	\$0	\$1,339	\$0	\$0	\$0	\$0	\$0	\$0	(\$4,014)	(\$717)	\$0	\$0	\$103,797	\$0
43		\$0	\$325	\$0	\$0	\$0	\$0	\$0	\$0	(\$10,460)	(\$1,868)	\$0	\$0	\$356,891	\$0
44		\$0	\$2,774	\$0	\$0	\$0	\$0	\$0	\$0	(\$87,818)	(\$15,682)	\$0	\$0	\$2,975,351	\$0
45		\$0	\$6,060	\$0	\$0	\$0	\$0	\$0	\$0	(\$53,501)	(\$9,554)	\$0	\$0	\$1,956,616	\$0
46		\$0	\$357	\$0	\$0	\$0	\$0	\$0	\$0	(\$17,316)	(\$3,092)	\$0	\$0	\$612,651	\$0
47		\$0	\$4,771	\$0	\$0	\$0	\$0	\$0	\$0	(\$5,528)	(\$1,887)	\$0	\$0	\$0	\$0
48		\$0	\$43,257	\$0	\$0	\$0	\$0	\$0	\$0	(\$270,067)	(\$91,153)	\$0	\$0	\$6,005,306	\$0
49		*-	A= 700	**			**	**		164 482	(80.445)		A -		**
50		\$0	\$5,730	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$4,151)	(\$3,418)	\$0 \$0	\$0	\$0 \$0	\$0 \$0
51		\$0	\$0	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 (\$5,005)	\$0	\$0 \$0	\$0	\$0 \$0	\$0 \$0
52		\$0 \$0	\$924	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$5,965)	(\$4,912)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
53 54		\$0 \$0	\$18,237 \$1,466	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$21,886)	(\$18,024)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
	Schedule 485-P V2014 Schedule 485-P V2015	\$0 \$0	\$1,466 \$4,680	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$3,108)	(\$1,243)	\$0 \$0	\$0 \$0	\$0 \$755.618	\$0 \$0
	Schedule 485-P V2016	\$0 \$0	\$4,680 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$27,024) \$0	(\$4,913) \$0	\$0 \$0	\$0 \$0	\$755,618 \$0	
50	Schedule 485-P V2017	\$0 \$0	\$0 \$6,114	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$50,249)	\$0 (\$9,136)	\$0 \$0	\$0 \$0	\$0 \$1,827,247	\$0 \$0
	Schedule 485-P V2017	\$0 \$0	\$0,114	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$50,249)	(\$9,136)	\$0 \$0	\$0 \$0	\$365,142	\$0 \$0
	Schedule 485-P V2019	\$0 \$0	\$4,646	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$9,276)	(\$1,067)	\$0 \$0	\$0 \$0	\$645,317	\$0 \$0
	Schedule 489-P V2004	\$0 \$0	\$17,986	\$0 \$0	\$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$8,252)	(\$9,753)	\$0 \$0	\$0 \$0	\$045,517	\$0 \$0
	Schedule 489-P V2004	\$0 \$0	\$22,412	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$8,070)	(\$9,753)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
	Schedule 489-P V2010	\$0 \$0	\$17,080	\$0 \$0	\$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	(\$19,709)	(\$23,292)	\$0 \$0	\$0	\$0	\$0 \$0
	Schedule 489-P V2012	\$0	\$1,423	\$0	\$0	\$0	\$0	\$0	\$0	(\$9,583)	(\$11,326)	\$0	\$0	\$0	\$0
	Schedule 489-P V2013	\$0	\$1,423	\$0	\$0	\$0	\$0 \$0	\$0 \$0	\$0	(\$6,204)	(\$7,332)	\$0	\$0	\$0	\$0 \$0
	Schedule 489-P V2014	\$0	\$649	\$0	\$0	\$0	\$0 \$0	\$0 \$0	\$0	(\$17,029)	(\$8,855)	\$0	\$0	\$0	\$0 \$0
	Schedule 489-P V2016	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	(\$44,387)	(\$8,612)	\$0	\$0	\$1,725,810	\$0
	Schedule 489-P V2017	\$0	\$27,611	\$0	\$0	\$0	\$0	\$0	\$0	(\$95,914)	(\$18,610)	\$0	\$0	\$3,729,205	\$0
01		ΨΟ	ψ=1,011	Ψ0	Ψ0	Ψ0	ΨΟ	ΨΟ	Ψ0	(\$30,014)	(\$10,010)	ΨΟ	ΨΟ	#U,1 EU,200	ΨΟ

	A B C D	AV	AW	AX	AY	AZ	BA
1	7 5 5	Α,	7.11	700	Α1	712	D/N
2	PORTLAND GENERAL ELECTRIC						
3	Revenues at Proposed Prices						
4	1						
5			Revenues	Revenues			Revenues
6		Sch 137	Without	With	Supplemental	Total	Without
7	Grouping	Revenues	Supplementals	Sch 102	Revenues	Revenues	Sch 109
8							
9	Schedule 7	\$3,557,391	\$962,557,267	\$898,230,706	(\$20,199,769)	\$942,357,498	\$912,308,893
10	Schedule 15 Residential	\$1,208	\$710,480	\$682,736	(\$11,196)	\$699,284	\$677,089
11	Subtota	\$3,558,599	\$963,267,747	\$898,913,442	(\$20,210,965)	\$943,056,782	\$912,985,982
12	Schedule 15 Commercial	\$4.000	en 700 074	¢0.700.074	¢c0.400	ê0 700 407	ên 704 400
13		\$4,629 \$718,589	\$2,723,071 \$188,764,472	\$2,723,071 \$186,647,295	\$63,426 \$1,259,542	\$2,786,497	\$2,701,429 \$184,134,546
15		\$13,849	\$4,129,655	\$4,124,117	\$1,239,342	\$190,024,014 \$4,248,375	\$4,120,001
16		\$11,466	\$4,379,465	\$4,213,032	(\$44,637)	\$4,334,828	\$4,198,754
17		\$32,916	\$9,364,212	\$8,902,199	(\$188,850)	\$9,175,362	\$8,886,000
18		\$1,240,533	\$262,139,726	\$260,219,296	\$6,752,556	\$268,892,282	\$260,870,257
19	Schedule 85-S	\$891,417	\$166,659,481	\$166,377,461	\$4,880,198	\$171,539,680	\$166,995,474
20	Schedule 89-S	\$0	\$0	\$0	\$0	\$0	\$0
21	Schedule 91	\$9,949	\$5,892,665	\$5,892,665	\$138,742	\$6,031,407	\$5,846,956
22	Schedule 92	\$973	\$204,497	\$204,497	\$7,363	\$211,860	\$205,446
23	Schedule 95	\$8,767	\$5,192,900	\$5,192,900	\$122,266	\$5,315,167	\$5,152,619
24	Subtotal	\$2,933,087	\$649,450,146	\$644,496,535	\$13,109,327	\$662,559,472	\$643,111,480
25	a-tt-t-os a	40.40.40	# 4 P 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	A40 ====	# 225=	A44 470 05-	A40 744 0==
26		\$242,484	\$43,626,070	\$43,588,792	\$844,855	\$44,470,925	\$43,741,075
27 28	Schedule 89-P Schedule 90-P	\$156,459 \$707,205	\$25,387,759 \$105,835,971	\$25,387,759 \$105,835,971	\$76,223 \$483,877	\$25,463,982 \$106,319,848	\$25,463,982 \$106,319,848
29	Subtotal	\$1,106,148	\$174,849,799	\$174,812,521	\$1,404,956	\$176,254,755	\$175,524,905
30	Gubtotal	\$1,100,140	Ψ114,043,133	\$174,012,021	ψ1, 101 ,330	\$170,254,755	\$175,524,505
31	Schedule 89-T	\$24,476	\$4,612,304	\$4,612,304	\$2,510	\$4,614,815	\$4,614,815
32	Schedule 75-T	\$0	\$0	\$0	\$0	\$0	\$0
33	Schedule 76R	\$0	\$0	\$0	\$0	\$0	\$0
34	Subtotal	\$24,476	\$4,612,304	\$4,612,304	\$2,510	\$4,614,815	\$4,614,815
35							
36		\$0	\$129,772	\$129,772	(\$3,990)	\$125,782	\$125,782
37	Schedule 485-S V2010	\$0	\$381,073	\$381,073	\$23,634	\$404,707	\$371,218
38	Schedule 485-S V2011	\$0	\$432,787	\$432,787	\$73,792	\$506,579	\$423,905
39 40	Schedule 485-S V2012	\$0 \$0	\$3,056,637	\$3,056,637	\$415,772	\$3,472,409	\$3,006,591
41	Schedule 485-S V2013 Schedule 485-S V2014	\$0 \$0	\$1,339,579 \$141,459	\$1,339,579 \$141,459	\$203,055 \$21,515	\$1,542,634 \$162,974	\$1,310,687 \$136,678
42	Schedule 485-S V2015	\$0	\$163,323	\$163,323	\$7,407	\$170,731	\$159,166
43		\$0	\$529,611	\$529,611	\$19,301	\$548,912	\$518,777
44		\$0	\$4,306,014	\$4,306,014	\$162,045	\$4,468,059	\$4,215,060
45		\$0	\$2,743,347	\$2,743,347	\$98,722	\$2,842,069	\$2,687,935
46		\$0	\$894,663	\$894,663	\$31,952	\$926,615	\$876,729
47	Schedule 489-S V2014	\$0	\$278,385	\$278,385	(\$7,280)	\$271,105	\$271,105
48	Subtotal	\$0	\$14,396,651	\$14,396,651	\$1,045,926	\$15,442,576	\$14,103,632
49		4 -					
50		\$0	\$210,656	\$210,656	(\$6,592)	\$204,064	\$204,064
51	Schedule 485-P V2011	\$0	\$0	\$0	\$0	\$0	\$0
52 53	Schedule 485-P V2012 Schedule 485-P V2013	\$0 \$0	\$372,192 \$1,416,240	\$372,192 \$1,416,240	\$11,548 \$167,264	\$383,740	\$363,392 \$1,297,045
54	Schedule 485-P V2013	\$0 \$0	\$1,416,240	\$1,416,240	\$18,201	\$1,583,505 \$103,582	\$1,387,945 \$82,095
55		\$0	\$1,101,209	\$1,101,209	(\$30,534)	\$1,070,675	\$1,070,675
_	Schedule 485-P V2016	\$0	\$0	\$0	\$0	\$0	\$0
57	Schedule 485-P V2017	\$0	\$2,382,263	\$2,382,263	(\$16,188)	\$2,366,075	\$2,326,787
58		\$0	\$481,832	\$481,832	(\$10,481)	\$471,351	\$471,351
59		\$0	\$951,493	\$951,493	(\$18,977)	\$932,516	\$932,513
60	Schedule 489-P V2004	\$0	\$535,543	\$535,543	(\$17,255)	\$518,288	\$518,288
61	Schedule 489-P V2010	\$0	\$590,522	\$590,522	(\$16,874)	\$573,648	\$573,648
62	Schedule 489-P V2011	\$0	\$1,070,093	\$1,070,093	(\$41,209)	\$1,028,884	\$1,028,884
63		\$0	\$765,763	\$765,763	(\$20,038)	\$745,725	\$745,725
64	Schedule 489-P V2013	\$0 \$0	\$371,310	\$371,310	(\$12,972)	\$358,338	\$358,338
65 66	Schedule 489-P V2014	\$0 \$0	\$420,556 \$2,110,272	\$420,556 \$2,110,272	(\$25,202)	\$395,353	\$395,353
67	Schedule 489-P V2016	\$0 \$0	\$2,119,373 \$4,687,651	\$2,119,373 \$4,687,651	(\$52,337)	\$2,067,035 \$4,574,558	\$2,067,035 \$4,574,558
0/	Schedule 489-P V2017	φU	\$4,687,651	\$4,687,651	(\$113,093)	\$4,574,558	\$4,574,558

	A B C D	E	F	G	Н		J	K	L	М	N
9	PORTLAND GENERAL ELECTRIC										
3	Revenues at Current Prices										
4		Basic	Basic	Vol. Trans	Toursmission	Transmission	Vojemetric	Volumetric	Volumendo		
4		Charge	Charge	& Referred		& Rejated	Dist	Diet	Dist	FocBien	Facilities
7 6	Greeping	Sphase	Sphase	Reverses	Revenues	Revenues	Reverses	Revenues	Revenues	Revenues	Ravences
	Schedub 7	\$103,361,901	\$1,660	\$15,819,038	\$0	\$0	\$169,584,223	\$87,446,437	\$62,230,332	\$0	\$0
10	Schodule 15 Residential Substate	\$100,351,501	\$0	\$4,211	\$0 \$0		\$160,499	\$0	90	\$0	
12		\$103,351,501	\$1,500	\$15,023,246	- 50	- 50			POZ 230 332		
13	School 15 Commercia	\$0	\$0					\$0	50		
16	Schedule 32 Schedule 38	\$11,424,136	\$10,422,979	\$2,074,364	\$0 \$0		\$55,925,431	\$1,440,164	\$0 \$0		
18	Solvedus 47	\$47,940	\$685,770	\$39,373	\$0	30	\$768,326	\$1,192,795	90		80
17	Schedule 48 Schedule 53-5	\$1,440 \$245,820	\$304,320 \$5,206,060		\$0 \$5,594,330	\$0 \$0	\$1,515,538 \$0	\$2,708,896	90	\$14,982,872	\$0 \$24,502,127
10	Schedule 85-6	\$0	\$5,096,500	\$0	\$3,712,784	\$0	\$0		93	89,487,254	\$1,658,735
20 21	Schedul III-S Schedul III	\$0	\$0 \$0	\$34.006	\$0		\$1,586,543				50
22	Schedule 91 Schedule 92	\$0	\$0	\$3,396	\$0	\$0	\$69,189	\$0	92	50	50
23 24	School 55 Subsord	\$11,734,936	\$00 E04 F04	\$30,567	\$0 \$9,307,113	\$0 \$0	\$1,599,901 \$64,152,724	\$6 229 224	90	\$3 \$24,470,129	\$0 \$34 159 663
25											
25 27	Schools 15-P Schools 15-P	\$0 \$0	\$1,068,580	\$0	\$039,149 \$618,608		\$0 \$0	\$0 80		\$1,411,744	\$3,368,481
24	Schedule SG-P	\$0	\$249,000	\$0	\$1,702,023	\$0	\$0	\$0	90	\$33,120	\$89,360
29 30	Subtobil	\$0	\$1,539,800	\$0	\$3,158,060	\$0	\$0	\$0	\$0	\$1,530,854	\$4,025,041
31	School # 15-7	\$0	\$231,000	\$0	\$168,663	\$0	\$0	\$0	90	\$93,000	
33	Schedule 75-2 Schedule 76R	\$0	\$0 \$0	\$0 \$0	\$0	\$0	\$0 \$0	\$0 \$0	90	50	50 50
34	Schedule 75R Subtonel	\$0	\$231,000	\$0	\$168,963	\$0 \$0	\$0	80	90 90	\$93,000	\$279,000
35 35											
37	School 469-5 V2022 School 465-5 V2012	\$0 \$0	\$12,000	\$0			\$0 \$0				
-38	Sofredus 485-S V2011	\$0	\$48,000	\$0	\$0	\$0	\$0	\$0	90	\$65,088	\$178,844
33 40	Schedus 485-5 V2012 Schedus 485-5 V2013	\$0 \$0	\$594,000	\$0 \$0		90 90	\$0 \$0		90 90	\$805,464 \$250,352	\$746,275 \$467,074
41	Schedule 485-S V2014 Schedule 485-S V2015	\$0	\$18,000	\$0	\$0	\$0	\$0	\$0	90	\$24,408	\$51,844
84	Scheduls 485-3 V2815 Scheduls 485-3 V2815	\$0	\$42,000	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0	\$0 \$0	\$3,135 \$55,652	\$22,380 \$21,640
44	Schedule 485-3 V2017	\$0	\$228,000	\$0	50	90	\$0	50	93	\$309,155	\$391,901
45 46	Schedul 485-5 V2018 Schedul 485-5 V2013	\$0 \$0	\$158,000	\$0	\$0 \$0		\$0 \$0				
47	Schedut 483-5 V2014	\$0	\$37,920	\$0	\$0	90	\$0	\$0	90	\$12,000	\$57,040
45	Submid	80	\$1,435,020	\$0	50	80	\$0	80	93	\$1,914,768	\$2,479,267
50	Schedule 485-P V2810	\$0	\$5,640	\$0			\$0	\$0	90		
51 52	School # 485-P V2011	\$0									
83	Schedus 485-P V2013	\$0	\$167,620	\$0	\$0	\$0	\$6	\$0	93	\$211,008	\$455,414
54 55	Schedule 485-P V2814	\$0	\$11,280 \$11,280	\$0			\$0	\$0	\$0 \$0		\$34,407
56	School 485-7 V2015 School 485-7 V2015	\$0	\$0	\$0	\$0	\$0	\$0	80	93	80	50
57 58	Schedule 485-P V2017 Schedule 485-P V2018	\$0	\$45,120 \$5,040	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0	\$0 50		\$208,774 \$59,297
59	Schedule 485-P V2019	\$0	\$11,260	\$0	\$9	\$2	\$0	\$0	92	\$15,072	\$155,071
60 61	Sobort at 483-2 V2004	\$0	\$21,240 \$21,240	\$0	\$0 \$0	\$0	\$0 \$0	\$0 \$0	\$0 \$0	\$18,600	\$55,800
62	Schedus 483-P V2010 Schedus 483-P V2011	\$0	\$42,460	\$0	\$0	\$3	\$0	\$0	90	\$37,200	\$111,600
63	Schedul 489-P V2012 Schedul 489-P V2013	\$0	\$63,720 \$21,240	\$0	\$0 \$0	90 90	\$0 \$0	\$0 \$0	\$0 \$0		\$167,400
65	School & 483-P V2014	\$0	\$21,240	\$0	\$0	90	\$0	\$0	90	\$13,000	\$55,800
65	Schedule 489-P V2816 Schedule 489-P V2817	\$0	\$21,240 \$42,460	\$0			\$0 \$0		\$2 \$2		
69	Schedule 483-P V2018	\$0	\$42,460	\$0	\$0	\$0	\$0	\$0	\$0	\$37,200	\$111,600
93	Schedule 489-7 V2019	\$0	\$21,240	\$0 \$0	50	90	\$0 \$0	\$0 80	90	\$13,000	
70 71	Subtrook		\$594,060		10			80	92		\$2,152,664
72 73	Schedus 489-T V2897 DAX Schedus 489-T V2812 DAX	\$0 \$0	\$46,200	\$0 \$0		\$0	\$0 \$0	\$0 \$0	\$0		
74	Schedus 489 T V2812 DAX Schedus 489 T V2813 DAX	\$0	\$46,200 \$48,200	\$0		\$0 \$0	\$0		\$0 \$0	\$13,600 \$13,600	\$55,800 \$65,800
75	Subtote	\$0	\$138,600	\$0	\$0	\$0	\$0	\$0	90		\$111,619
76 77	COS Totals	\$115,086,437	\$25,386,804	\$18,965,177	\$12,634,157	80	\$233,917,446	\$65,775,261	\$62,296,332	823,193,990	\$38,463,703
78	Market Totals	\$0	\$0	\$0	\$0	\$0	\$0	\$0	90	93	90
79 80	Direct Access Totals Totals	\$0 \$115,086,437	\$2,169,480	\$18,085,177	\$12,634,157	\$0 \$0	\$0 \$223,917,445	\$00,775,261		\$2,574,632 \$28,958,622	
81						- "					
82	9	\$166,272,732		_				_	_		
8	III I	\$4,651,933									
85	I D	\$54,798,738									

	0	Р	Q	R	9	T	U	V	w	×
H										
÷				F						_
3				Exploit rolet						
6		Distribution		System	Block 1	Block 2	Block 3	Flet	On-peak	Offspeak
ŭ	Facilities	Demand	Demand	Urage	Energy	Energy	Energy	Energy	Energy	Energy
ž	Revenues	Revenues	Revenues	Revenuez	Revenues	Revenue	Revenues	Revenues	Revenue	Revenues
t	\$0	50	50	817 030 096	\$270,189,253	\$139,322,024	160 402 466	\$0	\$0	\$0
10	\$0	\$0	\$0	\$24,382	\$0	\$0	\$0	\$164,963	\$0	\$0
11	\$0	\$0	\$0	\$17,054,448	\$270,189,253	\$139,322,004	\$52,455,495	\$164,963	\$0	\$0
2	\$0	\$0	50	\$93,450	\$0	\$0	\$0	\$632,266	50	\$0
34	50	\$0	\$0	\$3,135,659	50	50	\$0	\$87,989,342	\$0	\$0
6	\$0	\$0	\$0	\$76,372	30	\$0	\$0	\$0	\$1,024,101	\$718,022
9	\$0 \$0	\$0 \$0	\$0	\$90,211	30	\$0 \$0	\$0	\$1,616,866	\$0	\$0
7		\$23,068,861	\$0 \$0	\$183,285 \$17,357,458	\$0 \$0		\$0 \$0		\$122,809,761	\$0 \$46.141.200
9	10	\$15,308,003	80	\$2,377,113	80	\$10	\$0	\$0	\$87,192,302	\$34,888,759
o.	\$0	\$0	\$6	\$0	\$0	\$0	\$0	\$0	\$0	\$6
1	\$0 \$0	\$0 \$0	\$0 \$0	\$99,217	\$0 \$0	\$0 \$0	\$0 \$0		\$0	\$0 \$0
á	\$0	10	80	\$87,435	80	\$0	\$0	\$1,197,545	80	80
7		\$38,373,944		\$23,515,238	50	\$0		\$107,337,066		\$60,746,012
ă										
55 77	\$0	\$2,875,864	\$0 \$0	\$638,738	90 90	\$0 \$0	\$0 \$0		\$23,064,300 \$14,104,946	
á	\$2,921,375		50	\$1,294,136	90 50	\$0 \$0	\$0 \$0	50	\$61,315,416	\$33,411,423
9		\$13,033,346	\$0	\$2,372,191	\$0	\$0	\$0	\$0	\$56,484,551	\$80,601,634
я										
1 2	\$143,726 \$0	\$343,376	\$0	\$68,407	\$0 \$0	\$0 \$0	\$0 \$0	\$0	\$2,390,492	\$942,013
3	\$0	- 40	\$0	\$0	90	\$0	\$0		\$0	\$0
4	\$143,726	\$343,376	\$0	\$68,407	80	\$0	\$0	\$0	12,390,492	\$942,013
Į	50	\$60,407	50		50	50	50	50	50	50
7	\$0	\$160,720	80		90		\$0		\$0	80
7	\$0	\$166,016	30		90	\$0	\$0	\$0	80	\$0
a	50		50	4829,4730	\$0	SD	50			50
2	\$0 \$0	\$80,794	\$0 \$0	(\$16,120)	\$0 80	\$0 \$0	\$0 \$0		\$0 \$0	
Н	50	29,228	\$0	(9717)	\$0	\$6	\$0	\$0	\$0	\$0
п	\$0	\$59,071	\$0	(\$1,990)	\$0	\$0	\$0	\$0	\$0	\$0
1	\$0	\$516,120	\$0	(\$15,682)	\$0	\$0	\$0	\$0	\$0	\$0 \$0
H	\$0	\$217,624 \$106,190	\$0 \$0		80 80	\$0	\$0 \$0			
H	\$52,700	\$114,750	\$0	(\$674)	50	\$0	\$0	\$0	\$0	\$0
3	\$82,700	\$3,181,195	80	(\$39,930)	90	\$0	\$0	\$0	\$0	80
9	50	\$115,066	50		50	\$0	SD.	50	so	\$0
i	\$0	\$115,066 \$0	\$0	93,990	\$0	\$0	\$0			\$0
2	10	\$196,319	\$0	(85,614)	80		\$0	\$0	\$0	\$0
3	\$0	\$701,701	\$0	(\$20,596)	\$0	\$0	\$0	\$0	\$0	\$6
4	\$0 \$0	\$40,724	\$0 \$0	(\$1,421)	\$0 \$0	\$0 \$0	\$0 \$0		\$0 \$0	
ı	\$0	\$0	80	\$0	80	\$0	\$0	\$0	\$0	\$0
7	\$0	\$293,147	\$0	(\$10,441)	\$0	\$0	\$0	\$0	\$0	\$0
5	\$0	\$50,370 \$154,318	\$0 \$0	(\$1,920)	\$0 80	\$0 \$0	\$0		\$0 \$0	
H	\$116,618	\$154,316	50	063,4911 063,7511	50	10	50		50	
ī	\$131,792	\$369,447	\$0	(\$3,990)	50	\$0	\$0	\$0	\$0	\$0
2	\$235,997	\$685,363	\$0	(\$8,958)	\$0	\$0	\$0	\$0	\$0	\$0
3	\$67,983 \$61,916	\$442,016 \$232,817	\$0	(84,356)	80 80	\$0 \$0	\$0 \$0		\$0	
5	\$79,236	\$297,730	\$0	(\$3,400)	90 90	\$0 \$0	\$0	\$0	\$0	\$0
č.	\$63,371	\$255,884	\$0	(\$3,312)	\$0	\$0	\$0	\$0	\$0	\$0
Į.	\$164,544	\$594,762	80	(\$7,198)	80		\$0	\$0	\$0	80
â	\$221,273	\$658,713 \$181,670	\$0 \$0	(\$6,320)	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0	\$0 \$0
ū	\$1,266,016	\$5,774,530	80	(\$101,096)	80	50	\$0	\$0	\$0	\$0
1										
2	50	\$13,492	\$0	(\$1940	50	\$0	\$0	\$0	\$0	
	\$254,035	\$204.547 \$249.930	\$0	(\$6,947) (\$6,999)	\$0 80	\$0 \$0	\$0	\$0	\$0	
3	\$412,863	\$467,968	\$0	(\$11,230)	\$0	\$0	\$0	\$0	\$0	\$0
4										
7	11,660,466	\$61,750,669	50		\$270,189,253	\$159,522,024	\$12,455,495	\$107,502,007 \$0	\$311,901,318	\$155,371,876 \$0
H	\$1,670,579	\$9,423,094	\$0	(\$202,235)	\$0	\$0	\$0	SD	\$0	\$0
g.		\$61,174,362		\$42,808,049	\$270,189,253	\$139,322,004	\$52,465,406	\$107,502,027	8311,901,318	\$125,371,876
1										
2		_	_	_			_	_	_	_
ž.										
9										

_				40	4.0	45	AE	- 15	4.0		AI	Al	AK	AL.	AM	AN	AO	AP		AR	AG	AT	ALI	W	AW	AX	AY	AZ	
1	-		~	All	, AG	ΑĐ	All	~	nia	AH.	~	~	- 75	~	- 04	AN	703	~	AG.	AK.	A9	- 01	AD.	~~	^***	۸۸.	AT	Λ.	iin.
3	-		_	+	+	+	+	+	-	_	_		_	_	_	+	_			_	\vdash	_		\vdash	_	_			-
4 5 W	***			-	-	\vdash	-	-	=		50.118	Sch 128		Sch 102	Seb 433	6-h 433				_	=			=	Revenues	Revenues			Revenues
ě D	mand	Reactive	Fixed	Sch 145	5ch 122s	Sch 122	b Sch 125	Sch 145	Sch 132	Sch 143	Diock 1	Diock 2	Sch 129	Block 1	Billock 2	Billack 3	Sch 105	Sch 109	Sich 110	Sch 112	Sch 123	Sch 126	Sch 135	Sch 137	Without	With	Supplemental	Total	Without
7 Re	*0.920.0	Revenues	Ravence	Revenue	a Revenue	Revenu	in Reverses	Revenue	Revenues	Revenues	Revenue	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues	Revenues				Supplementals	Sch 122	Revenue	Revenues	Sch 109
10	\$0 \$0	\$0	\$341.00	9 8	9 50			0 \$2,943,899		Ø1,439,0940	90 90	90 90	\$0 \$0	(\$42,597,795)	dk21,743,65	2 30	di1,211,027)	\$37,314,799 \$26,863	\$378,449	\$2,270,675		\$0 \$0	\$1,059,648	\$3,567,391		\$663,523,912 \$600,525	\$19,254,821) \$1,044	\$628,160,726 \$716,791	
ñ	50		\$341.09					0 \$2,044,325			50	50			(\$21,743.05	2) 50		\$37.341.529	\$379,772				\$1,060,006				(\$19.253,777)	\$625,667,520	
13	\$0		\$1,309,913					0 \$2,752			\$0					3 50			\$1,251				\$1,376						
14	50	\$0 \$27.101	\$0				20 \$	0 \$405,289 0 \$7,239	50	(\$277,635)	50	50	- 50	(\$2,077,324)	9	90	(\$244,970)	\$7,496,700	\$91,572	\$342,963		\$0	\$212,310	\$718,509	\$154,212,064			\$189,640,551	
18	\$0.	\$23	- 8	1 1	30		0 8	0 \$4,274	\$0	(\$4,327)	90 90			(\$163,301)		90		\$199,823	31,947	\$19,817	(91,791)		\$3,246		\$4,269,396	\$4,106,095	327,998		\$4,127.0
17		\$259,202	- 80	1 10	1 10		0 5	0 \$721,240	50	(\$492.443)	90 90	50	50	(\$1,884,282)		2 90	(\$490,443)	\$10,516,507	\$113,395	\$173,095	(\$225,771)		\$373,045	\$1,240,533	\$252,154,861	\$250,300,580	\$10,047,870	\$272,232,731	\$251,715.2
19 20	- 8	\$463,876						0 \$509.381		(\$380.812)	\$0 \$0			(\$274,711) \$0		30 30		\$6,003,897				\$0 \$0		\$891,417 \$0	\$170,083,385		86,718,256 90		\$170,792.7
2H 22	50	\$0	\$2,750,990	1 \$6	\$ \$0		n \$	0 \$5,915	\$0	(\$4,003)	90 90	90	\$0	\$0	9	90	(\$12,360)	\$200,853	\$2,589	\$4,722		\$0	\$7,958	\$9,949	\$5,840,331	\$5,040,331	\$210,533	\$6,000,004	
23.	\$0	\$0	\$2,431,333	1 10	3 \$0		0 8	0 \$5,213	80	(83,554)	90	\$0	\$0	\$0	-	3 83	(\$10,900)	\$177,002	82,370		(\$1,890)	\$0	\$2,606	\$8,767	\$5,143,780	\$6,146,780	\$185,532	\$5,392,312	\$5,155.31
24 25	\$0	\$764,634	\$6,499,911	1 80	90	1 8	0 \$	0 \$1,685,570	\$0	(\$1,191,315)	90	90	\$0	(\$4,890,396)		1	(\$1,113,997)	\$25,110,526	\$294,195	\$650,077	(\$1,633,628)	\$0	\$865,964	\$2,933,087	\$649,204,539	\$943,344,190	\$22,990,083	\$671,064,606	\$945,954,0
77		\$127,702						0 \$141,842		(\$100,542)	\$0 90					3 80		\$995,082	\$12,084	\$23,667 \$4,612			\$70,071 \$48,141			\$44,573,432 \$25,953,980		\$45,816,258 \$36,138,632	
20	50	\$10,718	- \$6	9	\$ \$0		0 9	0 \$409,435	50	(\$279,190)	90	90	\$0	\$3	9	93	(\$241,939)	90	90	\$18,611	\$3	\$3	\$294,717	\$707,205	\$108,051,384	\$108,051,394	\$818,899	\$106,670,263	\$108,870,2
10	\$0	\$171,995	\$0	90	90		9 \$	0 \$543,547	50	(\$443,800)	50				-	90	(\$362,805)	\$955,092	\$12,954	\$45,279	(\$24,127)	\$0	\$323,829	\$1,105,148	\$170,615,383	\$178,578,805	\$2,209,650	\$160,825,042	\$179,659,9
12	\$0 \$0	\$16,191	\$6					0 \$14,435			90 90	90 90				3 30		90 90	90 90	\$428 \$0	\$0 \$0	\$0 \$0					\$28,899 \$0		
33	- 60	\$0	- 8	1 10			22 \$	0 50	50		- 50	90 80		\$0				90		50	50	\$0 \$0		50	50	\$0	50	60	_
E .	- 80	\$16,191	- 10	1 16	9 \$0	+ *	8	0 814,435	- 80	(810,041)	90	50	- 10	80	- 3	3	(88,199)	93	83	\$628	80	80	\$7,531	\$24,476	\$4,676,168	\$4,676,168	\$28,899	\$4,766,037	
17	50	\$2,079	- 50	9 \$6		-	2 5	0 50	50	(\$1,995)	50 80	50		\$0 \$0		3 50	(\$2,220)	\$0 844 283	\$554	\$409 \$1,290		\$0 80	\$0 \$0	\$0	\$143,779 \$418,539	\$143,779	\$34,243	\$140,004	
ii.	80	\$2,166	- 8	1 16			0 1	0 10	- 10	g65,808)	- 80	90		10		90	(86,491)	\$109,322	\$1,367	\$1,387	(\$683)	\$0 \$0		\$0	\$477,928		\$99,073	\$677,061	\$497,7
0	50	\$5,252	\$0	\$ \$0	\$ \$0		0 5	0 50	50	(\$10,723)	90 90	50	50		9	90 90		\$615,958 \$305,707	\$3,534	\$7,689 \$4,301	(\$1,917)	\$0		\$0	\$1,459,342	\$1,459,342	\$559,212 \$274,214	\$1,733,586	\$1,425,8
11	- 8	11,838		3 \$			0 5	0 80	10	(\$1,847) (\$812)	90 90	\$0 \$0	\$125,366 \$112,160	\$0 \$0		3 30	(\$2,065)	\$34,772 \$16,292		\$435 \$191		\$0	\$0 \$0	\$0 \$0				\$311,603	
9	50	\$325		3 \$0	\$ \$0		0 \$	0 90		(\$2,117)	\$0 50	90	\$379,683		9	\$0		\$39,540	\$493	\$400 \$4.182	(\$249)	\$0	\$0	\$0	\$557,802	\$557,902	\$36,112	\$593,915	\$554,0
45		\$8,060		1 8	1 10		9 8	0 80			90 90	90	\$2,128,674	19		3 80	(\$12,101)	\$203,814	\$2,548	32,548	(81,274)	\$0			\$2,578,873	\$2,978,873	\$184,707	\$3,163,580	\$2,999,7
59 57	50	\$367	\$6	9 90				0 90			\$0 \$0	50	\$612,661	\$0		90 90		\$95,995		\$835 \$135		\$0 \$0		\$0		\$913,163	\$59,791	\$872,834	
43	50	\$43,257	- 80) #C	9 \$9	_	0 8	0 80	- 50	(\$193,459)	90	50	\$4,675,167	50		93	(8115,381)	\$1,770,505	822,131	\$23,939	(\$11,065)	\$0	50	80	\$15,692,465	815,992,495	81,595,593	\$17,279,154	\$15,508.6
522	\$0		\$6					0 \$0			90					90		\$0		\$977	\$0	\$0		\$0		\$232,585	(\$7,013)	\$224,773	\$224,7
51 52	50 50				9 \$0			0 50	\$0 \$0		90 90	50 50				3 50		\$29,907		\$1,403		\$0 \$0		50	\$0 \$404,521		\$15,848	\$420,368	\$393.4
3		\$18,237	- 8		90 \$0		0 S	0 \$0	50		\$0 \$0	50	\$101,038	\$3 \$0		30 30		\$259,591 \$20,412				\$0 \$0		\$0	\$1,523,682			\$1,742,662	\$1,494,1
8		\$4,080	- 80	1 10			9 5	0 50			50	90	\$815,334	\$0		3 50	(\$6,950)	\$20,412			\$3	50						\$1,185,569	
1.00	\$0 \$0		# #	90			0 \$	0 90			90 90		\$1,899,877	\$0 \$0			(\$12,398)	90 901,901				\$0 \$0					90 931,393		
55	50							0 50	\$0 \$0	(\$2,040)	90 90		\$395,825 \$645,217	\$0		90		\$0 \$3		\$482 \$873		\$0 \$0	\$0 \$0	\$0	\$525,749 \$882,213	\$525,749 \$982,213	(\$3,855)	\$521,694 \$675,236	
0	\$0.1	\$17,666	- 8	1 1	1 10		0 8	0 \$0			90 90	90	\$0	\$9	-	3 30	\$12,7630	90	30	\$790	\$0	\$0			\$659,060	\$999,090	(\$24,996)	\$636,063	\$535,0
1	\$0	\$22,412	\$0	1 10	\$ \$0		9 \$	0 \$0	50	(\$28,667)	90	50	\$0	50	9		(\$30,450)	90	50		50	50	\$0	\$0	\$1,120,781	\$1,120,761	(\$23,477) (\$57,334)	\$592,145 \$1,063,427	\$1,053,4
3	\$0 \$0	\$1,423	80		9 \$0			0 90	50 50		80 90			\$0		3 30		\$0 \$0		\$871 \$664		\$0 \$0		\$0		\$793,985 \$397,954	(827,879)	\$766,106 \$369,606	\$799.1 \$399.0
5	50		\$0		\$ \$0			0 90		(\$10,000)	90	50	\$607,334		9	90 90 90	(\$11,579)	\$0		\$681	\$3		\$0		\$1,057,183		(\$21,797)	\$1,045,367 \$2,229,206	\$1,045,3
17	80	\$27,611	- 8	1 16	10			0 50	1 1	(\$22,605)	92	80	\$4,075,642	80	-	3 30	(\$24,336)	\$0 80		\$662 \$1,432	80	80	80	100	\$5,079,710	\$6,076,710	(\$21,200)	\$5,030,001	\$5,030.6
9	\$0 \$0	\$15,904	\$0	9 \$6	90	1		0 90	\$0 \$0	(\$26,649)	\$0 \$0		\$4,618,360			90		90 \$3		\$1,660 \$459		\$0 \$0	50 50	\$0 \$0	\$5,897,202	\$6,997,202	(\$53,297)	\$5,943,904	
ų.	\$0	\$151,426	- 8) \$6	1 10		2 8	0 80	\$0	(\$210.063)	90		\$14,592,203	\$0 \$0		90		\$395,857		\$22,864	(82,287)	50	50	80	\$27,017,997	827,017,997	(\$45,425)	526,672,562	825,635.7
2	50	\$445	\$0	1 50	1 50		a s	0 50	50	(\$277)	\$0	50	50	\$0		\$0	(\$290)	50	\$0	\$17		50	50	\$0	\$134.452			\$133.697	
2		\$14,847	\$0 \$0					0 50		(\$16.124) (\$13.546)	90 80	50 50				3 83		93 83		\$1,008 \$847		\$0 80		\$0			(\$32.240)	\$505,733	
2		\$106,444	×					0 90			90	90	\$0					\$0		\$1,872		\$0		\$0		\$1,337,994	(959,995)	\$1,277,969	\$1,277,8
7		\$662,816			10			0 \$4,387,977		(B3,053,895)	80				dk21,743,65					\$2,993,479					81,779,647,173				
20	\$0 \$0	\$301,127			9 50			0 90	\$0 \$0		\$0 \$0		\$0 \$23,267,370			30 30			\$0 \$20,705			\$0	50	50	\$44,048,327	\$44,046,327	\$1,401,389	\$45,529,715	\$43,381,3
97	50	\$1,253,946	\$6,841,934	1 8	1 10	1	0 8	0 \$4,387,977	50	(\$3,397,331)	90	90	\$23,257,370	(\$47,001,050)	(\$21,743,65	2) 90	(\$3,090,771)	\$95,953,618	\$701,700	\$3,017,150	(\$890,195)	\$2	\$2,257,332	\$7,622,310	\$1,523,595,500	\$1,754,950,998	\$7,326,223	\$1,831,021,723	\$1,795,493.1
12																													
4								+								-													
6						_			_												_			_					

Schedule 132 Allocation

			Gen Rev	2019 Non-Gen
		Rev at Current	at Current	Base Rev at
		Prices	Prices	Current Prices
Sch 7		\$946,490,531	\$501,966,773	\$444,523,759
Sch 15		\$3,459,005	\$797,218	\$2,661,787
Sch 32		\$184,212,064	\$97,989,342	\$86,222,722
Sch 38		\$4,170,414	\$1,742,123	\$2,428,290
Sch 47		\$4,269,396	\$1,515,856	\$2,753,540
Sch 49		\$9,348,582	\$4,513,305	\$4,835,277
Sch 83		\$262,184,861	\$170,951,031	\$91,233,829
Sch 85				
8	85-S	\$170,083,395	\$122,081,042	\$48,002,353
8	85-P	\$44,610,009	\$33,191,691	\$11,418,318
Sch 89				
8	89-S			
8	89-P	\$25,953,980	\$21,247,965	\$4,706,016
8	39-T	\$4,676,168	\$3,332,505	\$1,343,663
Sch 90		\$108,051,394	\$94,726,839	\$13,324,554
Sch 91/95		\$10,987,111	\$2,556,465	\$8,430,646
Sch 92		\$205,446	\$129,842	\$75,604
Sch 485-S		. ,	,	,
	Sch 485-S V2013 and Prior	\$5,747,347		\$5,747,347
S	Sch 485-S V2014 L	\$280,091	\$125,395	\$154,696
	Sch 485-S V2015 M	\$177,527	\$112,160	\$65,367
	Sch 485-S V2016 N	\$557,802	\$378,683	\$179,120
	Sch 485-S V2017 O	\$4,686,768	\$3,254,487	\$1,432,281
	Sch 485-S V2018 P	\$2,978,873	\$2,126,674	\$852,200
	Sch 485-S V2019 Q	\$913,153	\$612,651	\$300,502
Sch 485-P		. ,	, ,	, ,
S	Sch 485-P V2013 and Prior	\$2,160,788		\$2,160,788
S	Sch 485-P V2014 L	\$193,366	\$101,838	\$91,528
S	Sch 485-P V2015 M	\$1,196,799	\$816,334	\$380,465
S	Sch 485-P V2016 N	\$0	\$0	\$0
S	Sch 485-P V2017 O	\$2,602,879	\$1,998,877	\$604,001
S	Sch 485-P V2018 P	\$525,749	\$396,826	\$128,924
S	Sch 485-P V2019 Q	\$982,213	\$645,317	\$336,896
Sch 489-S				
S	Sch 489-S V2014 L	\$350,904	\$65,118	\$285,786
Sch 489-P				
S	Sch 489-P V2013 and Prior	\$3,477,083		\$3,477,083
S	Sch 489-P V2014 L	\$1,067,183	\$627,334	\$439,849
S	Sch 489-P V2015 M			\$0
S	Sch 489-P V2016 N	\$2,241,405	\$1,829,822	\$411,583
S	Sch 489-P V2017 O	\$5,076,710	\$4,075,642	\$1,001,068
S	Sch 489-P V2018 P	\$5,997,202	\$4,918,360	\$1,078,842
S	Sch 489-P V2019 Q	\$1,496,618	\$1,181,852	\$314,766
Sch 489-T				
S	Sch 489-T V2013 and Prior	\$1,337,864		\$1,337,864
		\$1,822,750,682	\$1,080,009,366	\$742,741,316
		Ψ1,022,100,002	ψ 1,000,000,000	Ψι 12,1 - 1,010

\$444,524 \$2,662 \$86,223 \$2,428 \$2,754 \$4,835 \$91,234 \$48,002 \$11,418
\$4,706 \$1,344 \$13,325 \$8,431 \$76
\$5,747 \$155 \$65 \$179 \$1,432 \$852 \$301
\$2,161 \$92 \$380 \$0 \$604 \$129 \$337
\$286
\$3,477 \$440 \$0 \$412 \$1,001 \$1,079 \$315
\$1,338

PORTLAND GENERAL ELECTRIC CONSUMER IMPACT OFFSET

Grouping	Cycle MWH	Revenues at Current Prices (\$000)	2019 Allocated Costs (\$000)	Percent Change	Impact Offset Amount	Impact Offset MWH	CIO mills/kWh	CIO Revenues
Schedule 7	7,568,918	\$947,435	\$963,143	1.7%		7,568,918	(80.0)	(\$606)
Schedule 15	15,774	\$3,459	\$3,337	-3.5%		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	6.10	\$96
Schedule 32	1,633,156	\$184,212	\$188,882	2.5%		1,633,156	(80.0)	(\$131)
Schedule 38	31,475	\$4,170	\$4,130	-1.0%			0.00	\$0
Schedule 47	21,633	\$4,269	\$4,379	2.6%			0.00	\$0
Schedule 49	64,540	\$9,349	\$9,364	0.2%			0.00	\$0
Schedule 83	2,884,961	\$262,185	\$262,146	0.0%			0.00	\$0
Schedule 85	2,713,846	\$237,696.76	\$231,359.48	-2.7%			0.00	\$0
Schedule 89	463,935	\$51,675.12	\$48,568	-6.0%		463,935	0.38	\$176
Schedule 90	1,861,066	\$108,051	\$105,675	-2.2%		1,861,066	0.08	\$149
Schedules 91 & 95	50,583	\$10,987	\$11,182	1.8%			(1.90)	(\$96)
Schedule 92	2,496	\$205	\$205	-0.5%			0.00	\$0
COS TOTALS Sch 485 Energy Sch 489 Energy Totals	17,312,384 926,440 <u>1,161,686</u> 19,400,511	\$1,823,695	\$1,832,370	0.5%	\$0	<u>1,161,686</u> 12,688,761	0.00 0.38	\$0 <u>\$441</u> \$31
Note: does not include Sonote: does not include en		\$0 (\$945)	\$0 (\$960)					
Reconcile CIO workshee	t to revenues	\$1,822,751	\$1,831,409					
		\$1,822,751	\$1,831,409					
	CIO	0	0					
Schedules	Allocation	MWh	CIO (mills/kWh)					
89/489/589	\$618,652	1,625,621	0.38					
90/490/590	\$154,663	1,861,066	0.08					
Totals	\$773,315	3,486,688	5.00					
-	4	-,,						

	Allocated					Annual
	Inputs	Billing De	eterminants		Rate	Revenue
Schedule	(\$000)	Amount	Unit	Rate	Unit	(\$000)
SCHEDULE 7						
Residential						
Allocations						
Functional Costs						
Basic Charge	****			***		****
Single-Phase Three-Phase	\$225,045	. , ,	Customers		per cust. per mo.	\$225,024
Trans. & Rel. Serv. Charge	\$6 \$18,367	7,568,918	Customers		per cust. per mo. mills/kWh	\$6 \$18,392
Distribution Charge	\$214,566	7,568,918			mills/kWh	\$214,579
Franchise Fees & Other	\$17,073	7,568,918			mills/kWh	\$17,106
Energy Charge	\$488,086	7,568,918			mills/kWh	\$488,120
Subtotal	\$963,143	.,,,,,,,,,				\$963,227
Pricing						
Functional Costs						
Basic Charge						
Single-Phase			Customers		per cust. per mo.	\$103,352
Three-Phase			Customers	\$11.00		\$2
Trans. & Rel. Serv. Charge		7,568,918			mills/kWh	\$18,392
Distribution Charge		7,568,918	MWh	44.42	mills/kWh	\$336,211
System Usage Charge Calculation Franchise Fees & Other		7,568,918	L MA/IL	2.20	mills/kWh	\$17,106
Cust Impact Offset		7,568,918			mills/kWh	\$17,106 (\$606)
System Usage Charge		7,568,918			mills/kWh	\$16,500
Energy Charge		7,500,510	WWW	2.10	IIIIIS/KVVII	ψ10,000
Block 1 (First 500 kWh)		4,150,373	MWh	63.27	mills/kWh	\$262,594
Block 2 (501-1,000 kWh)		2,140,123			mills/kWh	\$135,406
Block 3 (Over 1,000 kWh)		1,278,422		70,49	mills/kWh	\$90,116
Subtotal						\$962,573
					w/o CIO	\$963,179
SCHEDULE 15						
Outdoor Area Lighting						
Allocations						
Functional Costs						
Basic Charge	\$472		Customers		per cust, per mo.	\$472
Trans. & Rel. Serv. Charge	\$24 \$372	15,774			mills/kWh mills/kWh	\$24
Distribution Charge Franchise Fees & Other	\$372 \$69	15,774 15,774			mills/kWh	\$372 \$68
Energy Charge	\$773	15,774			mills/kWh	\$773
Fixed Charges	\$1.628	15,774		40.90	IIIIII5/KVVII	\$1.628
Subtotal	\$3,337	10,774	WWW			\$3,337
Pricing						
Functional Costs						
Trans. & Rel. Serv. Charge		15,774	MWh	1,52	mills/kWh	\$24
Distribution Charge		15,774	MWh	53.55	mills/kWh	\$845
System Usage Charge Calc						
Franchise Fees & Other		15,774			mills/kWh	\$68
Cust Impact Offset		15,774			mills/kWh	<u>\$96</u>
System Usage Charge		15,774			mills/kWh	\$165
Energy Charge		15,774		48.98	mills/kWh	\$773
Fixed Charges		15,774	MWh			\$1,628
Subtotal						\$3,434
					w/o CIO	\$3,337
						Ψ0,007

	Allocated	DIII 5	atamuluar ta		Rate	Annual Revenue
Schedule	Inputs (\$000)	Amount	eterminants Unit	Rate	Unit	Revenue (\$000)
SCHEDULE 32	(4000)	Amount	Offic	Nate	Offic	(4000)
General Service <30 kW						
Allocations						
Functional Costs						
Basic Charge						
Single-Phase	\$23,466	56,001	Customers	\$34.92	per cust. per mo.	\$23,467
Three-Phase	\$23,283	37,764	Customers	\$51 . 38	per cust. per mo.	\$23,284
Trans. & Rel. Serv. Charge	\$3,367	1,633,156			mills/kWh	\$3,364
Distribution Charge	\$40,229	1,633,156			mills/kWh	\$40,225
Franchise Fees & Other	\$3,192	1,633,156			mills/kWh	\$3,185
Energy Charge	<u>\$95.345</u>	1,633,156	MWh	58.38	mills/kWh	\$95.344
Subtotal	\$188,882					\$188,868
Pricing						
Functional Costs						
Basic Charge						
Single-Phase		56,001	Customers	\$20.00	per cust. per mo.	\$13,440
Three-Phase		37,764	Customers	\$29,00	per cust. per mo.	\$13,142
Trans. & Rel. Serv. Charge		1,633,156	MWh	2.06	mills/kWh	\$3,364
Distribution Charge						
First 5 MWh		1,427,418			mills/kWh	\$57,739
Over 5 MWh		205,738	MWh	13.00	mills/kWh	\$2,675
System Usage Charge Calic Franchise Fees & Other		1,633,156	MWh	4.05	mills/kWh	\$3,185
Cust Impact Offset		1,633,156			mills/kWh	\$3,185 (\$131)
System Usage Charge		1,633,156			mills/kWh	\$3,054
Energy Charge		1,633,156			mills/kWh	\$95,344
Subtotal		1,000,100		00.00		\$188,758
					w/o CIO	\$188,888
SCHEDULE 38						
Time-of-Day G.S. >30 kW						
Allocations						
Functional Costs						
Basic	\$54		0	£04.0E		054
Single-Phase	•	328	Customers		per cust. per mo.	\$54
Three-Phase Trans. & Rel. Serv. Charge	\$530 \$54	31,475			per cust. per mo. per cust. per mo.	\$530 \$54
Distribution Charges	\$1,723	31,475		54.74		\$1,723
Franchise Fees & Other	\$1,723	31,475			mills/kWh	\$1,723
Energy Charge	\$1,69 <u>5</u>	31,475			mills/kWh	\$1,695
Subtotal	\$4,130	01,470		00.04	TIMIO/KVIII	\$4,129
P. Line						
Pricing Functional Costs						
Basic						
Single-Phase		55	Customers	\$30.00	per cust, per mo.	\$20
Three-Phase			Customers		per cust, per mo.	\$20 \$118
Trans. & Rel. Serv. Charge		31,475			mills/kWh	\$54
Distribution Charges		31,475			mills/kWh	\$2,142
System Usage Charge		0.,170		55101		42,142
Franchise Fees & Other		31,475	MWh	2,34	mills/kWh	\$74
Cust Impact Offset		31,475			mills/kWh	\$0
System Usage Charge		31,475		2.34		\$74
Energy Charge Calc						
On-Peak (special)		17,091	MWh	60.70	mills/kWh	\$1,037
Off-Peak		14,383	MWh	45.70	mills/kWh	\$657
Reactive Demand Charge		54,201	kVar	0,50	kVar	\$27
Subtotal						\$4,130
						** ***
					w/o C I O	\$4,130

	Allocated					Annual
	Inputs	Billing Do	eterminants		Rate	Revenue
Schedule	(\$000)	Amount	Unit	Rate	Unit	(\$000)
SCHEDULE 47						
rrig. & Drain. Pump < 30 kW						
Allocations						
Functional Costs						
Basic Charge	004	224	0	£47.70		004
Single-Phase	\$64 \$969		Customers		per cust. per summ. mo.	\$64
Three-Phase Trans, & Rel. Serv, Charge	\$969 \$46	21,633	Customers		per cust, per summ, mo, mills/kWh	\$969 \$46
Distribution Charges	\$1,675	21,633			mills/kWh	\$1,676
Franchise Fees & Other	\$90	21,633			mills/kWh	\$90
Energy Charge	\$1.53 <u>5</u>	21,633			mills/kWh	\$1.535
Subtotal	\$4,379	21,000				\$4,379
Pricing						
Functional Costs						
Basic Charge				***		***
Single-Phase			Customers		per cust. per summ. mo.	\$50
Three-Phase		,	Customers	\$37.00		\$630
Trans. & Rel. Serv. Charge		21,633	MINAL	2,13	mills/kWh	\$46
Distribution Charge Calc First 50 kWh per kW		7 536	MWh	106.84	mills/kWh	\$805
Over 50 kWh per kW		14,098			mills/kWh	\$1,224
System Usage Charge Calic		14,030	WWWII	00,04	IIIII3/KVVII	φ1,224
Franchise Fees & Other		21,633	MWh	4.15	mills/kWh	\$90
Cust Impact Offset		21,633			mills/kWh	\$0
System Usage Charge		21,633			mills/kWh	\$90
Energy Charge		21,633	MWh	70.94	mills/kWh	\$1,535
Reactive Demand Charge		45	kVar	\$0.50	kVar	\$0
Subtotal with Consumer Impact Offset						\$4,379
					w/o CIO	\$4,379
					W/O CIO	Φ4,379
SCHEDULE 49 Irrig. & Drain. Pump > 30 kW Allocations Functional Costs						
Basic						
Single-Phase	\$4		Customers		per cust, per summ, mo.	\$4
Three-Phase	\$812		Customers		per cust. per summ. mo.	\$812
Trans. & Rel. Serv. Charge	\$137	64,540			mills/kWh	\$137
Distribution Charges	\$3,674	64,540			mills/kWh	\$3,674
Franchise Fees & Other	\$175	64,540			mills/kWh	\$175
Energy Charge Subtotal	<u>\$4.562</u> \$9,364	64,540	MWN	70.68	mills/kWh	<u>\$4.562</u> \$9,364
Pricing Functional Costs						
Basic Charge						
Single-Phase		6	Customers	\$45.00	per cust. per summ. mo.	\$2
Three-Phase			Customers		per cust. per summ. mo.	\$342
Trans. & Rel. Serv. Charge		64,540			mills/kWh	\$137
Distribution Charge Calc						
First 50 kWh per kW		19,051	MWh	78,28	mills/kWh	\$1,491
Over 50 kWh per kW		45,489			mills/kWh	\$2,651
System Usage Charge Calc						
Franchise Fees & Other		64,540			mills/kWh	\$175
Cust Impact Offset		64,540			mills/kWh	\$0
System Usage Charge		64,540			mills/kWh	\$175
Energy Charge		64,540			mills/kWh	\$4,562
Reactive Demand Charge		8,709	kVar	0.50	kVar	\$4
Subtotal with Consumer Impact Offset						\$9,364
					w/o CIO	\$9,364
					W/0 OIO	ψ9,304

	Allocated Inputs	Billing De	sterminante		Rate	Annual Revenue
Schedule	(\$000)	Amount Unit		Rate	Unit	(\$000)
SCHEDULE 83	, ,					, ,
General Service 31-200 kW						
Allocations						
Functional Costs						
Basic Charge						
Single-Phase Secondary	\$828	683	Customers	\$101.03	per cust, per mo.	\$82
Three-Phase Secondary	\$24,211	10.846	Customers	\$186.02	per cust, per mo.	\$24.21
Transmission & Related Service Charge	\$6,042	8,610,027	kW demand		per kW demand	\$6,02
Distribution Charges	*-,	-,,				
Feeder Backbone	\$20,840	11.131.043	kW faccap	\$1.87	per kW faccap	\$20.81
Feeder Local Facilities	\$17,389	11,131,043			per kW faccap	\$17,36
Subtransmission Charge	\$10,468		kW demand		per kW demand	\$10,50
Substation Charge	\$10,395		kW demand		per kW demand	\$10,4
Secondary Franchise Fees & Other	\$3,845	2,884,961			mills/kWh	\$3,8
Secondary COS Energy Charge	\$168.128	2,884,961			mills/kWh	\$168.1
Subtotal	\$262,146	2,001,001		00,20		\$262,1
Pricing Functional Costs						
Basic Charge		con	0	#25.00		to.
Secondary Single-Phase			Customers		per cust, per mo.	\$2
Secondary Three-Phase		10,846	Customers	\$45.00	per cust, per mo.	\$5,8
Trans. & Rel. Serv. Charge		0.000.004	I-VAV alamanad	60.70	1/1/1	ec 7
On-peak			kW demand kW demand		per kW demand	\$6,7
Off-peak		3,300	kw demand	\$0,00	per kW demand	
Distribution Charges						
Secondary Facilities Charge		4.450.000	IAM forces	60.50	4- 00 IAM 6	\$14.5
First 30 kW Over 30 kW			kW faccap		<= 30 kW faccap	, , .
		6,960,663	kW faccap	\$3.40	> 30 kW faccap	\$23,7
Secondary Demand Charge On-peak		0 606 661	kW demand	60.61	per kW demand	\$22.4
			kW demand		per kW demand	
Off-peak Secondary System Usage Charge Ca l c		3,300	KVV demand	\$0.00	per kw demand	
Franchise Fees & Other		2.884.961	MMA	1 22	mills/kWh	\$3.8
Cust Impact Offset		_, _, _, _,			mills/kWh	\$3,0
		2,884,961 2,884,961			mills/kWh	\$16.3
Rate Design		-,,				
System Usage Charge		2,884,961	IVIVVII	6.99	mills/kWh	\$20,1
COS Energy Charge		1 000 050	MA/In	62.25	mills/kWh	6100.0
On-peak		1,909,059			mills/kWh	\$120,9
Off-peak		975,902				\$47,1
Reactive Demand Charge Subtotal		538,563	Kvar	\$0.50	KVar	\$2 \$262.1
Subtotal						\$262,14

	Allocated Inputs Billing Determinants				Rate	Annual Revenue	
Schedule	(\$000)	Amount	Unit	Rate	Unit	(\$000)	
SCHEDULE 85	(4000)	,		11010		(4000)	
General Service 201-4,000 kW							
Allocations							
Functional Costs							
Basic Charge							
Secondary	\$9,339	1 399	Customers	\$556.29	per cust, per mo.	\$9,340	
Primary	\$1,323	.,	Customers		per cust, per mo.	\$1,323	
Transmission & Related Service Charge	\$5,312		kW on-peak		per kW demand	\$5,330	
Distribution Charges	40,012	,,202,000	ner on poun		por ner domand	40,000	
Feeder Backbone	\$18.307	10.867.098	kW faccap	\$1.68	per kW faccap	\$18.257	
Feeder Local Facilities	\$8,956		kW faccap		per kW faccap	\$8,911	
Subtransmission Charge	\$11,549		kW on-peak		per kW on-peak demand	\$11,547	
Substation Charge	\$11,468		kW on-peak		per kW on-peak demand	\$11,457	
Secondary Franchise Fees & Other	\$1,885	2,717,524			mills/kWh	\$1,875	
Primary Franchise Fees & Other	\$452	922,762	MWh	0,49	mills/kWh	\$452	
COS Energy Charge	\$153,171	2,713,846	MWh	56.44	mills/kWh	\$153,169	
Subtotal	\$221,761					\$221,660	
Pricing							
Functional Costs							
Basic Charge							
Secondary		1,399	Customers	\$560.00	per cust, per mo.	\$9,402	
Primary		236	Customers	\$470.00	per cust, per mo.	\$1,333	
Secondary Trans. & Rel. Serv. Charge		5,711,975	kW on-peak	\$0.78	per kW demand	\$4,455	
Primary Trans. & Rel. Serv. Charge		1,490,713	kW on-peak	\$0.76	per kW demand	\$1,133	
Distribution Charges							
Secondary Facilities Charge							
First 200 kW			kW faccap		per kW faccap	\$10,644	
Over 200 kW		4,850,961	kW faccap	\$1.97	per kW faccap	\$9,556	
Primary Facilities Charge							
First 200 kW			kW faccap	\$3,10		\$1,758	
Over 200 kW			kW faccap		per kW faccap	\$3,973	
Secondary Demand Charge			kW on-peak		per kW demand	\$17,895	
Primary Demand Charge		2,164,764	kW on-peak	\$2.53	per kW demand	\$5,477	
Secondary System Usage Charge Calc							
COS Franchise Fees & Other		2,122,422			mills/kWh	\$2,059	
Cust Impact Offset		2,122,422			mills/kWh	<u>\$0</u>	
COS System Usage Charge		2,122,422			mills/kWh	\$2,059	
DA Franchise Fees & Other		595,102			mills/kWh	(\$167)	
Cust Impact Offset		595,102			mills/kWh	\$0 (\$167)	
DA System Usage Charge		595,102	MWN	(0.28)	mills/kWh	(\$167)	
Primary System Usage Charge Calc COS Franchise Fees & Other		591.424	LANA/Is	0.00	mills/kWh	\$550	
Cust Impact Offset		591,424			mills/kWh	\$0	
COS System Usage Charge		591,424			mills/kWh	\$550	
DA Franchise Fees & Other		331,338			mills/kWh	(\$96)	
Cust Impact Offset		331,338			mills/kWh	\$0	
DA System Usage Charge		331,338			mills/kWh	(\$96)	
Secondary COS Energy Charge		001,000		(0120)	, minority m	(400)	
On-peak		1,390,849	MWh	61.91	mills/kWh	\$86,107	
Off-peak		731,573			mills/kWh	\$34,318	
Primary COS Energy Charge		,				,	
On-peak		374,238	MWh	60.86	mills/kWh	\$22,776	
Off-peak		217,186			mills/kWh	\$9,960	
Reactive Demand Charge		1,343,897			kVar	\$672	
Subtotal						\$221,806	
					w/o CIO	\$221,806	

	Allocated Inputs	Billing De	eterminants		Rate	Annual Revenue
Schedule	(\$000)	Amount	Unit	Rate	Unit	(\$000)
SCHEDULE 89 GT 4,000 kW	(+/					(+)
General Service						
Allocations						
Functional Costs						
Secondary Basic Charge	\$40		Customers	\$3,339.30		\$40
Primary Basic Charge	\$591 \$381	26	Customers Customers	\$1,893.41		\$591 \$381
Subtransmission Basic Charge Transmission & Related Service Charge	\$1,085		kW on-peak	\$3,972.99 \$0.99	per cust, per mo. per kW on-peak demand	\$1,082
Distribution Charges	Ψ1,000	1,000,010	KW OII-peak	ψ0.00	per kvv on-peak demand	Ψ1,002
Feeder Backbone	\$3,729	3,573,990	kW faccap	\$1.04	per kW faccap	\$3,717
Feeder Local Facilities			•			\$0
Subtransmission Demand Charge	\$4,370		kW on-peak	\$1,43		\$4,367
Substation Demand Charge	\$3,569	_, ,	kW on-peak		per kW on-peak demand	\$3,567
Secondary Franchise Fees & Other	(\$7)	13,482			mills/kWh	(\$7)
Primary Franchise Fees & Other	(\$259)	1,362,209			mills/kWh	(\$259)
Subtransmission Franchise Fees & Other Energy Charge	(\$62) \$23,979	249,930 463,935			mills/kWh mills/kWh	(\$62) \$23,981
Subtotal	\$37,416	403,933	IVIVVII	51.09	IIIIII5/KVVII	\$37,398
	****					*,
Pricing						
Functional Costs						
Secondary Basic Charge		1	Customers	\$3,340.00	per cust, per mo.	\$40
Primary Basic Charge			Customers	\$1,890.00		\$590
Subtransmission Basic Charge		8		\$3,970.00	per cust, per mo.	\$381
Secondary Trans. & Rel. Serv. Charge			kW on-peak	\$0.78		\$0
Primary Trans. & Rel. Serv. Charge			kW on-peak		per kW on-peak demand	\$624
Subtransmission Trans. & Rel. Serv. Charge		272,521	kW on-peak	\$0 . 75	per kW on-peak demand	\$204
Distribution Charges						
Secondary Facilities Charge First 1.000 kW		40.000	MM forces	04.50	144/ 6	640
1,001–4,000 kW			kW faccap kW faccap		per kW faccap per kW faccap	\$18 \$55
Greater than 4.000 kW			kW faccap		per kW faccap	\$50
Primary Facilities Charge		41,172	KW laccap	91,22	per KW laccap	φ30
First 1,000 kW		300.000	kW faccap	\$1.49	per kW faccap	\$447
1,001–4,000 kW		,	kW faccap		per kW faccap	\$1,341
Greater than 4,000 kW			kW faccap		per kW faccap	\$1,713
Subtransmission Facilities Charge						
First 1,000 kW		132,000	kW faccap	\$1.49	per kW faccap	\$197
1,001–4,000 kW			kW faccap		per kW faccap	\$375
Greater than 4,000 kW			kW faccap		per kW faccap	\$530
Secondary Demand Charge			kW on-peak		per kW on-peak demand	\$112
Primary Demand Charge			kW on-peak		per kW on-peak demand	\$5,990
Subtransmission Demand Charge		643,925	kW on-peak	\$1.27	per kW on-peak demand	\$818
Secondary System Usage Charge Calc COS Franchise Fees & Other		0	MWh	0.64	mills/kWh	\$0
Cust Impact Offset		0			mills/kWh	\$0 \$0
COS System Usage Charge		0			mills/kWh	\$0
DA Franchise Fees & Other		13,482			mills/kWh	(\$7)
Cust Impact Offset		13,482			mills/kWh	<u>\$5</u>
DA System Usage Charge		13,482			mills/kWh	(\$2)
Primary System Usage Charge Calc				,,,,,,		(/
COS Franchise Fees & Other		401,176	MWh	0.61	mills/kWh	\$245
Cust Impact Offset		401,176		0.38	mills/kWh	\$152
COS System Usage Charge		401,176			mills/kWh	\$397
DA Franchise Fees & Other		961,033			mills/kWh	(\$509)
Cust Impact Offset		961,033			mills/kWh	<u>\$365</u>
DA System Usage Charge		961,033	MWh	(0.15)	mills/kWh	(\$144)
Subtransmission System Usage Charge Calc		62,759	L MAZIL	0.50	III - #AA/I-	607
COS Franchise Fees & Other Cust Impact Offset		62,759			mills/kWh mills/kWh	\$37
COS System Usage Charge		62,759			mills/kWh	<u>\$24</u> \$61
DA Franchise Fees & Other		187,171			mills/kWh	(\$99)
Cust Impact Offset		187,171			mills/kWh	\$71
DA System Usage Charge		187,171			mills/kWh	(\$28)
Secondary Energy Charge		,		(01.0)		(425)
On-peak		0	MWh	58.69	mills/kWh	\$0
Off-peak		0			mills/kWh	\$0
Primary Energy Charge						
On-peak		238,945	MWh	57,73	mills/kWh	\$13,794
Off-peak		162,231	MWh	42.73	mills/kWh	\$6,932
Subtransmission Energy Charge						
On-peak		41,003			mills/kWh	\$2,338
Off-peak		21,755			mills/kWh	\$914
Reactive Demand Charge		541,041	кVar	0.50	kVar	\$271
Subtotal						\$38,018
					w/o CIO	\$27.400
					W/O CIC	\$37,400

	Allocated					Annual
	Inputs _		eterminants		Rate	Revenue
Schedule	(\$000)	Amount	Unit	Rate	Unit	(\$000)
SCHEDULE 90						
Primary Voltage Service						
Allocations						
Functional Costs						
Primary Basic Charge	\$292	4	Customers	\$6,090.84	per cust, per mo.	\$292
Transmission & Related Service Charge	\$2,682	2,701,624	kW on-peak	\$0.99	per kW on-peak demand	\$2,675
Distribution Charges			·			
Feeder Backbone	\$2,029	2,826,257	kW faccap	\$0.72	per kW faccap	\$2,035
Subtransmission Demand Charge	\$3,865	2,701,624	kW on-peak	\$1.43	per kW on-peak demand	\$3,863
Substation Demand Charge	\$4,000	2,701,624	kW on-peak	\$1.48	per kW on-peak demand	\$3,998
Primary Franchise Fees & Other	\$862	1,861,066	MWh	0.46	mills/kWh	\$856
Energy Charge	\$91,944	1,861,066	MWh	49.40	mills/kWh	\$91,937
Subtotal	\$105,675					\$105,656
Pricing						
Functional Costs						
Primary Basic Charge			Customers		per cust, per mo.	\$293
Primary Trans. & Rel. Serv. Charge		2,701,624	kW on-peak	\$0.76	per kW on-peak demand	\$2,053
Distribution Charges						
Primary Facilities Charge						
First 4,000 kW			kW faccap		per kW faccap	\$155
Over 4,000 kW		_, _, _, _,	kW faccap		per kW faccap	\$3,549
Primary Demand Charge		2,701,624	kW on-peak	\$2.53	per kW on-peak demand	\$6,835
Primary System Usage Charge Calc						
COS Franchise Fees & Other		1,861,066			mills/kWh	\$856
Cust Impact Offset		1,861,066	MWh		mills/kWh	<u>\$149</u>
COS System Usage Charge		1,861,066	MWh	0,54	mills/kWh	\$1,005
Primary Energy Charge						
On-peak		1,070,638	MWh	55 . 77	mills/kWh	\$59,709
Off-peak		790,429	MWh	40,77	mills/kWh	\$32,226
Reactive Demand Charge		21,436	kVar	\$0,50	kVar	<u>\$11</u>
						\$105,836
					w/o CIO	\$105,687

	Allocated						Annual
	Inputs	Billing De	eterminants	:		Rate	Revenue
Schedule	(\$000)	Amount	Unit		Rate	Unit	(\$000)
SCHEDULES 91 & 95							
Street & Highway Lighting							
Allocations Functional Costs							
Basic Charge	\$1,865	203	Customers		\$765.76	per cust, per mo.	\$1,865
Trans, & Rel. Serv, Charge	\$77	50,583				mills/kWh	\$77
Distribution Charge	\$1,236	50,583	MWh		24.43	mills/kWh	\$1,236
Franchise Fees & Other	\$232	50,583				mills/kWh	\$232
COS Energy Charge Fixed Charges	\$2,478 \$5,294	50,583	MWh		48.98	mills/kWh	\$2,478 \$5,294
Subtotal	\$5.294 \$11,182						\$11,182
044.044	¥11,102						\$11,102
Pricing Functional Costs							
Trans. & Rel. Serv. Charge		50,583	MWh		1.52	mills/kWh	\$77
Distribution Charge		50,583				mills/kWh	\$3,101
System Usage Charge Calc							
Franchise Fees & Other		50,583				mills/kWh	\$232
Cust Impact Offset		50,583				mills/kWh	<u>(\$96)</u>
System Usage Charge COS Energy Charge		50,583 50,583				mills/kWh mills/kWh	\$136 \$2,478
Fixed Charges		50,583			40,00	TIMIO/KVVII	\$5,294
Subtotal		,					\$11,086
SCHEDULE 92						w/o C I O	\$11,182
Traffic Signals							
Allocations							
Functional Costs							
Basic Charge	\$47		Customers	;		per cust, per mo.	\$47
Trans. & Rel. Serv. Charge	\$4		MWh			mills/kWh	\$4
Distribution Charge	\$23 \$3		MWh			mills/kWh mills/kWh	\$23 \$3
Franchise Fees & Other COS Energy Charge	\$3 \$128		MWh MWh			mills/kWh	\$128
Subtotal	\$205	2,400			01.00	THIII GYRVVII	\$205
Detailer							
Pricing Functional Costs							
Trans. & Rel. Serv. Charge		2,496	MWh		1,59	mills/kWh	\$4
Distribution Charge			MWh			mills/kWh	\$70
System Usage Charge Calc							
Franchise Fees & Other		2,496				mills/kWh	\$3
Cust Impact Offset System Usage Charge		,	MWh MWh			mills/kWh mills/kWh	<u>\$0</u> \$3
COS Energy Charge			MWh			mills/kWh	\$128
Subtotal		2,400			01.00	TIMIS/KVVII	\$204
						/a CIO	#204
						w/o CIO	\$204
Summary of Inputs	Allocated						
Functional Costs	Inputs	DesSumm	Deltas				
Basic Charge	\$313,625	\$313,625		\$0			
Trans. & Rel. Serv. Charge	\$37,196	\$37,196		\$0			
Distribution Charge	\$394,432	\$394,432		\$0			
Fixed Charges	\$6,922 \$37,634	\$6,922		\$0 \$0			
Franchise Fees & Other Energy Charge	\$27,624 \$1.031.821	\$27,624 \$1.031.821		\$0 \$0			
Subtotal	\$1,811,619	\$1,811,619		ΨΟ			
Functional Costs Revenues	Annual Revenue	Revenue	Deltas				
Basic Charge	\$149,279	\$149,279	Deltas	\$0			
Trans. & Rel. Serv. Charge	\$37,281	\$37,271		(\$10)	(\$10)	(Voluntary TOU)	
Distribution Charges	\$541,168	\$541,137		(\$31)		(Voluntary TOU)	
Fixed Charges	\$6,922	\$6,922		\$0			
System Usage Charge	\$43,996	\$43,996		\$0	624	(Valuntary TOU)	
Energy Charge Reactive	\$1,031,828 <u>\$1,254</u>	\$1,031,859 <u>\$1,254</u>		\$31 <u>\$0</u>	\$31	(Voluntary TOU)	
Subtotal	\$1,811,728	\$1,811,719		(\$ 9)	(\$9))	
Note: figures are before employee discount and Schedule 129					1/		
On-peak demand	23,383,373	23,383,373		0			
Facility Capacity	28,398,387	28,398,388		(1)			
kVar	2,507,892	2,507,892		0			

PORTLAND GENERAL ELECTRIC Commercial and Industrial Pricing

Economies of Scale Blocking, Rate Continuum

	Inputs	Billing Det			Rate	Revenue
_	(\$000)	Amount	Unit	Rate	Unit Note	(\$000)
Fransmission Demand Price for Schedules 83, 85, 89,	90					
Fransmission & Ancillary Pricing	\$15,121	19,603,983	kW		per kW demand	\$15,09
Secondary		14,318,636			per kW demand per kW demand	\$11,16
Primary Subtransmission		5,012,826 272,521			per kW demand	\$3,81 \$20
Total Schedule 83/85/89/90 Transmission Revenue:	\$15,121	,		*****	,	\$15,18
						V 10,10
Distribution Demand Pricing for Schedules 83, 85, 89,						
Distribution Demand Pricing (subtransmission) Secondary	\$30,251	23,383,373 15,505,649			per kW demand per kW demand	\$30,25 \$20,27
Primary		7,233,799		\$1.27		\$9,16
Subtransmission		643,925			per kW demand	\$81
						\$30,25
Distribution Demand Pricing (substations)	\$29,431	22,739,448			per kW demand	\$29,43
Secondary Primary		15,505,649 7,233,799			per kW demand per kW demand	\$20,26 \$9,16
rimary		1,233,133	KVV	91,27	per kwy demand	\$29,43
Distribution Demand Prices						\$25,43
Secondary		15,505,649		\$2.61		\$40,47
Primary Subtransmission		7,233,799 643,925		\$2.53 \$1.26		\$18,30 \$81
	\$59,682					\$59,58
0	400,002			***		\$00,00
Secondary/Primary Transmission Delta Secondary/Subtransmission Transmission Delta				\$0.02 \$0.03		
Secondary/Primary 115 kV Delta Secondary/Subtransmission kV Delta				\$0.04 \$0.05		
Secondary/Primary Substation Delta				\$0.04		
Schedule 85 Price Differentials						
Schedule 85 Energy Allocations	\$153,171	2,713,846			mills/kWh mills/kWh	\$153,17 \$120,27
Schedule 85 Secondary Energy Schedule 85 Primary Energy		2,122,422 591,424			mills/kWh	\$32,89
Secondary/Primary Delta					mills/kWh	
On/off peak delta				15.00	mills/kWh	
Schedule 85 Secondary Energy Pricing						
On-peak Off-peak		1,390,849 731,573			mills/kWh mills/kWh	\$86,10 \$34,31
Schedule 85 Primary Energy Pricing						
On-peak Off-peak		374,238 217,186			mills/kWh mills/kWh	\$22,77 \$9,96
OII-peak		217,100		40200	Tillio KVVII	\$5,50
Total Schedule 85 Energy Revenues	\$153,171					\$153,16
Schedule 85 Facility Charges Under-recovery of other charges	\$27,263 (\$1,377)					
Total Facilities Revenues to Recover Schedule 85 Secondary Facilities	\$25,886	10,867,098			per kW faccap	\$25,88
First 200 Over 200			kW faccap kW faccap		per kW faccap per kW faccap	\$10,64 \$9,55
Schedule 85 Primary Facilities First 200		567.200	kW faccap	\$3.10	per kW faccap	\$1,75
Over 200			kW faccap		per kW faccap	\$3,97
Secondary/Primary Facilities Delta			Line Loss	\$0.07		\$25,93
				90.07		

\$1.20

Schedule 89 Price Differentials					
Schedule 89 Energy Allocations	\$23,979 463,9	35 MWh	51.69 m	ills/kWh	\$23,979
Schedule 89 Secondary Energy		0 MWh	52.74 m	ills/kWh	\$0
Schedule 89 Primary Energy	401,1	76 MWh	51.78 m	ills/kWh	\$20,773
Schedule 89 Subtransmission Energy	62,7	759 MWh	51.07 m	ills/kWh	\$3,205
Total Schedule 89 Energy Revenues	\$23,979				\$23,978
Secondary/Primary Delta			0.96		
Primary/Subtransmission Delta			0.71		
On/off peak delta			15.00		
Schedule 89 Secondary Energy Pricing					
On-peak		0 MWh	58.69 m	ills/kWh	\$0
Off-peak		0 MWh	43.69 m	ills/kWh	\$0
Schedule 89 Primary Energy Pricing					
On-peak	238,9	45 MWh	57.73 m	ills/kWh	\$13,794
Off-peak	162,2	31 MWh	42.73 m	ills/kWh	\$6,932
Schedule 89 Subtransmission Energy Pricing					
On-peak	41,0	03 MWh	57.02 m	ills/kWh	\$2,338
Off-peak	21,7	55 MWh	42.02 m	ills/kWh	\$914
Total Schedule 89 Energy Revenues	\$23,979				\$23,979

Schedule 89/90 Facilities Blocking at 4,000 kW

Schedule 89 Facility Charges	\$3,729			
Under-recovery of other charges	\$1,013			
Total Facilities Revenues to Recover	\$4,743 3,573,990	kW faccap	\$1.33 per kW faccap	\$4,753
Secondary				
First 4,000	48,000	kW faccap	\$1.53 per kW faccap	\$74
Over 4,000	41,172	kW faccap	\$1.22 per kW faccap	\$50
Primary				
First 4,000	1,200,000	kW faccap	\$1.49 per kW faccap	\$1,793
Over 4,000	1,451,944	kW faccap	\$1.18 per kW faccap	\$1,720
Subtransmission				
First 4,000	384,012	kW faccap	\$1.49 per kW faccap	\$574
Over 4,000	448,862	kW faccap	\$1.18 per kW faccap	\$532
				\$4,743
Secondary/Primary Facilities Delta Blocking			\$0.04	
Blocking	\$0.31		\$0.31	

Theoretic Facilities Charge Differential between Schedule 89 Primary and Subtransmission Voltage Service Billing Demand greater than 4,000 kW Primary Feeder Costs \$76,614

\$77,041 (\$427) 139% Subtransmission Feeder Costs Delta Distribution Equal Percent Equal Percent Difference Average Annual Facilities Billing Determinant Facilities Charge Delta per Faccap Subtransmission Facilities Billing Determinants 102,495 832,874 Adder (Subtractor) to Demand Charge (\$000)

Demand and Energy Loss Differentials for Selected Schedules

Losses Schedule 85: Secondary/Primary Embedded energy loss differentials

1.890% Peak demand loss differential 2.852%

Sec/Prim 1.890% 2.852% Prim/Subtrans Embedded energy loss differentials Peak demand loss differentials 1.400% 1.415%

2019 Schedule 7 COS Energy Prices

2019 Schedule 7 COS T&D Prices

				Energy
	Energy			Prices
	Prices	Monthly		with adder
Blocks	mills/kWh	kWh	Revenues	mills/kWh
Block 1 (first 1,000 kWh)	63.27	806	\$51.00	63.29
Block 2 (over 1,000 kWh)	70.49	0	\$0.00	/0.51
Consumption		806	\$51.00	

2019 Schedule 7 TOU Energy Prices

2019 Schedule 7 TOU Transmission Prices

2013 Ochledaje 7 100 El	ergy rinces				2015 Ocheduje 7 100	r i i a i i i i i i i i i i i i i i i i	OII FIICES					
Peaks	Energy Prices mills/kWh	Month l y kWh	Revenues	Energy Prices with adder mills/kWh	Peaks	Trans Price mills/kWh	TOU Ave Monthly kWh	Adjusted Ave Month l y kWh	Adjusted Revenues	TOU Trans Price mills/kWh	TOU Adj Trans Revenues	Trans Prices with adder mills/kWh
On-peak	123.78				On-peak	2.43	21					3.97
•												
Mid-peak	70.49				Mid-peak	2.43	43:					3.97
Off-peak	41.26	313	\$12.90	41.28	Off-peak	2.43	55	7 411		0.00		0.00
Block 1 Adjustment	(7.22)	806	(\$5.82) \$51.00		2019 Schedule 7 TOL	I Distributio	n Prices		\$2.57		\$2.57	
On/Off Ratio	3.00					Distribution	n TOU Ave	Adjusted		TOU Distribution	TOU Adj	Distribution Prices
		Non-TOU				Price	Monthly	Ave Monthly	Adjusted	Price	Distribution	with adder
							,	-	-			
Barto	Sch 7 Non-To				Peaks	mills/kWh	kWh	kWh	Revenues	mills/kWh	Revenues	mills/kWh
Peaks	Percents	kWh	_		On-peak	46,60	21					76,16
On-peak	21.28%	1/2	<u> </u>		Mid-peak	46.60	43	2 432	\$20.13	/6.14	\$32.88	/6.16
Mid-peak Off-peak	39.92% 38.79%				Off-peak	46.60	55	7 411	\$19.15 \$49.37	0.00	\$0.00 \$49.37	0.00

2016 TOU Profiles

Peaks	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
On-peak	19.23%	20.81%	21.07%	20.82%	17.39%	13.47%	13.96%	15.54%	14.90%	13.86%	16.51%	20.42%
Mid-peak	32.68%	33.63%	33.18%	33.00%	36.09%	38.53%	38.83%	39.78%	39.52%	40.23%	37.80%	33.73%
Off-peak	48.09%	45.56%	45.75%	46,18%	46,52%	48.00%	47.20%	44.68%	45.59%	45,91%	45,69%	45.85%
Tota l s	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%

Schedule 7-TOU	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Customers													
Single Phase	2,202	2,204	2,206	2,209	2,211	2,213	2,215	2,218	2,221	2,224	2,226	2,229	26,578
Three Phase	15	15	15	15	15	15	15	15	15	15	15	15	180
Energy (MWh)													
Energy 1st 500 (MWh)	1,046	1,025	1,004	979	957	949	959	965	966	945	979	1,046	11,820
Energy 501-1,000 (MWh)	727	617	546	467	410	403	459	489	474	376	453	673	6,095
Over 1,000 (MWh)	1,853	1,503	1,425	1,197	1,018	1,007	933	985	986	877	1,045	1,517	14,346
Peak Energy Detail (MWh)													
On-peak Energy	721	625	592	526	370	366	364	378	376	341	493	644	5,795
Mid-peak Energy	1,236	1,072	1,014	901	908	898	895	928	923	836	844	1,103	11,557
Off-peak Energy	1,669	1,447	1,370	1,217	1,108	1,096	1,092	1,133	1,127	1,021	1,140	1,489	14,909
Callendar Energy (MWh)	3,470	2,765	2,834	2,525	2,424	2,325	2,518	2,487	2,181	2,347	2,861	3,548	32,286

Energy Revenues at Standard Tariff

Blocks	MWh	Price	Revenues
Block 1 Energy	17,915	63.27	\$1,133,453
Block 2 Energy	14.346	70.49	\$1.011.270
Totals	32,261		\$2,144,723

T&D Revenues at Standard Tariff

		Price	
	MWh	mills/kWh	Revenues
Trans	32,261	2.43	\$78,394
Dist	32,261	46.60	\$1,503,355
			\$1,581,749

Energy Revenues at TOU Pricing

Peaks	MWh	Price	Revenues
On-peak Energy	5,795	123.78	\$717,320
Mid-peak Energy	11,557	70,49	\$814,624
Off-peak Energy	14,909	41.26	\$615,151
Block Credit	17,915	(7.22)	(\$129,343)
Totals	32,261		\$2,017,751

Transmission Revenues at TOU Pricing

		Sch 7 TOU	TOU Trans
Peaks	MWh	D&T Price	Revenues
On-peak Energy	5,795	3.97	\$23,007
Mid-peak Energy	11,557	3.97	\$45,880
Off-peak Energy	14,909	0.00	\$0
Totals	32,261	-	\$68,886

Distribution Revenues at TOU Pricing

		Sch 7 TOU	TOU Dist
Peaks	MWh	D&T Price	Revenues
On-peak Energy	5,795	76.14	\$441,241
Mid-peak Energy	11,557	76.14	\$879,918
Off-peak Energy	14,909	0.00	\$0
Totals	32,261	_	\$1,321,159

	Energy	Trans	Dist	Tota
TOU Decrement	(\$126,972)	(\$9,508)	(\$182,196)	(\$318,675)
Schedule 7 Energy (MWh)	7,568,918	7,568,918	7,568,918	
Standard Tariff Energy Adder (mills/kWh)	0.02	0.00	0.02	0.04
Revenues	\$151,378	\$0	\$151,378	\$302,757

B1 (\$99,906) B2 (\$51,516) B3 (\$30,774)

2019 Schedule 32 COS Energy Prices

				Energy
	Energy			Prices
	Prices	Monthly		with adder
Energy	mills/kWh	kWh	Revenues	mills/kWh
Schedule 32	58.38	1.451	\$84.71	58.42

2019 Schedule 32 TOU Energy Prices

				Energy
	Energy			Prices
	Prices	Monthly		with adder
Peaks	mills/kWh	kWh	Revenues	mills/kWh
On-peak	103.74	288	\$29.92	103.78
Mid-peak	58.38	613	\$35.80	58.42
Off-peak	34.58	549	\$19.00	34.62

\$84.72

TOU Energy Revenues 1,451

On/Off Ratio 3.00

 Peaks
 Sch 32 Non-TOU Percents

 On-peak
 19.88%

 Mid-peak
 42.26%

 Off-peak
 37.86%

2016 TOU Profiles

Peaks	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
On-peak	19.23%	20.59%	20.51%	20.68%	18,29%	14.60%	14.63%	15.43%	15.02%	14.86%	16.78%	19.69%
Mid-peak	33.53%	35.78%	35.81%	35,87%	38,82%	40,36%	40,55%	41.58%	40.94%	41.45%	39,85%	34.97%
Off-peak	47,24%	43,62%	43,68%	43,45%	42,89%	45.04%	44.83%	42,99%	44.04%	43.69%	43,37%	45,34%
Tota l s	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%

Schedule 32-TOU	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Customers - Single Phase	241	241	241	241	241	241	242	243	243	243	243	244	2,904
Customers - Three Phase	71	71	71	71	71	71	71	71	71	71	71	71	852
Energy (MWh)													
First 5 MWh	1,120	1,123	1,143	1,103	1,070	1,090	1,117	1,149	1,135	1,092	1,076	1,073	13,292
Over 5 MWh	871	767	707	696	727	826	857	863	886	718	660	728	9,305
Peak Energy Detail (MWH)													
On-peak Energy	390	370	362	353	278	296	305	311	312	280	340	353	3,949
Mid-peak Energy	715	678	664	646	730	778	802	818	821	735	623	647	8,658
Off-peak Energy	886	841	823	801	789	841	867	884	887	795	773	802	9,990
Callendar Energy (MWh)	1,865	1,721	1,847	1,782	1,938	1,880	2,127	2,043	1,826	1,902	1,844	1,812	22,588
	715	678	664	646	730	778	802	818	821	735	623	647	

Energy Revenues at Standard Tariff

Energy	MWh	Price	Revenues	
Schedule 32	22,597	58,38	\$1,319,207	

Energy Revenues at TOU Pricing

Peaks	MWh	Price	Revenues
On-peak Energy	3,949	103.74	\$409,715
Mid-peak Energy	8,658	58.38	\$505,430
Off-peak Energy	9,990	34.58	\$345,449
Totals	22,597		\$1,260,595
TOU Decrement Schedule 32 Energy (MWh)			(\$58,612) 1,633,156
Standard Tariff Adder (mills/	kWh)		0.04
Schedule 32 Revenues	,		\$65,326

PORTLAND GENERAL ELECTRIC

Schedule 123, Summary of Sales Normalization Components

Schedule	Fixed Charge Energy Rate mills/kWh	Monthly Fixed Charge Per Customer	Monthly Secondary Fixed Charge Per Customer
7	88.70	\$71.45	\$49.30
32, 532	76.93	\$111.66	
38, 538	104.79	\$717.79	
47	142.07	\$83.67	
49, 549	112.26	\$473.94	
83	37.90	\$790.34	
85 - S	36.49	\$4,612.97	
85-P	35.84	\$7,474.14	

Schedule 7 Tariff Category	Price mills/kWh	2019 MWH	Revenues	Per Cust. Revenues	Monthly Revenues
Transmission & Ancillary	2.43	7,568,918	\$18,392,471	\$23,49	\$1.96
Distribution	44.42	7,568,918	\$336,211,339	\$429.40	\$35.78
Trojan Decommissioning	0.11	7,568,918	\$832,581	\$1.06	\$0.09
CIÓ	(80.0)	7,568,918	(\$605,513)	(\$0.77)	(\$0.06)
Fixed Generation	41.82	7,568,918	\$316,532,152	\$404.27	\$33.69
Totals	88.70		\$671,363,030	\$857.44	\$71.45
Secondary Fixed Charge (69%)		69%			\$49.30
Number of 2019 Customers	782,981				
Revenues per customer	\$857.44				
Monthly Revenues per customer	\$71.45				
Annual kWh per Customer	9,667				
	Price	2019		Per Cust.	Monthly
Schedule 32 Tariff Category	mills/kWh	MWH	Revenues	Revenues	Revenues
Transmission & Ancillary	2.06	1,633,156	\$3,364,301	\$35.88	\$2.99
Distribution Block 1	40.45	1,427,418	\$57,739,059	\$615,78	\$51.32
Distribution Block 2	13.00	205,738	\$2,674,590	\$28,52	\$2.38
Trojan Decommissioning	0.10	1,633,156	\$163,316	\$1.74	\$0.15
CIO	(80.0)	1,633,156	(\$130,652)	(\$1.39)	(\$0.12)
Fixed Generation	37.86	1,633,156	\$61,831,275	\$659,43	\$54.95
Totals	76.93		\$125,641,887	\$1,339.96	\$111 . 66
Number of 2019 Customers	93,765				
Revenues per customer	\$1,339.96				
Monthly Revenues per customer	\$111.66				
Annual kWh per Customer	17,418				
	Price	2019		Per Cust.	Monthly

mills/kWh

1.71

68.07

0.00

MWH

31,475

31,475

0

Revenues

\$53,822

\$0

\$2,142,476

Revenues

\$140.56

\$0.00

\$5,595.15

Schedule 38 Tariff Category

Transmission & Ancillary

Distribution Block 1

Distribution Block 2

Revenues

\$11.71

\$0.00

\$466.26

Trojan Decommissioning	0.09	31,475	\$2,833	\$7.40	\$0.62
CIO Fixed Generation	0.00 34.92	31,475 31,475	\$0 \$1.099.093	\$0.00 \$2,870.32	\$0.00 \$239.19
i izod Generalien	01.02	01,170	\$1,000,000	42,070.02	\$200110
Totals	104.79		\$3,298,223	\$8,613,42	\$717.79
Number of 2019 Customers	383				
Revenues per customer	\$8,613,42				
Monthly Revenues per customer	\$717.79				
Annual kWh per Customer	82,197				
	Price	2019		Per Cust.	Monthly
Schedule 47 Tariff Category	mills/kWh	MWH	Revenues	Revenues	Revenues
Transmission & Ancillary	2.13	21,633	\$46,079	\$15.05	\$1.25
Distribution Block 1	106.84	7,536	\$805,133	\$263,03	\$21.92
Distribution Block 2	86.84 0.12	14,098 21,633	\$1,224,233 \$2,596	\$399.95 \$0.85	\$33.33 \$0.07
Trojan Decommissioning CIO	0.00	21,633	\$2,596 \$0	\$0.00	\$0.00
Fixed Generation	46.01	21,633	\$995,355	\$325.17	\$27.10
		,000	4000,000	4020	4 2.710
Totals	142.07		\$3,073,396	\$1,004.05	\$83.67
Number of 2019 Customers	3,061				
Revenues per customer	\$1,004.05				
Monthly Revenues per customer	\$83.67				
Annual kWh per Customer	7,067				
	Price	2019		Per Cust.	Monthly
Schedule 49 Tariff Category	Price mills/kWh	2019 MWH	Revenues	Per Cust. Revenues	Monthly Revenues
Schedule 49 Tariff Category Transmission & Ancillary			Revenues \$136,825		•
	mills/kWh	MWH 64,540 19,051	\$136,825 \$1,491,343	\$107.40 \$1,170.60	Revenues
Transmission & Ancillary Distribution Block 1 Distribution Block 2	mills/kWh 2.12 78.28 58.28	64,540 19,051 45,489	\$136,825 \$1,491,343 \$2,651,095	\$107.40 \$1,170.60 \$2,080.92	\$8.95 \$97.55 \$173.41
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning	mills/kWh 2.12 78.28 58.28 0.12	MWH 64,540 19,051 45,489 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745	\$107.40 \$1,170.60 \$2,080.92 \$6.08	\$8.95 \$97.55 \$173.41 \$0.51
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO	mills/kWh 2.12 78.28 58.28 0.12 0.00	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning	mills/kWh 2.12 78.28 58.28 0.12	MWH 64,540 19,051 45,489 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745	\$107.40 \$1,170.60 \$2,080.92 \$6.08	\$8.95 \$97.55 \$173.41 \$0.51
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO	mills/kWh 2.12 78.28 58.28 0.12 0.00	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84 112.26	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84 112.26 1,274 \$5,687.23	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84 112.26 1,274 \$5,687.23 \$473.94	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84 112.26 1,274 \$5,687.23 \$473.94 50,660 Price	MWH 64,540 19,051 45,489 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer	mills/kWh 2.12 78.28 58.28 0.12 0.00 45.84 112.26 1,274 \$5,687.23 \$473.94 50,660 Price mills/kWh	MWH 64,540 19,051 45,489 64,540 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24 \$5,687.23	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary	### 12.26 ### 12.26 ### 12.26 ### 12.26 ### 12.26 ### 13.94 ### 50,660 ### Price #### mills/kWh ### 0.00	MWH 64,540 19,051 45,489 64,540 64,540 64,540	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537	\$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322,24 \$5,687.23 Per Cust. Revenues \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1	### 12.26 ### 12.26 ### 12.26 ### 12.26 ### 12.26 ### 13.94 ### 50,660 ### 10.00 ### 0.00 ### 0.00 ### 0.00 ### 0.00	MWH 64,540 19,051 45,489 64,540 64,540 64,540 2019 MWH	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322,24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues \$0.00 \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1 Distribution Block 2	### ### ##############################	MWH 64,540 19,051 45,489 64,540 64,540 64,540 2019 MWH	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues \$0 \$0 \$0	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322,24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00 \$0.00 \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues \$0.00 \$0.00 \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning	### ### ##############################	MWH 64,540 19,051 45,489 64,540 64,540 64,540 2019 MWH 0 0 2,884,961	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues \$0 \$0 \$0 \$0 \$288,496	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00 \$0.00 \$25.02	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues \$0.00 \$0.00 \$0.00 \$2.09
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO	### ### ##############################	64,540 19,051 45,489 64,540 64,540 64,540 64,540 2019 MWH 0 0 0 2,884,961 2,884,961	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues \$0 \$0 \$0 \$0 \$288,496 \$0	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00 \$25.02 \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues \$0.00 \$0.00 \$0.00 \$2.09 \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation	### ### ##############################	MWH 64,540 19,051 45,489 64,540 64,540 64,540 2019 MWH 0 0 2,884,961	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues \$0 \$0 \$0 \$0 \$109,051,542	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00 \$25.02 \$0.00 \$9,459.03	## Revenues \$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 ## Monthly Revenues \$0.00 \$0.00 \$0.00 \$2.09 \$0.00 \$788.25
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO	### ### ##############################	64,540 19,051 45,489 64,540 64,540 64,540 64,540 2019 MWH 0 0 0 2,884,961 2,884,961	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues \$0 \$0 \$0 \$0 \$288,496 \$0	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00 \$25.02 \$0.00	\$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 Monthly Revenues \$0.00 \$0.00 \$0.00 \$2.09 \$0.00
Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation Totals Number of 2019 Customers Revenues per customer Monthly Revenues per customer Annual kWh per Customer Schedule 83 Tariff Category Transmission & Ancillary Distribution Block 1 Distribution Block 2 Trojan Decommissioning CIO Fixed Generation	### ### ##############################	64,540 19,051 45,489 64,540 64,540 64,540 64,540 2019 MWH 0 0 0 2,884,961 2,884,961	\$136,825 \$1,491,343 \$2,651,095 \$7,745 \$0 \$2,958,528 \$7,245,537 Revenues \$0 \$0 \$0 \$0 \$109,051,542	Revenues \$107.40 \$1,170.60 \$2,080.92 \$6.08 \$0.00 \$2,322.24 \$5,687.23 Per Cust. Revenues \$0.00 \$0.00 \$25.02 \$0.00 \$9,459.03	## Revenues \$8.95 \$97.55 \$173.41 \$0.51 \$0.00 \$193.52 \$473.94 ## Monthly Revenues \$0.00 \$0.00 \$0.00 \$2.09 \$0.00 \$788.25

Revenues per customer	\$9,484.05
Monthly Revenues per customer	\$790.34
Annual kWh per Customer	250,239

	Price	2019		Per Cust.	Monthly
Schedule 85-S Tariff Category	mills/kWh	MWH	Revenues	Revenues	Revenues
Transmission & Ancillary	0.00	0	\$0	\$0.00	\$0.00
Distribution Block 1	0.00	0	\$0	\$0.00	\$0.00
Distribution Block 2	0.00	0	\$0	\$0.00	\$0.00
Trojan Decommissioning	0.09	2,122,422	\$191,018	\$136.53	\$11.38
CIO	0.00	2,122,422	\$0	\$0.00	\$0.00
Fixed Generation	36.40	2,122,422	\$77,256,166	\$55,219.13	\$4,601.59
Totals	36.49		\$77,447,184	\$55,355.66	\$4,612.97
Number of 2019 Customers	1,399				
Revenues per customer	\$55,355.66				
Monthly Revenues per customer	\$4,612.97				
Annual kWh per Customer	1,517,009				
	Price	2019		Per Cust.	Monthly
Schedule 85-P Tariff Category	mills/kWh	MWH	Revenues	Revenues	Revenues
Transmission & Ancillary	0.00	0	\$0	\$0.00	\$0.00
Distribution Block 1	0.00	0	\$0	\$0.00	\$0.00
Distribution Block 2	0.00	0	\$0	\$0.00	\$0.00
Trojan Decommissioning	0.09	591,424	\$53,228	\$225,23	\$18,77
CIÓ	0.00	591,424	\$0	\$0.00	\$0.00
Fixed Generation	35.75	591,424	\$21,143,421	\$89,464.40	\$7,455.37
Totals	35.84		\$21.196.649	\$89.689.63	\$7,474,14

lotais	35.84	\$21,196,649	Ф
Number of 2019 Customers	236		
Revenues per customer	\$89,689.63 \$7,474.14		
Monthly Revenues per customer	φ7,474 . 14 2.502.501		

PORTLAND GENERAL ELECTRIC SCHEDULES 15 & 91/95 COMPARISON OF PRICES

		2019 GRC	2018	Delta	Delta	Percent Change
Schedule 91 & 95 Categories	MWH	Price	Price	Price	Revenues	of Total Bill
Functional Costs						
Trans. & Rel. Serv. Charge	50,583	1.52	1.29	0.23	\$12	0.11%
Distribution Charge	50,583	61.31	59.08	2.23	\$113	1.03%
Franchise Fees & Other	50,583	4.58	4.62	(0.04)	(\$2)	-0.02%
CIO	50,583	(1.90)	(0.93)	(0.97)	(\$49)	-0.45%
COS Energy Charge	50,583	48.98	50.54	(1.56)	(\$79)	-0.72%
Schedule 125	50,583	0.00	0.00	0.00	\$0	0.00%
Schedule 122	50,583	0.00	0.00	0.00	\$0	0.00%
Fixed Charges	50,583	<u>104.67</u>	102.61	2.06	<u>\$104</u>	<u>0.95%</u>
Subtotal		219.16	217.21	1.95	\$98	0.90%

	2019 GRC	2018	Delta	Delta	Percent Change
MWH	Price	Price	Price	Revenues	of Total Bill
15,774	1.52	1.29	0.23	\$4	0.10%
15,774	53.55	55.30	(1.75)	(\$28)	-0.80%
15,774	4.34	4.58	(0.24)	(\$4)	-0.11%
15,774	6.10	2.89	3.21	\$51	1.46%
15,774	48.98	50.54	(1.56)	(\$25)	-0.71%
15,774	0.00	0.00	0.00	\$0	0.00%
15,774	0.00	0.00	0.00	\$0	0.00%
15,774	<u>103.18</u>	104.69	<u>(1.50)</u>	<u>(\$24)</u>	<u>-0.69%</u>
	217.67	219.29	(1.61)	(\$25)	-0.74%
15,774	59.41	\$937	\$6.10	\$96,221	
50,583	67.41	\$3,410	(\$1.90)	(\$96,108)	
66,357		\$4,347	\$65.51	\$114	
15,774	48.98	\$773	\$0.00	\$48.98	
50,583	48.98	\$2,478	\$0.00	\$48.98	
66,357		\$3,250	\$48.98		
	15,774 15,774 15,774 15,774 15,774 15,774 15,774 15,774 15,774 50,583 66,357	MWH Price 15,774 1.52 15,774 53.55 15,774 4.34 15,774 6.10 15,774 0.00 15,774 0.00 15,774 103.18 217.67 15,774 59.41 50,583 67.41 50,583 48.98 50,583 48.98	MWH Price Price 15,774 1.52 1.29 15,774 53.55 55.30 15,774 4.34 4.58 15,774 6.10 2.89 15,774 0.00 0.00 15,774 0.00 0.00 15,774 0.00 0.00 15,774 103.18 104.69 217.67 219.29 15,774 59.41 \$937 50,583 67.41 \$3.410 66,357 \$4,347 15,774 48.98 \$773 50,583 48.98 \$2,478	MWH Price Price Price 15,774 1.52 1.29 0.23 15,774 53.55 55.30 (1.75) 15,774 4.34 4.58 (0.24) 15,774 6.10 2.89 3.21 15,774 48.98 50.54 (1.56) 15,774 0.00 0.00 0.00 15,774 0.00 0.00 0.00 15,774 103.18 104.69 (1.50) 217.67 219.29 (1.61) 15,774 59.41 \$937 \$6.10 50.583 67.41 \$3.410 (\$1.90) 50,583 48.98 \$773 \$0.00 50,583 48.98 \$2.478 \$0.00	MWH Price Price Price Revenues 15,774 1.52 1.29 0.23 \$4 15,774 53.55 55.30 (1.75) (\$28) 15,774 4.34 4.58 (0.24) (\$4) 15,774 6.10 2.89 3.21 \$51 15,774 48.98 50.54 (1.56) (\$25) 15,774 0.00 0.00 0.00 \$0 15,774 0.00 0.00 0.00 \$0 15,774 103.18 104.69 (1.50) (\$24) 217.67 219.29 (1.61) (\$25) 15,774 59.41 \$937 \$6.10 \$96,221 50.583 67.41 \$3,410 (\$1.90) (\$96,108) 50,583 48.98 \$773 \$0.00 \$48.98 50,583 48.98 \$2,478 \$0.00 \$48.98

System Usage Charge Summary

Schedules	Total mills/kWh
Schedule 7	2.18
Schedule 15	10.44
Schedule 515	9.14
Schedule 32	1.87
Schedule 532	0.32
Schedule 38	2.34
Schedule 538	0.91
Schedule 47	4.15
Schedule 49	2.71
Schedule 549	0.84
Schedule 83	6.99
Schedule 583	5.44
Schedule 85-S	0.97
Schedule 485-S	(0.28)
Schedule 585-S	(0.28)
Schedule 89-S GT 4 MW	1.02
Schedule 589-S GT 4 MW	(0.14)
Schedule 85-P	0.93
Schedule 485-P	(0.29)
Schedule 585-P	(0.29)
Schedule 89-P GT 4 MW	0.99
Schedule 489-P GT 4 MW	(0.15)
Schedule 589-P GT 4 MW	(0.15)
Schedule 89-T	0.97
Schedule 489-T	(0.15)
Schedule 589-T	(0.15)
Schedule 90-P	0.54
Schedule 490	(0.77)
Schedule 590	(0.77)
Schedules 91/95 Schedule 591/595	2.68 1.38
Schedule 92	1.38
Schedule 592	
Schedule 392	(0.26)

Daily Schedule 76 Prices

Schedule 76 ERP Daily Distribution Demand Charge

	Secondary	Primary	Subtransmis	sion
Annual	\$31.32	\$30.36	\$15.24	
Month l y	\$2.61	\$2.53	\$1.27	
Daily	0.102	0.099	0.049	(annual charge / (313-5))

Schedule 76 ERP Daily Transmission Demand Charge

	Secondary	Primary	Subtransmiss	sion
Annual	\$9.36	\$9.12	\$9.00	
Monthly	\$0.78	\$0.76	\$0.75	
Daily	0.030	0.030	0.029	(annual charge / (313-5))

Daily charges are for on-peak hours only

Twenty Five Percent Load Factor

Sch 32	Prices	Units	BD	Charges	Cents/kWh
Customer Charge	\$29.00	cust.	1	\$29.00	
Transmission Charge	2.06	kWh	5,475	\$11.28	
Distribution Charge					
First 5,000 kWh	40.45	kWh	5,000	\$202.25	
Over 5,000 kWh	13.00	kWh	475	\$6.18	
System Usage Charge	1.87	kWh	5,475	\$10.24	
Energy Charges	58.42	kWh	5,475	<u>\$319.85</u>	10.57
Total Charges				\$578.80	
Sch 83 Secondary	Prices	Units	BD	Charges	Cents/kWh
con co coconaary	1 11000	OTILLO	55	onargoo	Comonition
Customer Charge	\$45.00	cust.	1	\$45.00	
Transmission Charge	\$0.78	dem	30	\$23.40	
Distribution Demand Charge	\$2,61	dem	30	\$78.30	
Distribution Facilities Charge)				
First 30 kW	\$3.50	fac	30	\$105.00	
Over 30 kW	\$3.40	fac	0	\$0.00	
System Usage Charge	6.99	kWh	5,475	\$38.27	
Energy Charges					
On-peak (64%)	63.35	kWh	3,504	\$221.98	
Off-peak (36%)	48.35	kWh	1,971	<u>\$95.30</u>	
Total Charges				\$607.25	11.09
Load Factor	25.00%		Percent C	hange	4.92%
Demand	30			ŭ	
Billing Hours	730				

Thirty Percent Load Factor

Sch 32	Prices	Units	BD	Charges	Cents/kWh
Customer Charge Transmission Charge Distribution Charge	\$29.00 2.06	cust. kWh	1 6,570	\$29.00 \$13.53	
First 5,000 kWh Over 5,000 kWh	40.45 13.00		5,000 1,570	\$202.25 \$20.41	
System Usage Charge		kWh	6,570	\$12.29	
Energy Charges Total Charges	58.42	kWh	6,570	\$383.82 \$661.30	10.07
Sch 83 Secondary	Prices	Units	BD	Charges	Cents/kWh
Customer Charge	\$45.00		1		
Transmission Charge Distribution Demand Charge	\$0.78 \$2.61		30 30		
Distribution Facilities Charge		uem	30	Ψ/0.50	
First 30 kW	\$3.50		30		
Over 30 kW	\$3.40		6 570	\$0.00 \$45.92	
System Usage Charge Energy Charges	6.99	kWh	6,570	\$45.9 2	
On-peak (64%)	63.35	kWh	4,205	\$266.39	
Off-peak (36%)	48.35	kWh	2,365	\$114.35	40.00
Total Charges				\$678.36	10.33
Load Factor	30.00%		Percent C	hange	2.58%
Demand	30				
Billing Hours	730				
Forty Percent Load Factor					
Sch 32	Prices	Units	BD	Charges	Cents/kWh
Customer Charge	Prices \$29.00		BD 1	Charges \$29.00	Cents/kWh
Customer Charge Transmission Charge	\$29.00			•	Cents/kWh
Customer Charge Transmission Charge Distribution Charge	\$29.00 2.06	cust. kWh	1 8,760	\$29.00 \$18.05	Cents/kWh
Customer Charge Transmission Charge	\$29.00	cust. kWh kWh	1	\$29.00	Cents/kWh
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge	\$29.00 2.06 40.45 13.00	cust. kWh kWh	1 8,760 5,000	\$29.00 \$18.05 \$202.25	Cents/kWh
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges	\$29.00 2.06 40.45 13.00	cust. kWh kWh kWh	1 8,760 5,000 3,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76	Cents/kWh
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge	\$29.00 2.06 40.45 13.00 1.87	cust. kWh kWh kWh	1 8,760 5,000 3,760 8,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38	
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges	\$29.00 2.06 40.45 13.00 1.87	cust. kWh kWh kWh	1 8,760 5,000 3,760 8,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76	
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges	\$29.00 2.06 40.45 13.00 1.87 58.42	cust. kWh kWh kWh kWh kWh	1 8,760 5,000 3,760 8,760 8,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78	cust. kWh kWh kWh kWh LUnits	1 8,760 5,000 3,760 8,760 8,760 BD	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61	cust. kWh kWh kWh kWh LUnits	1 8,760 5,000 3,760 8,760 8,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61	cust. kWh kWh kWh kWh Units cust. dem	1 8,760 5,000 3,760 8,760 8,760 BD	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61	cust. kWh kWh kWh kWh Units cust. dem dem	1 8,760 5,000 3,760 8,760 8,760 BD	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40	cust. kWh kWh kWh kWh Units cust. dem dem	1 8,760 5,000 3,760 8,760 8,760 BD	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Pemand Charge First 30 kW Over 30 kW System Usage Charge Energy Charges	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tonits cust. dem dem fac fac kWh	1 8,760 5,000 3,760 8,760 8,760 BD 1 30 30 0 8,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$61.23	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh	1 8,760 5,000 3,760 8,760 8,760 BD 1 30 30 30 8,760 5,606	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$61.23	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%) Off-peak (36%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh	1 8,760 5,000 3,760 8,760 8,760 BD 1 30 30 0 8,760	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$61.23 \$355.14 \$152.50	9.43 Cents/kWh
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh	1 8,760 5,000 3,760 8,760 8,760 BD 1 30 30 30 8,760 5,606	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$61.23	9.43
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%) Off-peak (36%) Total Charges Load Factor	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh kWh	1 8,760 5,000 3,760 8,760 8,760 BD 1 30 30 30 8,760 5,606	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$61.23 \$355.14 \$152.50 \$820.57	9.43 Cents/kWh
Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%) Off-peak (36%) Total Charges	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	cust. kWh kWh kWh kWh twh Units cust. dem dem fac fac kWh kWh	1 8,760 5,000 3,760 8,760 8,760 BD 1 30 30 30 8,760 5,606 3,154	\$29.00 \$18.05 \$202.25 \$48.88 \$16.38 \$511.76 \$826.32 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$61.23 \$355.14 \$152.50 \$820.57	9.43 Cents/kWh

Fifty Percent Load Factor

Sch 32	Prices	Units	BD	Charges	Cents/kWh
Customer Charge Transmission Charge Distribution Charge	\$29.00 2.06	cust. kWh	1 10,950	\$29.00 \$22.56	
First 5,000 kWh Over 5,000 kWh	40.45 13.00		5,000 5,950	\$202.25 \$77.35	
System Usage Charge		kWh	10,950	\$20.48	
Energy Charges Total Charges	58.42	kWh	10,950	\$639.70 \$991.34	9.05
Sch 83 Secondary	Prices	Units	BD	Charges	Cents/kWh
Customer Charge	\$45.00		1	\$45.00	
Transmission Charge Distribution Demand Charge	\$0.78 \$2.61		30 30		
Distribution Facilities Charge		dem	30	\$70.30	
First 30 kW	\$3.50		30		
Over 30 kW	\$3.40		0		
System Usage Charge	6.99	kWh	10,950	\$76.54	
Energy Charges On-peak (64%)	63.35	kWh	7,008	\$443.96	
Off-peak (36%)	48.35		3,942	\$190.60	
Total Charges				\$962.80	8.79
Load Factor	50.00%		Percent C	hange	-2.88%
Demand	30			· ·	
Billing Hours	730				
Sixty Percent Load Factor					
Oixty i crocint Loud i dotor					
Sch 32	Prices	Units	BD	Charges	Cents/kWh
Sch 32 Customer Charge	Prices \$29.00		BD 1	\$29.00	Cents/kWh
Sch 32 Customer Charge Transmission Charge	\$29.00			•	Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge	\$29.00 2.06	cust. kWh	1 13,140	\$29.00 \$27.07	Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh	\$29.00 2.06 40.45	cust. kWh	1 13,140 5,000	\$29.00 \$27.07 \$202.25	Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh	\$29.00 2.06 40.45 13.00	cust. kWh kWh kWh	1 13,140 5,000 8,140	\$29.00 \$27.07 \$202.25 \$105.82	Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh	\$29.00 2.06 40.45 13.00	cust. kWh kWh kWh	1 13,140 5,000	\$29.00 \$27.07 \$202.25	Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge	\$29.00 2.06 40.45 13.00 1.87	cust. kWh kWh kWh	1 13,140 5,000 8,140 13,140	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57	
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges	\$29.00 2.06 40.45 13.00 1.87	cust. kWh kWh kWh	1 13,140 5,000 8,140 13,140	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64	
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges	\$29.00 2.06 40.45 13.00 1.87 58.42	cust. kWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices	cust. kWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35 Charges \$45.00	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61	cust. kWh kWh kWh kWh LUnits	1 13,140 5,000 8,140 13,140 13,140 BD	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35 Charges \$45.00 \$23.40	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61	cust. kWh kWh kWh kWh Units cust. dem	1 13,140 5,000 8,140 13,140 13,140 BD	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35 Charges \$45.00 \$23.40 \$78.30	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61	cust. kWh kWh kWh kWh Units cust. dem dem	1 13,140 5,000 8,140 13,140 13,140 BD	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40	cust. kWh kWh kWh kWh tWh kWh fac dem fac fac	1 13,140 5,000 8,140 13,140 13,140 BD 1 30 30	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 <u>\$767.64</u> \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40	cust. kWh kWh kWh kWh Units cust. dem dem	1 13,140 5,000 8,140 13,140 13,140 BD	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Pemand Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140 BD 1 30 30 0 13,140 8,410	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 <u>\$767.64</u> \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$91.85	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%) Off-peak (36%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140 BD 1 30 30 0 13,140	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 \$767.64 \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$91.85 \$532.77 \$228.70	8.80 Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Pemand Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140 BD 1 30 30 0 13,140 8,410	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 <u>\$767.64</u> \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$91.85	8.80
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%) Off-peak (36%)	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	cust. kWh kWh kWh kWh tWh th kWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140 BD 1 30 30 0 13,140 8,410	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 <u>\$767.64</u> \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$91.85 \$532.77 \$228.70 \$1,105.02	8.80 Cents/kWh
Sch 32 Customer Charge Transmission Charge Distribution Charge First 5,000 kWh Over 5,000 kWh System Usage Charge Energy Charges Total Charges Sch 83 Secondary Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charges On-peak (64%) Off-peak (36%) Total Charges	\$29.00 2.06 40.45 13.00 1.87 58.42 Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	cust. kWh kWh kWh kWh tWh kWh kWh kWh kWh	1 13,140 5,000 8,140 13,140 13,140 BD 1 30 30 30 13,140 8,410 4,730	\$29.00 \$27.07 \$202.25 \$105.82 \$24.57 <u>\$767.64</u> \$1,156.35 Charges \$45.00 \$23.40 \$78.30 \$105.00 \$0.00 \$91.85 \$532.77 \$228.70 \$1,105.02	8.80 Cents/kWh

Eighty Percent Load Factor

Sch 32	Prices	Units	BD	BD Charges	
Customer Charge	\$29.00	cust.	1	\$29.00	
Transmission Charge Distribution Charge	2.06	kWh	17,520	\$36.09	
First 5,000 kWh	40.45	kWh	5,000	\$202.25	
Over 5,000 kWh	13.00	kWh	12,520	\$162.76	
System Usage Charge	1.87	kWh	17,520	\$32.76	
Energy Charges	58.42	kWh	17,520	\$1,023.52	8.48
Total Charges				\$1,486.38	
Sch 83 Secondary	Prices	Units	BD	Charges	Cents/kWh
Customer Charge	\$45.00	cust.	1	\$45.00	
Transmission Charge	\$0.78	dem	30	\$23.40	
Distribution Demand Charge	\$2.61	dem	30	\$78.30	
Distribution Facilities Charge					
First 30 kW	\$3.50	fac	30	\$105.00	
Over 30 kW	\$3.40	fac	0	\$0.00	
System Usage Charge	6.99	kWh	17,520	\$122.46	
Energy Charges					
On-peak (64%)	63.35	kWh	11,213	\$710.34	
Off-peak (36%)	48.35	kWh	6,307	<u>\$304.94</u>	
Total Charges				\$1,389.44	7.93
Load Factor Demand Billing Hours	80.00% 30 730		Percent C	hange	-6.52%

Proposed Schedule 83 Seco	-			
	Prices	Units	BD	Charges
Customer Charge	\$45.00	cust.	1	\$45.00
Transmission Charge	\$0.78	dem	200	\$156.00
Distribution Demand Charge	\$2.61	dem	200	\$522.00
	φ2.01	uem	200	φ322.00
Distribution Facilities Charge				
First 30 kW	\$3.50	fac	30	\$105.00
Over 30 kW	\$3.40	fac	170	\$578.00
System Usage Charge	6.99	kWh	36,500	\$255.14
	0.99	KVVII	30,300	φ233.1 4
Energy Charge				
On-peak (64%)	63.35	kWh	23,360	\$1,479.86
Off-peak (36%)	48.35	kWh	13,140	\$635.32
Total Charges				\$3,776.31
D D !				4.000/
Revenue Delta				-4.88%
Proposed Schedule 85 Seco	ondary 25%	I oad F	actor	
i roposea ochedale os oeco				01
	Prices	Units	BD	Charges
Customer Charge	\$560.00	cust.	1	\$560.00
Transmission Charge	\$0.78	dem	200	\$156.00
Distribution Demand Charge	\$2.61	dem	200	\$522.00
•	φ2.0 I	uem	200	Φ522.00
Distribution Facilities Charge				
First 200 kW	\$3.17	fac	200	\$634.00
Over 200 kW	\$1.97	fac	0	\$0.00
System Usage Charge		kWh		
, ,	0.97	KVVII	36,500	\$35.41
Energy Charge				
On-peak (64%)	61.91	kWh	23,360	\$1,446.22
Off-peak (36%)	46.91	kWh	13,140	\$616.40
On peak (0070)	40.01	124411	10,140	ψ010.40
Tatal Observes				#2.070.00
Total Charges				\$3,970.02
Proposed Schedule 83 Seco	ndary 40%	Load F	actor	
1 Toposca Gonicadie do Occi				
	-		DD.	01
	Prices	Units	BD	Charges
Customer Charge	-		BD 1	Charges \$45.00
	Prices \$45.00	Units cust.	1	\$45.00
Transmission Charge	Prices \$45.00 \$0.78	Units cust. dem	1 200	\$45.00 \$156.00
Transmission Charge Distribution Demand Charge	Prices \$45.00	Units cust.	1	\$45.00
Transmission Charge	Prices \$45.00 \$0.78	Units cust. dem	1 200	\$45.00 \$156.00
Transmission Charge Distribution Demand Charge	Prices \$45.00 \$0.78	Units cust. dem	1 200	\$45.00 \$156.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW	Prices \$45.00 \$0.78 \$2.61 \$3.50	Units cust. dem dem	1 200 200 30	\$45.00 \$156.00 \$522.00 \$105.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW	\$45.00 \$0.78 \$2.61 \$3.50 \$3.40	Units cust. dem dem	1 200 200 30 170	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge	Prices \$45.00 \$0.78 \$2.61 \$3.50	Units cust. dem dem	1 200 200 30	\$45.00 \$156.00 \$522.00 \$105.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW	\$45.00 \$0.78 \$2.61 \$3.50 \$3.40	Units cust. dem dem	1 200 200 30 170	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge	\$45.00 \$0.78 \$2.61 \$3.50 \$3.40	Units cust. dem dem	1 200 200 30 170	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%)	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%)	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%)	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%)	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Units cust. dem dem fac fac kWh	1 200 200 30 170 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Units cust. dem dem fac fac kWh kWh	1 200 200 30 170 58,400 37,376 21,024	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges	\$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Units cust. dem dem fac fac kWh kWh	1 200 200 30 170 58,400 37,376 21,024	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58%
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Units cust. dem dem fac fac kWh kWh kWh	1 200 200 30 170 58,400 37,376 21,024	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	\$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Units cust. dem dem fac fac kWh kWh	1 200 200 30 170 58,400 37,376 21,024	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58%
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Units cust. dem dem fac fac kWh kWh kWh	1 200 200 30 170 58,400 37,376 21,024	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 endary 40% Prices \$560.00 \$0.78	Units cust. dem dem fac fac kWh kWh Load F	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Units cust. dem dem fac fac kWh kWh Load I Units cust.	1 200 200 30 170 58,400 37,376 21,024	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61	Units cust. dem fac fac kWh kWh Load I Units cust. dem dem	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 endary 40% Prices \$560.00 \$0.78	Units cust. dem dem fac fac kWh kWh Load F	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61	Units cust. dem fac fac kWh kWh Load I Units cust. dem dem	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97	Units cust. dem dem fac fac kWh kWh kWh fac dem dem fac fac fac kWh	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200 0	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00 \$634.00 \$0.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61 \$3.17	Units cust. dem dem fac fac kWh kWh kWh fac ust. dem dem fac fac kWh fac fac fac kWh fac	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200 200	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00 \$634.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97 0.97	Units cust. dem dem fac fac kWh kWh kWh	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200 58,400	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00 \$634.00 \$0.00 \$56.65
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97	Units cust. dem dem fac fac kWh kWh kWh fac dem dem fac fac fac kWh	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200 0	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00 \$634.00 \$0.00
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97 0.97	Units cust. dem dem fac fac kWh kWh kWh	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200 58,400	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00 \$634.00 \$0.00 \$56.65
Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97 0.97	Units cust. dem dem fac fac kWh kWh kWh Load F Units cust. dem dem fac fac kWh kWh	1 200 200 30 170 58,400 37,376 21,024 Factor BD 1 200 200 0 58,400 37,376	\$45.00 \$156.00 \$522.00 \$105.00 \$578.00 \$408.22 \$2,367.77 \$1,016.51 \$5,198.50 -0.58% Charges \$560.00 \$156.00 \$522.00 \$634.00 \$0.00 \$56.65 \$2,313.95

\$5,228.83

Total Charges

Proposed Schedule 83 Seco	-				Chaur :
	Prices	Units	BD		Charges
Customer Charge		cust.		1	\$45.0
Transmission Charge	\$0.78	dem		200	\$156.0
Distribution Demand Charge	\$2.61	dem		200	\$522.0
Distribution Facilities Charge					
First 30 kW	\$3.50	fac		30	\$105.0
Over 30 kW	\$3.40	fac		170	\$578.0
System Usage Charge	6.99	kWh	73	,000	\$510.2
Energy Charge		kWh			
On-peak (64%)	63.35	kWh	46	,720	\$2,959.7
Off-peak (36%)	48.35	kWh	26	,280	\$1,270.6
Total Charges					\$6,146.6
Revenue Delta					1.29
Proposed Schedule 85 Seco	ndary 50%	Load F	actor		
roposed concadic ob occo	Prices	Units	BD		Charges
Customer Charge	\$560.00		22	1	\$560.0
Transmission Charge	\$0.78			200	\$156.0
Distribution Demand Charge	\$2.61	dem		200	\$522.0
Distribution Facilities Charge	Ψ2.01	acili		200	ψυΖΖ.0
First 200 kW	\$3.17	fac		200	\$634.0
Over 200 kW	\$3.17 \$1.97				\$0.0
			70	0	
System Usage Charge	0.97	KVVN	73	,000	\$70.8
Energy Charge	04.04		40	700	#0.000.4
On-peak (64%)	61.91	kWh		,720	\$2,892.4
Off-peak (36%)	46.91	kWh	26	,280	\$1,232.7
. , ,	10.01			,	
Total Charges	10.01		20	•	\$6,068.0
Total Charges				,	
Total Charges	ndary 60%	Load F	actor	,	\$6,068.0
Total Charges Proposed Schedule 83 Seco	ndary 60% Prices	Load F Units			\$6,068.0 Charges
Total Charges Proposed Schedule 83 Seco Customer Charge	ndary 60% Prices \$45.00	Load F Units cust.	actor	1	\$6,068.0 Charges \$45.0
Total Charges Proposed Schedule 83 Seco Customer Charge	ndary 60% Prices	Load F Units cust.	actor		\$6,068.0 Charges \$45.0
Total Charges Proposed Schedule 83 Seco Customer Charge Transmission Charge	ndary 60% Prices \$45.00	Load F Units cust.	actor	1	\$6,068.0 Charges \$45.0 \$156.0
Total Charges Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge	ndary 60% Prices \$45.00 \$0.78	Load F Units cust. dem	actor	1 200	\$6,068.0 Charges \$45.0 \$156.0
Total Charges Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge	ndary 60% Prices \$45.00 \$0.78	Load F Units cust. dem	actor	1 200	\$6,068.0 Charges \$45.0 \$156.0 \$522.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50	Load F Units cust. dem dem	actor	1 200 200 30	\$6,068.0 Charges \$45.0 \$156.0 \$522.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40	Load F Units cust. dem dem fac fac	actor BD	1 200 200 30 170	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40	Load F Units cust. dem dem fac fac kWh	actor BD	1 200 200 30	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge	Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Load F Units cust. dem dem fac fac kWh kWh	actor BD 87	1 200 200 30 170 ,600	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40	Load F Units cust. dem dem fac fac kWh kWh	actor BD 87 56	1 200 200 30 170	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%)	rndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Load F Units cust. dem dem fac fac kWh kWh	actor BD 87 56	1 200 200 30 170 ,600	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7
Proposed Schedule 83 Secon Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%)	rndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99	Load F Units cust. dem dem fac fac kWh kWh	actor BD 87 56	1 200 200 30 170 ,600	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta	rindary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Load F Units cust. dem dem fac fac kWh kWh kWh	actor BD 87 56 31	1 200 200 30 170 ,600	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Load F Units cust. dem dem fac fac fac kWh kWh kWh kWh	actor BD 87 56 31	1 200 200 30 170 ,600	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Load F Units cust. dem dem fac fac kWh kWh kWh kWh	actor BD 87 56 31	1 200 200 30 170 ,600 ,064 ,536	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 2.71 Charges
Proposed Schedule 83 Seco Customer Charge Customer Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Load F Units cust. dem dem fac fac kWh kWh kWh kWh	actor BD 87 56 31	1 200 200 30 170 ,600 ,064 ,536	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 Charges \$560.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Transmission Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 andary 60% Prices \$560.00 \$0.78	Load F Units cust. dem fac fac kWh kWh kWh kWh the Load F	actor BD 87 56 31	1 200 200 30 170 6,600 ,,064 ,,536	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 Charges \$560.0 \$156.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Distribution Demand Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35	Load F Units cust. dem dem fac fac kWh kWh kWh kWh	actor BD 87 56 31	1 200 200 30 170 ,600 ,064 ,536	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 Charges \$560.0 \$156.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Distribution Demand Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 andary 60% Prices \$560.00 \$0.78	Load F Units cust. dem fac fac kWh kWh kWh kWh the Load F	actor BD 87 56 31	1 200 200 30 170 6,600 ,,064 ,,536	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 Charges \$560.0 \$156.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Distribution Demand Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 andary 60% Prices \$560.00 \$0.78	Load F Units cust. dem fac fac kWh kWh kWh kWh the Load F	actor BD 87 56 31	1 200 200 30 170 6,600 ,,064 ,,536	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 2.71 Charges \$560.0 \$522.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Distribution Demand Charge Distribution Facilities Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 andary 60% Prices \$560.00 \$0.78 \$2.61	Load F Units cust. dem dem fac fac kWh kWh kWh th kWh kWh	actor BD 87 56 31	1 200 200 30 170 ,600 ,064 ,536	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 2.71 Charges \$560.0 \$156.0 \$522.0
Proposed Schedule 83 Seco Customer Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Demand Charge First 200 kW Over 200 kW	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 andary 60% Prices \$560.00 \$0.78 \$2.61 \$3.17	Load F Units cust. dem fac fac kWh kWh kWh kWh toad F Units cust. dem dem fac	actor BD 87 56 31	1 200 200 30 170 ,600 ,064 ,536	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 Charges \$560.0 \$156.0 \$522.0 \$634.0 \$0.0
Proposed Schedule 83 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Transmission Charge Distribution Demand Charge Distribution Facilities Charge First 200 kW Over 200 kW System Usage Charge	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Indary 60% Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97	Load F Units cust. dem fac fac kWh kWh kWh kWh toust. dem dem fac fac	actor BD 87 56 31	1 200 200 30 170 ,600 ,064 ,536 1 200 200 200 0	\$6,068.0 Charges \$45.0 \$156.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7 Charges \$560.0 \$156.0 \$522.0 \$634.0 \$0.0
Proposed Schedule 83 Seco Customer Charge Distribution Demand Charge Distribution Facilities Charge First 30 kW Over 30 kW System Usage Charge Energy Charge On-peak (64%) Off-peak (36%) Total Charges Revenue Delta Proposed Schedule 85 Seco Customer Charge Distribution Demand Charge Distribution Demand Charge Distribution Pacilities Charge First 200 kW	ndary 60% Prices \$45.00 \$0.78 \$2.61 \$3.50 \$3.40 6.99 63.35 48.35 Indary 60% Prices \$560.00 \$0.78 \$2.61 \$3.17 \$1.97	Load F Units cust. dem fac fac kWh kWh kWh kWh toust. dem dem fac fac	actor BD 87 56 31 actor BD	1 200 200 30 170 ,600 ,064 ,536 1 200 200 200 0	\$6,068.0 Charges \$45.0 \$156.0 \$522.0 \$105.0 \$578.0 \$612.3 \$3,551.6 \$1,524.7 \$7,094.7

\$6,907.25

Total Charges

Proposed Schedule 83 Secondary 80% Load Factor Prices Units BD

	Prices	Units	BD	Charges
Customer Charge	\$45.00	cust.	1	\$45.00
Transmission Charge	\$0.78	dem	200	\$156.00
Distribution Demand Charge	\$2.61	dem	200	\$522.00
Distribution Facilities Charge				
First 30 kW	\$3.50	fac	30	\$105.00
Over 30 kW	\$3.40	fac	170	\$578.00
System Usage Charge	6.99	kWh	116,800	\$816.43
Energy Charge		kWh		
On-peak (64%)	63.35	kWh	74,752	\$4,735.54
Off-peak (36%)	48.35	kWh	42,048	\$2,033.02
Total Charges				\$8,990.99
Bayanya Dalta				4.700/
Revenue Delta				4.72%

Proposed Schedule 85 Secondary 80% Load Factor

	Prices	Units	BD	Charges
Customer Charge	\$560.00	cust.	1	\$560.00
Transmission Charge	\$0.78	dem	200	\$156.00
Distribution Demand Charge	\$2.61	dem	200	\$522.00
Distribution Facilities Charge				
First 200 kW	\$3.17	fac	200	\$634.00
Over 200 kW	\$1.97	fac	0	\$0.00
System Usage Charge	0.97	kWh	116,800	\$113.30
Energy Charge				
On-peak (64%)	61.91	kWh	74,752	\$4,627.90
Off-peak (36%)	46.91	kWh	42,048	\$1,972.47
Total Charges				\$8,585.66

PORTLAND GENERAL ELECTRIC DISPOSITION OF SYSTEM USAGE CHARGE SELECTED SCHEDULES

			Flat	Block 1	Block 2	Block 3	On-peak	Off-peak	Flat	Block 1	Block 2
	FF &		Energy	Energy	Energy	Energy	Energy	Energy	Distribution	Distribution	Distribution
	Other	CIO	Charge	Charge	Charge	Charge	Charge	Charge	Charge	Charge	Charge
Schedule 7	2.26	(0.08)		63.29	63.29	70.51			44.42		
Schedule 15	4.34	6.10	48.98						53.55		
Schedule 32	1.95	(80.0)	58.42							40.45	13.00
Schedule 38	2.34	0.00					60.70	45.70	68.07		
Schedule 47	4.15	0.00	70.94							106.84	86.84
Schedule 49	2.71	0.00	70.68							78.28	58.28
Schedule 91 & 95	4.58	(1.90)	48.98						61.31		
Schedule 92	1.10	0.00	51.09						28.15		

Tariff Charges with Franchise Fees & Regulatory Assets and CIO

	Flat Energy Charge	Block 1 Energy Charge	Block 2 Energy Charge	Block 3 Energy Charge	On-peak Energy Charge	Off-peak Energy Charge	Flat Distribution Charge	Block 1 Distribution Charge	Block 2 Distribution Charge	System Usage Charge
Schedule 7		63.29	63.29	70.51			46.60			
Schedule 15	48.98						63.99			
Schedule 32	58.42							42.32	14.87	
Schedule 38					60.70	45.70	70.41			
Schedule 47	70.94							110.99	90.99	
Schedule 49	70.68							80.99	60.99	
Schedule 91 & 95	48.98						63.99			
Schedule 92	51.09						29.25			
Schedule 515							62.69			
Schedule 532								40.77	13.32	
Schedule 538							68.98			
Schedule 549								79.12	59.12	
Schedule 583										5.44
Schedule 591							62.69			
Schedule 592							27.89			

PORTLAND GENERAL ELECTRIC MARGINAL COSTS FOR DISTRIBUTION & CONSUMER SERVICES

					DEST	RIBUTION SER	RVICES							CONSUM	MER SERVIC	ES			
	Sub-			Backbone	Feeder Loca			& Trans.		ters		Mete		Bill			her	Uncolle	
	trans- mission	Sub- station		umer Type er kW)	By Consun (\$ per			ımer Type r Cust)		ımer Type onsumer)	Con- sumer	By Consur (\$ per Co		By Consu	mer Type ons/Light)	By Consu (\$ per Co		By Consu Pero	
	(\$ per	(\$ per	Single-	Three-	Single-	Three-	Single-	Three-	Single-	Three-	Service	Single-	Three-	Single-	Three-	Single-	Three-	Single-	Three-
Grouping	kW)	kW)	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase	(Lights)	Phase	Phase	Phase	Phase	Phase	Phase	Phase	Phase
SCH 7 Residential	\$12.15	\$12.24	\$20.41	\$20.41	\$20.10	\$20.10	\$83.97	\$140.51	\$19.43	\$58.07		\$0.31	\$0.31	\$39.01	\$39.01	\$24.05	\$24.05	92.60%	0.00%
SCH 15 Outdoor Area Lighting Residential	\$12.15	\$12.24	\$21.38	N/A	\$20.78		\$2.89	N/A	N/A	N/A	\$3.89	\$0.00	N/A	\$6_28	N/A	\$4.95	N/A	0.47%	
Commercial	\$12.15	\$12.24	\$21.38	N/A	\$20.78		\$2.89	N/A	N/A	N/A	\$3.89	\$0.00	N/A	\$8.06	N/A	\$4.95	N/A	0.34%	
SCH 32 General Service <30 kW	\$12.15	\$12.24	\$24.70	\$24.70	\$27.24	\$12.94	\$150.15	\$236.86	\$17.23	\$72.71		\$0.69	\$0.69	\$33.09	\$33.09	\$46.82	\$46.82	2.81%	1.89%
SCH 38 Opt TOD G.S. > 30 kW	\$12.15	\$12.24	\$24.54	\$24.54	\$26.38	\$13.09	\$196.72	\$581.00	\$58.07	\$130.80		\$11.27	\$11.27	\$41_14	\$41.14	\$109.69	\$109.69	0.00%	0.00%
SCH 47 Irrig. & Drain. Pump.< 30 kW	\$12.15	\$12.24	\$24.70	\$24.70	\$23.90	\$11.35	\$10.77	\$21.43	\$57.73	\$86.54		\$1.05	\$1.05	\$33.15	\$33.15	\$44.91	\$44.91	0.01%	0.09%
SCH 49 Irrig. & Drain. Pump.> 30 kW	\$12.15	\$12.24	\$24_54	\$24.54	\$24.34	\$12.08	\$144.93	\$144.93	\$58.07	\$71.36		\$1.18	\$1.18	\$36.48	\$36.48	\$109.48	\$109.48	0.00%	0.09%
SCH 83 Secondary	\$12.15	\$12.24	\$24.54	\$24.54	\$26.38	\$13.09	\$388.14	\$1,050.66	\$57.73	\$129.44		\$2.57	\$2.57	\$41_59	\$41.59	\$205.64	\$205.64	0.07%	1.05%
SCH 85 Secondary Primary	\$12.15 \$12.15	\$12.24 \$12.24		\$19.54 \$19.54		\$7.12 \$7.12	N/A	\$2,419.89	N/A N/A	\$162.33 \$1,805.54		\$11.93 \$11.93	\$11.93 \$11.93	\$83_38 \$83_38	\$83.38 \$83.38	\$1,220.21 \$1,220.21	\$1,220.21 \$1,220.21		0.50% 0.08%
SCH 89 Secondary Primary Subtransmission	\$12.15 \$12.15 \$12.15	\$12.24 \$12.24 N/A		\$76,614.00 \$76,614.00 \$77,041.00		N/A N/A N/A		\$14,124.26		\$175.85 \$1,809.13 \$19,774.56		N/A N/A N/A	\$1.48 \$1.48 \$1.48	N/A N/A	\$181.76 \$181.76 \$181.76	N/A N/A N/A	\$9,411.51 \$9,411.51 \$9,411.51		0.00% 0.00% 0.00%
SCH 90 Primary	\$12.15	\$12.24		365,087.00				\$0.00		\$1,805.54			\$0.21		\$17.96		\$33,521.59		0.00%
SCH 91 & 95 Street & Highway Light	\$12.15	\$12.24	\$21_38	N/A	\$23.11		\$2_89	N/A	N/A	N/A	\$3.89	\$0.00	N/A	\$984_82	N/A	\$4.95	N/A	0.00%	
SCH 92 Traffic Signals	\$12,15	\$12,24		\$21,38		\$10,44	\$9.19	N/A	N/A	N/A		\$0.00	N/A	\$981.15	N/A	N/A	\$4.95		0.00%

PORTLAND GENERAL ELECTRIC SUMMARY OF MARGINAL COST STUDY

SCHEDULE	SUBTRANSMISSION COSTS	SUBSTATION COSTS	FEEDER BACKBONE COSTS	FEEDER TAPLINE COSTS	SERVICE & TRANSFORMER COSTS	METER COSTS	CUSTOMER COSTS
Schedule 7 Residential	040.45	#40.04	# 00.44	# 00.40	#00.07	040.40	* 00.07
Single-phase Three-phase	\$12.15 \$12.15	\$12.24 \$12.24	\$20.41 \$20.41	\$20.10 \$20.10	\$83.97 \$140.51	\$19.43 \$58.07	\$63.37 \$63.37
Schedule 15 Residential	\$12.15	\$12.24	\$21.38	\$20.78	\$2.89	N/A	\$11.23
Schedule 15 Commercial	\$12.15	\$12.24	\$21.38	\$20.78	\$2.89	N/A	\$13.01
Schedule 32 General Service Single-phase Three-phase	\$12.15 \$12.15	\$12.24 \$12.24	\$24.70 \$24.70	\$27.24 \$12.94	\$150.15 \$236.86	\$17.23 \$72.71	\$80.60 \$80.60
Schedule 38 TOU Single-phase Three-phase	\$12.15 \$12.15	\$12.24 \$12.24	\$24.54 \$24.54	\$26.38 \$13.09	\$196.72 \$581.00	\$58.07 \$130.80	\$162.10 \$162.10
Schedule 47 Irrigation Single-phase Three-phase	\$12.15 \$12.15	\$12.24 \$12.24	\$24.70 \$24.70	\$23.90 \$11.35	\$10.77 \$21.43	\$57.73 \$86.54	\$79.11 \$79.11
Schedule 49 Irrigation Single-phase Three-phase	\$12.15 \$12.15	\$12.24 \$12.24	\$24.54 \$24.54	\$24.34 \$12.08	\$144.93 \$144.93	\$58.07 \$71.36	\$147.14 \$147.14
Schedule 83 Secondary General Service Single-phase Three-phase	\$12.15 \$12.15	\$12.24 \$12.24	\$24.54 \$24.54	\$26.38 \$13.09	\$388.14 \$1,050.66	\$57.73 \$129.44	\$249.80 \$249.80
Schedule 85 Secondary General Service	\$12.15	\$12.24	\$19.54	\$7.12	\$2,419.89	\$162.33	\$1,315.52
Schedule 85 Primary General Service	\$12.15	\$12.24	\$19.54	\$7.12	\$0.00	\$1,805.54	\$1,315.52
Schedule 89 Secondary	\$12.15	\$12.24	\$76,614	N/A	\$14,124.26	\$175.85	\$9,594.75
Schedule 89 Primary	\$12.15	\$12.24	\$76,614	N/A	\$0.00	\$1,809.13	\$9,594.75
Schedule 89 Subtransmission	\$12.15	N/A	\$77,041	N/A	N/A	\$19,774.56	\$9,594.75
Schedule 90 Primary	\$12.15	\$12.24	\$365,087.00	N/A	\$0.00	\$1,805.54	\$33,539.76
Schedules 91 & 95 Streetlighting	\$12.15	\$12.24	\$21.38	\$23.11	\$2.89	N/A	\$989.77
Schedules 92 Traffic Signals	\$12.15	\$12.24	\$21.38	\$10.44	\$9.19	N/A	\$986.10

Summary of 2013 - 2017 Write-offs by Schedule

	Allocation
Schedule	Percent
Schedule 7	92.60%
Schedule 15	0.81%
Schedule 32	4.70%
Schedule 38	0.00%
Schedule 47	0.10%
Schedule 49	0.09%
Schedule 83	1.12%
Schedule 85	0.58%
Schedule 89	0.00%
Schedule 90	0.00%
Schedule 91 & 95	0.00%
Schedule 92	0.00%
Total	100.00%

Employee Discount

	2018	2019 Proposed	
Customers Total Consumption	2,631 30,657	2,631 30,657	
Customer Charge	\$11.00	\$11.00	
Table 1 Volumetric Charge Block 1 Table 1 Volumetric Charge Block 2	110.30 117.52	112.34 119.56	
Table 2 Volumetric Charge Block 1 Table 2 Volumetric Charge Block 2	100.14 117.52	103.12 114.61	
Table 3 Volumetric Charge Block 1 Table 3 Volumetric Charge Block 2	101.11 118.49	106.60 118.09	
Annual Customer Charges Discount	\$347,292 (\$86,823)	\$347,292 (\$86,823)	
Annual Volumetric Charges Block 1 MWH Block 2 MWH	23,662 6,995	23,662 6,995	
Table 1 Table 1 Block 1 Revenue Table 1 Block 2 Revenue Volumetric Revenue Table 1 Volumetric Discount	\$2,609,901 \$822,079 \$3,431,979 (\$857,995)	\$2,658,171 \$836,349 \$3,494,520 (\$873,630)	
Table 2 Block 1 Revenue Block 2 Revenue Volumetric Revenue Discount	\$2,369,496 \$822,079 \$3,191,575 (\$797,894)	\$2,440,009 \$801,723 \$3,241,731 (\$810,433)	
Table 3 Block 1 Revenue Block 2 Revenue Volumetric Revenue Discount	\$2,392,448 \$828,864 \$3,221,312 (\$805,328)	\$2,522,352 \$826,066 \$3,348,418 (\$837,104)	
Table 1 Table 2 Table 3 Table 4	(\$944,818) (\$884,717) (\$892,151) (\$892,151)	(\$960,453) (\$897,256) (\$923,927) (\$923,927)	
Block 1 Transmission Distribution Generation System Usage Schedule 125 Schedule 143 Schedule 145 Schedule 102 Schedule 105 Schedule 109 Schedule 110 Schedule 110 Schedule 144 Schedule 122 Schedule 122 Schedule 122 Schedule 122 Schedule 123 Schedule 126 Schedule 137 Block 1 Total	2.09 40.86 65.10 2.25 0.00 (0.19) 0.27 (10.16) 4.93 0.05 0.30 0.00 0.00 0.00 0.14 0.47 101.11	2.43 44.44 63.29 2.18 0.00 (0.17) 0.26 (9.22) 0.13 3.97 0.05 0.30 0.00 0.00 0.00 0.00 0.44 0.47	(less Sch 109)
Block 2 Transmission Distribution Generation System Usage Schedule 125 Schedule 143 Schedule 145 Schedule 105 Schedule 105 Schedule 109 Schedule 110 Schedule 112 Schedule 122 Schedule 122 Schedule 122 Schedule 122 Schedule 122 Schedule 125 Schedule 125 Schedule 127 Schedule 127 Schedule 128 Schedule 128 Schedule 127 Schedule 135 Schedule 137 Block 2 Total	2.09 40.86 72.32 2.25 0.00 (0.19) 0.27 (0.16) 4.93 0.05 0.30 0.00 0.00 0.00 0.00 0.14 0.47 118.49	2.43 44.44 70.51 2.18 0.00 (0.17) 0.26 (4.95) 0.13 3.97 0.05 0.30 0.00 0.00 0.00 0.00 0.00 0.44 0.47 118.09	(less Sch 109)

DA Billing Demand for Transmission & Ancillary Revenues

Schedule	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Schedule 485-S	87,911	87,914	87,880	89,007	93,693	99,699	101,789	106,671	104,614	99,663	93,756	91,599	1,144,196
Schedule 485-P	52,267	52,132	50,167	53,977	60,789	59,983	58,039	61,928	63,419	56,343	55,414	49,593	674,051
Schedule 489-S	498	539	502	1,483	2,052	3,164	7,004	7,099	7,764	6,540	4,119	2,053	42,817
Schedule 489-P	115,907	116,357	114,583	127,121	132,278	137,410	137,392	136,639	139,104	135,217	130,732	124,182	1,546,922
Schedule 489-T	33,230	30,851	27,817	29,424	30,646	29,163	28,400	31,827	29,698	32,490	35,921	31,937	371,404
Totals	289,813	287,793	280,949	301,012	319,458	329,419	332,624	344,164	344,599	330,253	319,942	299,364	3,779,390
OATT (Attachment N)	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	\$0.49	
Revenues	\$142,008	\$141,019	\$137,665	\$147,496	\$156,534	\$161,415	\$162,986	\$168,640	\$168,854	\$161,824	\$156,772	\$146,688	\$1,851,901
Off-peak increments	4,699	4,266	4,493	4,854	4,915	5,366	6,934	5,371	5,502	5,608	4,530	4,415	60,953

DA Billing for Operating & Spinning Reserve Revenues

Billing Demand	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Secondary	88,409	88,453	88,382	90,490	95,745	102,863	108,793	113,770	112,378	106,203	97,875	93,652	1,187,013
Primary	168,174	168,489	164,750	181,098	193,067	197,393	195,431	198,567	202,523	191,560	186,146	173,775	2,220,973
Subtransmission	33,230	30,851	27,817	29,424	30,646	29,163	28,400	31,827	29,698	32,490	35,921	31,937	371,404
Totals	289,813	287,793	280,949	301,012	319,458	329,419	332,624	344,164	344,599	330,253	319,942	299,364	3,779,390
Coincidence Factor (based on 2016 data)	0,831	0,841	0.786	0,777	0.798	0,782	0,812	0.797	0.851	0,828	0.827	0,850	
Schedule 5 Prices	\$0,100425	\$0,100425	\$0,100425	\$0.100425	\$0.100425	\$0,100425	\$0,100425	\$0,100425	\$0.100425	\$0.100425	\$0,100425	\$0,100425	
Schedule 6 Prices	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	\$0.100425	
Schedule 5 Revenues	\$24,178	\$24,309	\$22,187	\$23,479	\$25,601	\$25,885	\$27,128	\$27,531	\$29,458	\$27,458	\$26,571	\$25,563	\$309,349
Schedule 6 Revenues	\$24,178	\$24,309	\$22,187	\$23,479	\$25,601	\$25,885	\$27,128	\$27,531	\$29,458	\$27,458	\$26,571	\$25,563	\$309,349
Reserve Revenues	\$48,356	\$48,619	\$44,375	\$46,957	\$51,203	\$51,770	\$54,257	\$55,061	\$58,916	\$54,915	\$53,143	\$51,126	\$618,698
Total ESS OATT Revenues	\$190,365	\$189,637	\$182,040	\$194,453	\$207,737	\$213,185	\$217,243	\$223,702	\$227,769	\$216,739	\$209,915	\$197,814	\$2,470,599

MWh

Schedule	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Scriedule	Jan	ren	Wai	Aþi	way	Juli	Jul	Aug	oeh	OCL	NOV	Dec	TOTAL
Schedule 485-S	45,894	42,863	47,350	46,370	49,317	50,726	54,842	53,374	49,350	51,970	50,553	52,706	595,315
Schedule 485-P	31,798	23,806	27,619	26,364	27,934	27,946	30,497	33,021	29,737	29,039	24,655	18,765	331,181
Schedule 489-S	217	206	229	333	473	701	1,725	3,099	3,256	1,789	976	419	13,424
Schedule 489-P	85,299	73,639	79,176	78,668	82,094	82,065	84,557	88,570	82,485	81,921	76,717	66,033	961,223
Schedule 489-T	14,495	14,818	15,746	15,199	15,923	15,785	16,321	16,459	16,113	14,862	15,999	15,768	187,488
Totals	177,702	155.333	170.120	166.935	175.741	177,223	187.942	194,522	180.940	179.582	168,900	153.691	2.088.633

Average Energy	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Totals
Schedule 7	1,226,5	1,073.5	957,7	849.9	774,9	758.0	835.0	853,7	770,2	769.4	970,5	1,242,7	923,2
Schedule 15	2.4	2.3	2.0	1.7	1.5	1.4	1.4	1.6	1.9	2.1	2.4	2.5	1.9
Schedule 32	204.8	209.7	199.8	190.2	184.6	193.1	207.5	204.6	190.6	189.8	196.9	217.3	199.1
Schedule 38	3.4	3.8	4.4	3.7	3.4	3.3	3.8	3.8	3.6	4.1	4.8	4.1	3.8
Schedule 47	0.6	0.6	0.7	1.1	1.7	4.4	8.5	8.2	4.0	1.0	0.4	0.3	2.6
Schedule 49	0.9	1_0	1.5	2.7	5.2	13.7	26.3	25.2	12.4	3.1	1.1	0.7	7.9
Schedule 83	332.7	347.5	340.1	328.2	329.4	353.3	376.6	373.1	355.3	355.3	357.3	376.3	352.2
Schedule 85	430.1	428.8	432.0	427.5	431.1	457.8	473.7	473.4	445.2	450,7	438.5	415,3	442.1
Schedule 89	197.9	194.0	187.8	190.0	193.0	198.4	197.7	211.4	207.1	195.1	187.9	160.5	193.4
Schedule 90	210.6	225.2	217.1	217.9	219.4	221.4	226.6	234.2	230.7	224.8	234.5	222.8	223.7
Schedule 91	4.1	3.9	3.4	2.9	2.5	2.3	2.4	2.7	3.2	3.6	4.0	4.3	3.3
Schedule 92	0,3	0.3	0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3
Schedule 95	3.6	3.5	3.0	2.6	2.2	2.0	2.1	2.4	2.8	3.2	3.6	3.7	2_89
TOTALS	2,618.0	2,494.1	2,349.6	2,218.6	2,149.2	2,209.3	2,361.9	2,394.7	2,227.3	2,202.6	2,402.4	2,650.9	2,356.4
Hours	744	672	743	720	744	720	744	744	720	744	721	744	8,760

Callendar Energy (MWh)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Totals
Schedule 7	854,006	675,141	665,973	572,688	539,570	510,789	581,402	594,409	518,962	535,750	654,901	865,323	7,568,915
Schedule 15	1,691	1,445	1,371	1,147	1,025	912	983	1,123	1,259	1,486	1,596	1,737	15,774
Schedule 32	142,600	131,869	138,904	128,132	128,527	130,111	144,475	142,491	128,458	132,163	132,864	151,316	1,631,912
Schedule 38	2,361	2,412	3,039	2,468	2,386	2,206	2,658	2,613	2,416	2,832	3,240	2,864	31,497
Schedule 47	385	394	462	736	1,181	2,967	5,918	5,732	2,701	678	274	242	21,670
Schedule 49	605	634	1,023	1,835	3,610	9,252	18,312	17,521	8,378	2,128	759	453	64,510
Schedule 83-S	231,651	218,528	236,503	221,179	229,361	238,050	262,243	259,781	239,420	247,414	241,130	262,050	2,887,308
Schedu l e 85-S 201-4,000 kW	208,734	200,083	219,824	212,845	223,880	230,874	248,177	242,298	221,474	236,519	228,945	237,644	2,711,297
Schedule 89-S GT 4 MW	217	206	229	333	473	701	1,725	3,099	3,256	1,789	976	419	13,424
Schedu l e 85-P 201-4,000 kW	92,415	70,862	82,025	76,547	77,690	78,985	83,134	88,938	79,954	78,702	68,173	52,428	929,851
Schedule 89-P GT 4 MW	120,455	104,152	111,812	109,825	115,479	114,815	117,370	125,305	117,834	116,549	107,215	93,011	1,353,822
Schedule 90-P	149,287	144,211	153,668	149,448	155,522	151,861	160,595	166,032	158,251	159,364	161,091	157,897	1,867,228
Schedule 89-T	19,887	20,097	21,202	20,473	21,132	20,848	21,291	21,662	21,210	20,227	21,176	20,642	249,847
Schedule 91	2,882	2,463	2,337	1,955	1,748	1,554	1,675	1,914	2,146	2,533	2,721	2,960	26,888
Schedule 92	214	206	210	209	210	208	207	206	210	204	205	208	2,496
Schedule 95	2,540	2,170	2,059	1,723	1,540	1,370	1,476	1,687	1,891	2,232	2,398	2,609	23,695
TOTALS	1.829.931	1,574,872	1.640.641	1,501,542	1,503,334	1,495,502	1,651,640	1,674,813	1,507,821	1,540,572	1.627.663	1,851,803	19.400.134

Note: Energy includes DA

Busbar Energy (MWh)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Totals	aMW
Schedule 7	912,506	721,388	711,592	611,917	576,531	545,778	621,228	635,126	554,511	572,449	699,762	924,598	8,087,386	923,2
Schedule 15	1,807	1,544	1,465	1,225	1,096	974	1,050	1,200	1,345	1,588	1,706	1,856	16,855	1.9
Schedule 32	152,369	140,902	148,419	136,909	137,331	139,024	154,371	152,252	137,257	141,216	141,965	161,682	1,743,698	199.1
Schedule 38	2,523	2,577	3,248	2,637	2,550	2,357	2,840	2,793	2,582	3,026	3,462	3,060	33,655	3.8
Schedule 47	412	421	494	786	1,262	3,170	6,323	6,125	2,886	725	292	259	23,155	2.6
Schedule 49	646	677	1,093	1,961	3,857	9,886	19,566	18,722	8,952	2,274	811	484	68,929	7.9
Schedule 83-S	247,519	233,498	252,703	236,330	245,072	254,356	280,206	277,576	255,821	264,362	257,647	280,001	3,085,089	352.2
Schedule 85-S 201- 4,000 kW	223,032	213,788	234,882	227,424	239,216	246,689	265,177	258,896	236,645	252,721	244,627	253,923	2,897,021	330.7
Schedule 89-S GT 4 MW	232	221	245	356	505	750	1,843	3,311	3,479	1,912	1,043	447	14,344	1.6
Schedule 85-P 201-4,000 kW	96,999	74,377	86,093	80,344	81,543	82,902	87,257	93,349	83,920	82,605	71,554	55,029	975,972	111.4
Schedule 89-P GT 4 MW	126,430	109,318	117,358	115,272	121,206	120,510	123,192	131,520	123,678	122,330	112,533	97,624	1,420,971	162.2
Schedule 90-P	156,692	151,363	161,290	156,860	163,236	159,393	168,560	174,268	166,101	167,269	169,082	165,729	1,959,842	223,7
Schedule 89-T	20,595	20,813	21,957	21,202	21,884	21,590	22,049	22,433	21,965	20,947	21,930	21,377	258,742	29,5
Schedule 91	3,080	2,632	2,497	2,089	1,867	1,661	1,790	2,046	2,293	2,706	2,907	3,163	28,730	3.3
Schedule 92	229	220	224	223	224	222	221	221	224	218	219	222	2,667	0.3
Schedule 95	2,714	2,319	2,200	1,841	1,646	1,463	1,577	1,803	2,020	2,385	2,562	2,788	25,318	2.89
TOTALS	1,947,783	1,676,056	1,745,759	1,597,377	1,599,027	1,590,725	1,757,252	1,781,638	1,603,679	1,638,733	1,732,102	1,972,240	20,642,371	2,356.4
Busbar Energy (MWh)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Totals	aMW
Schedule 85 Schedule 89	237,618 42,485	217,379 37,493	241,393 39,906	230,550 38,164	238,745 40,435	246,058 39,618	261,825 39,588	260,556 43,944	236,622 42,381	249,317 41,901	236,288 37,372	232,939 33,363	2,889,290 476,650	
	162,840 60,617	157,220 47,056	172,474 54,406	166,474 50,183	174,563 49,756	180,148 51,038	193,335 52,636	188,924 55,917	172,124 50,217	184,549 49,663	178,391 43,518	184,938 33,663	18,441,262	

		B C D	E	F	G	Н	ı	J	K	L	М	N	0	Р	Q	R
1	_	RTLAND GENERAL ELECTRIC	_													
3		9 Cycle Billing Determinants	+					 								
4						Demand	Demand									Impli
5			Basic	Basic	Vol. Trans	Transmission	Transmission	Volumetric	Volumetric	Volumetric				Distribution		& Exp
7			Charge BD	Charge BD	& Related	& Related	& Related	Dist	Dist.	Dist.	Facilities	Facilities	Facilities	Demand	Demand	Sys. Us
8	Grot	puping	1-phase Cust.	3-phase Cust.	MWh	Block 1 kW	Block 2 kW	Block 1 MWh	Block 2 MWh	Block 3 MWh	Block 1 kW	Block 2 kW	Block 3 kW	Block 1 kW	Block 2 kW	MWI
9	Sch	nedule 7	9,395,591	180	7,568,918	0	0	4,150,373	2,140,123	1,278,422	0	0	0	0	0	7,568,
10	Sch	nedule 15 Residentia	65,892	0	3,264	0	0	3,264	0		0	0	0	0	0	3,
11	\vdash															
	Sch	nedule 15 Commercial	47,940	0	12,510	0	0	12,510	0		0	0	0	0	0	12,
		nedule 32	672,008	453,173	1,633,156	0			205,738		0					
		nedule 38	660	3,935	31,475	0	0		14,383		0	0	0			
		nedule 47 nedule 49	1,344	17,022 7,608	21,633 64,540	0			14,098 45,489		0		0			
		neduje 49 neduje 83-S	8,194	130,152	04,540	8,606,661	3,366	19,051	45,489		4,150,380		0		3,366	2,884,
19	Sch	nedule 85-S	0	13,993	0	5,711,975	6,572	0	0		2,798,600		0	.,,		
		nedule 89-S	0	0	0	0					0					
		nedule 91 nedule 92	2,292 192	0	26,888 2,496	0			0		0					
		nedule 92 nedule 95	144	0	23,695	0			0		0					
24												<u> </u>				
25		11.05.0		0.515		4 400 712	4.555				440.000	4 500 700		4 400 710	4.555	F2.
	_	nedule 85-P nedule 89-P	0	2,248 132	0	,	4,859 5,091	0			449,600 120,000	1,503,786 360,000	480,157	1,490,713 820,489	4,859 5,091	591, 401,
28		nedule 90-P	0	48	0	2,701,624	85	0	0		24,000	72,000	2,730,257	2,701,624	85	
29	\Box															
30	e a k	and the SO T				070 504		_			60.000	180.000	145 000	270 504		
		nedule 89-T nedule 75-T	0	60	0	272,521 0	0		0		60,000	180,000	115,908	272,521	0	
	_	nedule 76R	0	0		-					0			_		
34																
35	Sab	nedule 485-S V2003	0	24	0	22,540	172	0	0		4.800	21,708	0	22.540	172	44
		nedule 485-S V2003	0	96	0	59,970	269	0			19,200	58,871	0		269	11, 32,
38	Sch	nedule 485-S V2011	0	96	0	70,528	195	0	0		19,200	71,825	0	70,528	195	34,
		nedule 485-S V2012	0	1,188	0	417,254	3,457	0			237,600	299,709	0		3,457	192,
	_	nedule 485-S V2013 nedule 485-S V2014	0	384 36	0	205,520 22,476	521 306	0			76,800 7,200	187,580 20,821	0		521 306	107,
		nedule 485-S V2015	0	12	0		6	0			2,400	8,988	0	,	6	
43	Sch	nedule 485-S V2016	0	84	0	22,340	41	0	0		16,800	8,771	0	22,340	41	12,
		nedule 485-S V2017	0	456	0	192,582	1,314	0			91,200	157,390	0		1,314	
		nedule 485-S V2018 nedule 485-S V2019	0	312 108	0	81,203 39,250	52,953 0	0			62,400 21,600	108,648 28,443	0		52,953 0	63, 20,
47		nedule 489-S V2014	0	12	0		0				12,000	36,000	41,172	,	_	
48																=
49	Sob	nedule 485-P V2010		10	0	44,256		0	0		2,400	45,768		44,256		24
51		nedule 485-P V2010	0	12	0	44,256	0				2,400	45,768	0			
52	Sch	nedule 485-P V2012	0	60	0	76,469	45	0	0		12,000	64,514	0	76,469	45	35,
		nedule 485-P V2013	0	336	0	269,885	626	0			67,200	203,310	0		626	
		nedule 485-P V2014 nedule 485-P V2015	0	24 24	0	15,663 73,223	33	0	_		4,800 4,800	10,896 73,513	0	,	33	
		nedule 485-P V2015	0	0							4,800					
57	Sche	nedule 485-P V2017	0	96	0	112,749	100	0	0		19,200	93,649	0	112,749	100	65,
		nedule 485-P V2018	0	12	0		0				2,400	26,472	0			
		nedule 485-P V2019 nedule 489-P V2004	0	24 12	0	59,353 128,295	0				4,800 12,000	69,228 36,000	93,240	59,353 128,295		
		neduje 489-P V2010	0	12			0				12,000	36,000	106,284	142,095		
62	Sch	nedule 489-P V2011	0	24	0	263,601	0	0	0		24,000	72,000	190,320	263,601	0	179
		nedule 489-P V2012	0	36	0		46				36,000	108,000	54,825			
		nedule 489-P V2013 nedule 489-P V2014	0	12 12	0		31 222				12,000 12,000	36,000 36,000	49,932 63,900	89,545 102,973		
		nedule 489-P V2014	0	12	0		0				12,000	36,000	51,106	98,417		
		nedule 489-P V2017	0	24			596				24,000	72,000	156,890	228,766		

	Α	В	C D	AD	AE	AF	AG	AH	A	AJ	AK	AL	AM	AN	AO	AP	AQ	AR	AS	AT
1	^	2		Aυ	/IL	Al	7.0	All	Α	ΛV	AN	AL	CIVI	ON	AQ.	ΛF	Au	AIX	7.0	
2	РО	RTL	AND GENERAL ELECTRIC																	
3	201	9 Cy	ycle Billing Determinants																	
4	\sqcup								0 - h 400	0 db 400		0.1.100	0 - h 40°	0.1.405						
5	\vdash	-		Sch 122b	Sch 125	Sob 44F	Sob 422	Sch 143	Sch 128 Block 1	Sch 128 Block 2	Sch 129	Sch 102 Block 1	Sch 102 Block 2	Sch 102 Block 2	Sch 105	Sah 400	Sob 440	Sch 112	Sob 422	Sob 426
	Gro	upir	na	MWh	MWh	Sch 145 MWh	Sch 132 MWh	MWh	MWh	MWh	MWh	MWh	MWh	MWh	MWh	Sch 109 MWh	Sch 110 MWh	MWh	Sch 123 MWh	Sch 126 MWh
8				1010011	1017411	1017711	1414411	1010011	1010011	2010011	1414411	1010011	1010011	1017711	1414411	1917711	1010011	1010011	1414411	1010011
	Scl	nedu	ile 7	7,568,918	7,568,918	7,568,918	7,568,918	7,568,918				4,150,373	2,140,123	1,278,422	7,568,918	7,568,918	7,568,918	7,568,918	7,568,918	7,568,918
10	Scl	nedu	le 15 Residentia	3,264	3,264	3,264	3,264	3,264				3,264	3,264		3,264	3,264	3,264	3,264	3,264	3,264
11	\Box																			
12	Sel	ned:	ıle 15 Commercial	12,510	12,510	12,510	12,510	12,510				0	0		12,510	12,510	12,510	12,510	12,510	12,510
			ile 32	1,633,156	1,633,156	1,633,156	1,633,156	1,633,156				249,080	249,080		1,633,156	1,631,432	1,631,432	1,633,156	1,631,432	1,633,156
	_		ile 38	31,475	31,475	31,475	31,475	31,475				652	652		31,475	31,387	31,387	31,475	31,387	31,475
			ile 47	21,633	21,633	21,633	21,633	21,633				19,580	19,580		21,633	21,633	21,633	21,633	21,633	21,633
			ile 49	64,540	64,540	64,540	64,540	64,540				54,354	54,354		64,540	64,303	64,303	64,540	64,303	64,540
_			ile 83-S ile 85-S	2,884,961	2,884,961 2,122,422	2,884,961	2,884,961 2,122,422	2,884,961				225,933	225,933		2,884,961	2,834,638 1,877,771	2,834,638 1,877,771		2,834,638	2,884,961 2 2,122,422 2
19	-		ile 89-S	2,122,422	2,122,422	2,122,422	2,122,422	2,122,422				33,179 0	33,179		2,122,422	1,877,771	1,877,771	2,122,422	1,877,771	2,122,422
			ile 91	26,888	26,888	26,888	26,888	26,888				0			26,888	26,888	26,888	26,888	26,888	26,888
			ile 92	2,496	2,496	2,496	2,496	2,496				0	0		2,496	2,496	2,496	2,496	2,496	2,496
23	Scl	nedu	ile 95	23,695	23,695	23,695	23,695	23,695				0	0		23,695	23,695	23,695	23,695	23,695	23,695
24	\sqcup	_																		
25 26	Sel	nadri	ile 85-P	591,424	591,424	591,424	591,424	591,424				4,386	4,386		591,424	301,591	301,591	591,424	301,591	591,424
			ile 89-P	401,176	401,176	401,176	401,176	401,176				4,366	4,366		401,176	0		401,176	0	401,176
28			ile 90-P	1,861,066	1,861,066	1,861,066	1,861,066	1,861,066							1,861,066	0			0	1,861,066
29																				
30		Ţ			00.77	00	00								00					00.772
			ile 89-T	62,759	62,759	62,759	62,759	62,759				0	_		62,759	0		62,759	0	62,759
33			ıle 75-T ıle 76R	0	0	0	0	0				0	0		0	0		0	0	0
34	-																			
35																				
			le 485-S V2003			11,734	11,734	11,734			11,734	0			11,734	0		11,734	0	0
			ile 485-S V2010			32,240	32,240	32,240			32,240	0			32,240	13,838	13,838	32,240	13,838	0
38			ile 485-S V2011 ile 485-S V2012			34,163 192,487	34,163 192,487	34,163 192,487			34,163 192,487	0	0		34,163 192,487	34,163 192,487	34,163 192,487	34,163 192,487	34,163 192,487	0
40			ile 485-S V2013			107,529	107,529	107,529			107,529	0			107,529	95,846	95,846	107,529	95,846	0
41		_	ile 485-S V2014			10,866	10,866	10,866			10,866	0	0		10,866	10,866	10,866	10,866	10,866	0
42			ile 485-S V2015			4,779	4,779	4,779			4,779	0	0		4,779	4,779	4,779	4,779	4,779	0
43			ile 485-S V2016			12,453	12,453	12,453			12,453	0	_		12,453	12,453	12,453	12,453	12,453	0
44			ile 485-S V2017 ile 485-S V2018			104,545 63,692	104,545 63,692	104,545 63,692			104,545 63,692	0	0		104,545 63,692	104,545 63,692	104,545 63,692	104,545 63,692	104,545 63,692	0
46	_		ile 485-S V2019			20,614	20,614	20,614			20,614	0			20,614	20,614	20,614	20,614	20,614	0
47			ile 489-S V2014			13,482	13,482	13,482			13,482	0			13,482	0	0	13,482	0	0
48																				
49			In 485 D V/2040			04.445	04.445	04.445			04 445		_		24.445		_	04.445		
			ile 485-P V2010 ile 485-P V2011			24,415 0	24,415	24,415			24,415	0	0		24,415	0	0	24,415	0	0
52			ile 485-P V2012			35,086	35,086	35,086			35,086	0	0		35,086	8,408	8,408	35,086	8,408	0
53			ile 485-P V2013			128,740	128,740	128,740			128,740	0	0		128,740	80,810	80,810	128,740	80,810	0
			ile 485-P V2014			8,879	8,879	8,879			8,879	0	_		8,879	8,879	8,879	8,879	8,879	0
			lle 485-P V2015			35,096	35,096	35,096			35,096	0	0		35,096	0			0	0
			ile 485-P V2016 ile 485-P V2017			65 250	65 250	65.250			65.250	0			65.250	16 235			16 235	0
			lle 485-P V2017 ile 485-P V2018			65,259 12,047	65,259 12,047	65,259 12,047			65,259 12,047	0	_		65,259 12,047	16,235 0	16,235 0	65,259 12,047	16,235 0	0
			ile 485-P V2019			21,816	21,816	21,816			21,816	0			21,816	1		21,816	1	1
60	Scl	nedu	le 489-P V2004			75,020	75,020	75,020			75,020	0			75,020	0		75,020	0	0
			le 489-P V2010			73,367	73,367	73,367			73,367	0			73,367	0			0	0
_			ile 489-P V2011			179,170	179,170	179,170			179,170	0			179,170	0			0	0
			ile 489-P V2012 ile 489-P V2013			87,123 56,400	87,123 56,400	87,123 56,400			87,123 56,400	0			87,123 56,400	0			0	0
			ile 489-P V2013			68,114	68,114	68,114			68,114	0			68,114	0			0	0
			ile 489-P V2016			66,250	66,250	66,250			66,250	0			66,250	0		,	0	0
			le 489-P V2017			143,156	143,156	143,156			143,156	0			143,156	0			0	

Schedule 109 & 110 MWh Exceptions

Exception Energy	MWH	Eligible	MWH
Schedule 15	0		
Schedule 32	1,724		
Schedule 38	87		
Schedule 47	0		
Schedule 49	238	Schedule 485-S 2010	13,838
Schedule 83 Secondary	50,324	Schedule 485-P V2012	8,408
Schedule 85 Secondary	244,651	Schedule 485-P V2013	80,810
Schedule 85 Primary	289,833	Schedule 485-P V2017	16,235
Schedule 485 S 2013	11,683		
Totals	598.540		

Note: This reflects the site definition of 1 aMW SDC.

85-P elig. 301,489

	A B C	D	E	F	G	Н		J	K	L	M	N	0	P	Q	R
1	\vdash															
3	 															
4																
	Schedule		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
6																
7 8	Schedule 7 Customer															
9		e Phase	778 522	779 190	779.943	780 761	781.500	782.320	783.158	784,204	785.089	786,105	786 989	787.810	9 395 591	
10		e Phase	15	15	15	15	15	15	15	15	15	15	15	15	180	
11		MWh)														
12	Enen	rgy 1st 500 kWh (MWh)	367,469 255,360	359,993 216,619	352,541 191,870	343,541 163,963	336,051 143,799	333,275	336,764 161 334	338,783 171,744	339,165 166 442	331,743 132.068	343,921 158,975	367,126 236,348	4,150,373 2,140,123	
14		rgy 501-1,000 kWh (MWh) rgy over 1,000 kWh (MWh)	269,836	191,318	191,870	91.846	143,799 50,986	43,510	161,334 44,827	72,222	71.535	132,068 37,788	63,980	236,348 185,672	2,140,123 1,278,422	
15	Calendar	Energy (MWh)	854,006	675,141	665,973	572,688	539,570	510,789	581,402	594,409	518,962	535,750	654,901	865,323	7,568,915	
16			0.113	0.089	0.088	0.076	0.071	0.067	0.077	0.079	0.069	0.071	0.087	0.114		
17			5 404	F 404	F 404		F 404	5 101	F 404	F 404	E 404	F 404	E 101	F 404	05.000	5 404
18 19			5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	5,491 272	65,892 3,264	5,491
20	Calendar	Energy (MWh)	350	299	284	237	212	189	203	232	260	307	330	359	3,264	
21															·	
22	Schedule 15	Commercia	2 005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	0.005	47.040	0.005
23	Customer Energy (N		3,995 1,051	3,995 1,049	3,995 1,048	3,995 1,046	3,995 1,045	3,995 1,043	3,995 1,042	3,995 1,040	3,995 1,039	3,995 1,037	3,995 1,036	3,995 1,034	47,940 12,510	3,995
24 25 26 27	Calendar	Energy (MWh)	1,341	1,049	1,048	909	813	723	779	1,040	1,039	1,037	1,036	1,034	12,510	
26			1,271	.,	.,,							-,	.,	.,	12,276	
27																
28 29		rs - Single Phase	24,957 2,646	24,975 2,648	24,995 2.650	25,017 2,652	25,037 2,655	25,060 2.657	25,082 2,659	25,111	25,135 2.665	25,162	25,186 2.670	25,208 2.673	300,925 31,905	
30		rs - Three Phase MWh)	2,646	2,648	2,650	2,652	2,655	2,657	2,659	2,662	2,665	2,668	2,670	2,673	31,905	
31		5 MWh	24,265	22,391	20,690	18,559	16,968	16,283	16,531	16,809	16,930	16,262	17,490	20,855	224,032	
32	Over	r 5 MWh	3,065	2,574	2,268	1,807	1,618	1,682	1,910	2,058	2,156	1,633	1,718	2,558	25,047	
33	Calendar	Energy (MWh)	24,793	22,516	22,800	20,263	19,440	18,369	19,747	18,918	17,294	18,859	20,388	24,634	248,021	
34 35	Schedule 32															
36	Customer	rs - Single Phase	30,774	30,798	30,823	30,850	30,874	30,902	30,930	30,965	30,995	31,029	31,058	31,085	371,083	
37	Customer	rs - Three Phase	34,937	34,962	34,991	35,022	35,050	35,081	35,113	35,152	35,186	35,225	35,259	35,290	421,268	
38 39	Energy (M	MWh)	110.908	105.655	400 771	00.075	02.465	05.000	00.400	103.595	102.718	04.400	04.550	404.455	4 000 000	
40	First	5 MWh	110,908	105,685 15,419	102,771 13,998	96,941 11,321	93,198 10,938	95,003 14,112	99,198 17.102	103,595	102,718	94,402 12,886	94,552 11,160	104,416 15,704	1,203,386 180,690	
41		Energy (MWh)	117,808	109,353	116,104		109,087	111,742	124,728	123,573	111,164	113,305	112,475	126,682	1,383,891	
42																
43																
44 45		rs - Single Phase rs - Three Phase	13	13	13	1 13	13	1 13	13	1 13	13	13	13	1 13	12 156	
46	Energy (N		13	13	13	10	10	10	13	10	10	13	13	13	100	
47	On-P	Peak	25	22	21	18	17	16	19	39	93	34	28	23	354	
48	Off-P		19	18		14	12	14	18	32	83	31	21	18	298	
49 50	Calendar	Demand (kVar) Energy (MWh)	55 40	69 36	64 38	52 32	57 30	68	78 40	110 71	169	137	61 52	57 42	977 640	
51	Caanda	Chargy (mivery	40	50	- 50	UZ.	30		40		100	- 00	02		040	
52																
53	Customer	rs - Single Phase	54	54	54	54	54	54	54	54	54	54	54	54	648	
54 55	Energy (N	rs - Three Phase	313	314	314	314	314	315	315	315	316	316	316	317	3,779	
56	On-P		1,321	1,401	1,516	1,379	1,260	1,154	1,368	1,430	1,332	1,435	1,696	1,445	16,738	
57	Off-P	^o eak	1,238	1,233	1,506	1,069	993	973	1,077	1,105	1,159	1,188	1,308	1,237	14,086	
58 59	Reactive	Demand (kVar) Energy (MWh)	3,537 2,322	3,586 2,376	4,119 3,002	4,537 2,436	3,918 2.356	5,114 2,175	5,351 2,618	4,528 2,542	4,609 2,257	4,729 2,764	5,042 3,189	4,154 2,821	53,224 30,857	
60	Capandar	Energy (MVVII)	2,322	2,376	3,002	2,436	2,300	2,175	2,618	2,042	2,251	2,764	3,169	2,021	30,057	
61	Schedule 47	RPA														
62		rs - Single Phase	77				185	185	185	185	185	185				
63		rs - Three Phase	1,118	1,118	1,118	1,118	2,689	2,689	2,689	2,689	2,689	2,689	1,118	1,118	22,842	
65		50 kWh per kW	149	189	162	204	480	876	1.243	1,311	1,152	694	256	153	6,868	
66	Over	50 kWh per kW	147	163	154	187	403	1,070	2,736	3,893	2,788	805	214	151	12,713	
67	Reactive	Demand (kVar)	0	0	0	0	0	0	0	0	3	4	0	0	7	
68 69	Calendar	Energy (MWh)	347	348	398	651	1,036	2,691	5,472	5,285	2,474	581	220	204	19,706	
70	Schedule 47	,														
71	Customer	rs - Single Phase	16	16	16	16	39	39	39	39	39	39	16	16	330	
72	Customer	rs - Three Phase	61	61	61	61	148	148	148	148	148	148	61	61	1,254	
73 74	Energy (M	MWh) 50 kWh per kW	18	23	90	27	63	75	96	105	97	82	37	200	668	
74 75		50 kWh per kW r 50 kWh per kW	18	23	22 29		63 61	75 124	96 228	105 335	97 265	171	77	23 32		
76	Reactive	Demand (kVar)	1	4	0	0	7	5	4	4	4	5	- 4	0	38	
77	Calendar	Energy (MWh)	38	46	64	85	145	276	446	447	227	98	53	38	1,964	
78 79	Sahadula 40	BDA														
80		rs - Single Phase	2	2	2	2	4	4	4	4	4	4	2	2	36	
81	Customer	rs - Single Phase	478	478		478	1,150	1,150	1,150		1,150	1,150	478			
82	Energy (N	MWh)														
83		50 kWh per kW	153	208 187			1,020	2,230	3,019	3,065	2,684	1,883	535 607		15,542 38.813	
84 85		r 50 kWh per kW Demand (kVar)	193 75	187	235 98	379 683	1,383	3,385 775	8,478 242	12,084 225	8,975 172	2,698 198	607 125	209 76	38,813 4,521	
86	Calendar	Energy (MWh)	405	390		1,181	2,819	7,765	15,809	15,386	7,320	1,774	536	283	54,218	
87																
88			1	1	1	1	2	2	2	2	2	2	- 1	1	18	
89 90	Customer	rs - Single Phase rs - Three Phase	1 49	49			118	118	118	118	118	118	49			
91	Energy (N	MWh)									- 110	- 110				
92 93	First	50 kWh per kW	100	156	164	144	307	503	501	492	415	381	241	107	3,510	
93	Over	50 kWh per kW	71	90	212	249	368	573	1,320	1,611	1,270	533	235	144	6,676	
94 95	Calendar	Demand (kVar) Energy (MWh)	186 200	238 243	226 473	318 654	604 791	319 1,487	499 2,503	437 2,135	315 1,058	410 354	393 223	243 169		

_	A B C D	E	F	G	н			К		М	N	0	Р	Q	R
96 97	Schedule 83S RPA 31-200 kW	-	r	G	- "		3	K	-	W	н	Ü	r	ч	, R
98	Customers - Single Phase Customers - Three Phase	128 650	129 651	129 651	129 651	129 652	129 653	129 653	129 654	129 654	130 656	130 656	130 657	1,550 7,838	
100	Energy (MWh) On-Peak	14,192	12,813	12,016	10,828	10,334	10,572	11,095	12,102	12,384	10,814	10,851	12,604	140,605	
102 103	Off-Peak Facility Capacity (kW)	8,878	8,205	7,576	6,747	6,380	6,381	6,528	6,932	7,137	6,294	6,478	7,793	85,328	
104	First 30 kW Over 30 kW	23,340 47,285	23,400 44,515	23,400 39,699	23,400 36,527	23,430 35,543	23,460 35,700	23,460 38,710	23,490 41,794	23,490 40,895	23,580 38,249	23,580 36,058	23,610 39,333	281,640 474,308	
106	Demand (kW) On-Peak	54,747	52,637	48,880	46,412	45,668	45,817	48,164	50,580	49,875	47,899	46,187	48,772	585,638	
108 109	Off-Peak Increment Reactive Demand (kVar)	21 840	21 788	20 824	18 919	18 959	18 965	19 1,270	20 1,453	20 1,596	18 1,455	18 1,113	19 969	230 13,151	
110 111 112	Calendar Energy (MWh) Schedule 85S RPA 201-4,000 kW	20,928	18,957	19,457	17,487	17,483	17,334	18,871	19,086	17,687	18,029	18,393	21,460	225,172	
113	Customers - Single Phase Customers - Three Phase	0 22	0 264												
115 116	Energy (MWh)	2,035	1,783	1,787	1,641	1,646	1,606	1,693	1,997	1,921	1,664	1,591	1,745	21,110	
117 118	Off-Peak Facility Capacity (kW)	1,256	1,132	1,075	958	975	897	921	1,085	1,004	876	859	1,030	12,069	
119 120	First 200 kW Over 200 kW	4,400 4,852	4,400 4,978	4,400 4,331	4,400 3,960	4,400 3,744	4,400 3,579	4,400 3,578	4,400 3,484	4,400 3,430	4,400 3,687	4,400 3,862	4,400 4,320	52,800 47,805	
121	Demand (kW) On-Peak	7,153	7,293	6,735	6,451	6,275	6,445	7,072	6,993	6,958	7,029	6,724	7,066	82,194	
123	Off-Peak Increment Reactive Demand (kVar)	675	769	745	875	932	936	895	717	713	835	930	952	9,974	
125 126 127	Calendar Energy (MWh) Schedule 89S RPA GT 4,000 kW	2,986	2,630	2,842	2,587	2,742	2,559	2,799	3,090	2,650	2,677	2,600	2,920	33,082	
128	Customers - Single Phase Customers - Three Phase	0	0	0	0	0	0	0	0	0	0	0	0	0	
130	Energy (MWh)	0	0	0	0	0	0	0	0	0	0	0	0	0	
132	Off-Peak Facility Capacity (kW)	0	0	0	0	0		0	0	0	0	0	0	0	
134 135	First 1,000 kW 1,001-4,000 kW	0	0	0	0	0		0	0	0	0	0	0	0	
136 137	Over 4,000 kW Demand (kW)	0	0	0	0	0	0	0	0	0	0	0	0	0	
138	On-Peak Off-Peak Increment	0	0	0	0	0	0	0		0	0	0	0	0	
140 141 142	Reactive Demand (kVar) Calendar Energy (MWh)	0	0	0	0	0		0	0	0	0	0	0	0	
143 144	Schedule 83S 31-200 kW Customers - Single Phase	550	551	551	552	553	554	554	555	555	556	556	557	6,644	
145	Customers - Single Phase Customers - Three Phase Energy (MWh)	10,144	10,152	10,160	10,168	10,177	10,185	10,195	10,207	10,216	10,227	10,237	10,246	122,314	
147	On-Peak Off-Peak	151,124 80,893	144,298 76,695	143,948 74,321	135,254 69,163	135,268 66,983	144,657 70,865	152,031 74,888	161,556 78,116	164,381 79,942	146,513 70,697	139,685 69,651	149,739 78,361	1,768,454 890,574	
149 150	Facility Capacity (kW) First 30 kW	320,820	321,090	321,330	321,600	321,900	322,170	322,470	322,860	323,130	323,490	323,790	324,090	3,868,740	
151 152	Over 30 kW Demand (kW)	509,058	504,486	498,601	489,093	531,042	561,438	586,874	615,093	614,462	581,149	513,896	501,163	6,506,355	
153 154	On-Peak Off-Peak Increment	641,482 251	638,201 249	633,913 248	626,691 245	659,333 258	683,046 267	703,006 275	725,115 284	724,962 283	699,496 273	647,703 253	638,075 250	8,021,023 3,136	
155 156 157	Reactive Demand (kVar) Calendar Energy (MWh)	33,755 210,722	34,452 199,571	36,210 217,045	37,943 203,692	43,051 211,878	46,565 220,716	50,004 243,372	52,372 240,695	51,436 221,733	48,971 229,385	41,124 222,736	49,529 240,590	525,412 2,662,136	
158 159	Schedule 85S 201-4,000 kW Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0	
160	Customers - Three Phase Energy (MWh)	1,138	1,140	1,141	1,141	1,142	1,144	1,145	1,145	1,146	1,148	1,149	1,150	13,729	
162 163	On-Peak Off-Peak	113,867 62,753	110,746 61,066	112,077 59,158	108,165 57,000	108,396 56,354	114,657 59,534	117,595 60,876	122,978 62,914	123,559 64,061	114,912 58,336	109,690 56,690	113,097 60,761	1,369,739 719,504	
164 165	Facility Capacity (kW) First 200 kW	227,600	228,000	228,200	228,200	228,400	228,800	229,000	229,000	229,200	229,600	229,800	230,000	2,745,800	
166 167	Over 200 kW Demand (kW)	292,383	292,354	291,338	300,529	322,370	338,417	342,901	353,946	354,472	341,493	306,217	293,982	3,830,402	
168 169	On-Peak Increment	445,678 358	445,860 435	444,772 779	452,459 855	471,826 178	485,912 109	489,065 726	498,951 170	499,102 618	488,753 513	458,737 1,032	448,666 799	5,629,781 6,572	
170 171 172	Reactive Demand (kVar) Calendar Energy (MWh)	61,681 159,855	63,886 154,590	67,110 169,632	71,120 163,888	79,182 171,821	83,712 177,589	85,898 190,536	89,855 185,835	87,432 169,473	84,242 181,872	75,981 175,791	67,676 182,018	917,775 2,082,899	
173	Schedule 89S GT 4,000 kW Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0	
175 176	Customers - Three Phase Energy (MWh)	0	0	0		0		0	0	0	0	0	ō	0	
177 178	On-Peak Off-Peak	0	0	0		0		0	0	0	0	0	0		
179 180	Facility Capacity (kW) First 1,000 kW	0	0	0		0		0	0	0	0	0		0	
181 182 183	1,001-4,000 kW Over 4,000 kW Demand (kW)	0	0	0	0	0	0	0	0	0	0	0	0	0	
184 185	On-Peak Off-Peak Increment	0	0	0	0	0	0	0	0	0	0	0	0	0	
186 187	Reactive Demand (kVar) Calendar Energy (MWh)	0	0	0	0	0		0	0	0	0	0	0	0	
188 189	Schedule 85P RPA 201-4,000 kW														
190 191	Customers - Three Phase Energy (MWh)	2	2	2	2	2	2	2	2	2	2	2	2	24	
192 193	On-Peak Off-Peak	291 175	284 183	228 139	228 140	245 145	267 169	271 154	201 117	200 123	154 93	185 109	170 113	2,724 1,661	
194 195 196	Facility Capacity (kW) First 200 kW Over 200 kW	400 665	4,800 7,980												
196 197 198	Demand (kW) On-Peak	933	838	788	787	987	908	891	778	726	652	566	558	9,412	
199	Off-Peak Increment Reactive Demand (kVar)	0	0	0 7	0 57	0	0	0	0 194	0	0 142	0 86	0 47	1,104	
201 202	Calendar Energy (MWh)	547	435	408	379	403	437	446	343	304	256	266	191	4,416	
203 204	Schedule 89P RPA GT 4,000 kW Customers - Three Phase	0	0	0	0	0	0	0	0	0	0	0	0	0	
205 206	Energy (MVVh) On-Peak	0	0	0	0	0	0	0	0	0	0	0	0	0	
207 208	Off-Peak Facility Capacity (kW)	0	0	0		0		0	0	0	0	0	0	0	
209 210 211	First 1,000 kW 1,001-4,000 kW	0	0 0	0	0 0 0	0	0	0	0	0	0	0	0	0	
211 212 213	Over 4,000 kW Demand (kW) On-Peak	0		0		0		0	0	0	0	0	0		
214	Off-Peak Increment Reactive Demand (kVar)	0	0	0	0	0	0	0	0	0	0	0	0	0	
216 217	Calendar Energy (MWh)	0	0	0	0	ō	0	0	0	0	0	0	0	0	
218 219	Schedule 85P 201=1,000 kW Customers - Three Phase	184	184	184	185	185	185	185	185	186	187	187	187	2,224	
220 221	Energy (MWh) On-Peak	31,870								33,064	29,941	29,704	30,333		
_															

_															
222	A B C D	E 19.023	F 18.660	G 18.093	H 17.703	17.142	J 18.253	K 17.727	L 18.271	M 19.035	N 16 061	0 16.947	P 17.709	Q 215.525	R
223	Facility Capacity (kW)		,		,	,	,		12,211	,	10,801				
224	First 200 kW	36,800	36,800	36,800	37,000	37,000	37,000	37,000	37,000	37,200	37,400	37,400	37,400	444,800	
225 226	Over 200 kW Demand (kW)	125,265	127,093	120,211	121,791	132,183	125,637	124,492	127,921	128,262	123,987	125,107	113,857	1,495,806	
227	On-peak	123,694	125,118	118,969	121,228	129,787	124,440	123,638	126,145	126,863	122,803	123,508	115,108	1,481,301	
228	Off-peak increment Reactive Demand (kVar)	279 19.674	267 18.542	1,058 18,998	260 20.012	164 22.615	100 23.081	104 22.012	177 23.552	14 23.636	898 22.417	1,284 20,691	254 19.250	4,859 254,480	
230	Calendar Energy (MWh)	60,069	46,621	53,998	49,804	49,353	50,602	52,191	55,574	49,913	49,406	43,251	33,472	594,254	
231															
232	Schedule 89P GT 4,000 kW Customers - Three Phase	11	11	11	11	11	11	11	11	11	11	11	11	132	
234	Energy (MWh)														
235	On-Peak	19,591	18,828	18,710	18,734	19,660	19,895	19,599	21,155	22,319	20,755	19,653	20,046	238,945	
236 237	Off-Peak Facility Capacity (kW)	12,928	13,336	12,560	12,454	13,669	13,453	12,992	14,607	14,997	13,995	13,403	13,836	162,231	
238	First 1,000 kW	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	120,000	
239	1,001-4,000 kW	30,000	30,000	30,000	30,000	30,000	30,000	30,000	30,000	30,000	30,000	30,000	30,000	360,000	
240	Over 4,000 kW Demand (kW)	35,264	37,718	35,729	37,089	41,875	39,369	36,941	39,470	40,849	42,795	46,126	46,932	480,157	
242	On-peak	59,822	63,386	59,428	64,311	68,144	69,495	70,236	73,527	72,469	73,239	73,346	73,086	820,489	
243	Off-peak increment Reactive Demand (kVar)	441 4,579	921 4,336	260 3,728	0 4,969	278 5,731	811 5,698	6,729	49 6,901	316 6,190	879 6,578	806 6,639	330 4,891	5,091 66,969	
245	Calendar Energy (MWh)	35,157	30,513	32,636	31,157	33,385	32,750	32,813	36,735	35,349	34,628	30,498	26,978	392,599	
246															
247	Schedule 90P Customers - Three Phase	4	4	4	4	4	4	4	4	4	4	4	203,39	48	
249	Energy (MWh)	-		- 1	-							-	,	- 10	
250 251	On-Peak Off-Peak	88,321	83,739	82,682	89,646	83,328	90,882	88,465	90,853	97,691	92,097	89,648	93,286	1,070,638	
251 252	Facility Capacity (kW)	63,415	65,548	61,528	64,022	66,120	64,640	63,396	69,741	68,342	66,154	69,717	67,806	790,429	
253	First 1,000 kW	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	24,000	
254 255	1,001-4,000 kW	6,000	6,000 212,499	6,000 212,499	6,000	6,000 213,471	6,000 220,319	6,000	6,000 238,530	6,000 242,838	6,000 243,826	6,000	6,000 243,826	72,000 2,730,257	
256	Over 4,000 kW Demand (kW)	212,499	212,489	212,489	213,018	215,9/1	220,319	233,106	230,030	292,038	243,026	243,826	243,626	2,730,257	
257	On-peak	213,009	208,768	195,580	215,243	214,723	231,524	244,777	242,373	250,990	246,529	224,274	213,834	2,701,624	
258	Off-peak increment Reactive Demand (kVar)	1.867	58 10.044	0		0 447	736	0 844	0 893	741	1.322	27 286	2.699	85 21.436	
260	Calendar Energy (MWh)	149,287	144,211	153,668	149,448	155,522	151,861	160,595	166,032	158,251	159,364	161,091	157,897	1,867,228	
261															
262 263	Schedule 89T Customers - Three Phase	5	5	5	5	5	5	5	5	5	5	5	5	60	
264	Energy (MWh)														
265	On-Peak	3,428	3,394	3,427	3,622	3,447	3,425	3,387	3,229	3,394	3,389	3,499	3,362	41,003	
266 267	Off-Peak Facility Capacity (kW)	1,846	1,998	1,853	1,835	1,827	1,784	1,676	1,741	1,808	1,708	1,865	1,815	21,755	
268	First 1,000 kW	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	60,000	
269 270	1,001-4,000 kW	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	180,000	
271	Over 4,000 kW Demend (kW)	9,659	9,659	9,659	9,659	9,659	9,659	9,659	9,659	9,659	9,659	9,659	9,659	115,908	
-															
272	On-Peak	26,409	28,780	22,458	22,804	22,992	24,221	22,393	18,355	21,137	22,507	21,167	19,298	272,521	
273	On-Peak Off-Peak Increment	0	0	0	0	0	0	0	0	0	0	0	0	0	
273 274 275	On-Peak	26,409 0 2,427 5,392	0	22,458 0 2,240 5,457	0 2,889			22,393 0 2,970 4,970	18,355 0 2,881 5,202	21,137 0 2,600 5,097	0 2,827	21,167 0 2,712 5,177	19,298 0 2,361 4,874	0	
273 274 275 276	On-Peak Off-Peak Increment Reactive Demand (kVar) Calendar Energy (MWh)	0 2,427	0 2,392	0 2,240	0 2,889	0 3,136	0 2,947	2,970	0 2,881	2,600	0 2,827	2,712	0 2,361	0 32,382	
273 274 275	Or-Peak Off-Peak Increment Reactive Demand (kVar)	0 2,427	0 2,392	0 2,240	0 2,889	0 3,136	0 2,947	2,970	0 2,881	2,600	0 2,827	2,712	0 2,361	0 32,382	
273 274 275 276 277 278 279	Ort-Peak Increment Reactive Demand (IVar) Calendar Energy (MWh) Partial Requirements Schedule 75 Customers	0 2,427	0 2,392	0 2,240	0 2,889 5,274	0 3,136	0 2,947	2,970	0 2,881	2,600	0 2,827	2,712	0 2,361	0 32,382 62,359	
273 274 275 276 277 278 279 280	On-Peak Off-Peak Increment Reactive Demand (MVar) Celendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh)	0 2,427 5,392	0 2,392 5,279	0 2,240 5,457	0 2,889 5,274	0 3,136 5,209	0 2,947 5,063	0 2,970 4,970	0 2,881 5,202	0 2,600 5,097	0 2,827 5,364	0 2,712 5,177	0 2,361 4,874	0 32,382 62,359	
273 274 275 276 277 278 279 280 281	Ort-Peak Increment Reactive Demand (IVar) Calendar Energy (MWh) Partial Requirements Schedule 75 Customers	0 2,427 5,392	0 2,392 5,279	0 2,240 5,457	0 2,889 5,274	0 3,136 5,209	0 2,947 5,063	0 2,970 4,970	0 2,881 5,202	0 2,600 5,097	0 2,827 5,364	0 2,712 5,177	0 2,361 4,874	0 32,382 62,359 0	
273 274 275 276 277 278 279 280 281 282 283	On-Peak Off-Peak Increment Resetive Demand (KVar) Celendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak	0 2,427 5,392	0 2,392 5,279 0	0 2,240 5,457 0	0 2,889 5,274 0 0	0 3.138 5,209	0 2,947 5,063 0	0 2,970 4,970 0	0 2,881 5,202 0 0	0 2,600 5,097 0	0 2,827 5,364 0 0	0 2,712 5,177 0 0	0 2,361 4,874 0 0	0 32,382 62,359 0 0	
273 274 275 276 277 278 279 280 281 282 283 284	Ort-Peak Off-Peak Increment Reactive Demand (kVar) Colendar Energy (MWh) Partila Requirements Schedule 75 Customers Energy (MWh) Ort-Peak Off-Peak Fadily Capacity (kW) First 1,000 kW	0 2,427 5,392 0 0	0 2,392 5,279 0 0	0 2,240 5,457 0 0	0 2,889 5,274 0 0	0 3,138 5,209 0 0	0 2,947 5,063 0 0	0 2,970 4,970 0 0	0 2,881 5,202 0 0	0 2,600 5,097 0 0	0 2,827 5,364 0 0	0 2,712 5,177 0 0	0 2,361 4,874 0 0	0 32,382 62,359	
273 274 275 276 277 278 279 280 281 282 283 284 285 286	On-Peak Off-Peak Increment Reactive Demand (AVer) Calendar Energy (MWh) Parfild Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Fediby Capacity (KW) I,001-4,000 KW Over 4,000 KW	0 2,427 5,392	0 2,392 5,279 0 0	0 2,240 5,457 0	0 2,889 5,274 0 0	0 3.138 5,209	0 2,947 5,063 0	0 2,970 4,970 0	0 2,881 5,202 0 0	0 2,600 5,097 0	0 2,827 5,364 0 0	0 2,712 5,177 0 0	0 2,361 4,874 0 0	0 32,382 62,359 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 287	On-Peak Off-Peak Increment Resetive Demand (NVar) Calendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak Off-Peak Union (MW) Ower 4,000 KW Ower 4,000 KW Ower 4,000 KW Ower 4,000 KW	0 2,427 5,392 0 0 0 0 0	0 2,392 5,279	0 2,240 5,457 0 0 0	0 2,889 5,274 0 0 0 0	0 3,138 5,209 0 0 0	0 2,947 5,063 0 0 0 0	0 2,970 4,970 0 0 0	0 2,881 5,202 0 0 0 0	0 2,600 5,097 0 0 0	0 2,827 5,364 0 0 0 0	0 2,712 5,177 0 0 0 0	0 2,361 4,874 0 0 0 0	0 32,382 62,359 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286	On-Peak Off-Peak Increment Reactive Demand (AVer) Calendar Energy (MWh) Parfild Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Fediby Capacity (KW) I,001-4,000 KW Over 4,000 KW	0 2,427 5,392 0 0 0 0	0 2,392 5,279 0 0 0 0 0	0 2,240 5,457 0 0 0	0 2,889 5,274 0 0 0 0 0	0 3,136 5,209 0 0	0 2,947 5,063 0 0	0 2,970 4,970 0 0	0 2,881 5,202 0 0 0 0	0 2,600 5,097 0 0	0 2,827 5,364 0 0 0 0	0 2,712 5,177 0 0 0	0 2,361 4,874 0 0 0 0 0	0 0 32,382 62,359 62,359 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290	On-Peak Off-Peak Increment Resotive Demand (MVar) Calendar Energy (MWh) Parfial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak 1,001-4,000 kW 1,001-4,000 kW 1,001-4,000 kW Demand (kW) On-Peak Off-Peak Off-Peak Off-Peak Off-Peak Resotive Demand (Var)	0 2.427 5.392 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0	0 2,240 5,457	0 2,889 5,274 0 0 0 0 0 0	0 3,136 5,209 0 0 0 0 0	0 2,947 5,063	0 2,970 4,970 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0	0 2,600 5,097	0 2,827 5,364 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0	0 2,361 4,874	0 32,382 62,359 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291	On-Peak Off-Peak Increment Resetive Demand (N/ar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak On-Peak Off-Peak On-Peak	0 2.427 5,392 0 0 0 0 0	0 2,392 5,279 0 0 0 0 0 0	0 2,240 5,457 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0	0 3,136 5,209 0 0 0 0	0 2,947 5,063 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0	0 2,600 5,097	0 2,827 5,364 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0	0 0 32,382 62,359 62,359 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290	On-Peak Off-Peak Increment Resotive Demand (MVar) Calendar Energy (MWh) Parfial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak 1,001-4,000 kW 1,001-4,000 kW 1,001-4,000 kW Demand (kW) On-Peak Off-Peak Off-Peak Off-Peak Off-Peak Resotive Demand (Var)	0 2.427 5.392 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0	0 2,240 5,457	0 2.889 5,274 0 0 0 0 0 0 0	0 3,136 5,209 0 0 0 0 0	0 2,947 5,063	0 2,970 4,970 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0	0 2,600 5,097	0 2,827 5,364 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0	0 2,361 4,874	0 32,382 62,359 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 286 289 290 291 292 293 293 293	On-Peak Off-Peak Increment Resetive Demand (Wair) Calendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak 1001-4 (000 kW 1,001-4 (000 k	0 2,427 5,392 0 0 0 0 0 0 0	0 2 392 5,279 0 0 0 0 0 0 0 0 0	0 2.240 5,457	0 2.889 5,274 0 0 0 0 0 0 0 0	0 3,136 5,209 0 0 0 0 0 0 0	0 2.947 5,063 0 0 0 0 0 0 0	0 2,970 4,870 0 0 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097	0 2,827 5,384 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 280 281 282 283 284 285 286 287 289 290 291 292 293 293 294 292 293 294 294 295 296 297	On-Peak Off-Peak Increment Resetive Demand (N/ar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak	0 2.427 5,392 0 0 0 0 0 0 0 0	0 2392 5,279 0 0 0 0 0 0 0 0 0 0	0 2240 5,457	0 2,889 5,274 0 0 0 0 0 0 0 0 0	0 3.138 5,209 0 0 0 0 0 0 0 0	0 2.947 5,063	0 2.970 4,970 0 0 0 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0 0 0 0 0	0 2,860 5,097	0 2,287 5,364	0 2712 5,177 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0	0 32,382 62,359 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 281 282 283 284 286 287 288 289 290 291 291 292 293 294 295 296 297 292 293 294 295 296 297 297 298 299 290 299 290 290 290 290 290 290 290	On-Peak Off-Peak Increment Resetive Demand (NVar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak On-Peak Off-Peak Celendar Energy (MWh) Scheduler 76 Customers Energy (MWh) On-Peak Off-Peak Off-Peak Off-Peak	0 2.427 5,392 0 0 0 0 0 0 0 0 0	0 2392 5,279 0 0 0 0 0 0 0 0 0	0 2240 5,457	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0	0 3.138 5,209 0 0 0 0 0 0 0 0 0 0	0 2.947 5,063 0 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,860 5,097	0 2,227 5,364 0 0 0 0 0 0 0 0 0 0 0	0 2712 5,177 0 0 0 0 0 0 0 0 0 0	0 2.381 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 32,382 62,359 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 295 296 297 298	On-Peak Off-Peak Increment Resective Demand (Wair) Calendar Energy (MWh) Partial Requirements Schedule 75 Castomers Energy (MWh) On-Peak Off-Peak 1,001-4,000 kW 1,001-4,000 kW 1,001-4,000 kW 1,001-4,000 kW On-Peak Off-Peak Off-Peak Off-Peak Off-Peak Off-Peak Off-Peak Fredity (Wh) Fredity (WWh) Fredity (WW)	0 2,427 5,392 0 0 0 0 0 0 0 0	0 2392 5,279 0 0 0 0 0 0 0 0 0 0 0	0 2240 5,457 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0 0 0 0 0 0	0 2,600 5,097 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0	0 2,172 5,177 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 281 282 283 284 286 287 288 289 290 291 291 292 293 294 295 296 297 292 293 294 295 296 297 297 298 299 290 299 290 290 290 290 290 290 290	On-Peak Off-Peak Increment Resetive Demand (NVar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak On-Peak Off-Peak	0 2.427 5,392 0 0 0 0 0 0 0 0 0	0 2392 5,279 0 0 0 0 0 0 0 0 0 0 0	0 2240 5,457	0 2,889 5,274 0 0 0 0 0 0 0 0 0	0 3.138 5,209 0 0 0 0 0 0 0 0 0 0	0 2.947 5,063 0 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0 0 0 0 0 0	0 2,860 5,097	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0	0 2712 5,177 0 0 0 0 0 0 0 0 0 0	0 2.381 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,359 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 290 291 292 293 294 295 296 297 298 299 300 301	On-Peak Off-Peak Increment Resetive Demand (KVar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak On-Peak Off-Peak	0 2.427 5.392 0 0 0 0 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0 0 0 0	0 2240 5,457 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5,202 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0	0 2.361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0	0 32,382 62,359 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 275 276 277 278 289 281 282 283 284 285 286 289 290 291 292 293 294 295 296 297 296 297 297 298 299 300 301 302 303 303 303 303 303 303 303 303 303	On-Peak Off-Peak Increment Resetive Demand (kVar) Calendar Enragy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.240 5.457 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5,202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,997 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 290 291 292 293 294 295 296 297 298 299 300 301	On-Peak Off-Peak Increment Resetive Demand (KVar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak On-Peak Off-Peak	0 2.427 5.392 0 0 0 0 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5,457 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5,202 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0	0 2.361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 280 281 282 283 284 285 286 289 290 291 292 293 294 295 292 293 300 301 302 303 303 303	On-Peak Off-Peak Increment Resetive Demand (NVar) Celendar Energy (MWh) Partial Requirements Scheduler 75 Customers Energy (MWh) On-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,240 5,457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,881 5,202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,359 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 276 277 280 281 282 283 284 285 286 289 290 291 292 293 294 295 296 297 298 290 301 302 303 304 304 305 306	Ort-Peak Off-Peak Increment Resetive Demand (kVar) Calendar Enropy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) Ort-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5,202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,997 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,172 5,177 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 280 281 282 283 284 285 286 287 288 290 291 291 292 293 293 294 295 295 297 295 295 297 300 301 302 303 304 305 305 305 305 305 305 305 305 305 305	On-Peak Off-Peak Increment Resetive Demand (kVar) Calendar Enregy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak Facility Capacity (kW) First 1,000 kW Over 4,000 kW	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5,457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 2745 276 2776 2776 280 281 281 282 283 284 285 286 289 290 291 292 293 294 292 293 300 301 302 303 304 306 307 308	On-Peak Off-Peak Increment Resetive Demand (War) Celendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5,457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 2,717 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,359 62,359 60 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 2744 275 276 276 277 278 280 281 282 283 284 285 286 287 292 291 292 293 300 301 302 303 303 303 303 303 303 303 303 303	On-Peak Off-Peak Increment Resetive Demand (kVar) Calendar Enregy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Off-Peak Facility Capacity (kW) First 1,000 kW Over 4,000 kW	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5,202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,997 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 2745 276 2776 2776 280 281 281 282 283 284 285 286 289 290 291 292 293 294 292 293 300 301 302 303 304 306 307 308	On-Peak Off-Peak Increment Resetive Demand (War) Celendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5,457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,970 4,970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 2,717 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,359 62,359 60 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 280 281 283 284 283 284 287 286 289 291 297 293 294 293 294 295 296 297 301 302 303 304 303 304 309 309 301 309 309 301 309 309 301 309 301 301 301 301 301 301 301 301 301 301	On-Peak Off-Peak Increment Resetive Demand (NVar) Calendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5.457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.970 4.970 4.970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,35	
273 274 275 276 277 278 277 278 279 280 281 282 283 285 286 287 289 290 291 301 302 292 303 304 305 306 307 308 309 311 312 313 313 314	On-Peak Off-Peak Increment Resetive Demand (kVar) Calendar Enregy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Toddy Capacity (kW) First 1,000 kW 1,001-4,000 kW Over 4,000 kW Over 4,000 kW Over 4,000 kW On-Peak Off-Peak Increment Resetive Demand (kW) On-Peak Off-Peak Increment Resetive Demand (kWr) Schedule 76 Customers Energy (MWh) On-Peak Off-Peak Increment Off-Peak Off	0 0 2.427 5.392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.392 5.279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,997 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 2 2827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 32,362 62,359 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 277 277 277 277 277 277 277 277	On-Peak Off-Peak Increment Resetive Demand (NVar) Calendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5.457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.970 4.970 4.970 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,361 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,35	
273 274 275 276 277 278 280 281 282 283 284 285 289 290 281 301 302 303 304 305 306 307 301 311 311 316 316 317 313 314 315 316 317 317 317 317 317 317 317 317 317 317	On-Peak Off-Peak Increment Resetive Demand (War) Celendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Off	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5.457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.970 4.970 4.970 4.970 4.970 4.970 6.00 6.00 6.00 6.00 6.00 6.00 6.00 6.	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 2827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,381 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,250 62,25	
273 274 275 276 277 278 279 280 281 282 283 284 285 286 297 283 284 285 286 297 286 293 303 303 304 305 307 308 309 310 311 312 314 315 317 318 316 317 318	Ort-Peak Off-Peak Increment Resetive Demand (kVar) Calendar Erresy (MWh) Partial Requirements Schedule 75 Customers Eenery (MWh) Ort-Peak Off-Peak	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0	0 2,800 5,997 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,381 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
273 274 275 276 277 278 280 281 282 283 284 285 289 290 281 301 302 303 304 305 306 307 301 311 311 316 316 317 313 314 315 316 317 317 317 317 317 317 317 317 317 317	On-Peak Off-Peak Increment Resetive Demand (War) Celendar Energy (MWh) Partial Requirements Schedule 75 Customers Energy (MWh) On-Peak Off-Peak Off	0 2,427 5,392 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 392 5279 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2240 5.457 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,889 5,274 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 3,138 5,209 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,947 5,063 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2.970 4.970 4.970 4.970 4.970 6.00 6.00 6.00 6.00 6.00 6.00 6.00 6.	0 2.881 5.202 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,800 5,097 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2 2827 5,364 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,712 5,177 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 2,381 4,874 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 32,382 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,359 62,250 62,25	

A B C D	E	F	G	н		J	К	L	М	N	0	Р	Q	R
322 Total PGE (Annual)														
323 Customers	896,577	897,328	898,166	899,076	902,435	903,352	904.285	905,451	906,439	907,576	906,027	906,944	10,833,656	
324 Energy (MWh)	1,734,813	1,576,977	1,490,333	1,365,993	1,287,530	1,315,764	1,368,233	1,456,064	1,460,121	1,297,798	1,342,997	1,615,761	17,312,384	
325 Facility Capacity (kW)	1,918,290	1,916,057	1,895,262	1,895,331	1,974,082	2,019,013	2,061,656	2,115,712	2,121,352	2,072,380	1,972,786	1,941,637	23,903,558	
326 Demand (kW)	1,574,277	1,572,832	1,533,888	1,557,764	1,620,631	1,673,113	1,710,366	1,743,517	1,754,333	1,711,488	1,605,632	1,566,115	19,623,956	
327 Reactive Demand (kVar)	129,352	139,210	134,370	145,930	162,529	171,055	176,924	184,122	179,783	174,272	155,187	152,904	1,905,638	
328 Calendar Energy (MWh)	1,652,229	1,419,539	1,470,521	1,334,607	1,327,593	1,318,279	1,463,698	1,480,291	1,326,881	1,360,990	1,458,763	1,698,112	17,311,501	
329														
330														
331														
332 Total (VP)										,				
333 Customers	0	0	0	0	0	0	0	0	0	0	0	0	0	
334 Energy (MWh)	0	0	0	0	0	0	0	0	0	0	0	0	0	
335 Facility Capacity (kW)	0	0	0	0	0	0	0	0	0	0	0	0	0	
336 Demand (kW)	0	0	0	0	0	0	0	0	0	0	0	0	0	
337 Reactive Demand (kVar)	0	0	0	0	0	0	0	0	0	0	0	0	0	
338 Calendar Energy (MWh)	0	0	0	0	0	0	0	0	0	0	0	0	0	
339														
340 Total Direct Access														
341 Customers	301	301	301	301	301	301	301	301	301	301	301	301	3,612	
342 Energy (MWh)	171,126	164,729	163,184	164,618	169,801	175,541	179,928	187,256	192,477	176,590	169,506	173,371	2,088,126	
343 Facility Capacity (kW)	359,777	358,950	355,056	363,496	377,706	382,989	388,561	396,315	393,639	382,163	372,161	364,016	4,494,829	
344 Demand (kW)	294,512	292,078	285,442	305,866	324,434	334,785	339,558	349,535	350,101	335,861	324,472	303,779	3,840,423	
345 Reactive Demand (kVar)	45,970	40,230	41,418	44,647	55,841	51,820	56,155	57,638	56,129	54,814	50,025	47,567	602,254	
346 Calendar Energy (MWh)	177,702	155,333	170,120	166,935	175,741	177,223	187,942	194,522	180,940	179,582	168,900	153,691	2,088,633	
347														
348 Total PGE & Direct Access														
349 Customers	896,878	897,629	898,467	899,377	902,736	903,653	904,586	905,752	906,740	907,877	906,328	907,245	10,837,268	
350 Energy (MWh)	1,905,939	1,741,706	1,653,517	1,530,611	1,457,332	1,491,304	1,548,161	1,643,320	1,652,598	1,474,388	1,512,503	1,789,132	19,400,511	
351 Facility Capacity (kW)	2,278,067	2,275,007	2,250,318	2,258,827	2,351,788	2,402,002	2,450,217	2,512,027	2,514,991	2,454,543	2,344,947	2,305,653	28,398,387	
352 Demand (kW)	1,868,789	1,864,910	1,819,330	1,863,630	1,945,065	2,007,898	2,049,924	2,093,052	2,104,434	2,047,349	1,930,104	1,869,894	23,464,379	
353 Reactive Demand (kVar)	175,322	179,440	175,788	190,577	218,370	222,875	233,079	241,760	235,912	229,086	205,212	200,471	2,507,892	
354 Calendar Energy (MWh)	1,829,931	1,574,872	1,640,641	1,501,542	1,503,334	1,495,502	1,651,640	1,674,813	1,507,821	1,540,572	1,627,663	1,851,803	19,400,134	

	ALD OLD D	E	F	_				IZ.	-		NI NI	_	P	Q
1	A B C D		Г	G	Н	-	J	K	_	М	N	0	P	- u
2														
3														
5	Schedule	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
6	Schedule	Jan	reb	wai	Api	may	Jun	Jul	Aug	Зер	Oct	1404	Dec	Total
7	Schedule 485S 201-4,000 kW V2003													
8	Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
10	Customers - Three Phase Energy (MWh)	2	2	2	2	2	2	2	2	2	2	2	2	24
11	On-Peak	600	565	575	594	540	574	686	647	696	650	598	551	7,278
12	Off-Peak	340	362	336	341	322	353	407	392	448	392	367	396	4,456
13	Facility Capacity (kW)	400	400	400	400	400	400	400	400	400	400	400	400	4.000
14 15	First 200 kW Over 200 kW	1,809	1,809	1,809	400 1,809	400 1,809	1,809	400 1,809	1,809	1,809	1,809	1,809	1,809	4,800 21,708
16	Demand (kW)													
17	On-Peak	1,665	1,704	1,676	1,781	1,699	1,979	1,988	2,141	2,193	2,002	1,873	1,839	22,540
18 19	Off-Peak Increment Reactive Demand (kVar)	0 432	0 414	0 416	0 423	47 406	0 522	0 516	508	39 510	552	46 493	32 422	172 5,614
20	Calendar Energy (MWh)	852	836	905	931	902	948	1,171	1,042	1,037	1,098	1,025	997	11,743
21														
22	Schedule 485S 201-4,000 kW V2010 Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
24	Customers - Single Phase Customers - Three Phase	8	8	8	8	8	8	8	8	8	8	8	8	
25	Energy (MWh)													
26	On-Peak	1,547	1,558	1,498	1,565	1,586	1,663	1,622	1,652	1,751	1,524	1,492	1,578	19,036
27 28	Off-Peak Facility Capacity (kW)	1,058	1,117	1,048	1,096	1,084	1,177	1,137	1,143	1,241	1,030	1,016	1,056	13,204
29	First 200 kW	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	19,200
30	Over 200 kW	4,521	4,527	4,873	5,045	4,987	5,024	4,941	5,433	5,289	4,995	4,690	4,546	58,871
31	Demand (kW) On-Peak	4,704	4,697	4,933	5,125	5,047	5,104	5,043	5,409	5,312	4,990	4,857	4,749	59,970
33	Off-Peak Increment	18	30	61	5,125	36	7	3,043	15	0,312	98	4,057	4,749	269
34	Reactive Demand (kVar)	496	435	495	457	569	520	547	508	480	497	453	500	5,957
35	Calendar Energy (MWh)	2,363	2,412	2,528	2,647	2,793	2,904	2,954	2,803	2,711	2,692	2,662	2,772	32,243
36 37	Schedule 485S 201-4,000 kW V2011													-
38	Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
39	Customers - Three Phase	8	8	8	8	8	8	8	8	8	8	8	8	96
40	Energy (MWh)	1,910	1,771	1,789	1,776	1,736	1,797	1,950	1,980	2,049	1,844	1,751	1,800	22,152
42	Off-Peak	992	974	948	947	925	998	1,067	1,066	1,110	983	971	1,000	12,011
43	Facility Capacity (kW)													
44	First 200 kW	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	1,600	19,200
45 46	Over 200 kW Demand (kW)	5,262	5,226	5,307	5,509	5,726	6,334	7,049	6,844	7,004	6,524	5,684	5,356	71,825
47	On-Peak	5,261	5,214	5,320	5,495	5,716	6,219	6,664	6,572	6,715	6,336	5,644	5,372	70,528
48	Off-Peak Increment	0	23	0	25	0	0	111	0	3	33	0	0	195
49 50	Reactive Demand (kVar) Calendar Energy (MWh)	57 2,632	47 2,476	67 2,718	104 2,709	394 2,782	651 2,857	633 3,231	663 3,054	662 2,862	605 2,979	319 2,889	109 2,980	4,311 34,170
51	Calcinda Liisigy (WWII)	2,002	2,410	2,710	2,100	2,702	2,007	0,201	0,004	2,002	2,070	2,000	2,500	34,170
52	Schedule 485S 201-4,000 kW V2012													
53 54	Customers - Single Phase Customers - Three Phase	99	99	99	99	99	99	99	99	99	99	99	99	1,188
55	Energy (MWh)	99	99	33	33	99	99	99	33	33	99	99	99	1,100
56	On-Peak	10,340	9,954	9,922	9,475	9,570	10,275	10,588	10,847	11,042	9,750	9,529	10,357	121,648
57	Off-Peak Facility Capacity (kW)	6,014	6,134	5,892	5,547	5,593	5,932	5,946	6,074	6,232	5,531	5,608	6,336	70,838
58 59	First 200 kW	19,800	19,800	19,800	19,800	19,800	19,800	19,800	19,800	19,800	19,800	19,800	19.800	237,600
60	Over 200 kW	23,105	22,619	21,850	22,503	25,683	26,702	27,735	29,725	28,111	25,240	23,026	23,410	299,709
61	Demand (kW)	00.445	00.075	00.075	00.745	05.000	00.400	00.000	00.745	07.400	04.04	00.440	00 555	447.05
62 63	On-Peak Off-Peak Increment	33,142 440	33,073 123	32,278 334	32,715 409	35,338 278	36,169 249	36,688 540	38,715 62	37,466 56	34,944 323	33,146 388	33,580 255	417,254 3,457
64	Reactive Demand (kVar)	934	1,054	1,194	1,286	2,402	2,982	3,223	3,217	3,173	2,649	1,688	1,402	25,204
65	Calendar Energy (MWh)	14,836	14,511	15,705	14,946	15,860	16,572	17,705	16,966	15,651	16,104	16,067	17,563	192,486
66 67	Schedule 485S 201-4,000 kW V2013													
68	Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
69	Customers - Three Phase	32	32	32	32	32	32	32	32	32	32	32	32	384
70	Energy (MWh)	E 5.40	E 447	E 404	E 000	E 407	E 400	E 045	0 405	6 201	E 77/	E 045	E 005	05.040
71 72	On-Peak Off-Peak	5,542 3,549	5,147 3,382	5,184 3,309	5,069 3,226	5,161 3,384	5,490 3,412	5,645 3,503	6,135 3,831	6,391 3,943	5,771 3,558	5,215 3,248	5,095 3,339	65,846 41,683
73	Facility Capacity (kW)													
74	First 200 kW	6,400	6,400	6,400	6,400	6,400	6,400	6,400	6,400	6,400	6,400	6,400	6,400	76,800
75 76	Over 200 kW Demand (kW)	12,999	12,893	13,475	13,490	14,927	17,037	17,897	18,848	18,610	17,813	15,624	13,967	187,580
77	On-Peak	15,015	15,027	15,450	15,485	16,630	18,244	18,710	19,675	19,478	18,844	17,149	15,813	205,520
78	Off-Peak Increment	113	17	49	22	1	16	216	0	3	13	11	60	521
79 80	Reactive Demand (kVar) Calendar Energy (MWh)	8,247	408 7,693	565 8,434	606 8,253	790 8,938	1,182 9,102	1,279 9,796	1,281 9,992	1,322 9,364	1,121 9,831	859 8,983	641 8,873	10,503 107,508

	A B C D	E	F	G	Н	ı	J	К	L	М	N	0	Р	Q
81	Schedule 485S 201=4,000 kW V2014													
82 83	Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
84	Customers - Three Phase	3	3	3	3	3	3	3	3	3	3	3	3	36
85 86	Energy (MWh) On-Peak	326	451	564	580	553	555	530	605	524	556	561	405	6,210
87 88	Off-Peak Facility Capacity (kW)	236	328	421	455	408	406	406	457	388	404	444	304	4,656
89	First 200 kW	600	600	600	600	600	600	600	600	600	600	600	600	7,200
90	Over 200 kW Demand (kW)	1,665	1,616	1,663	1,703	1,725	2,296	1,705	2,144	1,569	1,595	1,615	1,525	20,821
92	On-Peak	1,796	1,660	1,747	1,813	1,892	2,291	1,908	2,218	1,790	1,820	1,834	1,707	22,476
93 94	Off-Peak Increment Reactive Demand (kVar)	7 294	87 269	50 258	42 244	0 259	11 358	5 302	45 415	17 371	23 334	10 281	9 290	306 3,675
95	Calendar Energy (MWh)	510	703	978	1,030	1,005	982	1,003	1,064	827	1,011	1,066	746	10,925
96 97	Schedule 485S 201-4,000 kW V2015													
98	Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
99 100	Customers - Three Phase Energy (MWh)	1	1	1	1	1	1	1	1	1	1	1	1	12
101 102	On-Peak Off-Peak	230 136	218 117	231 139	233 124	243 131	267 141	285 180	289 159	266 146	273 176	251 139	257 149	3,043 1,736
103	Facility Capacity (kW)													
104 105	First 200 kW Over 200 kW	200 749	200 749	200 749	200 749	200 749	200 749	2,400 8,988						
106	Demand (kW)													
107 108	On-Peak Off-Peak Increment	754 5	810 0	843 0	894 0	889	881 0	916 1	976 0	904	922	871 0	873 0	10,533 6
109	Reactive Demand (kVar)	247	212	222	223	227	234	221	216	229	216	214	217	2,678
110	Calendar Energy (MWh)	332	302	367	355	391	417	498	449	373	474	414	427	4,799
112	Schedule 485S 201-4,000 kW V2016									-				
113	Customers - Single Phase Customers - Three Phase	7	7	7	7	7	7	7	7	7	7	7	7	0 84
115 116	Energy (MWh) On-Peak	610	564	589	599	595	648	649	693	704	659	615	643	7,568
117	Off-Peak	392	371	380	599 391	384	418	649 416	693 446	704 448	418	403	643 419	7,568 4,885
118 119	Facility Capacity (kW) First 200 kW	1,400	1,400	1,400	1,400	1,400	1,400	1,400	1,400	1,400	1,400	1,400	1,400	16,800
120	Over 200 kW	686	679	703	769	749	734	736	745	725	750	764	731	8,771
121	Demand (kW) On-Peak	1,621	1,632	1,669	1,756	1,774	1,966	2,093	2,099	2,118	2,012	1,804	1,796	22,340
123	Off-Peak Increment	0	0	0	0	0	6	11	8	0	6	10	0	41
124 125	Reactive Demand (kVar) Calendar Energy (MWh)	31 908	32 843	33 963	43 984	58 1,025	60 1,090	78 1,140	77 1,142	77 1,044	64 1,135	50 1,081	46 1,117	649 12,471
126						.,	.,,	.,	.,,,,,	.,,	.,	.,	.,	,
127	Schedule 485S 201-4,000 kW V2017 Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
129	Customers - Three Phase	38	38	38	38	38	38	38	38	38	38	38	38	456
130	Energy (MWh) On-Peak	5,914	5,133	5,296	5,088	5,177	5,363	5,434	5,651	5,661	5,205	4,992	5,340	64,254
132 133	Off-Peak Facility Capacity (kW)	4,153	3,185	3,200	3,202	3,391	3,298	3,317	3,507	3,355	3,170	3,106	3,406	40,291
134	First 200 kW	7,600	7,600	7,600	7,600	7,600	7,600	7,600	7,600	7,600	7,600	7,600	7,600	91,200
135 136	Over 200 kW Demand (kW)	12,212	12,445	12,416	12,385	12,697	14,006	14,541	14,989	14,167	13,829	12,110	11,593	157,390
137	On-Peak	15,438	15,580	15,575	15,322	15,689	16,741	16,970	17,610	16,982	16,422	15,327	14,926	192,582
138 139	Off-Peak Increment Reactive Demand (kVar)	271	44 318	25 342	259 477	140 495	115 578	307 659	19 644	633	295 498	51 322	47 311	1,314 5,548
140	Calendar Energy (MWh)	9,132	7,502	8,438	8,248	8,962	8,855	9,372	9,184	8,169	8,826	8,595	9,201	104,486
141	Schedule 485S 201-4,000 kW V2018													
143 144	Customers - Single Phase Customers - Three Phase	0 26	0 26	0 26	0 26	0 26	0 26	0						
145	Energy (MWh)	26		26		26	26	26		26	26		26	312
146 147	On-Peak Off-Peak	3,356 2,112	3,036 1,958	3,123 1,985	3,044 1,949	3,066 1,904	3,297 2,065	3,517 2,189	3,589 2,169	3,660 2,243	3,238 1,989	3,064 1,847	3,238 2,051	39,230 24,462
148	Facility Capacity (kW)													
149 150	First 200 kW Over 200 kW	5,200 8,003	5,200 7,759	5,200 7,694	5,200 8,016	5,200 8,874	5,200 9,572	5,200 10,554	5,200 10,912	5,200 10,770	5,200 9,521	5,200 8,623	5,200 8,350	62,400 108,648
151	Demand (kW)													
152 153	On-Peak Off-Peak Increment	6,345 4,010	6,298 3,866	6,160 3,953	6,289 4,076	6,626 4,413	6,950 4,636	7,131 5,226	7,415 5,222	7,414 5,111	7,082 4,464	6,863 3,978	6,630 3,998	81,203 52,953
154 155	Reactive Demand (kVar) Calendar Energy (MWh)	745 4,961	781 4,504	831 5,073	846 4,968	1,091 5,199	1,204 5,483	1,321 6,110	1,282 5,774	1,166 5,348	1,074 5,509	923 5,213	856 5,565	12,120 63,708
156		4,301	4,004	5,073	4,500	3,188	5,463	0,110	5,774	0,040	9,309	5,∠13	5,565	03,706
157 158	Schedule 485S 201-4,000 kW V2019 Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
159	Customers - Three Phase	9	9	9	9	9	9	9	9	9	9	9	9	108
160 161	Energy (MWh) On-Peak	714	699	737	765	819	888	1,040	1,137	1,278	1,289	1,395	1,367	12,128
162	Off-Peak	521	499	512	538	577	596	699	760	889	905	1,015	976	8,486
163 164	Facility Capacity (kW) First 200 kW	1,800	1,800	1,800	1,800	1,800	1,800	1,800	1,800	1,800	1,800	1,800	1,800	21,600
165	Over 200 kW	967	1,029	1,043	1,173	1,251	2,222	2,889	3,098	3,608	3,667	3,795	3,701	28,443
166 167	Demand (kW) On-Peak	2,170	2,219	2,229	2,332	2,393	3,155	3,678	3,841	4,242	4,289	4,388	4,314	39,250
168	Off-Peak Increment	0	0	0	0	0	0	0	0	0	0	0	0	0
169 170	Reactive Demand (kVar) Calendar Energy (MWh)	21 1,121	32 1,080	27 1,241	28 1,297	60 1,460	59 1,517	103 1,862	83 1,903	105 1,963	77 2,312	62 2,558	57 2,465	714 20,777
171 172	Schedule 489S GT 4,000 kW V2014													
173	Customers - Single Phase	0	0	0	0	0	0	0	0	0	0	0	0	0
174 175	Customers - Three Phase Energy (MWh)	1	1	1	1	1	1	1	1	1	1	1	1	12
176	On-Peak	146	148	143	238	342	450	1,063	1,953	2,223	1,128	650	288	8,771
177 178	Off-Peak Facility Capacity (kW)	93	81	88	97	110	236	548	1,137	1,370	570	270	110	4,711
1/0	i deilità Cabacità (KAA)													

RA 3 - ADV 1130 PGE Response to Staff IR 3, Attachment IR 3B&4A Marginal Costs.XLX ORDER NO. Page 176 20-483

	Α	вс	D	Е	F	G	Н		J	К	L	М	N	0	Р	Q
179		First 1 000 kW		1.000	1.000	1.000	1.000	1.000	1.000	1,000	1.000	1,000	1,000	1.000	1,000	12.000
180	\top	1.000 kW to 4.000 k	w	3.000	3,000	3,000	3.000	3,000	3.000	3,000	3,000	3,000	3.000	3,000	3,000	36,000
181	\top	Over 4,000 kW		3.431	3,431	3.431	3.431	3,431	3.431	3,431	3,431	3,431	3.431	3.431	3,431	41,172
182	1	Demand (kW)			-,	-,	-,,	-,		-,	-,,,,,,	-,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	-,	-,	-,	,
183	7	On-Peak		498	539	502	1,483	2,052	3,164	7,004	7,099	7,764	6,540	4,119	2,053	42,817
184	T	Off-Peak Increment		0	0	0	0	0	0	0	0	0	0	0	0	0
185	F	Reactive Demand (kVa	r)	0	0	0	0	35	559	2,107	2,161	2,210	1,668	801	0	9,541
186	(Calendar Energy (MWh)	217	206	229	333	473	701	1,725	3,099	3,256	1,789	976	419	13,424
187																
188	Scl	hedule 485P 201-4,00	0 kW V2010													
189	- (Customers - Three Pha	se	1	1	1	1	1	1	1	1	1	1	1	1	12
190	E	Energy (MWh)														
191		On-Peak		1,220	1,125	1,172	1,182	1,257	1,328	1,273	1,284	1,296	1,307	1,168	1,209	14,820
192		Off-Peak		747	726	791	744	795	886	805	807	834	882	758	823	9,595
193	F	Facility Capacity (kW)														
194		First 200 kW		200	200	200	200	200	200	200	200	200	200	200	200	2,400
195		Over 200 kW		3,814	3,814	3,814	3,814	3,814	3,814	3,814	3,814	3,814	3,814	3,814	3,814	45,768
196		Demand (kW)														
197		On-Peak		3,555	3,368	3,283	3,630	3,985	4,043	3,733	3,821	3,950	3,688	3,632	3,568	44,256
198		Off-Peak Increment		0	0	0	0	0	0	0	0	0	0	0	0	0
199		Reactive Demand (kVa		951	898	836	894	994	1,054	955	943	1,186	953	923	873	11,460
200	(Calendar Energy (MWh)	2,306	1,724	2,180	1,983	2,123	2,216	2,178	2,258	2,008	2,267	1,744	1,368	24,355
201																
	_	hedule 485P 201-4,00														
203		Customers - Three Pha	se	0	0	0	0	0	0	0	0	0	0	0	0	0
204	E	Energy (MWh)														
205		On-Peak		0	0	0	0	0	0	0	0	0	0	0	0	0
206	_[Off-Peak		0	0	0	0	0	0	0	0	0	0	0	0	0
207	F	Facility Capacity (kW)														
208		First 200 kW		0	0	0	0	0	0	0	0	0	0	0	0	0
209	_	Over 200 kW		0	0	0	0	0	0	0	0	0	0	0	0	0
210		Demand (kW)														
211		On-Peak		0	0	0	0	0	0	0	0	0	0	0	0	0
212	_	Off-Peak Increment		0	0	0	0	0	0	0	0	0	0	0	0	0
213		Reactive Demand (kVa		0	0	0	0	0	0	0	0	0	0	0	0	0
214	(Calendar Energy (MWh)	0	0	0	0	0	0	0	0	0	0	0	0	0

The Forest March	\Box	ABC D	E	F	G	Н	1	J	К	L	М	N	0	Р	Q
The Common Process 5	215														
The process of the			5	5	5	5	5	5	5	5	5	5	5	5	60
200 Control Control			2.074	1 000	1 0/1	1 707	1 500	1 526	1 075	2 400	2 226	4 824	1 960	1 607	22.244
The Price of Control 1,000	220	Off-Peak													
December December			1,000	1,000	1,000	1,000	1,000	1,000	1.000	1 000	1,000	1 000	1.000	1.000	12 000
Comment	223	Over 200 kW													
Company Comp			6.410	6 246	5 951	6.416	6 294	5.076	6 912	7 252	7 594	6 217	6 363	5 797	76.460
Section Compare (Month) 3-24 2-21 3-20 3-80 3-80 3-50 3-90		Off-Peak Increment													45
Column C															1,848
Company Comp			3,042	2,011	3,233	2,030	2,565	2,439	3,120	3,540	3,309	2,921	2,001	1,701	35,106
2015		7	20	20	29	20	20	20	20	20	20	20	20	20	226
Conference								20							330
200 Prince Company (NV)															
Cover 200 W	235	Facility Capacity (kW)													
232 Charlest (W)															
280 Co-Press Incomment 102 0 21 0 0 141 349 0 9 4 0 0 0 0	238	Demand (kW)													
241 Reactive Demand (Var)															
253	241	Reactive Demand (kVar)	2,438	2,243	2,296	2,760	3,309	3,403	3,668	3,906	3,765	3,289	2,848	2,549	36,474
244 December 1999 299		Calendar Energy (MWh)	12,820	9,452	11,042	10,343	11,220	11,473	12,038	12,703	11,289	10,532	8,922	6,822	128,656
215 Energy (CMPN)	244														
247 Co-Peak 308 370 381 404 409 442 494 491 521 479 393 392			2	2	2	2	2	2	2	2	2	2	2	2	24
249 Facility Connection (AVI)	247	On-Peak													5,100
255 Columbia Col			217	273	273	309	290	328	388	368	388	372	290	283	3,778
1.525 Columnate (NV)	250	First 200 kW													
253 Con-Peak 1,316 1,205 1,215 1,191 1,213 1,445 1,327 1,445 1,471 1,357 1,359 1,068 15,663 256 Reserve Demand (LVar) 203 248 268 229 265 248 250 229 260 277 241 245 2,831 257 Columbia Exempty (MWN) 016 604 728 734 724 780 222 28 867 788 618 454 2,831 258 Schedular 485P 201-4,000 kW 2015 2 2 2 2 2 2 2 2 2			918	841	815	791	813	1,061	927	1,045	1,071	966	959	689	10,896
255 Reactive Demand (kVar)	253	On-Peak													
Calebrate Energy (MVh)															
258 Schedule 485P 2014_000 KW 12015	256														8,848
259 Customers Three Phase 2 2 2 2 2 2 2 2 2		Schedule 485P 201-4.000 kW V2015													
	259	Customers - Three Phase	2	2	2	2	2	2	2	2	2	2	2	2	24
SSS Render Capacity (NY)			1.696	1.676	1.657	1.748	1.831	1.827	1.917	1.906	1.968	1.854	1.786	1.661	21.528
First 200 kW	262	Off-Peak													
285 Over 200 kW			400	400	400	400	400	400	400	400	400	400	400	400	4.800
287 Compensit (compens)	265	Over 200 kW													
288 Reactive Demand (I/Var)			5.852	5,819	5,671	6.063	6.260	6.449	6.203	6.557	6.620	6,190	5,917	5.622	73,223
	268	Off-peak increment	0	0	0	0	0	0	0	0	0	0	0	0	0
271															
273 Customers - Three Phase 0 0 0 0 0 0 0 0 0	271														
Energy (MWh)			0	0	0	0	0	0	0	0	0	0	0	0	0
277 Facility Capacity (NW) 0				_	_			_					_	_	
Priest 200 kW															0
279 Over 200 kW	277	Facility Capacity (kW)													
Demand (kW)															0
283 Racitiv Demand (KVar)	280	Demand (kW)													
Reactive Demand (kVar)		Off-peak increment		0	0									0	0
286 Schedule 485P 201-4,000 kW 2017		Reactive Demand (kVar)		0	0							0			0
288 Customers - Three Phase 8	285		U	U	U	J	U	U	U	U	0	U	U	J	U
Energy (MWh) Ener															06
Page	288	Energy (MWh)													
Facility Capacity (kW)															38,272 26,986
293 Over 200 kW 6,067 6,279 5,647 6,496 7,841 7,883 8,847 9,651 9,887 9,414 8,199 7,438 93,649	291	Facility Capacity (kW)													
294 Demand (kW) 7,667 7,879 7,247 8,096 9,441 9,483 10,383 11,251 11,487 11,014 9,763 9,038 112,749															19,200
296	294	Demand (kW)													
Page Reactive Demand (kVar) 709 912 702 795 918 1,000 1,059 1,304 1,374 1,304 1,187 963 12,227															112,749
299	297	Reactive Demand (kVar)	709	912	702	795	918	1,000	1,059	1,304	1,374	1,304	1,187	963	12,227
300 Schedule 485P 201-4,000 kW v2018		Calendar Energy (MWh)	6,189	4,250	4,862	4,945	5,323	5,211	5,938	6,760	6,108	6,358	5,223	3,758	64,924
Solution Solution	300														
303 On-Peak 583 509 502 514 600 644 677 762 740 592 558 573 7,255			1	1	1	1	1	1	1	1	1	1	1	1	12
305 Facility Capacity (kW) 200	303	On-Peak													7,255
306 First 200 kW 200 2			394	335	326	341	420	414	429	516	468	378	369	401	4,792
308 Demand (kW)	306	First 200 kW													2,400
309 On-peak	307	Over 200 kW													26,472
311 Reactive Demand (kVar) 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	309	On-peak	1,489	1,468	1,466		2,153	2,052		2,436		1,936		1,627	22,453
															0
312 Calendar Energy (MWh) 1,147 785 920 881 1,056 1,059 1,160 1,380 1,139 1,004 840 656 12,027		Calendar Energy (MWh)	1,147	785	920	881	1,056	1,059	1,160	1,380	1,139	1,004	840	656	12,027

П	A E	вс	D	Е	F	G	Н	- 1	J	К	L	М	N	0	Р	Q
313	_															
314	Sch	neduje 485F	201-4,000 kW V2019													
315	C	Customers -	Three Phase	2	2	2	2	2	2	2	2	2	2	2	2	24
316	E	nergy (MW	h)													
317		On-Peak	•	932	953	974	994	1,015	1,036	1,041	1,050	1,105	1,113	1,137	1,139	12,489
318		Off-Peak		688	703	718	734	749	764	795	822	803	831	843	877	9,327
319	F	acility Capa	city (kW)													
320	Т	First 200	kW	400	400	400	400	400	400	400	400	400	400	400	400	4,800
321		Over 200	kW	5,769	5,769	5,769	5,769	5,769	5,769	5,769	5,769	5,769	5,769	5,769	5,769	69,228
322	D	emand (kW	")													
323		On-peak		5,609	5,733	5,858	5,982	6,107	6,232	2,862	3,286	4,704	3,588	5,995	3,397	59,353
324		Off-peak	ncrement	0	0	0	0	0	0	0	0	0	0	0	0	0
325	R	Reactive De	mand (kVar)	1,028	1,051	1,074	1,097	1,120	1,143	470	555	603	635	40	476	9,292
326	C	alendar En	ergy (MWh)	1,656	1,692	1,728	1,764	1,800	1,836	1,872	1,908	1,944	1,980	2,016	2,052	22,248
327																
328	Sch	nedu l e 489F	GT 4,000 kW V2004													
329	C	Customers -	Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
330	E	nergy (MW	h)													
331		On-Peak		3,522	3,527	3,553	3,738	3,913	3,867	4,017	4,023	4,128	3,823	3,654	3,770	45,534
332		Off-Peak		2,439	2,344	2,431	2,372	2,474	2,377	2,683	2,473	2,596	2,553	2,333	2,414	29,486
333	F	acility Capa														
334		First 1,00		1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
335		1,001-4,0		3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	36,000
336		Over 4,00		7,770	7,770	7,770	7,770	7,770	7,770	7,770	7,770	7,770	7,770	7,770	7,770	93,240
337	D	emand (kW	')													
338		On-peak		9,927	9,882	9,441	10,763	11,148	11,430	11,489	11,240	12,051	10,405	10,508	10,011	128,295
339		Off-peak		0	0	0	0	0	0	0	0	0	0	0	0	0
340			mand (kVar)	2,899	2,856	2,577	3,014	3,247	3,222	3,140	3,176	3,123	2,861	2,993	2,864	35,972
341	C	Calendar En	eray (MWh)	5,871	5,983	6,109	6,387	6,244	6,699	6,496	6,724	6,375	5,987	6,184	5,961	75,020

0.40	ABC	D	E	F	G	Н		J	K	L	М	N	0	P	Q
342	Schodule	489P GT 4,000 kW V2010													
344		ners - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
345		(MWh)									- '				12
346	On-I	Peak	3,547	3,287	3,523	3,550	3,689	3,901	3,779	3,671	3,779	3,764	3,531	3,412	43,432
347	Off-	Peak	2,340	2,274	2,536	2,415	2,541	2,759	2,480	2,432	2,531	2,678	2,399	2,549	29,935
348		Capacity (kW)													
349		t 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
350		01-4,000 kW	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	36,000 106,284
351 352	Deman	er 4,000 kW	8,857	8,857	8,857	8,857	8,857	8,857	8,857	8,857	8,857	8,857	8,857	8,857	100,284
353		peak	10,867	11,161	10,304	12,754	12,345	12,728	12,960	12,583	12,313	11,398	11,608	11,074	142,095
354		peak increment	0	0	0	0	0	0	0	0	0	0	0	0	0
355		ve Demand (kVar)	3,576	3,416	3,679	3,556	4,090	3,776	3,436	3,603	4,340	3,815	3,940	3,597	44,824
356	Calend	ar Energy (MWh)	6,905	5,179	6,730	6,144	6,448	6,666	6,562	6,590	5,949	6,669	5,371	4,013	73,227
357	لبلبل														
358		489P GT 4,000 kW V2011													0.4
359 360	Energy	ners - Three Phase	2	2	2	2	2	2	2	2	2	2	2	2	24
361		Peak	8.653	8,274	8,119	8,150	8,270	8,771	8,639	8,876	9,505	8,878	8,406	8,413	102,954
362		Peak	6,239	6,418	5,951	5,942	6,499	6,301	6,286	6,782	6,837	6,358	6,241	6,361	76,216
363		Capacity (kW)	_,	_,	-,	-,	_,,	-,	-,	-,	_,	_,	_,	_,	,
364	First	t 1,000 kW	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	24,000
365		01–4,000 kW	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	72,000
366		r 4,000 kW	15,766	15,766	15,766	15,766	15,766	15,766	15,992	15,839	15,839	16,018	16,018	16,018	190,320
367 368	Deman		20,089	20,184	19,960	21,256	20.004	22.042	23,995	22,457	22.442	22.742	22 504	04.070	262 604
368		peak peak increment	20,089	20,184	19,960	21,256	20,981	23,040	23,995	22,457	23,412	23,748	22,501 0	21,978	263,601
370		ve Demand (kVar)	2,502	2,493	2,522	2,533	4,587	2,877	2,836	2,676	2,751	2,950	2,859	2,574	34,160
371		ar Energy (MWh)	15,241	13,843	14,423	14,778	15,116	15,050	15,628	16,465	15,499	14,513	14,442	13,962	178,958
372		a znagy (mm)	10,611	10,010	11,120	11,110	10,110	10,000	10,020	10,100	10,100	11,010	,	10,000	110,000
373	Schedule	489P GT 4,000 kW V2012													
374	Custon	ners - Three Phase	3	3	3	3	3	3	3	3	3	3	3	3	36
375	Energy														
376		Peak	4,130	4,219	3,838	4,147	4,357	4,667	4,798	5,038	5,292	4,768	4,330	3,938	53,523
377		Peak	2,659	2,748	2,366	2,653	2,667	2,922	3,001	3,095	3,393	2,934	2,702	2,460	33,599
378 379		Capacity (kW) t 1,000 kW	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	36,000
380		1-4,000 kW	9,000	9,000	9,000	9,000	9,000	9,000	9,000	9,000	9,000	9,000	9,000	9,000	108,000
381		r 4,000 kW	4,318	4,287	3,632	4,748	5,570	4,981	4,588	4,780	4,812	4,495	4,759	3,855	54,825
382	Deman		.,	1,20	0,002	.,,	0,0.0	1,00	.,,,,,	.,	1,012	1,100	1,700	0,000	0.1,02.0
383		peak	11,757	11,878	11,297	12,622	15,047	16,509	15,318	16,603	16,619	15,635	14,474	12,247	170,006
384		peak increment	0	0	0	0	0	0	46	0	0	0	0	0	46
385		ve Demand (kVar)	36	166	164	215	283	340	406	262	359	262	215	138	2,846
386	Callend	ar Energy (MWh)	7,963	6,489	6,891	7,005	7,270	7,597	8,177	8,782	8,188	7,974	6,369	4,307	87,011
387	Sabadula	489P GT 4,000 kW V2013													
389		ners - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
390	Energy										- '				12
391		Peak	2,718	2,640	2,694	2,698	2,707	2,664	2,739	2,739	2,669	2,727	2,742	2,696	32,433
392	Off-	Peak	1,975	2,061	2,002	2,001	1,996	2,030	1,935	1,938	2,022	1,979	1,992	2,037	23,966
393		Capacity (kW)													
394		t 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
395 396		01–4,000 kW er 4,000 kW	3,000 4,161	36,000 49,932											
396	Deman		4,161	4,161	4,101	4,161	4,161	4,161	4,161	4,161	4,161	4,161	4,161	4,161	49,932
398		peak	7,640	6,485	7,276	7,287	7,982	7,938	7,682	8,340	7,375	7,622	7,453	6,465	89,545
399		peak increment	0	31	0	0	0	0	0	0,040	0	0	0	0,400	31
400		ve Demand (kVar)	0	0	0	0	0	0	194	0	9	0	0	0	203
401		ar Energy (MWh)	4,701	4,695	4,699	4,703	4,694	4,674	4,678	4,690	4,706	4,733	4,733	4,693	56,400
402	لبليا														
403		489P GT 4,000 kW V2014								,					
404		ners - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
405 406	Energy	(MWh) Peak	3,295	3,131	3,042	3,068	3,097	3,250	3,529	3,472	3,514	3,470	3,217	3,039	39,125
407		Peak	2,406	2,420	2,206	2,252	2,281	2,496	2,572	2,472	2,707	2,499	2,351	2,328	28,990
408		Capacity (kW)	2,400	2,720	2,200	2,202	2,201	2,400	2,012	2,412	2,107	2,400	2,001	2,020	_0,000
409		t 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
410	1,00	01-4,000 kW	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	36,000
411		r 4,000 kW	5,325	5,325	5,325	5,325	5,325	5,325	5,325	5,325	5,325	5,325	5,325	5,325	63,900
412	Deman														
413		peak	7,612	7,619	7,860	8,299	8,269	9,355	9,028	9,295	9,221	9,168	8,822	8,425	102,973
414		peak increment	0	7	0	0	724	153	48	0	0	0	0	14	222
415 416		ve Demand (kVar) lar Energy (MWh)	0 5,551	0 5,249	57 5,320	5,377	731 5.745	6,101	5,944	6,221	24 5,969	486 5,568	5,367	0 5.787	1,298 68,200
710	- Calend	CH ENGINE (MINTH)			0.040	0.011									

	A B C D	E	F	G	Н	ı	J	К	L	М	N	0	Р	Q
417														
418	Schedule 489P GT 4,000 kW V2016 Customers - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
420	Energy (MWh)													
421	On-Peak Off-Peak	2,949 2,115	2,878 2,269	2,993 2,237	3,095 2,218	3,010 2,386	3,199 2,280	3,232 2,330	3,178 2,467	3,359 2,369	3,378 2,433	3,319 2,576	3,459 2,518	38,052 28,198
423	Facility Capacity (kW)	2,115	2,209	2,231	2,210	2,300	2,260	2,330	2,467	2,309	2,433	2,576	2,516	20,190
424	First 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
425 426	1,001-4,000 kW Over 4,000 kW	3,000 3,467	3,000 3,467	3,000 3,467	3,000 3,525	3,000 3,824	3,000 4,335	3,000 4,748	3,000 4,748	3,000 4,797	3,000 4,887	3,000 4,887	3,000 4,954	36,000 51,106
427	Demand (kW)													
428 429	On-peak Off-peak increment	7,222	7,380 0	7,186 0	7,565 0	8,084	8,585 0	8,910 0	8,338	8,684 0	8,864 0	8,601 0	8,998 0	98,417
430	Reactive Demand (kVar)	0	0	0	0	0	0	0	0	0	0	0	0	0
431	Calendar Energy (MWh)	5,147	5,230	5,313	5,396	5,479	5,562	5,645	5,728	5,811	5,894	5,977	6,077	67,263
433	Schedule 489P GT 4,000 kW V2017													
434	Customers - Three Phase	2	2	2	2	2	2	2	2	2	2	2	2	24
435 436	Energy (MWh) On-Peak	5,869	6,820	6,597	6,525	6,587	6,879	6,916	6,849	7,281	6,905	7,006	7,437	81,672
437	Off-Peak	4,327	5,174	5,082	4,874	5,192	5,096	5,094	5,341	5,403	4,949	5,395	5,558	61,484
438 439	Facility Capacity (kW) First 1,000 kW	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	24,000
440	1,001-4,000 kW	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	6,000	72,000
441 442	Over 4,000 kW Demand (kW)	12,486	12,486	12,437	13,283	13,283	13,283	13,283	13,283	13,283	13,283	13,250	13,250	156,890
443	On-peak	16,091	17,004	17,406	21,011	19,613	19,388	19,581	18,476	20,099	20,543	20,100	19,454	228,766
444	Off-peak increment	0	32	0 2 704	0	4,971	0	0	0	233	331	0	0	596
445 446	Reactive Demand (kVar) Calendar Energy (MWh)	5,060 12,407	3,927 11,518	3,791 11,602	4,124 11,751	12,137	4,854 11,718	4,785 12,403	4,476 12,759	4,785 11,894	4,766 12,679	4,844 12,941	4,839 9,354	55,222 143,163
447														
448 449	Schedule 489P GT 4,000 kW V2018 Customers - Three Phase	2	2	2	2	2	2	2	2	2	2	2	2	24
450	Energy (MWh)													
451 452	On-Peak Off-Peak	8,131 6,117	7,324 5,337	7,382 5,348	7,583 5,491	8,265 6,326	8,316 5,968	8,265 5,857	8,588 6,486	8,736 6,224	7,780 5,597	7,670 5,569	8,077 6,119	96,117 70,438
453	Facility Capacity (kW)													
454 455	First 1,000 kW 1,001-4,000 kW	2,000 6,000	24,000 72,000											
456	Over 4,000 kW	14,524	14,481	13,578	15,118	16,253	15,440	14,897	15,163	15,206	14,768	15,133	13,885	178,446
457	Demand (kW)													
458 459	On-peak Off-peak increment	19,169	19,261 0	18,540 0	20,085	23,144	22,322	22,471 0	23,211	22,972	21,755	20,660	19,761 0	253,351 20
460	Reactive Demand (kVar)	2,357	2,349	2,228	2,616	2,888	2,730	2,687	2,947	2,812	2,727	2,775	2,692	31,808
461 462	Calendar Energy (MWh)	16,711	11,791	14,139	13,467	15,101	14,298	14,805	16,279	14,104	13,850	11,991	9,557	166,093
463	Schedule 489P GT 4,000 kW V2019													
464	Customers - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
465 466	Energy (MWh) On-Peak	2,372	2,219	2,052	2,048	2,137	2,084	2,325	2,338	2,380	2,276	2,126	1,954	26,310
467	Off-Peak	1,722	1,713	1,504	1,506	1,592	1,612	1,699	1,673	1,851	1,638	1,563	1,496	19,569
468 469	Facility Capacity (kW) First 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
470	Over 1,001-4,000 kW	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	36,000
471 472	Over 4,000 kW Demand (kW)	2,237	2,237	2,237	2,237	2,237	2,237	2,237	2,237	2,237	2,237	2,237	2,237	26,844
473	On-peak	5,533	5,503	5,313	5,479	5,665	6,115	5,958	6,096	6,358	6,079	6,005	5,769	69,873
474 475	Off-peak increment Reactive Demand (kVar)	1,065	19 1,063	0 895	1,026	61 1,145	1,017	1,068	1,098	1,056	1,174	1,263	1,058	12,928
476	Calendar Energy (MWh)	4,802	3,662	3,950	3,660	3,860	3,699	4,219	4,331	3,989	4,053	3,341	2,323	45,888
477 478	Schedule 489T V2007													
479	Customers - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
480	Energy (MWh)												-	
481 482	On-Peak Off-Peak	83 61	82 63	81 64	81 63	83 62	82 63	82 63	82 62	82 63	85 60	81 64	84 57	988 745
483	Facility Capacity (kW)													
484 485	First 1,000 kW 1,001–4,000 kW	4,000	4,000	4,000	4,000	4,000	4,000	4,000	4,000	4,000	4,000	4,000	4,000	48,000 12
486	Over 4,000 kW	0	0	0	Ö	0	0	0	0	0	0	0	0	0
487 488	Demand (kW) On-Peak	4,001	4,001	271	240	224	245	229	215	244	234	422	382	10,708
489	Off-Peak Increment	0	0	0	0	0	0	0	0	0	0	0	0	0
490 491	Reactive Demand (kVar) Calendar Energy (MWh)	0	2 145	80 145	99 145	23	25 145	31 145	32 145	41 145	54 145	242 141	261 0	890 1.588
492		145	145	145	145	145	145	145	140	140	140	141	U	1,588
493	Schedule 489T V2012													
494 495	Customers - Three Phase Energy (MWh)	1	1	1	1	1	1	1	1	1	1	1	1	12
496	On-Peak	4,735	4,340	4,559	4,604	4,695	4,933	4,963	5,132	5,213	5,136	4,639	5,041	57,991
497 498	Off-Peak Facility Capacity (kW)	3,411	3,333	3,308	3,365	3,446	3,785	3,627	3,656	3,992	3,657	3,368	3,838	42,787
499	First 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000
500 501	1,001-4,000 kW Over 4,000 kW	3,000 13,712	36,000 164,544											
502	Demand (kW)													
503	On-Peak	11,272	10,724	11,915	12,261	12,639	13,934	12,511	13,549	14,421	15,601	19,823	13,689	162,339
504 505	Off-Peak Increment Reactive Demand (kVar)	2,057	1,695	2,002	2,172	2,882	2,694	2,536	2,716	2,778	3,034	2,943	2,184	29,693
506	Calendar Energy (MWh)	7,673	7,867	7,970	8,141	8,718	8,590	8,788	9,205	8,793	8,007	8,880	8,146	100,778
507 508	Schedule 489T V2013													
509	Customers - Three Phase	1	1	1	1	1	1	1	1	1	1	1	1	12
510 511	Energy (MWh) On-Peak	4,473	4,084	4,108	4,782	4,147	4,349	4 4 4 7	4,160	4,359	4,380	4,094	4,209	51,263
512	Off-Peak	2,687	2,593	4,108 2,698	4,782 2,849	2,766	4,349 2,712	4,117 2,933	4,160 3,228	4,359 2,750	4,380 2,795	4,094 2,617	4,209 2,769	33,398
513	Facility Capacity (kW)		4.000		1.000					4.600				
514	First 1,000 kW	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	12,000

1	A E	B C D	E	F	G	Н	ı	J	K	L	M	N	0	Р	Q
515	Т	1,001-4,000 kW	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	36,000
516	Т	Over 4,000 kW	14,264	14,264	13,845	13,845	13,946	13,946	13,946	14,086	14,086	14,086	14,086	14,010	168,410
517	D	Demand (kW)													
518	Т	On-Peak	17,957	16,126	15,631	16,923	17,783	14,984	15,660	18,063	15,033	16,655	15,676	17,866	198,357
519	Т	Off-Peak Increment	0	0	0	0	0	0	0	0	0	0	0	0	0
520	R	Reactive Demand (kVar)	16,418	12,112	13,111	13,983	16,806	13,652	16,454	17,443	14,726	15,864	15,228	16,508	182,305
521	С	Calendar Energy (MWh)	6,677	6,806	7,631	6,913	7,061	7,050	7,388	7,109	7,175	6,711	6,978	7,622	85,123
522	Т														
523	Γota	tal Direct Access													
524	С	Customers	301	301	301	301	301	301	301	301	301	301	301	301	3,612
525	E	Energy (MWh)	171,126	164,729	163,184	164,618	169,801	175,541	179,928	187,256	192,477	176,590	169,506	173,371	2,088,126
526	F	Facility Capacity (kW)	359,777	358,950	355,056	363,496	377,706	382,989	388,561	396,315	393,639	382,163	372,161	364,016	4,494,829
527	D	Demand (kW)	294,512	292,078	285,442	305,866	324,434	334,785	339,558	349,535	350,101	335,861	324,472	303,779	3,840,423
528	R	Reactive Demand (kVar)	45,970	40,230	41,418	44,647	55,841	51,820	56,155	57,638	56,129	54,814	50,025	47,567	602,254
529	C	Calendar Energy (MWh)	177,702	155,333	170,120	166,935	175,741	177,223	187,942	194,522	180,940	179,582	168,900	153,691	2,088,633

PORTLAND GENERAL ELECTRIC

Calculation of 2019 Wheeling Charge

Nonresidential		Applicable													
Schedules	12 CP	MWh	aMW	LF	Wheeling										
Schedule 15	1.8	16,855	1.9			_									
Schedule 32	264.4	1,743,698	199.1												
Schedule 38	4.2	33,655	3.8												
Schedule 47	3.5	23,155	2.6												
Schedule 49	10.4	68,929	7.9												
Schedule 83	475.5	3,085,089	352.2												
Schedule 85	416.4	2,889,290	329.8												
Schedule 89	58.3	476,650	54.4												
Schedule 90	232.3	1,959,842	223.7												
Schedule 91/95	5.9	54,048	6.2												
Schedule 92	0.3	2,667	0.3												
Totals	1,473.1	10,353,876	1,181.9	80.24%	3.06										
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	:	Nov	Dec		
Hours	744	672	744	720	744	7	20	744	744	720	744		720	744	8

BPA PTP 1.793 kW-month

Hours 730 average hours per 12 months

20-483

PORTLAND GENERAL ELECTRIC 2019 LINE LOSS PROJECTIONS

	Internal	External	
Delivery Voltage	Losses	Losses	Losses
Secondary	4.74%	2.11%	6.85%
Primary	2.85%	2.11%	4.96%
Subtransmission	1.45%	2.11%	3.56%

		G&T	G&T	115 kV	115 kV	Primary	Primary
Category	MWh	Losses	MWh	Losses	MWh	Losses	MWh
Residentia	7,572,179	1.0685		1.0474	7,931,100	1.032	7,817,743
Secondary	7,374,128	1.0685		1.0474	7,723,662	1.032	7,613,269
Primary	4,150,900	1.0496		1.0285	4,269,201	1.014	4,208,182
Subtransmission	249,847	1.0356		1.0145	253,470		
Lighting	53,079	1.0685		1.0474	55,595	1.032	54,800
Totals	19,400,134				20,233,028		19,693,995

For delivery voltage differentiated pricing

Peak

Category	Losses
Secondary	8.16%
Primary	5.30%
Subtransmission	3.89%

Totals

Secondary peak uses 500 kVa transformer additional losses at peak loading Primary peak loss is from Attachment D of line loss study Subtransmission peak loss is from Attachment C of line loss study